

Southwest Regional Office CLEAN WATER PROGRAM

Application Type

Facility Type

Major / Minor

Minor

NPDES PERMIT FACT SHEET INDIVIDUAL INDUSTRIAL WASTE (IW) AND IW STORMWATER

 Application No.
 PA0095010

 APS ID
 1053944

 Authorization ID
 1380225

Applicant Name	Great	ter Johnstown Water Authority	Facility Name	Riverside Water Treatment Plant
Applicant Address	P.O. l	Box 1407 640 Franklin Street	Facility Address	242 Neil Street
	Johns	stown, PA 15907-1407	_	Johnstown, PA 15904-4404
Applicant Contact	Tom	Brown	Facility Contact	Tom Brown
Applicant Phone	(814)	533-4300	Facility Phone	(814) 536-0770
Client ID	2615	9	Site ID	255260
SIC Code	4941		Municipality	Stonycreek Township
SIC Description	Trans	s. & Utilities - Water Supply	County	Cambria
Date Application Rec	eived	December 22, 2021	EPA Waived?	Yes
Date Application Acc	epted	December 29, 2021	If No, Reason	

Summary of Review

Background

The Department received an NPDES permit renewal application from the Greater Johnstown Water Authority (GJWA) on December 22, 2021 for coverage of the discharge from its Riverside Water Treatment Plant (WTP) in Stonycreek Township of Cambria County. The facility is a municipal water treatment plan with an SIC Code 4941 (Water Supply). The current NPDES permit was renewed on July 1, 2017 and expired on June 30, 2022. Water Quality Management (WQM) permit 1184202 was approved in 1984 and amended in 2008.

Riverside WTP's application and previous permit contained incorrect outfall locations. The plant field-located the outfall locations and provided updated outfall coordinates and an updated outfall map on April 17, 2023.

Property and Operations

The 14 million-gallon-per-day (MGD) Riverside WTP serves Johnstown, PA as a municipal water treatment plant and has been in operation since 1985. Riverside WTP withdraws water from the Quemahoning Reservoir, the Dalton Run Reservoir, and the North Fork Reservoir. Riverside WTP's treatment system includes chemical treatment, microfiltration and disinfection.

Riverside WTP operates as a municipal water treatment plant that treats water to produce potable water for community use in the Johnstown area. Riverside WTP's treatment system consists of chemical pre-treatment and post-treatment, a flocculation basin, mixed media filters, clearwell, and finished water storage tank. Wastewater discharges to the plant's two

Approve	Deny	Signatures	Date
Х		House Myli	
		Lauren Nolfi, E.I.T. / Environmental Engineering Specialist	April 19, 2023
Х		Michael E. Fifth, P.E. / Environmental Engineer Manager	May 12, 2023

Summary of Review

wastewater treatment lagoons. A site plan of the plant is included in Attachment A. A line drawing of the treatment system is included in Attachment B.

Outfalls

The facility has four outfalls, Outfalls 001 – 004, which discharge to Stonycreek River, designated in 25 PA Code Chapter 93 as a Warm Water Fishery (WWF). Outfall 001 discharges supernatant water from the plant's two wastewater treatment lagoons at a design flow of 0.243 MGD. The wastewater treatment lagoons receive filter backwash and filter to wastewater, flocculation basin drain water, sample sink drain water, plant overflow roof and floor drain water, and roof drain and unloading dock stormwater. Lagoon supernatant discharges via Outfall 001 to Stonycreek River. Solids from the lagoons are dewatered in the sludge drying beds before being mixed with topsoil and spread at line projects.

Outfall 002 discharges stormwater runoff from south side of the parking lot, loading dock, and building roof drain. The stormwater is piped to a conveyance ditch, which discharges to Stonycreek River. Outfall 003 discharges stormwater runoff from the catch basin on the north side of the building via a drainage ditch. The drainage ditch is piped west into a wetland area, which discharges to Stonycreek River. Outfall 004 discharges stormwater runoff from north side of the parking lot. The stormwater is conveyed via a ditch on the east side of the property where it is commingled with offsite water prior to discharging to Stonycreek River.

Riverside WTP reported in the application that a PPC plan was in development and would be completed prior to the date of permit expiration in June of 2022.

Public Participation

Greater Johnstown Water Authority provided evidence of Act 14 municipal and county notifications to Stonycreek Township and Cambria County on November 2, 2021.

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Conclusion

Draft permit issuance is recommended.

Discharge, Receiving	Waters and Water Supply Inform	nation	
Outfall No. 001		Design Flow (MGD)	0.243
Latitude 40° 17	7' 1.96"	Longitude	-78° 55′ 36.19"
Quad Name Joh	ınstown	Quad Code	1614
Wastewater Descrip	drain water, plant overflow	o waste water, flocculation basi roof and floor drain water, and	
Receiving Waters	Stonycreek River (WWF)	Stream Code	45084
NHD Com ID	123720396	RMI	5.77
Drainage Area	452	Yield (cfs/mi²)	0.0808
Q ₇₋₁₀ Flow (cfs)	36.5	Q ₇₋₁₀ Basis	USGS StreamStats
Elevation (ft)	1191	Slope (ft/ft)	0.002
Watershed No.	18-E	Chapter 93 Class.	WWF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Impaired		
Cause(s) of Impairm	nent Cause Unknown		
Source(s) of Impairr	ment Source Unknown		
TMDL Status	Final	Kiskiminetas Name <u>Watersheds</u>	s-Conemaugh River TMDL
Nearest Downstrear	m Public Water Supply Intake	Saltsburg Municipal Waterwo	rks
PWS Waters C	Conemaugh River	_ Flow at Intake (cfs)	0.93
PWS RMI 0	0.52	Distance from Outfall (mi)	57

Changes Since Last Permit Issuance: Outfall 001's coordinates in the previous permit corresponded to a location discharging to Bens Creek. Outfall 001's location has been field-located and the outfall coordinates have been updated.

Other Comments: The USGS Stream Stats Data for the drainage area is displayed in Attachment C.

utfall No. Se	o Toblo 1		Design Flow (MCD)	Varios (Starmwater)
	e Table 1		Design Flow (MGD)	Varies (Stormwater)
	e Table 1		Longitude	See Table 1
	Johnstowr	1	Quad Code	1614
Wastewater Des	cription:	Stormwater		
Receiving Water	s Stony	creek River (WWF)	Stream Code	45084
NHD Com ID	12372	20424/ 123720396	RMI	See Table 1
Drainage Area	See 7	able 1	Yield (cfs/mi²)	See Table 1
Q ₇₋₁₀ Flow (cfs)	See 7	able 1	Q ₇₋₁₀ Basis	USGS StreamStats
Elevation (ft)	See 7	able 1	Slope (ft/ft)	0.002
Watershed No.	18-E		Chapter 93 Class.	WWF
Existing Use			Existing Use Qualifier	
Exceptions to Us	e		Exceptions to Criteria	
Assessment Stat	us	Impaired		
Cause(s) of Impa	airment	Cause Unknown		
Source(s) of Imp	airment	Source Unknown		
TMDL Status		Final	Kiskiminetas Name Watersheds	s-Conemaugh River TMDL
Nearest Downstr	eam Publi	ic Water Supply Intake	Saltsburg Municipal Waterwor	rks
PWS Waters	Conema	augh River	Flow at Intake (cfs)	0.93
PWS RMI	0.52		Distance from Outfall (mi)	57

Changes Since Last Permit Issuance: Outfalls 003 and 004 were not identified or included in the previous permit. Outfall 002's coordinates in the previous permit corresponded to a location discharging to Bens Creek. Locations for Outfalls 002 - 004 have been field-located and the outfall coordinates have been updated.

Other Comments: Outfall locations for the above-mentioned outfalls are displayed below in Table 1.

	Table 1: Stormwater Outfall Locations								
Outfall	Latitude	Longitude	RMI	Drainage Area (mi ²⁾	Q ₇₋₁₀ Flow (cfs)	Yield (cfs/mi ²⁾	Elevation (ft)		
002	40° 16' 55.38"	-78° 55' 33.36"	6.03	403	32.6	0.0809	1198		
003	40° 16' 57.99"	-78° 55' 35.24"	6.03	403	32.6	0.0809	1198		
004	40° 17' 3.13"	-78° 55' 34.8"	5.74	452	36.5	0.0808	1191		

Compliance History

DMR Data for Outfall 001 (from March 1, 2022 to February 28, 2023)

Parameter	FEB-23	JAN-23	DEC-22	NOV-22	OCT-22	SEP-22	AUG-22	JUL-22	JUN-22	MAY-22	APR-22	MAR-22
Flow (MGD)												
Average Monthly	0.2661	0.33587	0.3328	0.3929	0.3724	0.36066	0.35245	0.3638	0.2636	0.2278	0.20446	0.27004
Flow (MGD)												
Daily Maximum	0.3944	0.56402	0.4206	0.6247	0.4797	0.75059	0.49194	0.66588	0.3926	0.5152	0.28903	0.45618
pH (S.U.)												
Minimum	6.53	6.26	7.06	6.90	6.27	6.90	6.41	6.77	6.62	6.04	6.07	6.03
pH (S.U.)												
Maximum	6.77	6.91	7.07	7.00	6.70	7.16	6.60	6.84	6.65	6.22	6.63	6.06
TRC (mg/L)												
Average Monthly	0.23	0.055	0.455	0.135	0.25	0.365	0.30	0.175	0.515	0.265	0.30	0.065
TRC (mg/L)												
Instantaneous	0.04	0.000	0.55	0.00	0.44	0.74	0.00	0.00	0.50	0.00	0.55	0.070
Maximum	0.31	0.060	0.55	0.22	0.44	0.71	0.32	0.26	0.52	0.38	0.55	0.070
TSS (mg/L) Average Monthly	2.00	3.20	3.40	2.20	3.60	2.40	7.80	2.40	4.80	4.80	1.80	3.80
TSS (mg/L)	2.00	3.20	3.40	2.20	3.60	2.40	7.00	2.40	4.00	4.00	1.00	3.60
Instantaneous												
Maximum	2.40	3.20	4.40	2.40	4.40	3.20	10.0	3.20	5.60	5.20	2.00	6.00
Total Aluminum	2.40	0.20	7.70	2.40	7.70	3.20	10.0	3.20	3.00	5.20	2.00	0.00
(mg/L)												
Average Monthly	0.414	0.4535	0.413	0.3665	0.4405	0.3965	0.313	0.484	0.5135	0.577	0.440	0.460
Total Aluminum	0	01.1000	01110	0.0000	011100	0.0000	0.0.0	0	0.0.00	0.01.	01110	01.00
(mg/L)												
Instantaneous												
Maximum	0.441	0.467	0.433	0.457	0.564	0.409	0.367	0.542	0.543	0.578	0.466	0.501
Total Iron (mg/L)												
Average Monthly	< 0.200	< 0.200	< 0.200	< 0.200	0.245	0.2025	< 0.200	< 0.200	< 0.200	0.765	< 0.200	< 0.200
Total Iron (mg/L)												
Instantaneous												
Maximum	< 0.200	< 0.200	< 0.200	< 0.200	0.290	0.205	< 0.200	< 0.200	< 0.200	1.33	< 0.200	< 0.200
Total Manganese												
(mg/L)												
Average Monthly	0.0736	0.164	0.1955	0.188	0.09835	0.6085	0.512	0.0935	0.381	1.749	0.0373	0.145
Total Manganese												
(mg/L)												
Instantaneous	0.0770	0.402	0.200	0.006	0.440	1.04	0.644	0.0044	0.625	2.20	0.0546	0.046
Maximum	0.0773	0.193	0.309	0.286	0.110	1.04	0.641	0.0944	0.635	3.30	0.0546	0.216

NPDES Permit No. PA0095010

NPDES Permit Fact Sheet Riverside Water Treatment Plant

DMR Data for Outfall 002 (from March 1, 2022 to February 28, 2023)

Parameter	FEB-23	JAN-23	DEC-22	NOV-22	OCT-22	SEP-22	AUG-22	JUL-22	JUN-22	MAY-22	APR-22	MAR-22
Flow (MGD)											0.01131	
Average Monthly	0.02663	0.0138	0.0132	0.0201	0.00465	0.0163	0.0077	0.01657	0.0214	0.0213	7	0.01158
Flow (MGD)											0.04986	0.04879
Daily Maximum	0.05791	0.0606	0.04504	0.1287	0.00751	0.04075	0.0874	0.05738	0.0402	0.0879	9	6

Compliance History

Effluent Violations for Outfall 001, from: April 1, 2022 To: February 28, 2023

Parameter	Date	SBC	DMR Value	Units	Limit Value	Units
TRC	06/30/22	Avg Mo	0.515	mg/L	.5	mg/L
Total Manganese	05/31/22	Avg Mo	1.749	mg/L	1.0	mg/L
Total Manganese	05/31/22	IMAX	3.30	mg/L	2.0	mg/L

Summary of Inspections: The facility was most recently inspected on February 12, 2021 by Lisa Milsop as a compliance evaluation. Riverside WTP received violations on February 12, 2021 (resolved February 16, 2021) and July 9, 2018 (resolved July 17, 2018) for exceeding effluent limitations.

Other Comments:

Monitoring data from the past three years shows six effluent violations for the parameters aluminum, pH, manganese, and total residual chlorine.

The client has five open violations. One violation, from the SWRO's Safe Drinking Water Program, was issued to GJWA's Saltlick Plant for failure to meet design and construction standards. Four violations, from the SWRO's Storage Tanks Program, were issued to GJWA's Riverside WTP for UST requirement failures and failure to meet performance standards for new/ upgraded tanks.

 Outfall No.
 001
 Design Flow (MGD)
 0.243

 Latitude
 40° 17' 1.96"
 Longitude
 -78° 55' 36.19"

Filter backwash and filter to waste water, flocculation basin drain water, sample sink drain

water, plant overflow roof and floor drain water, and roof drain and unloading dock

Wastewater Description: stormwater.

Technology-Based Limitations (TBELs)

Riverside WTP is not subject to Federal Effluent Limitation Guidelines (ELGs) as the SIC code is not listed under 40 CFR parts 405 through 471.

Regulatory Effluent Standards and Monitoring Requirements

Flow monitoring is required pursuant to 25 Pa. Code § 92a.61(d)(1) as indicated in Table 1.

Effluent standards for pH pursuant to 25 Pa. Code § 92a.48(a)(2) and 25 Pa. Code § 95.2(1), as indicated in Table 1, are also imposed on all industrial wastes.

Pennsylvania regulations at 25 Pa. Code § 92a.48(b) require the imposition of technology-based TRC limits for facilities that use chlorination and that are not already subject to TRC limits based on applicable federal ELGs or a facility-specific BPJ evaluation as indicated in Table 2.

Table 2: Regulatory Effluent Standards							
Parameter	Monthly Average Daily Maximum		IMAX				
Flow (MGD)	Monitor	Monitor					
pH (S.U.)	Not less than 6.0 nor gre						
TRC	0.5 mg/l	1.0 mg/l	1.6 mg/l				

Best Practicable Control Technology Currently Achievable (BPT)

BPT for wastewater from treatment of water treatment plant (WTP) sludges and filter backwash is found in DEPs Technology-Based Control Requirements for Water Treatment Plant Wastes Document which recommends effluent limitations be imposed under Best Professional Judgement in accordance with 40 CFR § 125.3, and detailed in Table 3.

Table 3: BPT Limits for WTP sludge and filter backwash wastewater							
Parameter	Monthly Average (mg/L)	Daily Maximum (mg/L)					
Total Suspended solids	30.0	60.0					
Total Iron	2.0	4.0					
Total Aluminum	4.0	8.0					
Total Manganese	1.0	2.0					
Flow (MGD)	Monitor and Report						
pH (S.U.)	Not less than 6.0 nor greater than 9.0 at all times						
Total Residual Chlorine	0.5	1.0					

Water Quality-Based Effluent Limitations (WQBELs)

Toxics Management Analysis

The Department's Toxics Management Spreadsheet (TMS) was utilized to facilitate calculations necessary for completing a reasonable potential analysis and determine Water Quality-Based Effluent Limitations (WQBELs) for discharges containing toxic pollutant concentrations. TMS combines the functionality of two (2) of the Department's analysis tools, Toxics Screening Analysis Spreadsheet and PENTOXSD water quality model.

DEP's procedures for evaluating reasonable potential are as follows:

- 1. For IW discharges, the design flow to use in modeling is the average flow during production or operation and may be taken form the permit application.
- 2. Perform a Toxics Screening Analysis to identify toxic pollutants of concern. All toxic pollutants, as reported in the permit application or on DMRs, are modeled by the TMS to determine the parameters of concern. [This includes pollutants reported as "Not Detectable" or as "<MDL" where the method detection limit for the analytical method used by the applicant is greater than the most stringent water quality criterion].
 - Establish limits in the draft permit where the maximum reported concentration equals or exceeds 50% of the WQBEL. Use the average monthly and maximum daily limits for the permit as recommended by TMS. Establish an IMAX limit at 2.5 times the average monthly limit.
 - For non-conservative pollutants, establish monitoring requirements where the maximum reported concentration is between 25% 50% of the WQBEL.
 - For conservative pollutants, establish monitoring requirements where the maximum reported concentration is between 10% 50% of the WQBEL.

Discharges from Outfall 001 are evaluated based on concentrations reported on the application and contained in the DMRs; data from those sources are used as inputs into the TMS. A summary of TMS Inputs is contained in Tables 4 and 5 below.

Table 4: TMS Design Inputs						
Parameter	Value					
Design Flow (MGD)	0.243					
Hardness (mg/L)	22.4					
pH (S.U.)	7.5					
Partial Mix Factors (PMFs)						
AFC	calc.					
CFC	calc.					
THH	calc.					
CRL	calc.					
Complete Mix Tir	nes					
Q ₇₋₁₀ (min)	calc.					
Q _h (min)	calc.					

Table 5: TMS Stream Inputs						
Parameter	Value					
Stream Code	45084					
RMI	5.77					
Elevation	1191					
Drainage Area (mi ²)	452					
Slope (ft/ft)	0.002					
PWS Withdrawal (MGD)						
Apply Fish Criteria	Yes					
Low Flow Yield (cfs/mi²)	0.0808					
Stream Flow (cfs)	36.5					
Tributary Flow (cfs)	N/A					
Width (ft)						
Stream Hardness (mg/L)	100					
Stream pH (S.U.)	7					

Output from the TMS model runs is included in Attachment D. Based on the recommendations of the TMS, no WQBELs are to be imposed at Outfall 001.

Total Dissolved Solids (TDS)

Per Policy and Procedure for NPDES Permitting of Discharges of Total Dissolved Solids (TDS) – 25 Pa. Code §95.10 (DEP-ID: 385-2100-002), a monitoring requirement for TDS for any discharge that exceeds 2,000 mg/L TDS should be applied at minimum. The maximum reported TDS concentration at Outfall 001 is 50 mg/L. Since the TDS discharge concentration is below 2,000 mg/L, no monitoring/limit requirements will be applied for TDS or its constituent parameters.

Total Residual Chlorine

To determine if WQBELs are required for discharges containing total residual chlorine (TRC), a discharge evaluation is performed using a DEP program called TRC_CALC created with Microsoft Excel for Windows. TRC_CALC calculates TRC Waste Load Allocations (WLAs) through the application of a mass balance model which considers TRC losses due to stream and discharge chlorine demands and first-order chlorine decay. Input values for the program include flow rates and discharge chlorine demands for the receiving stream, the number of samples taken per month, coefficients of TRC

NPDES Permit Fact Sheet Riverside Water Treatment Plant

variability, partial mix factors, and an optional factor of safety. The mass balance model calculates WLAs for acute and chronic criteria that are then converted to long term averages using calculated multipliers. The multipliers are functions of the number of samples taken per month and the TRC variability coefficients (normally kept at default values unless site specific information is available). The most stringent limitation between the acute and chronic long-term averages is converted to an average monthly limit for comparison to the BAT average monthly limit of 0.5 mg/L from 25 Pa. Code § 92a.48(b)(2). The more stringent of these average monthly TRC limitations is then proposed. The results of the modeling, included in Attachment Edse, identify that BPT is the most stringent criteria for TRC at an average monthly limit of 0.5 mg/L. The maximum daily limit is 2 times the average monthly limit resulting in a 1.0 mg/L limit for maximum daily.

Total Maximum Daily Load (TMDL)

Stonycreek River is located within the Kiskiminetas-Conemaugh River Watershed, for which the Department has developed a TMDL. The Kiskiminetas-Conemaugh River Watershed TMDL was finalized on January 29, 2010 to control acid mine drainage pollutants including aluminum, iron, manganese, sediment, and pH. Section 303(d) of the Clean Water Act and the U.S. Environmental Protection Agency's ("EPA's") Water Quality Planning and Management Regulations (codified at Title 40 of the Code of Federal Regulations Part 130) require states to develop a TMDL for impaired water bodies. A TMDL establishes the amount of a pollutant that a water body can assimilate without exceeding its water quality standard for that pollutant. TMDLs provide the scientific basis for a state to establish water quality-based controls to reduce pollution from both point and non-point sources to restore and maintain the quality of the state's water resources (USEPA 1991).

Stream reaches within the Kiskiminetas-Conemaugh River Watersheds are included in the state's 2008 Section 303(d) list because of various impairments, including metals, pH, and sediment. The TMDL includes consideration for each river and tributary within the target watershed and its impairment sources. Stream data is then used to calculate minimum pollutant reductions that are necessary to attain water quality criteria levels. Target concentrations published in the TMDL were based on established water quality criteria of 0.750 ^{mg}/_L total recoverable aluminum, 1.5 ^{mg}/_L total recoverable iron based on a 30-day average and 1.0 ^{mg}/_L total recoverable manganese. The reduction needed to meet the minimum water quality standards is then divided between each known point and non-point pollutant source in the form of a watershed allocation. TMDLs prescribe allocations that minimally achieve water quality criteria (i.e., 100 percent use of a stream's assimilative capacity). The Kiskiminetas-Conemaugh River Watershed TMDL does not include a wasteload allocation (WLA) for Riverside WTP.

The current permit's effluent limitations for aluminum, iron, manganese, and pH will be maintained to address the TMDL's target concentrations and meet in the instream criterion values for these parameters at the point of discharge.

Anti-Backsliding

The effluent limitations and monitoring requirements in Table 6 below are from the current permit, issued on July 1, 2017. The draft permit does not propose any effluent limits that are less stringent than those imposed in the previous permit.

Table 6: Current Permit Effluent Limitations – Outfall 001								
Parameter	Average Monthly	Maximum Daily	IMAX	Units	Monitoring Frequency			
Flow	Monitor 8	Monitor & Report		MGD	2/ month			
Total Residual Chlorine	0.5	-	1.0	mg/L	2/ month			
Total Suspended Solids	30	-	60	mg/L	2/ month			
Aluminum, total	0.75	-	1.5	mg/L	2/ month			
Iron, total	1.5	-	3.0	mg/L	2/ month			
Manganese, total	1.0	-	2.0	mg/L	2/ month			
pH	6.0	-	9.0	S.U.	2/ month			

Effluent Limitations and Monitoring Requirements

Effluent limitations and monitoring requirements applicable at Outfall 001 are the most stringent of TBELs, WQBELs, and regulatory effluent standards and monitoring requirements, as summarized below in Table 7. The applicable limits and monitoring requirements provided below are based on those in Tables 1-6 of this Fact Sheet.

Table 7: Effluent Limits and Monitoring Requirements – Outfall 001								
	Mass		Conce	entration	Monitoring Requirements			
Parameter	Average Monthly	Daily Maximum	Average Monthly (mg/L)	Daily Maximum (mg/L)	Monitoring Frequency	Sample Type		
Flow (MGD)	Monitor	& Report	-	•	2/ month	Measured		
Total Residual Chlorine	1	-	0.5	1.0	2/ month	Grab		
Total Suspended Solids	-	-	30.0	60.0	2/ month	Grab		
Aluminum, total	-	-	0.75	1.5	2/ month	Grab		
Iron, total	1	-	1.5	3.0	2/ month	Grab		
Manganese, total	-	-	1.0	2.0	2/ month	Grab		
pH (S.U.)	-	-	Not less than 6.0	nor greater than 9.0	2/ month	Grab		

Development of Effluent Limitations					
Outfall No.	002, 003, 004	Design Flow (MGD)	0		
Latitude	See Table 8	Longitude	See Table 8		
Wastewater D	escription: See Table 8	_			

Stormwater Drainage Overview

Stormwater runoff information for the stormwater outfalls is displayed below in Table 8. Stormwater monitoring will not be imposed at Outfall 004 since it is considered a no exposure outfall and contains comingled stormwater.

	Table 8: Stormwater Outfall Locations and Description					
Outfall	Latitude	Longitude	Stormwater Description			
002	40º 16' 55.38"	-78º 55' 33.36"	Stormwater runoff from south side of the parking lot, loading dock, and building roof drain. The stormwater is piped to a conveyance ditch, which discharges to Stonycreek River.			
003	40° 16' 57.99"	-78º 55' 35.24"	Stormwater runoff from the catch basin on the north side of the building via a drainage ditch. The drainage ditch is piped west into a wetland area, which discharges to Stonycreek River.			
004	40° 17' 3.13"	-78° 55' 34.8"	Stormwater runoff from north side of the parking lot. The stormwater is conveyed via a ditch on the east side of the property where it is commingled with offsite water prior to discharging to Stonycreek River.			

Technology-Based Limitations

Stormwater Technology Limits

Outfalls 002 and 003 will be subject to PAG-03 General Stormwater Permit conditions as a minimum requirement because the outfall discharges stormwater. The SIC code for the site is 4941 (Water Supply) and the corresponding appendix of the PAG-03 that would apply to the facility is Appendix J. The reporting requirements applicable to stormwater discharges are shown in Table 9 below. Along with the monitoring requirements, sector specific BMPs included in Appendix J (Additional Facilities) of the PAG-03 will also be included in Part C of the Draft Permit.

Table 9: PAG-03 Appendix J Monitoring Requirements								
Parameters	Average Monthly (mg/L)	Daily Maximum Benchmark Values (mg/L)		Monitoring Re Monitoring Frequency	quirements Sample Type			
Nitrogen, total	-	Monitor & Report	-	1/6 Months	Grab			
Phosphorus, total	-	Monitor & Report	-	1/6 Months	Grab			
Total Suspended Solids	-	Monitor & Report	100	1/6 Months	Grab			
Oil and Grease	-	Monitor & Report	30	1/6 Months	Grab			
рН	-	Monitor & Report	9.0	1/6 Months	Grab			
Chemical Oxygen Demand	-	Monitor & Report	120	1/6 Months	Grab			

Water Quality-Based Limitations

Stormwater WQBELs

Water quality analyses are typically performed under low-flow (Q7-10) conditions. Stormwater discharges occur at variable rates and frequencies but not however during Q7-10 conditions. Since the discharges from Outfalls 002 and 003 are composed entirely of stormwater, a formal water quality analysis cannot be accurately conducted. Accordingly, water quality-based effluent limitations based on water quality analyses are not proposed.

NPDES Permit Fact Sheet Riverside Water Treatment Plant

Additionally, reported analytical results submitted in the NPDES permit application for Outfall 002 did not indicate any parameters of concern.

Total Maximum Daily Load (TMDL)

Stonycreek River is located within the Kiskiminetas-Conemaugh River Watershed, for which the Department has developed a TMDL. The Kiskiminetas-Conemaugh River Watershed TMDL was finalized on January 29, 2010 to control acid mine drainage pollutants including aluminum, iron, manganese, sediment, and pH. Section 303(d) of the Clean Water Act and the U.S. Environmental Protection Agency's ("EPA's") Water Quality Planning and Management Regulations (codified at Title 40 of the Code of Federal Regulations Part 130) require states to develop a TMDL for impaired water bodies. A TMDL establishes the amount of a pollutant that a water body can assimilate without exceeding its water quality standard for that pollutant. TMDLs provide the scientific basis for a state to establish water quality-based controls to reduce pollution from both point and non-point sources to restore and maintain the quality of the state's water resources (USEPA 1991).

Stream reaches within the Kiskiminetas-Conemaugh River Watersheds are included in the state's 2008 Section 303(d) list because of various impairments, including metals, pH, and sediment. The TMDL includes consideration for each river and tributary within the target watershed and its impairment sources. Stream data is then used to calculate minimum pollutant reductions that are necessary to attain water quality criteria levels. Target concentrations published in the TMDL were based on established water quality criteria of 0.750 ^{mg}/_L total recoverable aluminum, 1.5 ^{mg}/_L total recoverable iron based on a 30-day average and 1.0 ^{mg}/_L total recoverable manganese. The reduction needed to meet the minimum water quality standards is then divided between each known point and non-point pollutant source in the form of a watershed allocation. TMDLs prescribe allocations that minimally achieve water quality criteria (i.e., 100 percent use of a stream's assimilative capacity). The Kiskiminetas-Conemaugh River Watershed TMDL does not include a wasteload allocation (WLA) for Riverside WTP.

Since the discharges from Outfalls 002 and 003 are composed entirely of stormwater, only monitor and report for aluminum, iron and manganese will be imposed at Outfalls 002 and 003 to address the Kiskiminetas-Conemaugh River Watersheds TMDL.

Anti-Backsliding

The monitoring requirements in Table 10 below are from the current permit, issued on July 1, 2017. Since the discharges from Outfalls 002 and 003 are composed entirely of stormwater, flow monitoring is not applicable to these outfalls and will be removed from the permit.

Table 10: Current Permit Monitoring Requirements - Outfall 002							
Parameter Average Maximum IMAX Units Monitoring Frequency							
Flow	Monitor & Report		-	MGD	1/ quarter		

Proposed Effluent Limitations and Monitoring Requirements

The proposed effluent monitoring requirements for Outfalls 002 and 003 are displayed in Table 11 below. Since discharges from Outfalls 002 and 003 are composed entirely of stormwater, flow monitoring is no longer imposed at Outfall 002. No effluent monitoring is proposed for Outfall 004 since it is considered a no exposure outfall and contains comingled stormwater.

A Part C condition is included in the Draft Permit requiring submission of a Corrective Action Plan when there are two consecutive exceedances of the benchmark values. The benchmark values are displayed below in Table 11 and included in the Part C condition. These values are from the EPA'S 2021 Multisector General Permit document and are not effluent limitations. Exceedance of the benchmark values is not a violation. If there are two consecutive exceedances of the benchmark value, a Corrective Action Plan must be conducted to evaluate site stormwater controls and BMPs. Benchmark monitoring is a feedback tool, along with routine inspections and visual assessments, for assessing the effectiveness of stormwater controls and BMPs. An exceedance of the benchmark provides permittees with an indication that the facility's controls may not be sufficiently controlling pollutants in stormwater.

NPDES Permit Fact Sheet Riverside Water Treatment Plant

The monitoring frequency for stormwater outfalls is reduced from quarterly to semiannually to reflect the monitoring frequency in the PAG-03 General Stormwater Permit.

Table 11: Proposed Effluent Monitoring Requirements - Outfalls 002, 003								
	Average	Daily Maximum	Benchmark Values	Monitoring Requirements				
Parameters	Monthly (mg/L)	(mg/L)	(mg/L)	Monitoring Frequency	Sample Type			
Aluminum, total	-	Monitor & Report	-	1/6 Months	Grab			
Iron, total	-	Monitor & Report	-	1/6 Months	Grab			
Manganese, total	-	Monitor & Report	-	1/6 Months	Grab			
Nitrogen, total	-	Monitor & Report	-	1/6 Months	Grab			
Phosphorus, total	-	Monitor & Report	-	1/6 Months	Grab			
Total Suspended Solids	-	Monitor & Report	100	1/6 Months	Grab			
Oil and Grease	-	Monitor & Report	30	1/6 Months	Grab			
рН	-	Monitor & Report	9.0	1/6 Months	Grab			
Chemical Oxygen Demand	-	Monitor & Report	120	1/6 Months	Grab			

	Tools and References Used to Develop Permit
	WQM for Windows Model (see Attachment)
	Toxics Management Spreadsheet (see Attachment D)
	TRC Model Spreadsheet (see Attachment E)
	Temperature Model Spreadsheet (see Attachment)
	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
	Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97.
	Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98.
	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96.
	Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97.
	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97.
	Pennsylvania CSO Policy, 385-2000-011, 9/08.
	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97.
	Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97.
	Implementation Guidance Design Conditions, 391-2000-006, 9/97.
	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004.
	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997.
	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99.
	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004.
	Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97.
	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008.
\boxtimes	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994.
	Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09.
	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97.
	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97.
	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99.
	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999.
	Design Stream Flows, 391-2000-023, 9/98.
	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98.
	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97.
	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
	SOP:
	Other:

Attachments

Attachment A: Site Plan

Attachment B: Line Drawing


Attachment C: USGS StreamStats Report


Attachment D: Toxics Management Spreadsheet Model Output

Attachment E: TRC Modeling Results

ATTACHMENT A:

Site Plan






Attachment B: Line Drawing

LINE DRAWING & WATER BALANCE

GREATER JOHNSTOWN WATER AUTHORITY RIVERSIDE WATER TREATMENT PLANT

STONYCREEK TOWNSHIP, CAMBRIA COUNTY



Attachment C: USGS StreamStats Report

StreamStats Report

Region ID:

PA20230407151248948000 Workspace ID:

Clicked Point (Latitude, Longitude): 40.28581, -78.92585

2023-04-07 11:13:09 -0400



Collapse All

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	452	square miles
ELEV	Mean Basin Elevation	2160	feet
PRECIP	Mean Annual Precipitation	43	inches

Low-Flow Statistics

Low-Flow Statistics Parameters [99.9 Percent (452 square miles) Low Flow Region 3]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	452	square miles	2.33	1720
ELEV	Mean Basin Elevation	2160	feet	898	2700
PRECIP	Mean Annual Precipitation	43	inches	38.7	47.9

Low-Flow Statistics Flow Report [99.9 Percent (452 square miles) Low Flow Region 3]

PII: Prediction Interval-Lower, Plu: Prediction Interval-Upper, ASEp: Average Standard Error of Prediction, SE: Standard Error (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	66.1	ft*3/s	43	43
30 Day 2 Year Low Flow	86	ft*3/s	38	38
7 Day 10 Year Low Flow	36.5	ft^3/s	54	54
30 Day 10 Year Low Flow	44.5	ft^3/s	49	49
90 Day 10 Year Low Flow	62.4	ft^3/s	41	41

Low-Flow Statistics Citations

Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (http://pubs.usgs.gov/sir/2006/5130/)

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.14.0

StreamStats Services Version: 1.2.22

NSS Services Version: 2.2.1


ATTACHMENT D:

Toxics Management Spreadsheet Model Output



Toxics Management Spreadsheet Version 1.3, March 2021

Discharge Information



			Discharge	Characteris	tics		80	
Design Flow	-11 (eth)	Partial Mix Factors (PMFs)		s)	Complete Mix Times (n			
(MGD)*	(MGD)* Hardness (mg/l)*	ardness (mg/l)* pH (SU)*	AFC	CFC	THH	CRL	Q ₇₋₁₀	Qh
0.243	22.4	7.5	0					

	in the second se				0.171	eft blank	0.5 M N	eft blank		if left blan	k	1 If lef	t blank
	Discharge Pollutant	Units	Ma	x Discharge Conc	Trib Conc	Stream Conc	Daily CV	Hourly CV	Strea m CV	Fate Coeff	FOS	5755TTTT	Chem Transl
	Total Dissolved Solids (PWS)	mg/L		50									
5	Chloride (PWS)	mg/L	13 - 137	9.67				1	7	00			
Group	Bromide	mg/L	<	0.036					Š.	8 8			60
5	Sulfate (PWS)	mg/L		12.6									
	Fluoride (PWS)	mg/L	<	0.05									
	Total Aluminum	µg/L		466									
	Total Antimony	µg/L	<	0.348									
	Total Arsenic	µg/L	<	1				3	-	**			S
	Total Barium	µg/L		34.7						9 9			ž.
	Total Beryllium	µg/L	<	0.676									
	Total Boron	µg/L	<	0.565					8	¥5 22			8
	Total Cadmium	µg/L	<	0.123					9	Q 19			ž .
	Total Chromium (III)	µg/L	<	0.00199									
	Hexavalent Chromium	µg/L	<	0.00025				18	8	× 7			9
	Total Cobalt	µg/L	<	0.119						8 8			
	Total Copper	µg/L		2.43									
N	Free Cyanide	µg/L							-				
Group	Total Cyanide	µg/L	<	0.006						8 8			
320	Dissolved Iron	µg/L	<	20									100701
~	Total Iron	µg/L		82.3					-				
	Total Lead	µg/L	<	0.172						8 8			ŝ
	Total Manganese	µg/L	0.01014	176									
	Total Mercury	µg/L	<	0.000104					-				1
	Total Nickel	µg/L	<	1.44					i.	8 8			ŝ
	Total Phenols (Phenolics) (PWS)	µg/L	<	0.002									
	Total Selenium	µg/L	<	1.67									1
	Total Silver	µg/L	<	0.274				di i		8 3			ă .
	Total Thallium	µg/L	<	0.068									
	Total Zinc	µg/L		48.3									
	Total Molybdenum	µg/L	<	0.2						8 2			Š.
	Acrolein	µg/L	<	0.2									
	Acrylamide	µg/L	<							1			
	Acrylonitrile	µg/L	<							0 0			
	Benzene	µg/L	<						8	8) IS			
	Bromoform	µg/L	<										

	Carbon Tetrachloride	medi	*		10		k 3	(i)			1	200
		µg/L	-									
	Chlorobenzene Chlorodinessenessenes	µg/L	- 2									
	Chlorodibromomethane	µg/L	*		8							2
	Chloroethane	µg/L	*							-		
	2-Chloroethyl Vinyl Ether	µg/L	*		2							8
	Chloroform	µg/L	*									
	Dichlorobromomethane	µg/L	*		ŅĮ.							22
	1,1-Dichloroethane	µg/L	*									
•	1,2-Dichloroethane	µg/L	*		ä -							ii.
4	1,1-Dichioroethylene	µg/L	*									
Group	1,2-Dichloropropane	µg/L	*									86
9	1,3-Dichioropropylene	µg/L	. 45									
	1,4-Dioxane	µg/L	*		2			6	3			8
	Ethylbenzene	µg/L	- es				-					
	Methyl Bromide	µg/L	<		0	1	()	0	3 3	1 1		0
	Methyl Chloride	µg/L	*				-	*				100
	Methylene Chloride	µg/L	*		0		S 19	80	3 3	8 9		90
	1,1,2,2-Tetrachloroethane	µg/L	*			3 3	-	80	3 3	1		20
	Tetrachloroethylene		*		96		8 19	80 1	2 3	8 19		90.
	Toluene	µg/L	*				1	20		1		100
		µg/L	0.0		99		2 10	201	0	2 10		20
	1,2-trans-Dichloroethylene	µg/L	*			3	- 4	50	3 3	- 3		
	1,1,1-Trichloroethane	µg/L	*		E	1 1	0 0	(6)	9 3	0 0		835
	1,1,2-Trichloroethane	µg/L	*									36
	Trichloroethylene	µg/L	- 45			5	1	8	5 5	4 3		33
	Vinyl Chloride	µg/L	*									1/1
	2-Chlorophenol	µg/L	*				()	8	8 8			
	2,4-Dichlorophenol	µg/L	*	,								
	2,4-Dimethylphenol	µg/L	-									
	4,6-Dinitro-o-Cresol	µg/L	40		0.							
4	2,4-Dinitrophenol	µg/L	-		82							99
Group	2-Nitrophenol	µg/L	*									
2	4-Nitrophenol	µg/L	*		0	3 3		0	3 3			00
_	p-Chloro-m-Cresol	µg/L	*									
	Pentachiorophenol	µg/L	*		0			0				0
	Phenol	µg/L	*									
	2,4,6-Trichiorophenol	µg/L	*		8			6				8
-	Acenaphthene	µg/L	*									-
	Acenaphthylene	µg/L	*		32							85
	Anthracene		*		4							44
		µg/L	100				-					
	Benzidine	µg/L	*		(i)			0				46
	Benzo(a)Anthracene	µg/L	*				-					
	Benzo(a)Pyrene	µg/L	*			3		8	3			8
	3,4-Benzofluoranthene	µg/L	*									
	Benzo(ghl)Perylene	µg/L	*			8		8				10
	Benzo(k)Fluoranthene	µg/L	*									
	Bls(2-Chloroethoxy)Methane	µg/L	*				1	8		4		80
	Bis(2-Chloroethyl)Ether	µg/L	40							-		
	Bis(2-Chloroisopropyi)Ether	µg/L	*				1 2	8		1		
	Bis(2-Ethylhexyl)Phthalate	µg/L	*			9 3	8 6	8	8	8 8		0
	4-Bromophenyl Phenyl Ether	µg/L	*									
	Butyl Benzyl Phthalate	µg/L	*			8 8	4 3	8	1 1	. 3		
	2-Chloronaphthalene	µg/L	40									
	4-Chlorophenyl Phenyl Ether	µg/L	*			3 3		8	1 1	. 1		
	Chrysene	µg/L	*				17	VII .		17		
	Dibenzo(a,h)Anthrancene	µg/L	-			1 1	7	10	1 1	7		100
			-					0	1	()		200
	1,2-Dichlorobenzene	µg/L	*		6					1		100
	1,3-Dichlorobenzene	µg/L	*		8.			8				4
0	1,4-Dichlorobenzene	µg/L	*				- 1	Co.		- 10		
¥	3,3-Dichlorobenzidine	µg/L	*		8.			8				8
droug	Diethyl Phthalate	µg/L	*									,
-	Dimethyl Phthalate	µg/L	*									8
	Di-n-Butyl Phthalate	µg/L	*		J.							J
	2,4-Dinitrotoluene	µg/L	*		88	Q 3		8				20


	2,6-Dinitrotoluene	µg/L	*			1 3			- 3			
			*			-						
	Di-n-Octyl Phthalate	µg/L	-	99			el:				di i	
	1,2-Diphenyihydrazine	µg/L	*			- 3			- 0			i.
Ų	Fluoranthene	µg/L	*									
	Fluorene	µg/L	¥									e e
	Hexachiorobenzene	µg/L	*									
	Hexachlorobutadiene	µg/L	*			- 8		3				Ġ.
	Hexachiorocyclopentadiene	µg/L	*	*			-		1			
	Hexachloroethane	µg/L	*	ė.	3 3	19	01 3	8 8	1.5		(E) 3	
	Indeno(1,2,3-cd)Pyrene	µg/L	*			- 3		7 3	- 2	_		
				51		10	O1 5	2 3	100		D))	
	Isophorone	µg/L	*	Į.		- 3		8 8	- 3			
	Naphthalene	µg/L	*									
	Nitrobenzene	µg/L	¥			1 8			- 8			
	n-Nitrosodimethylamine	µg/L	*	6		8	6	5 3	- 8		Ø	
	n-Nitrosodi-n-Propylamine	µg/L	*									
	n-Nitrosodiphenylamine	µg/L	*			- 3		8	- 3		1	
	Phenanthrene	µg/L	*									
	400-1-0			8		- 3		5 8	- 8			
	Pyrene	µg/L	*	6		10	\$1 - 3	8 8	. 8		80 3	0
_	1,2,4-Trichlorobenzene	µg/L	*									
	Aldrin	µg/L	*	8	8 8	8		8	. 8		1	3
	alpha-BHC	µg/L	*	Ų.								
	beta-BHC	µg/L	*			- 3						1
	gamma-BHC	µg/L	*									
	delta BHC	µg/L	*		8 0	70	61 3	7 9			S 3	
	Chlordane		*	3	-							3
		µg/L		Co.							-1	
	4,4-DDT	µg/L	*		6 6							8
	4,4-DDE	µg/L	*									
	4,4-DDD	µg/L	*	2		33						
	Dieldrin	µg/L	*									
	alpha-Endosulfan	µg/L	*								8	e e
	beta-Endosulfan	µg/L	*									
	Endosulfan Sulfate	µg/L	*					2 3			8: 1	
dion's	City Color Color City Color		*	-				-	-			
2	Endrin	µg/L					di .				d.	
9	Endrin Aldehyde	µg/L	*		E 5	3			3			i i
	Heptachlor	µg/L	*									
	Heptachlor Epoxide	µg/L	*			1 2		3 3	1 8			
	PCB-1016	µg/L	*									
	PCB-1221	µg/L	*	8		- 9		i 3				9
	PCB-1232	µg/L	*	*			-	1				
	PCB-1242		*	80			21 2	2 0	1 (8)		es >	e.
	C. (*C.) (*C.) (*C.) (*C.)	µg/L				- 0		3	- 0			-
	PCB-1248	µg/L	*									
	PCB-1254	µg/L	*	3	8	8	9	2 2	- 8			8
	PCB-1260	µg/L	*	81	8 3	8	Ni 3	3	. 8		1	8
	PCBs, Total	µg/L	*	L,		, ,						
	Toxaphene	µg/L	*	8	3	8		1 1	- 8		No.	1
	2,3,7,8-TCDD	ng/L	*									
7	Gross Alpha	pCl/L		ž.	£ 2	- 64		8 8	- 8		2 3	1
	C. DOLOGO C. C. C.	pCl/L	100	(a)	3	- 0	0 2	-	10			0
-	Total Beta		*	20		- ×	1					2
	Radium 226/228	pCI/L	*				4 1					i i
5	Total Strontlum	µg/L	*				4:				3:	
1	Total Uranium	µg/L	*			- 3						1
	Osmotic Pressure	mOs/kg										
į.		- 0				1 2		1	70			1
				-		- 20	31 3		- 55		6	
		-			3	- 3	8: 3		- 3		(i)	
											J	
		- 1		14	1	- 3	A)		- 3			
				ii.	8	3	3 3				8 3	
							1					
		- 1			2	-	d: 5		- 2		g:	
					100				1 110			
		-										



Toxics Management Spreadsheet Version 1.3, March 2021

Stream / Surface Water Information

Riverside Water Treatment Plant, NPDES Permit No. PA0095010, Outfall 001





Total Phenols (Phenolics) (PWS)

Total Selenium

Total Silver

Total Thallium

Total Zinc

0

0

0

0

0

0

0

0

0

0

0

0

0

N/A

N/A

3.026

65

113.705

Toxics Management Spreadsheet Version 1.3, March 2021

Chem Translator of 0.922 applied

Chem Translator of 0.85 applied

Chem Translator of 0.978 applied

Model Results

Riverside Water Treatment Plant, NPDES Permit No. PA0095010, Outfall 001

ructions Results	RETUR	I TO INPU	TS	SAVE AS	PDF	PRIN	т . • А	dl () Inputs (Results O Limits
Hydrodynamics Wasteload Allocations									
☑ AFC C	CCT (min):	15	PMF:	0.219	Ana	lysis Hardne	ess (mg/l):	96.509 A	nalysis pH: 7.01
Pollutants	Conc	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)		Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A		
Chloride (PWS)	0	0		0	N/A	N/A	N/A		
Sulfate (PWS)	0	0	3 3	0	N/A	N/A	N/A		
Fluoride (PWS)	0	0		0	N/A	N/A	N/A		
Total Aluminum	0	0	1 1	0	750	750	16,672		
Total Antimony	0	0		0	1,100	1,100	24,453		
Total Arsenic	0	0		0	340	340	7,558		Chem Translator of 1 applied
Total Barium	0	0		0	21,000	21,000	466,828		11867
Total Boron	0	0		0	8,100	8,100	180,062		
Total Cadmium	0	0		0	1.945	2.06	45.7	C	hem Translator of 0.945 applied
Total Chromium (III)	0	0		0	553.422	1,751	38,932	C	hem Translator of 0.316 applied
Hexavalent Chromium	0	0		0	16	16.3	362	C	hem Translator of 0.982 applied
Total Cobalt	0	0		0	95	95.0	2,112		
Total Copper	0	0		0	12.997	13.5	301	(Chem Translator of 0.96 applied
Dissolved Iron	0	0		0	N/A	N/A	N/A	~	
Total Iron	0	0		0	N/A	N/A	N/A	200	CO SECOND EXPLOSES - EATT
Total Lead	0	0	1	0	62.129	78.0	1,735	C	hem Translator of 0.798 applied
Total Manganese	0	0	3 (0	N/A	N/A	N/A		A ROLL OF THE STATE OF THE STAT
Total Mercury	0	0		0	1.400	1.65	36.6	(Chem Translator of 0.85 applied
Total Nickel	0	0		0	1.400 454.370	1.65 455	36.6 10,121		them Translator of 0.85 applied them Translator of 0.998 applied
LIDE LAND C. LANDINGS		- 0		- 0			2.552		

Model Results 4/10/2023 Page 5

N/A

N/A

3.56

65.0

116

N/A

N/A

79.1

1,445

2,585

Pollutants	Conc	Stream	Trib Conc	Fate	WQC	WQ Obj	WLA (µg/L)	Comments
Table District Called (DMC)	(und)	0	(µg/L)	Coef	(µg/L)	(µg/L) N/A		
Total Dissolved Solids (PWS)	0	570 5		0	N/A N/A	N/A	N/A N/A	
Chloride (PWS)	0	0		0	100000		1 1000000000000000000000000000000000000	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A N/A	
Fluoride (PWS)	0	0		0	N/A N/A	N/A N/A	N/A N/A	
Total Aluminum	11.56.0	770		3350	220	220	21.581	
Total Antimony	0	0		0	150	150		Character and applied
Total Arsenic Total Barium	0	0		0	4.100	4,100	14,714 402,189	Chem Translator of 1 applied
		* C		10.77500		124 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	I CONTRACTOR OF THE PARTY OF TH	
Total Boron	0	0		0	1,600 0.245	1,600	156,952 26.4	Chan Tanada - 10 000 - 1
Total Cadmium Total Chromium (III)	0	0		0	73.634	85.6	8,399	Chem Translator of 0.909 applied
Digital Control of Control of Control	4.	770			00.00	200103	A CONTRACTOR OF THE PARTY OF TH	Chem Translator of 0.86 applied
Hexavalent Chromium	0	0		0	10	10.4	1,020	Chem Translator of 0.962 applied
Total Cobalt	0	0		0	19	19.0	1,864	0 7 1 1000
Total Copper	0	0		0	8.895	9.27	909	Chem Translator of 0.98 applied
Dissolved Iron	0	0		0	N/A	N/A	N/A	WOO - 20 4 PMT - 4
Total Iron	0	0		0	1,500	1,500	147,142	WQC = 30 day average; PMF = 1
Total Lead	0	0		0	2.495	3.15	309	Chem Translator of 0.792 applied
Total Manganese	0	0		0	N/A	N/A	N/A	OL T 120 OS
Total Mercury	0	0		0	0.770	0.91	88.9	Chem Translator of 0.85 applied
Total Nickel	0	0		0	51.658	51.8	5,083	Chem Translator of 0.997 applied
Total Phenols (Phenolics) (PWS)	0	0		0	N/A	N/A	N/A	
Total Selenium	0	0		0	4.600	4.99	489	Chem Translator of 0.922 applied
Total Silver	0	0		0	N/A	N/A	N/A	Chem Translator of 1 applied
Total Thallium	0	0		0	13	13.0	1,275	
Total Zinc	0	0		0	117.347	119	11,675	Chem Translator of 0.986 applied
⊘ тнн со	CT (min): ##	****	PMF:	1	Ana	alysis Hardne	ess (mg/l):	N/A Analysis pH: N/A
Pollutants	Conc (ug/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	500,000	500,000	N/A	
Chloride (PWS)	0	0		0	250,000	250,000	N/A	
Sulfate (PWS)	0	0		0	250,000	250,000	N/A	
Fluoride (PWS)	0	0		0	2,000	2,000	N/A	
Total Aluminum	0	0		0	N/A	N/A	N/A	
Total Antimony	0	0	1	0	5.6	5.6	549	
Total Arsenic	0	0		0	10	10.0	981	
Total Barium	0	0		0	2,400	2,400	235,428	
Total Boron	0	0		0	3,100	3,100	304,094	
Total Cadmium	0	0		0	N/A	N/A	N/A	
Total Chromium (III)	0	0		0	N/A	N/A	N/A	

Hexavalent Chromium	0	0	8 3	0	N/A	N/A	N/A	
Total Cobalt	0	0		0	N/A	N/A	N/A	
Total Copper	0	0		0	N/A	N/A	N/A	
Dissolved Iron	0	0		0	300	300	29,428	
Total Iron	0	0		0	N/A	N/A	N/A	
Total Lead	0	0		0	N/A	N/A	N/A	
Total Manganese	0	0		0	1,000	1,000	98,095	
Total Mercury	0	0		0	0.050	0.05	4.9	
Total Nickel	0	0		0	610	610	59,838	
Total Phenols (Phenolics) (PWS)	0	0		0	5	5.0	N/A	
Total Selenium	0	0		0	N/A	N/A	N/A	
Total Silver	0	0	5 1	0	N/A	N/A	N/A	
Total Thallium	0	0		0	0.24	0.24	23.5	
Total Zinc	0	0		0	N/A	N/A	N/A	
☑ CRL CC	T (min): ##	- W	PMF:	1		alysis Hardn	ess (mg/l):	N/A Analysis pH: N/A
Pollutants	Conc	Stream	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Fluoride (PWS)	0	0		0	N/A	N/A	N/A	
Total Aluminum	0	0		0	N/A	N/A	N/A	

0

Total Antimony

0

0

N/A

N/A

N/A

✓ Recommended WQBELs & Monitoring Requirements

No. Samples/Month: 4

	Mass	Limits		Concentra	ation Limits		I		
Pollutants	AML (lbs/day)	MDL (lbs/day)	AML	MDL	IMAX	Units	Governing WQBEL	WQBEL Basis	Comments
	20,000,	100 015010							

Other Pollutants without Limits or Monitoring

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., <= Target QL).

Pollutants	Governing WQBEL	Units	Comments
Total Dissolved Solids (PWS)	N/A	N/A	PWS Not Applicable
Chloride (PWS)	N/A	N/A	PWS Not Applicable
Bromide	N/A	N/A	No WQS
Sulfate (PWS)	N/A	N/A	PWS Not Applicable
Fluoride (PWS)	N/A	N/A	Discharge Conc < TQL
Total Aluminum	10,686	µg/L	Discharge Conc ≤ 10% WQBEL
Total Antimony	N/A	N/A	Discharge Conc < TQL
Total Arsenic	N/A	N/A	Discharge Conc < TQL
Total Barium	235,428	µg/L	Discharge Conc ≤ 10% WQBEL
Total Beryllium	N/A	N/A	No WQS
Total Boron	115,413	µg/L	Discharge Conc < TQL
Total Cadmium	26.4	µg/L	Discharge Conc < TQL
Total Chromium (III)	8,399	µg/L	Discharge Conc < TQL
Hexavalent Chromium	232	µg/L	Discharge Conc < TQL
Total Cobalt	1,354	µg/L	Discharge Conc < TQL
Total Copper	193	µg/L	Discharge Conc ≤ 10% WQBEL
Total Cyanide	N/A	N/A	No WQS
Dissolved Iron	29,428	µg/L	Discharge Conc < TQL
Total Iron	147,142	µg/L	Discharge Conc ≤ 10% WQBEL
Total Lead	309	µg/L	Discharge Conc < TQL
Total Manganese	98,095	µg/L	Discharge Conc ≤ 10% WQBEL
Total Mercury	4.9	µg/L	Discharge Conc < TQL
Total Nickel	5,083	µg/L	Discharge Conc < TQL
Total Phenols (Phenolics) (PWS)		µg/L	Discharge Conc < TQL
Total Selenium	489	µg/L	Discharge Conc < TQL
Total Silver	50.7	µg/L	Discharge Conc < TQL
Total Thallium	23.5	µg/L	Discharge Conc < TQL
Total Zinc	1,657	µg/L	Discharge Conc ≤ 10% WQBEL
Total Molybdenum	N/A	N/A	No WQS

ATTACHMENT E:

TRC Modeling Results

TRC EVALUATION

0	0 = Chlorine De 0.5 = BAT/BPJ V 0 = % Factor o	e (MGD) s emand of Stream emand of Discharge alue of Safety (FOS)	0.5 0.219 1 15 313.75	= CFC_Criteria =Decay Coeffic	lix Factor Compliance Time (min) Compliance Time (min) ent (K)
Source	Reference	AFC Calculations	0.000	Reference	CFC Calculations
TRC PENTOXSD TRG	1.3.2.iii 5.1a	WLA afc = LTAMULT afc =		1.3.2.iii 5.1c	WLA cfc = 30.208 LTAMULT cfc = 0.581
PENTOXSD TRG	5.1b	LTAMOET alc =		5.1d	LTA cfc = 17.561
	0000000	s=.109==10.74	and the second		
Source	97	Efflue	ent Limit Calcul	ations	
PENTOXSD TRG	5.1f		AML MULT =	1.720	
PENTOXSD TRG	5.1g	AVG MON	LIMIT (mg/l) =	0.500	BAT/BPJ
WLA afc		C_tc)) + [(AFC_Yc*Qs*.019/Q C_Yc*Qs*Xs/Qd)]*(1-FOS/100		z))	
WLA afc LTAMULT afc	+ Xd + (AFC EXP((0.5*LN(C_Yc*Qs*Xs/Qd)]*(1-FOS/100) cvh^2+1))-2.326*LN(cvh^2+1)^() _	c))	
	+ Xd + (AF	C_Yc*Qs*Xs/Qd)]*(1-FOS/100) cvh^2+1))-2.326*LN(cvh^2+1)^() _	z))	
LTAMULT afc LTA_afc	+ Xd + (AFC EXP((0.5*LN(wla_afc*LTAM (.011/e(-k*CF	C_Yc*Qs*Xs/Qd)]*(1-FOS/100) cvh^2+1))-2.326*LN(cvh^2+1)^() 0.5) d*e(-k*CFC_tc		
LTAMULT afc	+ Xd + (AFC EXP((0.5*LN(wla_afc*LTAM (.011/e(-k*CF + Xd + (CFC	C_Yc*Qs*Xs/Qd)]*(1-FOS/100] cvh^2+1))-2.326*LN(cvh^2+1)^(ULT_afc C_tc) + [(CFC_Yc*Qs*.011/Qc) () () () () () () () () () () () () ()	:))	
LTAMULT afc LTA_afc WLA_cfc LTAMULT_cfc	+ Xd + (AFC EXP((0.5*LN(wla_afc*LTAM (.011/e(-k*CF + Xd + (CFC	C_Yc*Qs*Xs/Qd)]*(1-FOS/100] cvh^2+1))-2.326*LN(cvh^2+1)^(ULT_afc C_tc) + [(CFC_Yc*Qs*.011/Qc C_Yc*Qs*Xs/Qd)]*(1-FOS/100 cvd^2/no_samples+1))-2.326*LI) () () () () () () () () () () () () ()	:))	
LTAMULT afc LTA_afc WLA_cfc	+ Xd + (AFC EXP((0.5*LN() wla_afc*LTAM (.011/e(-k*CF + Xd + (CFC EXP((0.5*LN() wla_cfc*LTAM	C_Yc*Qs*Xs/Qd)]*(1-FOS/100] cvh^2+1))-2.326*LN(cvh^2+1)^(ULT_afc C_tc) + [(CFC_Yc*Qs*.011/Qc C_Yc*Qs*Xs/Qd)]*(1-FOS/100 cvd^2/no_samples+1))-2.326*LI) D.5) H*e(-k*CFC_to) N(cvd^2/no_sa	e)) mples+1)^0.5)	
LTAMULT afc LTA_afc WLA_cfc LTAMULT_cfc LTA_cfc	+ Xd + (AFC EXP((0.5*LN() wla_afc*LTAM (.011/e(-k*CF + Xd + (CFC EXP((0.5*LN() wla_cfc*LTAM EXP(2.326*LN	C_Yc*Qs*Xs/Qd)]*(1-FOS/100) cvh^2+1))-2.326*LN(cvh^2+1)^(ULT_afc C_tc) + [(CFC_Yc*Qs*.011/Qc C_Yc*Qs*Xs/Qd)]*(1-FOS/100) cvd^2/no_samples+1))-2.326*LI ULT_cfc) D.5) H*e(-k*CFC_to) N(cvd^2/no_sa .5*LN(cvd^2/no	e)) mples+1)^0.5)	