

Southwest Regional Office CLEAN WATER PROGRAM

# Application Type Renewal Facility Type Municipal Major / Minor Minor

#### NPDES PERMIT FACT SHEET INDIVIDUAL SEWAGE

Application No.	PA0096229
APS ID	<u>1021517</u>
Authorization ID	1323502

#### Applicant and Facility Information

Applicant Name	Marianna-West Bethlehem Joint Sewage Authority	Facility Name	Marianna-West Bethlehem Joint Sewage Authority WWTP			
Applicant Address	PO Box 428	Facility Address	East End Of Broad Street			
	Marianna, PA 15345-0428		Marianna, PA 15345			
Applicant Contact	ar Harris					
Applicant Phone	(724) 288-1550	Facility Phone _(724) 966-2278				
Client ID	44051	Site ID	237624			
Ch 94 Load Status	Not Overloaded	Municipality	West Bethlehem Township			
Connection Status	No Limitations	County	Washington			
Date Application Rece	ived <u>August 11, 2020</u>	EPA Waived? Yes	Date Application Accepted August			
19, 2020	_If No, Reason	Purpose of Applicati	on			
	Renewal of an existing NPDES permit for	the discharge of treated	sewage.			

#### **Public Participation**

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
x		<i>Derek S. Garner</i> Derek S. Garner / Project Manager	May 20, 2021
x		<i>Nícholas W. Hartranft</i> Nicholas W. Hartranft, P.E. / Environmental Engineer Manager	May 20, 2021

	Discharge, Receiving Waters and Water Supply Information						
Outfall No. <u>001</u> Latitude <u>40° 1' 29.60"</u> Quad Name <u>Ellsworth</u> Wastewater Description: <u>Sewage Effluent</u>	Design Flow (MGD) Longitude Quad Code	0.142 -80º 5' 6.34" 1805					
Receiving WatersTenmile CreekNHD Com ID99412040Drainage Area117Q7-10 Flow (cfs)2.39Elevation (ft)859Watershed No.19-BExisting Usen/a	Stream Code RMI Yield (cfs/mi <sup>2</sup> ) Q <sub>7-10</sub> Basis Slope (ft/ft) Chapter 93 Class. Existing Use Qualifier	40285 10.1 0.0204 Streamgage No. 03072840 n/a TSF n/a					
Exceptions to Usen/a         Assessment Status       Impaired         Cause(s) of Impairment       Habitat Alterations, Metals, Siltation         Source(s) of Impairment       Acid Mine Drainage, Streambank         TMDL Status       n/a         Nearest Downstream Public Water Supply Intake       Tri-Count	Exceptions to Criteria on <u>Modifications/Destabiliza</u> Name <u>n/a</u> ty Joint Municipal Authori	tionty on the Monongahela River					

#### **Treatment Facility Summary**

The Marianna-West Bethlehem Joint Sewage Authority ("MWBJSA") Wastewater Treatment Plant ("WWTP") was constructed and operates under WQM Permit No. 6386410, issued February 24, 1987. The WWTP has an average annual design flow of 0.142 MGD, hydraulic capacity of 0.307 MGD, and an organic capacity of 345 lbs/day. Treatment at the facility consists of:

- One (1) comminutor,
- One (1) grit removal chamber,
- Two (2) aeration tanks,
- Two (2) final clarifiers,
- Two (2) chlorine contact tanks
- Two (2) aerated sludge holding tanks, and
- Two (2) sludge drying beds

Disinfected effluent is ultimately discharged via Outfall 001 to Tenmile Creek.

When necessary, sludge is hauled offsite by Liquid Assets Disposal.

#### **Compliance History**

No effluent violations have occurred during the existing permit's term.

There are no open violations associated with the permittee.

The facility was most recently inspected by DEP on April 8, 2021. The inspection report indicates that all necessary treatment equipment is operable. No impacts to Tenmile Creek were noted. The inspection did not yield any violations.

#### **Development of Effluent Limitations**

Outfall No.	001		
Latitude	40° 1' 29.00	)"	
Wastewater D	escription:	Sewage Effluent	

 Design Flow (MGD)
 0.142

 Longitude
 -80° 5' 6.00"

#### **Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant Limit (mg/l) SBC F		Federal Regulation	State Regulation	
CROD	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
CBOD5	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
Solids	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform				
(5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform				
(5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform				
(10/1 - 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform				
(10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

#### Water Quality-Based Limitations

The applicability of WQBELs for ammonia-nitrogen, CBOD5, and dissolved oxygen were evaluated using DEP's WQM 7.0 v1.1. All input/output data and supporting documentation is attached. Reaches were created in WQM 7.0 along Tenmile Creek starting at Outfall 001 until a recovery in dissolved oxygen was observed. Existing effluent limits for ammonia-nitrogen, CBOD5, and dissolved oxygen were used for input values. The model results are as follows:

Deremeter	Effluent Limit (mg/l)					
Parameter	Average Monthly	Maximum	Minimum			
CBOD5	20	-	-			
Ammonia-nitrogen	5.0	10	-			
Dissolved Oxygen	-	-	4			

Based on the above model output, the existing effluent limits are protective of Tenmile Creek.

The existing TRC limit of 0.5 mg/l was evaluated using the TRC\_CALC spreadsheet (attached). The results indicate the existing requirements are protective of Tenmile Creek.

#### **Best Professional Judgment (BPJ) Limitations**

DEP proposes to continue requiring an effluent limit of 4 mg/l dissolved monitoring for total nitrogen and phosphorus to help characterize the wastewater.

The permit has historically included seasonal limits for CBOD5 and ammonia-n, based on the treatability of wastewater being significantly impacted by temperature and seasonal variances in stream flow. Since the facility has demonstrated compliance with the existing limits and no impacts to Tenmile Creek have been documented in relation to these parameters, DEP recommends the existing seasonal limits remain in the permit.

The permit currently requires influent monitoring for BOD5 and TSS to help characterize the wastewater for Chapter 94 reporting requirements. DEP recommends that these requirements remain in the permit.

#### NPDES Permit Fact Sheet MWBJSA WWTP

An annual monitoring requirement for E. Coli is proposed per the 2017 Triennial Review of Water Quality Standards, published in the PA Bulletin on July 11, 2020.

#### Anti-Backsliding

Proposed loading limits are slightly less stringent than the existing limits. The existing loading limits are based on a design flow of 0.14 MGD, instead of the correct flow of 0.142 MGD. Less stringent effluent limitations are allowed under 40 CFR 122.44(I)(2)(i)(B)(2) when a technical error was previously made.

#### **Existing Effluent Limitations and Monitoring Requirements**

The existing effluent limitations and monitoring requirements are as follows:

Effluent L			imitations.		Monitoring Requirements			
Deremeter	Mass Unit	s (lbs/day)		Concentrations (mg/L)				Required
Farameter	Average	Weekly		Average	Weekly	Instant.	Measurement	Sample
	Monthly	Average	Minimum	Monthly	Average	Maximum	Frequency	Туре
	Denert	Report	XXXX	XXXX	XXXX	XXXX	Operation	Deservised
FIOW (MGD)	Report	Daily Max	***	***	***	***	Continuous	Recorded
pH (S.U.)	XXX	ххх	6.0	ХХХ	ХХХ	9.0	1/day	Grab
Dissolved Oxygen	XXX	XXX	4.0	XXX	XXX	XXX	1/day	Grab
Total Residual Chlorine	ххх	xxx	xxx	0.5	xxx	1.6	1/day	Grab
CBOD5								8-Hr
May 1 - Oct 31	23.4	35.0	XXX	20	30	40	1/week	Composite
CBOD5								8-Hr
Nov 1 - Apr 30	29.2	43.8	XXX	25	37.5	50	1/week	Composite
BOD5	Desert	Report	NAVA	Desert		~~~~		8-Hr
Raw Sewage Influent	Report	Daily Max	XXX	Report	XXX	XXX	1/Week	Composite
Total Suspended Solids	Poport	Report	vvv	Poport	VVV	VVV	1/wook	8-Hr Composito
Raw Sewage Iniliaent	Кероп	Dally Max	^^^	Кероп	^^^	^^^	I/WEEK	
Total Suspended Solids	35.0	52.5	xxx	30	45	60	1/week	Composite
Fecal Coliform (CFU/100 ml)				200				
May 1 - Sep 30	XXX	XXX	XXX	Geo Mean	XXX	1,000	1/week	Grab
Fecal Coliform (CFU/100 ml)				2,000				
Oct 1 - Apr 30	XXX	XXX	XXX	Geo Mean	XXX	10,000	1/week	Grab
					Report			
Total Nitrogen	XXX	XXX	XXX	XXX	Daily Max	XXX	1/year	Grab
Ammonia-Nitrogen								8-Hr
May 1 - Oct 31	5.8	8.8	XXX	5.0	7.5	10.0	1/week	Composite
Ammonia-Nitrogen	47.5			45.0	00.5			8-Hr
Nov 1 - Apr 30	17.5	26.3	XXX	15.0	22.5	30.0	1/week	Composite
Total Phosphorus	XXX	XXX	xxx	XXX	Report Daily Max	ххх	1/year	Grab

Compliance Sampling Location: Outfall 001

#### **Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

#### Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

		Monitoring Requirements						
Deremeter	Mass Units (Ibs/day) Co			Concentrat	tions (mg/L)		Minimum	Required
Parameter	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum	Measurement Frequency	Sample Type
Flow (MGD)	Report	Report Daily Max	ххх	xxx	xxx	ххх	Continuous	Recorded
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	xxx	4.0 Inst Min	xxx	xxx	xxx	1/day	Grab
TRC	xxx	xxx	xxx	0.5	xxx	1.6	1/day	Grab
CBOD5 Nov 1 - Apr 30	29.6	44.4	ххх	25.0	37.5	50	1/week	8-Hr Composite
CBOD5 May 1 - Oct 31	23.7	35.5	XXX	20.0	30.0	40	1/week	8-Hr Composite
BOD5 Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	ХХХ	1/week	8-Hr Composite
TSS Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	ххх	1/week	8-Hr Composite
TSS	35.5	53.3	XXX	30.0	45.0	60	1/week	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	ххх	XXX	XXX	2000 Geo Mean	XXX	10000	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	ххх	ххх	200 Geo Mean	XXX	1000	1/week	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Total Nitrogen	ххх	ххх	ххх	xxx	Report Daily Max	ххх	1/year	Grab
Ammonia Nov 1 - Apr 30	17.8	26.6	ххх	15.0	22.5	30	1/week	8-Hr Composite

#### NPDES Permit Fact Sheet MWBJSA WWTP

#### Outfall 001, Continued (from Permit Effective Date through Permit Expiration Date)

		Monitoring Requirements						
Mass Units (Ibs/day) Concentrations (n				Concentrations (mg/L)			Minimum	Required
Faidineter	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum	Measurement Frequency	Sample Type
Ammonia May 1 - Oct 31	5.9	8.9	XXX	5.0	7.5	10	1/week	8-Hr Composite
Total Phosphorus	ХХХ	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab

Compliance Sampling Location: Outfall 001



## Marianna West Bethlehem Joint Sewage Authority WWTP

Outfall 001 drainage area

#### Basin Characteristics

Parameter			
Code	Parameter Description	Value	Unit
BSLOPD	Mean basin slope measured in degrees	10.0566	degrees
BSLOPDRAW	Unadjusted basin slope, in degrees	10.2909	degrees
BSLPDRPA20	Unadjusted basin slope, in degrees, from PA vI	11.4413	degrees
CARBON	Percentage of area of carbonate rock	0	percent
CENTROXA83	X coordinate of the centroid, in NAD_1983_Albers, meters	-188427.6336	meters
CENTROYA83	Basin centroid horizontal (y) location in NAD 1983 Albers	120551.1378	meters
DRN	Drainage quality index from STATSGO	3.6	dimensionless
DRNAREA	Area that drains to a point on a stream	117	square miles
ELEV	Mean Basin Elevation	1176	feet
ELEVMAX	Maximum basin elevation	1534	feet
FOREST	Percentage of area covered by forest	55.7916	percent
GLACIATED	Percentage of basin area that was historically covered by glaciers	0	percent
IMPNLCD01	Percentage of impervious area determined from NLCD 2001 impervious dataset	0.616	percent
LC01DEV	Percentage of land-use from NLCD 2001 classes 21-24	7.9619	percent
LCIIDEV	Percentage of developed (urban) land from NLCD 2011 classes 21-24	8.0843	percent
LCI IIMP	Average percentage of impervious area determined from NLCD 2011 impervious dataset	0.7004	percent
LONG_OUT	Longitude of Basin Outlet	-80.085423	degrees
MAXTEMP	Mean annual maximum air temperature over basin area from PRISM 1971-2000 800-m grid	61	degrees F
OUTLETXA83	X coordinate of the outlet, in NAD_1983_Albers,meters	-177999.7189	meters
OUTLETYA83	Y coordinate of the outlet, in NAD_1983_Albers, meters	115878.4172	meters
PRECIP	Mean Annual Precipitation	39	inches
ROCKDEP	Depth to rock	4.8	feet

#### PWS Apply FC Stream RMI Elevation Drainage Slope Area Withdrawal Code Stream Name (ft) (sq mi) (ft/ft) (mgd) 40285 TENMILE CREEK ✓ 10.100 859.00 117.00 ).00000 0.00 **Stream Data** LFY Stream Rch WD Rch Trib Rch Rch **Tributary** Stream Flow Flow Velocity Ratio Width Depth Temp pН Temp pН Design Trav Cond. Time (ft) (°C) (°C) (cfsm) (cfs) (cfs) (days) (ft) (fps) Q7-10 0.000 0.00 7.00 0.020 0.00 0.00 0.000 0.0 0.00 25.00 0.00 0.00 Q1-10 0.00 0.00 0.000 0.000 Q30-10 0.000 0.00 0.00 0.000 **Discharge Data** Existing Permitted Design Disc Disc Disc Disc Disc Reserve Temp pН Name Permit Number Flow Flow Flow Factor (mgd) (mgd) (mgd) (°C) MWBJSA WWTP PA0096229 0.1420 0.1420 0.1420 0.000 25.00 7.00 Parameter Data Disc Trib Stream Fate Conc Conc Conc Coef

(mg/L)

20.00

4.00

5.00

(mg/L)

2.00

8.24

0.00

(mg/L)

0.00

0.00

0.00

(1/days)

1.50

0.00

0.70

Parameter Name

CBOD5

NH3-N

**Dissolved Oxygen** 

## Input Data WQM 7.0

#### Apply FC RMI PWS Stream Elevation Drainage Slope Code Stream Name Area Withdrawal (ft) (sq mi) (ft/ft) (mgd) 40285 TENMILE CREEK 0.00 $\checkmark$ 7.960 846.00 122.00 ).00000 Stream Data LFY Trib WD Stream Rch Rch Rch Rch **Tributary** Stream Flow Flow Trav Velocity Ratio Width Depth Temp pН Temp pН Design Cond. Time (cfsm) (cfs) (cfs) (ft) (ft) (°C) (°C) (days) (fps) Q7-10 0.020 0.00 0.00 0.000 0.000 0.0 0.00 0.00 25.00 7.00 0.00 0.00 Q1-10 0.00 0.00 0.000 0.000 Q30-10 0.00 0.00 0.000 0.000 **D**: . . Dat

### Input Data WQM 7.0

Discharge Data									
Name	Permit Number	Existing I Disc Flow	Permitted Disc Flow	Desig Disc Flow	n Rese / Fac	D erve Te etor	isc emp	Disc pH	
		(mga)	(mga)	(mga	)	(*	<i>(</i> )		
		0.0000	0.0000	0.00	00 0	.000	25.00	7.00	
	Par	rameter Da	ita						
		Disc	: Tril	b S	Stream	Fate			
Para	ameter Name	Con			CONC	COEI			
		(mg/	L) (mg	/L) (	(mg/L)	(1/days)			
 CBOD5		25	5.00	2.00	0.00	1.50			
Dissolved Ox	ygen	3	3.00	8.24	0.00	0.00			
NH3-N		25	5.00	0.00	0.00	0.70			

	SW	P Basin	<u>Strea</u>	m Code				Stream	Name			
		19B	4	0285			TE	NMILE	CREEK			
RMI	Stream Flow	PWS With	Net Stream	Disc Analysis	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav	Analysis Temp	Analysis pH
	(cfs)	(cfs)	Flow (cfs)	Flow (cfs)	(ft/ft)	(ft)	(ft)		(fps)	Time (days)	(°C)	
Q7-1	Q7-10 Flow											
10.100	2.39	0.00	2.39	.2197	0.00115	.692	33.75	48.76	0.11	1.172	25.00	7.00
Q1-1	0 Flow											
10.100	1.62	0.00	1.62	.2197	0.00115	NA	NA	NA	0.09	1.424	25.00	7.00
Q30-	10 Flow											
10.100	4.30	0.00	4.30	.2197	0.00115	NA	NA	NA	0.15	0.862	25.00	7.00

## WQM 7.0 Hydrodynamic Outputs

# WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	$\checkmark$
WLA Method	EMPR	Use Inputted W/D Ratio	
Q1-10/Q7-10 Ratio	0.68	Use Inputted Reach Travel Times	
Q30-10/Q7-10 Ratio	1.8	Temperature Adjust Kr	✓
D.O. Saturation	90.00%	Use Balanced Technology	✓
D.O. Goal	5		

	SWP Basin	Strea	m Code		St	ream Name		
	19B	4	0285		TEN	MILE CREEK		
H3-N	Acute Alloo	ation	S					
RMI	Discharge	Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
10.1	00 MWBJSA W	/WTP	11.07	10	11.07	10	0	0
IH3-N	Chronic All	ocatio	ons					
RMI	Discharge N	lame	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
-								0

		(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	Reach	Reduction
10.10 MWBJSA	WWTP	20	20	5	5	4	4	0	0

SWP Basin	Stream Code			Stream Name	
19B	40285		T	ENMILE CREEK	
<u>RMI</u>	Total Discharge	Flow (mgd	<u>) Ana</u>	lysis Temperature ( <sup>6</sup>	<u>PC) Analysis pH</u>
10.100	0.14	2		25.000	7.000
Reach Width (ft)	Reach De	pth (ft)		Reach WDRatio	Reach Velocity (fps)
33.754	0.69	2		48.756	0.112
Reach CBOD5 (mg/L)	Reach Kc	<u>(1/days)</u>	<u>R</u>	each NH3-N (mg/L)	Reach Kn (1/days)
3.52	0.37	7		0.42	1.029
Reach DO (mg/L)	<u>Reach Kr (</u>	<u>1/days)</u>		Kr Equation	<u>Reach DO Goal (mg/L)</u>
7.885	1.37	3		Tsivoglou	5
Reach Travel Time (days	3)	Subreach	Results		
1.172	TravTime	CBOD5	NH3-N	D.O.	
	(days)	(mg/L)	(mg/L)	(mg/L)	
	0.117	3.33	0.37	7.49	
	0.234	3.15	0.33	7.20	
	0.352	2.98	0.29	6.98	
	0.469	2.82	0.26	6.82	
	0.586	2.66	0.23	6.72	
	0.703	2.52	0.20	6.65	
	0.821	2.38	0.18	6.62	
	0.938	2.25	0.16	6.62	
	1.055	2.13	0.14	6.63	
	1.172	2.02	0.13	6.67	

## WQM 7.0 D.O.Simulation

	<u>SWP Basin</u> <u>Stream</u> 19B 402	<u>Code</u> 85		Stream Name TENMILE CREI	<u>e</u> EK		
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
10.100	MWBJSA WWTP	PA0096229	0.142	CBOD5	20		
				NH3-N	5	10	
				Dissolved Oxygen			4

## WQM 7.0 Effluent Limits

1A	В	С	D	Е	F	G				
2	TRC EVALU	ATION								
3	Input appropri	ate values in	B4:B8 and E4:E7							
4	2.39	) = Q stream (	cfs)	0.5	= CV Daily					
5	0.142	2 = Q discharg	je (MGD)	0.5						
6	30	) = no. sample	es de la companya de	0.476	6 = AFC_Partial Mix Factor					
/	0.3	= Chlorine D	emand of Stream	1	lix Factor					
ð 0	0		emand of Discharge	15	= AFC_Criteria	Compliance Time (min)				
9	0.8	BAI/BPJ V	alue of Sofoty (EOS)	720	= CFC_Criteria	compliance Time (min)				
10	Sourco		AEC Calculations	0	Poforonco		-			
11		1 3 2 iii	WI A afc =	1 671	132	$WI \land cfc = 3.395$	-			
12	PENTOXSD TRG	5.1a	I TAMULT afc =	0.373	5.1c	$\mathbf{I} \mathbf{T} \mathbf{A} \mathbf{M} \mathbf{U} \mathbf{I} \mathbf{T} \mathbf{c} \mathbf{f} \mathbf{c} = 0.581$				
13	PENTOXSD TRG	5.1b	LTA afc=	0.623	5.1d	LTA cfc = $1.973$				
14						—				
15	Source		Effluent	Limit Calc	culations					
16	PENTOXSD TRG	6 5.1f	AMI	_ MULT =	1.231					
17	PENTOXSD TRG	5.1g	AVG MON LIMI	Г (mg/l) =	0.500	BAT/BPJ				
18			INST MAX LIMI	Г (mg/l) =	1.635					
							_			
	WLA afc	(.019/e(-k*A	FC tc)) + [(AFC Yc*Q	s*.019/Qo	d*e(-k*AFC tc)).					
		+ Xd + (AF	C_Yc*Qs*Xs/Qd)]*(1-F	OS/100)						
	LTAMULT afc	EXP((0.5*LN	(cvh^2+1))-2.326*LN(	vh^2+1)^	<b>`</b> 0.5)					
	LTA_afc	wla_afc*LTA	MULT_afc							
	WLA_ctc	(.011/e(-k*C	FC_tc) + [(CFC_Yc*Qs	5*.011/Qd <sup>3</sup>	*e(-k*CFC_tc) ).	••				
			·C_1C~Q\$~X\$/Q0)]~(1-r (cvd^2/no_samples+1)	·US/100)	N(cvd^2/no san	$n \log (+1)^{0} 5)$				
		wla cfc*LTA	MULT cfc	/)-2.020 L						
		·····								
	AML MULT	EXP(2.326*L	N((cvd^2/no_samples <sup>.</sup>	+1)^0.5)-0	).5*LN(cvd^2/no	_samples+1))				
	AVG MON LIMIT	MIN(BAT_BP	J,MIN(LTA_afc,LTA_c	fc)*AML_l	MULT)					
	INST MAX LIMIT	1.5*((av_mor	n_limit/AML_MULT)/LT	AMULT_a	fc)					