

Application Type Renewal  
 Facility Type Municipal  
 Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0103373  
 APS ID 1090683  
 Authorization ID 1443651

**Applicant and Facility Information**

Applicant Name	<u>Foxburg Borough Area Water &amp; Sewer Authority</u>	Facility Name	<u>Foxburg STP</u>
Applicant Address	<u>PO Box 2</u> <u>Foxburg, PA 16036-0002</u>	Facility Address	<u>End of River Road</u> <u>Foxburg, PA 16036-0002</u>
Applicant Contact	<u>Elizabeth Lander, Chairman</u> <u>(<a href="mailto:elander3433@gmail.com">elander3433@gmail.com</a>)</u>	Facility Contact	<u>Thomas Thompson, Gannett Fleming, Inc.</u> <u>(<a href="mailto:thompson@gfnet.com">thompson@gfnet.com</a>)</u>
Applicant Phone	<u>(724) 659-3433</u>	Facility Phone	<u>(724) 269-5168</u>
Client ID	<u>65293</u>	Site ID	<u>547946</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Foxburg Borough</u>
Connection Status	<u>No Limitations</u>	County	<u>Clarion</u>
Date Application Received	<u>May 30, 2023</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>May 30, 2023</u>	If No, Reason	<u>-</u>
Purpose of Application	<u>Renewal of an NPDES Permit for an existing discharge of treated sanitary wastewater from an existing municipal STP.</u>		

**Summary of Review**

Act 14 - Proof of Notification was submitted and received.

A Part II Water Quality Management permit is not required at this time.

The applicant should be able to meet the limits of this permit, which will protect the uses of the receiving stream.

**I. OTHER REQUIREMENTS:**

- A. Stormwater into Sewers
- B. Right of Way
- C. Solids Handling
- D. SBR Batch Discharges

**SPECIAL CONDITIONS:**

- II. Solids Management

The Department received Draft NPDES Permit comments from the PA Fish and Boat Commission (see Attachment 5), and the US Fish and Wildlife Service (see Attachment 6). Based on the comments received, monitoring for the pollutants of concern for mussels was added back to the NPDES Permit. Due to the changes to the monitoring, and the time that has elapsed since the original draft date of June 1, 2024, this NPDES Permit will be redrafted.

There are 30 open violations in effects associated with the subject Client ID (65293) as of 3/30/2026 (see Attachment 1).

Approve	Return	Deny	Signatures	Date
X			Stephen A. McCauley Stephen A. McCauley, E.I.T. / Project Manager	3/30/2026
X			Adam Olesnanik Adam Olesnanik, P.E. / Environmental Engineer Manager	3/31/2026
X			Justin C. Dickey, P.E. / Program Manager	

**Discharge, Receiving Waters and Water Supply Information**

Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.16</u>
Latitude	<u>41° 8' 13.78"</u>	Longitude	<u>-79° 40' 43.11"</u>
Quad Name	<u>-</u>	Quad Code	<u>-</u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Allegheny River (WWF)</u>	Stream Code	<u>42122</u>
NHD Com ID	<u>100480095</u>	RMI	<u>86.0</u>
Drainage Area	<u>6,410</u>	Yield (cfs/mi <sup>2</sup> )	<u>0.24</u>
Q <sub>7-10</sub> Flow (cfs)	<u>1,538</u>	Q <sub>7-10</sub> Basis	<u>calculated</u>
Elevation (ft)	<u>884</u>	Slope (ft/ft)	<u>0.0015</u>
Watershed No.	<u>17-C</u>	Chapter 93 Class.	<u>WWF</u>
Existing Use	<u>-</u>	Existing Use Qualifier	<u>-</u>
Exceptions to Use	<u>-</u>	Exceptions to Criteria	<u>-</u>
Assessment Status	<u>Attaining Use(s)</u>		
Cause(s) of Impairment	<u>-</u>		
Source(s) of Impairment	<u>-</u>		
TMDL Status	<u>-</u>	Name	<u>-</u>
Background/Ambient Data		Data Source	
pH (SU)	<u>-</u>		<u>-</u>
Temperature (°F)	<u>-</u>		<u>-</u>
Hardness (mg/L)	<u>-</u>		<u>-</u>
Other:	<u>-</u>		<u>-</u>
Nearest Downstream Public Water Supply Intake	<u>Parker Area Water Authority</u>		
PWS Waters	<u>Allegheny River</u>	Flow at Intake (cfs)	<u>951</u>
PWS RMI	<u>85.0</u>	Distance from Outfall (mi)	<u>2.0</u>

Sludge use and disposal description and location(s): All sludge is disposed of at an approved landfill.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the Pennsylvania Bulletin in accordance with 25 Pa. Code § 92a.82. Upon publication in the Pennsylvania Bulletin, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the Pennsylvania Bulletin at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Narrative: This Fact Sheet details the determination of draft NPDES permit limits for an existing discharge of 0.16 MGD of treated sewage from an existing Publicly Owned Treatment Works (POTW) in Foxburg Borough, Clarion County.

Treatment permitted under WQM Permit 1608402 consists of the following: An influent pump station, a head works building, a dual train concrete Sequential Batch Reactor (SBR) treatment plant, ultraviolet (UV) disinfection, sludge storage, and a sludge dewatering press.

**1. Streamflow:**

Allegheny River at Franklin, PA - USGS Stream Gage No. 03025500 (1967-2008)

Q <sub>7-10</sub> :	<u>5,982</u>	cfs	(USGS StreamStats)
Drainage Area:	<u>1,450</u>	sq. mi.	(USGS StreamStats)
Yieldrate:	<u>0.24</u>	cfs/m	calculated

Allegheny River at Outfall 001:

Yieldrate:	<u>0.24</u>	cfs/m	calculated above
Drainage Area:	<u>6,410</u>	sq. mi.	(USGS StreamStats)
% of stream allocated:	<u>100%</u>	Basis:	No nearby discharges
Q <sub>7-10</sub> :	<u>1,538</u>	cfs	calculated

**2. Wasteflow:**

Maximum discharge: 0.16 MGD = 0.24 cfs

Runoff flow period: 24 hours Basis: Runoff flow for municipal STPs

The calculated stream flow (Q<sub>7-10</sub>) is greater than 3 times the permitted discharge flow. In accordance with the SOP, since this is an existing discharge, the treatment requirements in document number 391-2000-014, titled, "Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers", dated April 12, 2008, were not evaluated for this facility.

Flow will be required to be monitored as authorized under Chapter 92a.61, and as recommended in the SOP.

**3. Parameters:**

The following parameters were evaluated: pH, Total Suspended Solids, Fecal Coliform, E. Coli, Total Phosphorus, Total Nitrogen, NH<sub>3</sub>-N, CBOD<sub>5</sub>, Dissolved Oxygen, and Disinfection.

a. pH

Between 6.0 and 9.0 at all times

Basis: Application of Chapter 93.7 technology-based limits.

The measurement frequency will remain as 1/day as recommended in the SOP, based on Table 6-3 in the "Technical Guidance for the Development and Specification of Effluent Limitations" (362-0400-001).

b. Total Suspended Solids

Limits are 30.0 mg/l as a monthly average and 60.0 as an instantaneous maximum.

Basis: Application of Chapter 92a47 technology-based limits.

c. Fecal Coliform

05/01 - 09/30: 200/100ml (monthly average geometric mean)  
1,000/100ml (instantaneous maximum)  
10/01 - 04/30: 2,000/100ml (monthly average geometric mean)  
10,000/100ml (instantaneous maximum)

Basis: Application of Chapter 92a47 technology-based limits

d. E. Coli

Monitoring was added for E. Coli at a frequency of 1/quarter.

Basis: Application of Chapter 92a.61 as recommended by the SOP for flows greater than 0.05 MGD and less than 1.0 MGD.

e. Total Phosphorus

Chapter 96.5 does not apply. The previous monitoring for Total Phosphorus will be retained in accordance with the SOP, based on Chapter 92a.61.

f. Total Nitrogen

The previous monitoring for Total Nitrogen will be retained in accordance with the SOP, based on Chapter 92a.61.

g. Ammonia-Nitrogen (NH<sub>3</sub>-N)

Median discharge pH to be used: 6.7 Standard Units (S.U.)

Basis: eDMR data from previous 12 months

Discharge temperature: 25°C (default value used in the absence of data)

Median stream pH to be used: 7.0 Standard Units (S.U.)

Basis: default value used in the absence of data

Stream Temperature: 25°C (default value used for WWF modeling)

Background NH<sub>3</sub>-N concentration: 0.1 mg/l

Basis: Default value

Calculated NH<sub>3</sub>-N Summer limits: 25.0 mg/l (monthly average)  
50.0 mg/l (instantaneous maximum)

Calculated NH<sub>3</sub>-N Winter limits: 25.0 mg/l (monthly average)  
50.0 mg/l (instantaneous maximum)

Result: WQ modeling resulted in the summer limits above (see Attachment 2). The winter limits are calculated as three times the summer limits, but since the technology-based limits would govern, they will be used. The calculated limits are the same as the previous permit and per the SOP, since the technology-based limits are recommended for NH<sub>3</sub>-N, the previous year long monitoring will be retained.

h. CBOD<sub>5</sub>

Median discharge pH to be used: 6.7 Standard Units (S.U.)

Basis: eDMR data from previous 12 months

Discharge temperature: 25°C (default value used in the absence of data)

Median stream pH to be used: 7.0 Standard Units (S.U.)

Basis: default value used in the absence of data

Stream Temperature: 25°C (default value used for WWF modeling)

Background CBOD<sub>5</sub> concentration: 2.0 mg/l

Basis: Default value

Calculated CBOD<sub>5</sub> limits: 25.0 mg/l (monthly average)  
50.0 mg/l (instantaneous maximum)

Result: WQ modeling resulted in the summer limits above (see Attachment 2). The calculated limits are the same as the previous permit and will be retained.

i. Influent Total Suspended Solids and BOD<sub>5</sub>

Monitoring for these two parameters will be retained as recommended in the SOP for POTWs, as authorized under Chapter 92a.61.

j. Dissolved Oxygen (DO)

The technology-based minimum of 4.0 mg/l is recommended by the WQ Model (see Attachment 2) and the SOP based on Chapter 93.7, under the authority of Chapter 92a.61. This is the same as the previous permit and will be retained.

The measurement frequency will remain as 1/day as recommended in the SOP, based on Table 6-3 in the "Technical Guidance for the Development and Specification of Effluent Limitations" (362-0400-001).

k. Disinfection

Ultraviolet (UV) light monitoring

TRC limits: \_\_\_\_\_ mg/l (monthly average)  
\_\_\_\_\_ mg/l (instantaneous maximum)

Basis: Monitoring for UV light intensity (mW/cm<sup>2</sup>) will be retained with this renewal.

The measurement frequency will remain as 1/day as recommended in the SOP, based on Table 6-3 in the "Technical Guidance for the Development and Specification of Effluent Limitations" (362-0400-001).

4. **Reasonable Potential Analysis for Receiving Stream:**

A Reasonable Potential Analysis was performed in accordance with State practices for Outfall 001 using the Department's Toxics Management Spreadsheet (see Attachment 3).

Result: None of the parameters sampled were found to have discharge values greater than 10% of the calculated WQBELs.

**5. Reasonable Potential for Downstream Public Water Supply (PWS):**

The Department's Toxics Management Spreadsheet does not calculate limits for parameters that are based on PWS criteria (TDS, Chloride, Bromide, and Sulfate).

Nearest Downstream potable water supply (PWS): Parker Area Water Authority

Distance downstream from the point of discharge: 2.0 miles

Parameter	PWS Criteria (mg/l)	Discharge Maximum (mg/l)
TDS	500	283
Chloride	250	63.7
Bromide	1.0	0.103
Sulfate	250	36.1

Result: Since none of the parameters are discharged at a concentration greater than the criteria at the PWS, no limits or monitoring are necessary as significant dilution is available.

**6. Flow Information:**

The Foxburg STP receives 56% of its flow from the Foxburg Borough and 44% of its flow from the Richland Township. Both of the municipalities are 100% separate sewer systems.

**7. Antibacksliding:**

Since all the permit limits in this renewal are the same or more restrictive than the previous NPDES Permit, anti-backsliding is not applicable.

**8. Attachment List:**

- Attachment 1 - Open Violations by Client
- Attachment 2 - WQ Modeling Printouts
- Attachment 3 - Toxics Management Spreadsheet
- Attachment 4 - Mussel Impact Evaluation Spreadsheet
- Attachment 5 - Draft NPDES Permit comments - PA Fish and Boat Commission
- Attachment 6 - Draft NPDES Permit comments - US Fish and Wildlife Service

(The Attachments above can be found at the end of this document)

**Threatened and Endangered Mussel Species Concerns and Considerations**

The Allegheny River is known to contain state and federally listed threatened and endangered mussel species. Due to this being a direct discharge to the Allegheny River, potential impacts were evaluated.

The USFWS has indicated that to protect threatened and endangered mussel species, wastewater discharges containing Ammonia-Nitrogen (NH<sub>3</sub>-N), Chloride (Cl<sup>-</sup>), Dissolved Nickel, and Dissolved Zinc, where mussels or their habitat exist, can be no more than 1.9 mg/l, 78 mg/l, 7.3 µg/l, and 13.18 µg/l, respectively.

Since this facility was previously identified, the sampling below was collected for Ammonia-Nitrogen, Chloride, and Nickel.

Sampling Data for USFWS Parameters of Concern	
Parameter	Sampling Data
Ammonia-Nitrogen (NH <sub>3</sub> -N) (mg/L)	1.35 avg. / 4.5 max. (24 samples - eDMR)
Chloride (mg/L)	66.3 avg. / 96.3 max. (24 samples - eDMR)
Total Nickel (µg/L)	0.0055 avg. / 0.008 max. (8 samples - eDMR)
Total Zinc (µg/L)	61.0 max. (1 sample - Renewal Application 6/20/2023)

The Department required monitoring during the previous NPDES Permit period for Ammonia-Nitrogen, Chloride, and Total Nickel to determine the discharge concentrations for each parameter.

Based on the reported sampling data, and the Mussel Impact Evaluation Spreadsheet calculations (see Attachment 4), the Department has determined that the discharge concentrations of Ammonia-Nitrogen, Chloride, and Total Nickel do not show a reasonable potential to cause harm to mussels in the receiving stream. This discharge consists of only treated sewage, and the Department doesn't anticipate any significant changes or variations in the wastestream in the upcoming permit cycle. In addition, any planned changes to the wastestream must be coordinate with DEP.

Mussel-related monitoring for Ammonia-Nitrogen, Chloride, and Total Nickel was removed with the First Draft of this renewal. However, the Department received Draft NPDES Permit comments from the PA Fish and Boat Commission (see Attachment 5), and the US Fish and Wildlife Service (see Attachment 6). Based on the comments received, monitoring for the pollutants of concern for mussels was added back to the NPDES Permit. Due to the changes to the monitoring, and the time that has elapsed since the original draft, this NPDES Permit will be redrafted.

The only data available for Total Zinc was from 1 sample submitted with the NPDES Permit renewal. Since Zinc was not required to be monitored in the previous NPDES Permit, the Department has decided to require quarterly monitoring with this renewal. In addition, the monitoring will be for Dissolved Zinc since that is the parameter of concern for mussels as indicated by the USFWS.

**Compliance History**

**DMR Data for Outfall 001 (from February 1, 2025 to January 31, 2026)**

Parameter	JAN-26	DEC-25	NOV-25	OCT-25	SEP-25	AUG-25	JUL-25	JUN-25	MAY-25	APR-25	MAR-25	FEB-25
Flow (MGD) Average Monthly	0.037	0.036	0.033	0.034	0.034	0.033	0.037	0.066	0.083	0.076	0.045	0.055
pH (S.U.) Instantaneous Minimum	6.2	6.3	6.7	6.5	6.6	6.2	6.6	6.6	6.6	6.6	6.7	6.7
pH (S.U.) Instantaneous Maximum	6.9	6.9	7.1	7.2	7.2	7.0	7.1	7.0	6.9	7.0	7.1	7.3
DO (mg/L) Instantaneous Minimum	5.9	6.0	5.6	4.6	4.4	4.2	4.6	5.5	5.0	5.3	4.5	5.0
CBOD5 (lbs/day) Average Monthly	< 1	1	1	2	2	1	1	2	18	6	< 2	3
CBOD5 (lbs/day) Weekly Average	1	1	1	2	2	2	1	2	34	9	3	5
CBOD5 (mg/L) Average Monthly	< 2.7	3.1	3.3	5.6	6.6	4.3	3.5	4.3	6.5	6.7	< 5.6	4.0
CBOD5 (mg/L) Weekly Average	3.3	3.1	3.9	6.8	7.8	4.5	4.4	5.8	9.2	6.9	9.2	5.2
BOD5 (lbs/day) Raw Sewage Influent Average Monthly	35	50	53	57	57	86	56	38	58	91	66	69
BOD5 (mg/L) Raw Sewage Influent Average Monthly	118	201	193	167	228	281	153	122	111	152	150	148
TSS (lbs/day) Average Monthly	< 2	< 2	< 2	< 2	2	2	< 2	< 2	< 20	< 7	< 3	< 3
TSS (lbs/day) Raw Sewage Influent Average Monthly	25	20	40	42	62	84	73	38	29	94	50	53
TSS (lbs/day) Weekly Average	< 2	< 2	< 2	< 3	2	2	< 2	< 2	37	10	4	< 4
TSS (mg/L) Average Monthly	< 5.0	< 5.0	< 5.0	< 6.5	6.6	5.5	< 5.0	< 5.0	< 7.5	< 6.5	< 8.0	< 5.0
TSS (mg/L) Raw Sewage Influent Average Monthly	82	79	145	114	246	273	195	121	61	144	115	55
TSS (mg/L) Weekly Average	< 5.0	< 5.0	< 5.0	8.0	7.0	6.0	< 5.0	< 5.0	10.0	8.0	11.0	< 5.0
Fecal Coliform (No./100 ml) Geometric Mean	< 1	< 1	< 2	< 17	< 10	< 9	< 17	< 1	< 4	< 59	< 1	< 1

**NPDES Permit Fact Sheet  
Foxburg STP**

**NPDES Permit No. PA0103373**

Fecal Coliform (No./100 ml) Instantaneous Maximum	< 1	1	11	133	131	248	111	2	320	2420	< 1	1
UV Intensity (mW/cm <sup>2</sup> ) Average Monthly	0.1	1.3	1.5	1.5	1.5	2.0	3.6	4.0	4.0	2.7	2.1	2.1
Total Nitrogen (mg/L) Average Quarterly		11.8			6.77			4.3			< 12.9	
Ammonia (mg/L) Average Monthly	< 0.15	< 0.15	< 0.46	< 0.17	0.2	< 0.15	< 0.15	< 0.2	< 0.21	0.32	< 0.15	< 0.15
Total Phosphorus (mg/L) Average Quarterly		5.99			5.64			1.0			3.06	
Total Nickel (ug/L) Average Quarterly		0.006			0.007			< 0.005			< 0.005	
Chloride (mg/L) Average Monthly	74.9	56.8	76.8	88.1	91.3	82.9	74.6	75.1	37.1	35.3	55.1	82.1

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	XXX	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	4.0 Inst Min	XXX	XXX	XXX	1/day	Grab
CBOD5	33.0	53.0	XXX	25.0	40.0	50	2/month	24-Hr Composite
BOD5 Raw Sewage Influent	Report	XXX	XXX	Report	XXX	XXX	2/month	24-Hr Composite
TSS	40.0	60.0	XXX	30.0	45.0	60	2/month	24-Hr Composite
TSS Raw Sewage Influent	Report	XXX	XXX	Report	XXX	XXX	2/month	24-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/week	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/quarter	Grab
UV Intensity (mW/cm <sup>2</sup> )	XXX	XXX	XXX	Report	XXX	XXX	1/day	Measured
Total Nitrogen	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	24-Hr Composite
Ammonia	XXX	XXX	XXX	Report	XXX	XXX	2/month	24-Hr Composite
Total Phosphorus	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	24-Hr Composite

Outfall 001 , Continued (from Permit Effective Date through Permit Expiration Date )

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Total Nickel	XXX	XXX	XXX	Report Avg Qrtly	Report Daily Max	XXX	1/quarter	24-Hr Composite
Dissolved Zinc	XXX	XXX	XXX	Report Avg Qrtly	Report Daily Max	XXX	1/quarter	24-Hr Composite
Chloride	XXX	XXX	XXX	Report Avg Qrtly	Report Daily Max	XXX	1/quarter	24-Hr Composite

Compliance Sampling Location: at Outfall 001, after ultraviolet (UV) light disinfection.

Flow is monitor only based on Chapter 92a.61. The limits for pH and Dissolved Oxygen are technology-based on Chapter 93.7. The limits for CBOD5, Total Suspended Solids, and Fecal Coliform are technology-based on Chapter 92a.47. Monitoring for influent BOD5 and influent Total Suspended Solids is based on Chapter 92a.61. Monitoring for E. Coli, UV Intensity, Total Nitrogen, Ammonia, Total Phosphorus, Total Nickel, Dissolved Zinc, and Chloride is based on Chapter 92a.61.

Attachment 1



WATER MANAGEMENT SYSTEM  
OPEN VIOLATIONS BY CLIENT

Client ID: 65293

Client: All

Open Violations: 30

	CLIENT ID	CLIENT	PF ID	FACILITY	PF KIND	PF STATUS	INSP PROGRAM	PROGRAM SPECIFIC ID
1	65293	FOXBURG BORO AREA WATER & SEW AUTH	282926	FOXBURG AREA WATER & SEWER AUTH	Community	Active	Safe Drinking Water	6160004
2	65293	FOXBURG BORO AREA WATER & SEW AUTH	282926	FOXBURG AREA WATER & SEWER AUTH	Community	Active	Safe Drinking Water	6160004
3	65293	FOXBURG BORO AREA WATER & SEW AUTH	282926	FOXBURG AREA WATER & SEWER AUTH	Community	Active	Safe Drinking Water	6160004
4	65293	FOXBURG BORO AREA WATER & SEW AUTH	282926	FOXBURG AREA WATER & SEWER AUTH	Community	Active	Safe Drinking Water	6160004
5	65293	FOXBURG BORO AREA WATER & SEW AUTH	282926	FOXBURG AREA WATER & SEWER AUTH	Community	Active	Safe Drinking Water	6160004
6	65293	FOXBURG BORO AREA WATER & SEW AUTH	282926	FOXBURG AREA WATER & SEWER AUTH	Community	Active	Safe Drinking Water	6160004
7	65293	FOXBURG BORO AREA WATER & SEW AUTH	282926	FOXBURG AREA WATER & SEWER AUTH	Community	Active	Safe Drinking Water	6160004
8	65293	FOXBURG BORO AREA WATER & SEW AUTH	282926	FOXBURG AREA WATER & SEWER AUTH	Community	Active	Safe Drinking Water	6160004
9	65293	FOXBURG BORO AREA WATER & SEW AUTH	282926	FOXBURG AREA WATER & SEWER AUTH	Community	Active	Safe Drinking Water	6160004
10	65293	FOXBURG BORO AREA WATER & SEW AUTH	282926	FOXBURG AREA WATER & SEWER AUTH	Community	Active	Safe Drinking Water	6160004
11	65293	FOXBURG BORO AREA WATER & SEW AUTH	282926	FOXBURG AREA WATER & SEWER AUTH	Community	Active	Safe Drinking Water	6160004
12	65293	FOXBURG BORO AREA WATER & SEW AUTH	282926	FOXBURG AREA WATER & SEWER AUTH	Community	Active	Safe Drinking Water	6160004
13	65293	FOXBURG BORO AREA WATER & SEW AUTH	282926	FOXBURG AREA WATER & SEWER AUTH	Community	Active	Safe Drinking Water	6160004
14	65293	FOXBURG BORO AREA WATER & SEW AUTH	282926	FOXBURG AREA WATER & SEWER AUTH	Community	Active	Safe Drinking Water	6160004
15	65293	FOXBURG BORO AREA WATER & SEW AUTH	282926	FOXBURG AREA WATER & SEWER AUTH	Community	Active	Safe Drinking Water	6160004
16	65293	FOXBURG BORO AREA WATER & SEW AUTH	282926	FOXBURG AREA WATER & SEWER AUTH	Community	Active	Safe Drinking Water	6160004
17	65293	FOXBURG BORO AREA WATER & SEW AUTH	282926	FOXBURG AREA WATER & SEWER AUTH	Community	Active	Safe Drinking Water	6160004
18	65293	FOXBURG BORO AREA WATER & SEW AUTH	282926	FOXBURG AREA WATER & SEWER AUTH	Community	Active	Safe Drinking Water	6160004
19	65293	FOXBURG BORO AREA WATER & SEW AUTH	282926	FOXBURG AREA WATER & SEWER AUTH	Community	Active	Safe Drinking Water	6160004
20	65293	FOXBURG BORO AREA WATER & SEW AUTH	282926	FOXBURG AREA WATER & SEWER AUTH	Community	Active	Safe Drinking Water	6160004
21	65293	FOXBURG BORO AREA WATER & SEW AUTH	282926	FOXBURG AREA WATER & SEWER AUTH	Community	Active	Safe Drinking Water	6160004
22	65293	FOXBURG BORO AREA WATER & SEW AUTH	282926	FOXBURG AREA WATER & SEWER AUTH	Community	Active	Safe Drinking Water	6160004
23	65293	FOXBURG BORO AREA WATER & SEW AUTH	282926	FOXBURG AREA WATER & SEWER AUTH	Community	Active	Safe Drinking Water	6160004
24	65293	FOXBURG BORO AREA WATER & SEW AUTH	282926	FOXBURG AREA WATER & SEWER AUTH	Community	Active	Safe Drinking Water	6160004
25	65293	FOXBURG BORO AREA WATER & SEW AUTH	282926	FOXBURG AREA WATER & SEWER AUTH	Community	Active	Safe Drinking Water	6160004
26	65293	FOXBURG BORO AREA WATER & SEW AUTH	282926	FOXBURG AREA WATER & SEWER AUTH	Community	Active	Safe Drinking Water	6160004
27	65293	FOXBURG BORO AREA WATER & SEW AUTH	282926	FOXBURG AREA WATER & SEWER AUTH	Community	Active	Safe Drinking Water	6160004
28	65293	FOXBURG BORO AREA WATER & SEW AUTH	282926	FOXBURG AREA WATER & SEWER AUTH	Community	Active	Safe Drinking Water	6160004
29	65293	FOXBURG BORO AREA WATER & SEW AUTH	282926	FOXBURG AREA WATER & SEWER AUTH	Community	Active	Safe Drinking Water	6160004
30	65293	FOXBURG BORO AREA WATER & SEW AUTH	282926	FOXBURG AREA WATER & SEWER AUTH	Community	Active	Safe Drinking Water	SM2429729

	INSP ID	VIOLATION ID	INSPECTION CATEGORY	VIOLATION DATE	VIOLATION CODE	VIOLATION	PF INSPECTOR	INSP REGION
1	3494964	983154	PF	01/26/2023	C4A	FAILURE TO OPERATE AND MAINTAIN THE WATER SYSTEM	MUMFORD, MIRANDA	NWRO
2	3494964	983155	PF	01/26/2023	C1A	FAILURE TO MEET DESIGN AND CONSTRUCTION STANDARDS	MUMFORD, MIRANDA	NWRO
3	3494964	983156	PF	01/26/2023	D6E	FAILURE OF A CWS TO DEVELOP AND/OR UPDATE AN EMERGENCY RESPONSE PLAN	MUMFORD, MIRANDA	NWRO
4	3494964	983157	PF	01/26/2023	C1A	FAILURE TO MEET DESIGN AND CONSTRUCTION STANDARDS	MUMFORD, MIRANDA	NWRO
5	3494964	983158	PF	01/26/2023	B6A	OTHER VIOLATIONS DEEMED TO BE SIGNIFICANT DEFICIENCIES	MUMFORD, MIRANDA	NWRO
6	3494964	983159	PF	01/26/2023	C1A	FAILURE TO MEET DESIGN AND CONSTRUCTION STANDARDS	MUMFORD, MIRANDA	NWRO
7	3494964	983160	PF	01/26/2023	C1A	FAILURE TO MEET DESIGN AND CONSTRUCTION STANDARDS	MUMFORD, MIRANDA	NWRO
8	3494964	983161	PF	01/26/2023	C4A	FAILURE TO OPERATE AND MAINTAIN THE WATER SYSTEM	MUMFORD, MIRANDA	NWRO
9	3494964	983163	PF	01/26/2023	B6A	OTHER VIOLATIONS DEEMED TO BE SIGNIFICANT DEFICIENCIES	MUMFORD, MIRANDA	NWRO
10	3494964	983164	PF	01/26/2023	C4A	FAILURE TO OPERATE AND MAINTAIN THE WATER SYSTEM	MUMFORD, MIRANDA	NWRO
11	3494964	983165	PF	01/26/2023	B6A	OTHER VIOLATIONS DEEMED TO BE SIGNIFICANT DEFICIENCIES	MUMFORD, MIRANDA	NWRO
12	3494964	983167	PF	01/26/2023	C4A	FAILURE TO OPERATE AND MAINTAIN THE WATER SYSTEM	MUMFORD, MIRANDA	NWRO
13	3494964	983168	PF	01/26/2023	B6A	OTHER VIOLATIONS DEEMED TO BE SIGNIFICANT DEFICIENCIES	MUMFORD, MIRANDA	NWRO
14	3883144	8210618	PF	12/09/2024	B6A	OTHER VIOLATIONS DEEMED TO BE SIGNIFICANT DEFICIENCIES	MUMFORD, MIRANDA	NWRO
15	4125748	8262898	PF	01/29/2026	C4A	FAILURE TO OPERATE AND MAINTAIN THE WATER SYSTEM	MUMFORD, MIRANDA	NWRO
16	4125748	8262899	PF	01/29/2026	B6A	OTHER VIOLATIONS DEEMED TO BE SIGNIFICANT DEFICIENCIES	MUMFORD, MIRANDA	NWRO
17	4125748	8262900	PF	01/29/2026	C1A	FAILURE TO MEET DESIGN AND CONSTRUCTION STANDARDS	MUMFORD, MIRANDA	NWRO
18	4125748	8262901	PF	01/29/2026	B6A	OTHER VIOLATIONS DEEMED TO BE SIGNIFICANT DEFICIENCIES	MUMFORD, MIRANDA	NWRO
19	4125748	8262902	PF	01/29/2026	D6E	FAILURE OF A CWS TO DEVELOP AND/OR UPDATE AN EMERGENCY RESPONSE PLAN	MUMFORD, MIRANDA	NWRO
20	4125748	8262903	PF	01/29/2026	C1A	FAILURE TO MEET DESIGN AND CONSTRUCTION STANDARDS	MUMFORD, MIRANDA	NWRO
21	4125748	8262904	PF	01/29/2026	C1A	FAILURE TO MEET DESIGN AND CONSTRUCTION STANDARDS	MUMFORD, MIRANDA	NWRO
22	4125748	8262905	PF	01/29/2026	C1A	FAILURE TO MEET DESIGN AND CONSTRUCTION STANDARDS	MUMFORD, MIRANDA	NWRO
23	4125748	8262906	PF	01/29/2026	B6A	OTHER VIOLATIONS DEEMED TO BE SIGNIFICANT DEFICIENCIES	MUMFORD, MIRANDA	NWRO
24	4125748	8262907	PF	01/29/2026	B6A	OTHER VIOLATIONS DEEMED TO BE SIGNIFICANT DEFICIENCIES	MUMFORD, MIRANDA	NWRO
25	4125748	8262908	PF	01/29/2026	C4A	FAILURE TO OPERATE AND MAINTAIN THE WATER SYSTEM	MUMFORD, MIRANDA	NWRO
26	4125748	8262909	PF	01/29/2026	C4A	FAILURE TO OPERATE AND MAINTAIN THE WATER SYSTEM	MUMFORD, MIRANDA	NWRO
27	4125748	8262910	PF	01/29/2026	B6A	OTHER VIOLATIONS DEEMED TO BE SIGNIFICANT DEFICIENCIES	MUMFORD, MIRANDA	NWRO
28	4125748	8262911	PF	01/29/2026	C4A	FAILURE TO OPERATE AND MAINTAIN THE WATER SYSTEM	MUMFORD, MIRANDA	NWRO
29	4139065	8263919	PF	02/09/2026	AA4	FAILURE TO PROVIDE TIER 1 PUBLIC NOTICE WITHIN 24 HRS. OF DETERMINING THAT AN IMMINENT THREAT EXISTS	MUMFORD, MIRANDA	NWRO
30	3838399	8202248	PF	09/26/2024	45	FAILURE TO ADDRESS A SIGNIFICANT DEFICIENCY	MUMFORD, MIRANDA	NWRO

Attachment 2

**WQM 7.0 Effluent Limits**

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>			
18A		42122		ALLEGHENY RIVER			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
86.000	Foxburg STP	PA0103373	0.160	CBOD5	25		
				NH3-N	25	50	
				Dissolved Oxygen			4

**WQM 7.0 D.O.Simulation**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
18A	42122	ALLEGHENY RIVER		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
86.000	0.160	25.000	7.000	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
882.408	1.000	882.633	1.744	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
2.00	0.003	0.00	1.029	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
7.539	5.338	Tsivoglou	5	
<u>Reach Travel Time (days)</u>	<b>Subreach Results</b>			
0.046	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.005	2.00	0.00	7.54
	0.009	2.00	0.00	7.54
	0.014	2.00	0.00	7.54
	0.018	2.00	0.00	7.54
	0.023	2.00	0.00	7.54
	0.027	2.00	0.00	7.54
	0.032	2.00	0.00	7.54
	0.036	2.00	0.00	7.54
	0.041	2.00	0.00	7.54
	0.046	2.00	0.00	7.54

**WQM 7.0 Modeling Specifications**

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
18A	42122	ALLEGHENY RIVER	86.000	855.00	6410.00	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary		Stream	
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.240	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Foxburg STP	PA0103373	0.1600	0.0000	0.0000	0.000	25.00	6.70

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	4.00	7.54	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
18A	42122	ALLEGHENY RIVER	84.700	851.00	6410.10	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary		Stream	
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.240	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	0.00	7.00

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

**WQM 7.0 Hydrodynamic Outputs**

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
18A		42122				ALLEGHENY RIVER						
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
<b>Q7-10 Flow</b>												
86.000	1538.40	0.00	1538.40	.2475	0.00058	1	882.41	882.63	1.74	0.046	25.00	7.00
<b>Q1-10 Flow</b>												
86.000	984.58	0.00	984.58	.2475	0.00058	NA	NA	NA	1.36	0.058	25.00	7.00
<b>Q30-10 Flow</b>												
86.000	2092.22	0.00	2092.22	.2475	0.00058	NA	NA	NA	2.07	0.038	25.00	7.00

**WQM 7.0 Wasteload Allocations**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
18A	42122	ALLEGHENY RIVER

**NH3-N Acute Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
86.000	Foxburg STP	11.07	50	11.07	50	0	0

**NH3-N Chronic Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
86.000	Foxburg STP	1.37	25	1.37	25	0	0

**Dissolved Oxygen Allocations**

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
86.00	Foxburg STP	25	25	25	25	4	4	0	0



## Discharge Information

Instructions Discharge Stream

Facility: **Foxburg STP** NPDES Permit No.: **PA0103373** Outfall No.: **001**

Evaluation Type: **Major Sewage / Industrial Waste** Wastewater Description: **Minor Municipal Sewage**

Discharge Characteristics								
Design Flow (MGD)*	Hardness (mg/l)*	pH (SU)*	Partial Mix Factors (PMFs)				Complete Mix Times (min)	
			AFC	CFC	THH	CRL	Q <sub>7-10</sub>	Q <sub>h</sub>
0.16	100	6.7						

Discharge Pollutant	Units	Max Discharge Conc	0 if left blank		0.5 if left blank		0 if left blank			1 if left blank	
			Trib Conc	Stream Conc	Daily CV	Hourly CV	Stream CV	Fate Coeff	FOS	Criteria Mod	Chem Transl
Group 1	Total Dissolved Solids (PWS)	mg/L	283								
	Chloride (PWS)	mg/L	63.7								
	Bromide	mg/L	0.103								
	Sulfate (PWS)	mg/L	36.1								
	Fluoride (PWS)	mg/L									
Group 2	Total Aluminum	µg/L									
	Total Antimony	µg/L									
	Total Arsenic	µg/L									
	Total Barium	µg/L									
	Total Beryllium	µg/L									
	Total Boron	µg/L									
	Total Cadmium	µg/L									
	Total Chromium (III)	µg/L									
	Hexavalent Chromium	µg/L									
	Total Cobalt	µg/L									
	Total Copper	µg/L	< 5								
	Free Cyanide	µg/L									
	Total Cyanide	µg/L									
	Dissolved Iron	µg/L									
	Total Iron	µg/L									
	Total Lead	µg/L	< 5								
	Total Manganese	µg/L									
	Total Mercury	µg/L									
	Total Nickel	µg/L									
	Total Phenols (Phenolics) (PWS)	µg/L									
	Total Selenium	µg/L									
Total Silver	µg/L										
Total Thallium	µg/L										
Total Zinc	µg/L	61									
Total Molybdenum	µg/L										
Acrolein	µg/L	<									
Acrylamide	µg/L	<									
Acrylonitrile	µg/L	<									
Benzene	µg/L	<									
Bromoform	µg/L	<									

Group 3	Carbon Tetrachloride	µg/L	<																	
	Chlorobenzene	µg/L	<																	
	Chlorodibromomethane	µg/L	<																	
	Chloroethane	µg/L	<																	
	2-Chloroethyl Vinyl Ether	µg/L	<																	
	Chloroform	µg/L	<																	
	Dichlorobromomethane	µg/L	<																	
	1,1-Dichloroethane	µg/L	<																	
	1,2-Dichloroethane	µg/L	<																	
	1,1-Dichloroethylene	µg/L	<																	
	1,2-Dichloropropane	µg/L	<																	
	1,3-Dichloropropylene	µg/L	<																	
	1,4-Dioxane	µg/L	<																	
	Ethylbenzene	µg/L	<																	
	Methyl Bromide	µg/L	<																	
	Methyl Chloride	µg/L	<																	
	Methylene Chloride	µg/L	<																	
	1,1,2,2-Tetrachloroethane	µg/L	<																	
	Tetrachloroethylene	µg/L	<																	
	Toluene	µg/L	<																	
1,2-trans-Dichloroethylene	µg/L	<																		
1,1,1-Trichloroethane	µg/L	<																		
1,1,2-Trichloroethane	µg/L	<																		
Trichloroethylene	µg/L	<																		
Vinyl Chloride	µg/L	<																		
Group 4	2-Chlorophenol	µg/L	<																	
	2,4-Dichlorophenol	µg/L	<																	
	2,4-Dimethylphenol	µg/L	<																	
	4,6-Dinitro- <i>o</i> -Cresol	µg/L	<																	
	2,4-Dinitrophenol	µg/L	<																	
	2-Nitrophenol	µg/L	<																	
	4-Nitrophenol	µg/L	<																	
	<i>p</i> -Chloro- <i>m</i> -Cresol	µg/L	<																	
	Pentachlorophenol	µg/L	<																	
	Phenol	µg/L	<																	
	2,4,6-Trichlorophenol	µg/L	<																	
	Group 5	Acenaphthene	µg/L	<																
Acenaphthylene		µg/L	<																	
Anthracene		µg/L	<																	
Benzidine		µg/L	<																	
Benzo(a)Anthracene		µg/L	<																	
Benzo(a)Pyrene		µg/L	<																	
3,4-Benzofluoranthene		µg/L	<																	
Benzo(ghi)Perylene		µg/L	<																	
Benzo(k)Fluoranthene		µg/L	<																	
Bis(2-Chloroethoxy)Methane		µg/L	<																	
Bis(2-Chloroethyl)Ether		µg/L	<																	
Bis(2-Chloroisopropyl)Ether		µg/L	<																	
Bis(2-Ethylhexyl)Phthalate		µg/L	<																	
4-Bromophenyl Phenyl Ether		µg/L	<																	
Butyl Benzyl Phthalate		µg/L	<																	
2-Chloronaphthalene		µg/L	<																	
4-Chlorophenyl Phenyl Ether		µg/L	<																	
Chrysene		µg/L	<																	
Dibenzo(a,h)Anthracene		µg/L	<																	
1,2-Dichlorobenzene		µg/L	<																	
1,3-Dichlorobenzene	µg/L	<																		
1,4-Dichlorobenzene	µg/L	<																		
3,3-Dichlorobenzidine	µg/L	<																		
Diethyl Phthalate	µg/L	<																		
Dimethyl Phthalate	µg/L	<																		
Di- <i>n</i> -Butyl Phthalate	µg/L	<																		
2,4-Dinitrotoluene	µg/L	<																		





Stream / Surface Water Information

Foxburg STP, NPDES Permit No. PA0103373, Outfall 001

Instructions Discharge Stream

Receiving Surface Water Name: Allegheny River No. Reaches to Model: 1

- Statewide Criteria
- Great Lakes Criteria
- ORSANCO Criteria

Location	Stream Code*	RMI*	Elevation (ft)*	DA (mi <sup>2</sup> )*	Slope (ft/ft)	PWS Withdrawal (MGD)	Apply Fish Criteria*
Point of Discharge	042122	86	855	6410			Yes
End of Reach 1	042122	84.7	851	6410.1			Yes

Q<sub>7-10</sub>

Location	RMI	LFY (cfs/mi <sup>2</sup> )*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness*	pH*	Hardness	pH
Point of Discharge	86	0.24										100	7		
End of Reach 1	84.7	0.24													

Q<sub>h</sub>

Location	RMI	LFY (cfs/mi <sup>2</sup> )*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness	pH	Hardness	pH
Point of Discharge	86														
End of Reach 1	84.7														



Model Results

Foxburg STP, NPDES Permit No. PA0103373, Outfall 001

All
  Inputs
  Results
  Limits

- Hydrodynamics
- Wasteload Allocations

**AFC**
 CCT (min): 
 PMF: 
 Analysis Hardness (mg/l): 
 Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Total Copper	0	0		0	13.439	14.0	1,617	Chem Translator of 0.96 applied
Total Lead	0	0		0	64.581	81.6	9,428	Chem Translator of 0.791 applied
Total Zinc	0	0		0	117.180	120	13,836	Chem Translator of 0.978 applied

**CFC**
 CCT (min): 
 PMF: 
 Analysis Hardness (mg/l): 
 Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Total Copper	0	0		0	8.956	9.33	7,408	Chem Translator of 0.96 applied
Total Lead	0	0		0	2.517	3.18	2,527	Chem Translator of 0.791 applied
Total Zinc	0	0		0	118.139	120	95,151	Chem Translator of 0.986 applied

**THH**
 CCT (min): 
 PMF: 
 Analysis Hardness (mg/l): 
 Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	500,000	500,000	N/A	
Chloride (PWS)	0	0		0	250,000	250,000	N/A	
Sulfate (PWS)	0	0		0	250,000	250,000	N/A	

Total Copper	0	0	0	N/A	N/A	N/A
Total Lead	0	0	0	N/A	N/A	N/A
Total Zinc	0	0	0	N/A	N/A	N/A

**CRL**      CCT (min):       PMF:       Analysis Hardness (mg/l):       Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0	0	0	N/A	N/A	N/A	
Chloride (PWS)	0	0	0	0	N/A	N/A	N/A	
Sulfate (PWS)	0	0	0	0	N/A	N/A	N/A	
Total Copper	0	0	0	0	N/A	N/A	N/A	
Total Lead	0	0	0	0	N/A	N/A	N/A	
Total Zinc	0	0	0	0	N/A	N/A	N/A	

**Recommended WQBELs & Monitoring Requirements**

No. Samples/Month:

Pollutants	Mass Limits		Concentration Limits				Governing WQBEL	WQBEL Basis	Comments
	AML (lbs/day)	MDL (lbs/day)	AML	MDL	IMAX	Units			

**Other Pollutants without Limits or Monitoring**

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., <= Target QL).

Pollutants	Governing WQBEL	Units	Comments
Total Dissolved Solids (PWS)	N/A	N/A	PWS Not Applicable
Chloride (PWS)	N/A	N/A	PWS Not Applicable
Bromide	N/A	N/A	No WQS
Sulfate (PWS)	N/A	N/A	PWS Not Applicable
Total Copper	1,036	µg/L	Discharge Conc ≤ 10% WQBEL
Total Lead	2,527	µg/L	Discharge Conc ≤ 10% WQBEL
Total Zinc	8,869	µg/L	Discharge Conc ≤ 10% WQBEL

Attachment 4

Facility:	Foxburg STP		
Permit Number:	PA0103373	Effective: N/A	Expiration: N/A
Outfall No:	001		
Location:	Foxburg Borough, Clarion County		
Discharge to:	Allegheny River		
Site Specific Mussel Survey Completed:	Yes (2013 survey determined no impact)		

Discharge and Stream Characteristics		Comments	
Q <sub>s</sub>	Stream Flow	993.548 MGD / 1538 cfs	Fact Sheet
Q <sub>D</sub>	Discharge Flow	0.16 MGD / 0.24759 cfs	Fact Sheet
C <sub>S(Cl<sup>-</sup>)</sub>	Instream chloride Concentration	17.37 mg/L	WQN #867 (3/2005 - 10/2016)
C <sub>E(Cl<sup>-</sup>)</sub>	Discharge chloride (existing)	96.3 mg/L	From renewal application - Max of 24 samples
C <sub>P(Cl<sup>-</sup>)</sub>	Discharge chloride (proposed)	96.3 mg/L	From renewal application - Max of 24 samples
C <sub>S(Ni)</sub>	Instream nickel Concentration	0.03 µg/L	Assumed - No WQN data below the criteria of 7.3 µg/L (reported at < 50)
C <sub>E(Ni)</sub>	Discharge nickel (existing)	0.008 µg/L	From renewal application - Max of 8 samples
C <sub>P(Ni)</sub>	Discharge nickel (proposed)	0.008 µg/L	From renewal application - Max of 8 samples
C <sub>S(Zn)</sub>	Instream zinc Concentration	0 µg/L	No data
C <sub>E(Zn)</sub>	Discharge zinc (existing)	61 µg/L	From renewal application - Max of 24 samples
Zn <sub>P(Cl<sup>-</sup>)</sub>	Discharge zinc (proposed)	61 µg/L	From renewal application - Max of 24 samples
C <sub>S(NH<sub>3</sub>-N)</sub>	Instream NH <sub>3</sub> -N	0.03 mg/L	WQN #867 (3/2005 - 10/2016)
C <sub>E(NH<sub>3</sub>-N)</sub>	Discharge NH <sub>3</sub> -N (existing)	4.5 mg/L	From renewal application - Max of 24 samples
C <sub>P(NH<sub>3</sub>-N)</sub>	Discharge NH <sub>3</sub> -N (proposed)	4.5 mg/L	From renewal application - Max of 24 samples
pH <sub>s</sub>	Instream pH	7.93 S.U.	WQN #867 (3/2005 - 10/2016) - Field Data
T <sub>s</sub>	Instream Temp.	25 °C	Default value for a WWF
C <sub>C(NH<sub>3</sub>-N)</sub>	Ammonia criteria	0.621 mg/L	<b>From ammonia criteria comparison spreadsheet -using instream pH and Temp</b>
C <sub>C(Cl<sup>-</sup>)</sub>	Chloride criteria	78 mg/L	USFWS criteria
C <sub>C(Ni)</sub>	Nickel criteria	7.3 µg/L	USFWS criteria
C <sub>C(Zn)</sub>	Zinc criteria	13.18 µg/L	USFWS criteria
W <sub>s</sub>	Stream width	185 meters	Google Earth

Ammonia Criteria Calculations:			
pH <sub>s</sub>	7.93	S.U.	(Default value is 7.0)
T <sub>s</sub>	25	°C	(Default value is 20 °)
Acute Criteria			
	METHOD and UNITS	CRITERIA	Comments
	Old CMC (mg TAN/L) =	2.103	
	EPA 2013 CMC (mg TAN/L) =	2.941	Oncorhynchus present * formula on pg. 41 (plateaus at 15.7 C)
		2.941	Oncorhynchus absent * formula on pg. 42 (plateaus at 10.2 C)
Chronic Criteria			
	METHOD and UNITS	CRITERIA	COMMENTS
	Old CMC (mg TAN/L) =	0.541	
C <sub>C(NH<sub>3</sub>-N)</sub>	EPA 2013 CMC (mg TAN/L) =	0.621	* formula on pg. 46 (plateaus at 7 C)

**Endangered Mussel Species Impact Area Calculations:**

**Existing Area of Impact**

N/A - No Site Specific Mussel Survey Completed for this Discharger

Approximate Area of Impact Determined from Survey =	N/A m <sup>2</sup>	(Enter N/A if no site specific survey has been completed)
Existing Mussel Density within Area of Impact =		
Rabbitsfoot ( <i>Quadrula cylindrica</i> )	N/A per m <sup>2</sup>	
Northern Riffleshell ( <i>Epioblasma torulosa rangiana</i> )	N/A per m <sup>2</sup>	
Rayed Bean ( <i>Villosa fabalis</i> )	N/A per m <sup>2</sup>	
Clubshell ( <i>Pleurobema clava</i> )	N/A per m <sup>2</sup>	
Sheepnose ( <i>Plethobasus cyphus</i> )	N/A per m <sup>2</sup>	
Snuffbox ( <i>Epioblasma triquetra</i> )	N/A per m <sup>2</sup>	
TOTAL	0 per m <sup>2</sup>	

**Method 1 - Utilizing Site Specific Mussel Survey Information**

N/A - No Site Specific Mussel Survey Completed for this Discharger

This method utilizes a simple comparison of the size of the existing area of impact as determined from a site specific mussel survey and the chlorides in the existing discharge compared to the chlorides in the proposed discharge after the facility upgrades treatment technologies. This method is only applicable to where the stream impairment is caused by TDS and/or chlorides as the plume has been delineated through conductivity measurements.

A. Area of Impact Determined from Survey:	N/A m <sup>2</sup>
B. Chlorides in Existing Discharge:	96 mg/L
C. Chlorides in Proposed Discharge after Treatment Facility Upgrades:	96.3 mg/L
D. Approximate Area of Impact after Treatment Facility Upgrades:	N/A m <sup>2</sup>

A/B = D/C      Therefore, D = (A \* C)/B

Endangered Mussel Species Impact Area Calculations: (continued...)

Method 2 - Mass Balance Relationship of Loading and Assimilative Capacity of Stream

Chloride (Cl <sup>-</sup> )	$L_{S(Cl^-)} = \text{Available Chloride Loading in Stream} = C_{Cl(Cl^-)} - C_{S(Cl^-)} \times Q_S(\text{MGD}) \times 8.34 =$	502,392 lbs/Day
	$L_{D-MAX(Cl^-)} = \text{Current Maximum Discharge Chloride Loading exceeding criteria} = (C_{E(Cl^-)} - C_{P(Cl^-)}) \times Q_D(\text{MGD}) \times 8.34 =$	24 lbs/Day
	$\%E_{Cl^-} = \text{Percent of Stream Capacity for Current Loading} = L_{D-MAX(Cl^-)} / L_{S(Cl^-)} =$	0% of Stream Capacity
	$L_{D(Cl^-)} = \text{Proposed Discharge Cl}^- \text{ Loading exceeding criteria after Treatment Facility Upgrades} = (C_{P(Cl^-)} - C_{T(Cl^-)}) \times Q_D(\text{MGD}) \times 8.34 =$	24.41952 lbs/Day
	$\%P_{Cl^-} = \text{Percent of Stream Capacity for Proposed Loading} = L_{D(Cl^-)} / L_{S(Cl^-)} =$	0.00% of Stream Capacity
Proposed Area of Impact due to Chloride * = $(\%P_{Cl^-}) \times W_S^2 \times 0.5 =$ * assuming equal flow across transect and 90° spread at discharge		0.0000 m <sup>2</sup>
Nickel (Ni)	$L_{S(Ni)} = \text{Available Nickel Loading in Stream} = C_{Cl(Ni)} - C_{S(Ni)} \times Q_S(\text{MGD}) \times 8.34 =$	60,241 lbs/Day
	$L_{D-MAX(Ni)} = \text{Current Maximum Discharge Nickel Loading exceeding criteria} = (C_{E(Ni)} - C_{P(Ni)}) \times Q_D(\text{MGD}) \times 8.34 =$	-10 lbs/Day
	$\%E_{Ni} = \text{Percent of Stream Capacity for Current Loading} = L_{D-MAX(Ni)} / L_{S(Ni)} =$	0% of Stream Capacity
	$L_{D(Ni)} = \text{Proposed Discharge Ni Loading exceeding criteria after Treatment Facility Upgrades} = (C_{P(Ni)} - C_{T(Ni)}) \times Q_D(\text{MGD}) \times 8.34 =$	-9.7304448 lbs/Day
	$\%P_{Ni} = \text{Percent of Stream Capacity for Proposed Loading} = L_{D(Ni)} / L_{S(Ni)} =$	-0.02% of Stream Capacity
Proposed Area of Impact due to Nickel * = $(\%P_{Ni}) \times W_S^2 \times 0.5 =$ * assuming equal flow across transect and 90° spread at discharge		0.0004 m <sup>2</sup>
Zinc (Zn)	$L_{S(Zn)} = \text{Available Zinc Loading in Stream} = C_{Cl(Zn)} - C_{S(Zn)} \times Q_S(\text{MGD}) \times 8.34 =$	109,212 lbs/Day
	$L_{D-MAX(Zn)} = \text{Current Maximum Discharge Zinc Loading exceeding criteria} = (C_{E(Zn)} - C_{P(Zn)}) \times Q_D(\text{MGD}) \times 8.34 =$	64 lbs/Day
	$\%E_{Zn} = \text{Percent of Stream Capacity for Current Loading} = L_{D-MAX(Zn)} / L_{S(Zn)} =$	0% of Stream Capacity
	$L_{D(Zn)} = \text{Proposed Discharge Zn Loading exceeding criteria after Treatment Facility Upgrades} = (C_{P(Zn)} - C_{T(Zn)}) \times Q_D(\text{MGD}) \times 8.34 =$	63.811008 lbs/Day
	$\%P_{Zn} = \text{Percent of Stream Capacity for Proposed Loading} = L_{D(Zn)} / L_{S(Zn)} =$	0.06% of Stream Capacity
Proposed Area of Impact due to Zinc * = $(\%P_{Zn}) \times W_S^2 \times 0.5 =$ * assuming equal flow across transect and 90° spread at discharge		0.0058 m <sup>2</sup>
Ammonia-Nitrogen (NH <sub>3</sub> -N)	$L_{S(NH_3-N)} = \text{Available NH}_3\text{-N Loading in Stream} = C_{Cl(NH_3-N)} - C_{S(NH_3-N)} \times Q_S(\text{MGD}) \times 8.34 =$	4,897 lbs/Day
	$L_{D-MAX(NH_3-N)} = \text{Current Maximum Discharge NH}_3\text{-N Loading} = C_{E(NH_3-N)} \times Q_D(\text{MGD}) \times 8.34 =$	6 lbs/Day
	$\%E_{NH_3-N} = \text{Percent of Stream Capacity for Current Loading} = L_{D-MAX(NH_3-N)} / L_{S(NH_3-N)} =$	0% of Stream Capacity
	$L_{D(NH_3-N)} = \text{Proposed Discharge NH}_3\text{-N Loading after Treatment Facility Upgrades} = C_{P(NH_3-N)} - C_{T(NH_3-N)} \times Q_D(\text{MGD}) \times 8.34 =$	5 lbs/Day
	$\%P_{NH_3-N} = \text{Percent of Stream Capacity for Proposed Loading} = L_{D(NH_3-N)} / L_{S(NH_3-N)} =$	0.10% of Stream Capacity
Proposed Area of Impact due to NH <sub>3</sub> -N * = $(\%P_{NH_3-N}) \times W_S^2 \times 0.5 =$ * assuming equal flow across transect and 90° spread at discharge		0.0178 m <sup>2</sup>

Endangered Mussel Species Impact Area Calculations: (continued...)

Method 3 - Mass Balance Relationship of Stream Flow, Proposed Effluent Quality, and Mussel Protection Criteria

Chloride (Cl <sup>-</sup> )	$Q_{A(Cl^-)} C_{S(Cl^-)} + Q_D C_{P(Cl^-)} = Q_T C_{Cl(Cl^-)}$	
	$Q_{A(Cl^-)} = \text{Assimilative Stream Flow Required to Achieve Criteria (cfs)}$	
	$Q_T = Q_S + Q_D \text{ (cfs)}$	
	$Q_{A(Cl^-)} C_{S(Cl^-)} + Q_D C_{P(Cl^-)} = (Q_D + Q_S) C_{Cl(Cl^-)}$	
	SOLVING FOR $Q_{A(Cl^-)} = [(Q_D C_{P(Cl^-)} / C_{Cl(Cl^-)}) - Q_D] / [1 - C_{S(Cl^-)} / C_{Cl(Cl^-)}] =$	0.07473028 cfs
	$\%P_{Cl^-} = \text{Percent of Stream Width Required to Assimilate Chlorides to Criteria}$ Concentration = $Q_{A(Cl^-)} / Q_S \text{ (cfs)} =$	0.0049%
	$W_{I(Cl^-)} = \text{Proposed Width of Stream required to Assimilate Chlorides to Criteria}$ Concentration = $W_S \times \%P_{Cl^-}$	0.008989 meters
Proposed Area of Impact due to Chloride * = $(W_{I(Cl^-)})^2 \times 0.5 =$ * assuming equal flow across transect and 90° spread at discharge		0.0000 m <sup>2</sup>
Nickel (Ni)	$Q_{A(Ni)} C_{S(Ni)} + Q_D C_{P(Ni)} = Q_T C_{Cl(Ni)}$	
	$Q_{A(Ni)} = \text{Assimilative Stream Flow Required to Achieve Criteria (cfs)}$	
	$Q_T = Q_S + Q_D \text{ (cfs)}$	
	$Q_{A(Ni)} C_{S(Ni)} + Q_D C_{P(Ni)} = (Q_D + Q_S) C_{Cl(Ni)}$	
	SOLVING FOR $Q_{A(Ni)} = [(Q_D C_{P(Ni)} / C_{Cl(Ni)}) - Q_D] / [1 - C_{S(Ni)} / C_{Cl(Ni)}] =$	-0.24833924 cfs
	$\%P_{Cl^-} = \text{Percent of Stream Width Required to Assimilate Nickel to Criteria}$ Concentration = $Q_{A(Ni)} / Q_S \text{ (cfs)} =$	-0.0161%
	$W_{I(Ni)} = \text{Proposed Width of Stream required to Assimilate Nickel to Criteria}$ Concentration = $W_S \times \%P_{Ni}$	-0.029872 meters
Proposed Area of Impact due to Nickel * = $(W_{I(Ni)})^2 \times 0.5 =$ * assuming equal flow across transect and 90° spread at discharge		0.0004 m <sup>2</sup>
Zinc (Zn)	$Q_{A(Zn)} C_{S(Zn)} + Q_D C_{P(Zn)} = Q_T C_{Cl(Zn)}$	
	$Q_{A(Zn)} = \text{Assimilative Stream Flow Required to Achieve Criteria (cfs)}$	
	$Q_T = Q_S + Q_D \text{ (cfs)}$	
	$Q_{A(Zn)} C_{S(Zn)} + Q_D C_{P(Zn)} = (Q_D + Q_S) C_{Cl(Zn)}$	
	SOLVING FOR $Q_{A(Zn)} = [(Q_D C_{P(Zn)} / C_{Cl(Zn)}) - Q_D] / [1 - C_{S(Zn)} / C_{Cl(Zn)}] =$	0.89831212 cfs
	$\%P_{Cl^-} = \text{Percent of Stream Width Required to Assimilate Zinc to Criteria}$ Concentration = $Q_{A(Zn)} / Q_S \text{ (cfs)} =$	0.0584%
	$W_{I(Zn)} = \text{Proposed Width of Stream required to Assimilate Zinc to Criteria}$ Concentration = $W_S \times \%P_{Zn}$	0.108054 meters

	Proposed Area of Impact due to Chloride $= (W_{(Cl^-)})^2 \times 0.5 =$ * assuming equal flow across transect and 90° spread at discharge	0.0058 m <sup>2</sup>
Ammonia-Nitrogen (NH3-N)	$Q_{A(NH3-N)}C_{S(NH3-N)} + Q_D C_{P(NH3-N)} = Q_T C_{C(NH3-N)}$	
	$Q_{A(NH3-N)} =$ Assimilative Stream Flow Required to Achieve Criteria (cfs)	
	$Q_T = Q_S + Q_D$ (cfs)	
	$Q_{A(NH3-N)}C_{S(NH3-N)} + Q_D C_{P(NH3-N)} = (Q_D + Q_S)C_{C(NH3-N)}$	
	SOLVING FOR $Q_{A(NH3-N)} = [(Q_D C_{P(NH3-N)} / C_{C(NH3-N)}) - Q_D] / \{1 - C_{S(NH3-N)} / C_{C(NH3-N)}\} =$	1.625045 cfs
	$\%_{P(NH3-N)} =$ Percent of Stream Width Required to Assimilate NH3-N to Criteria	
	Concentration = $Q_{A(NH3-N)} / Q_S$ (cfs) =	0.1057%
	$W_{(NH3-N)} =$ Proposed Width of Stream required to Assimilate NH3-N to Criteria	
	Concentration = $W_S \times \%_{P(NH3-N)}$	0.195470 meters
	Proposed Area of Impact due to NH3-N $= (W_{(NH3-N)})^2 \times 0.5 =$ * assuming equal flow across transect and 90° spread at discharge	0.0191 m <sup>2</sup>

Attachment 5

RE: Tionesta Borough WWTP - PA0047201 - Draft Permit Documents (Tionesta Borough, Forest County)

Kratina, Garret <gkratina@pa.gov>

Mon 2/26/2024 2:47 PM

To: Dickey, Justin <judickey@pa.gov>

Cc: McCauley, Stephen <smccauley@pa.gov>; Blakeslee, Carrie J <carrie\_blakeslee@fws.gov>; Urban, Chris <curban@pa.gov>; Brancato, Joseph <jbrancato@pa.gov>; Brown, Joshua <joshubrown@pa.gov>; Welte, Nevin <c-nwelte@pa.gov>; Lorson, Benjamin <belorson@pa.gov>

Hello Justin,

Thank you for sharing this permit renewal with the Pennsylvania Fish and Boat Commission (PFBC) and for allowing us to provide comments. Since the impact area calculation predicts that this discharge is expected to almost instantaneously dilute with the Allegheny River for Ammonia-Nitrogen, Chlorides, and Nickel, the PFBC does not have significant concerns regarding the approval of this permit. The PFBC appreciates the addition of effluent monitoring for dissolved Zinc to develop a dataset to evaluate potential impacts on threatened and endangered (T&E) mussels for future permit renewals. Given that total Copper has also been identified as a parameter of interest to the United States Fish and Wildlife Service (USFWS) when reviewing NPDES permit renewals for similar facilities that discharge into waters that have the potential to contain T&E mussels, the PFBC would like PADEP to consider the addition of total Copper effluent monitoring to this permit renewal.

Thank you for considering the PFBC's comments. If you'd like to provide feedback or have questions regarding our comments, please contact me at (717) 836-2134 or email [gkratina@pa.gov](mailto:gkratina@pa.gov).

Sincerely,

**Garret Kratina** | Fisheries Biologist

Pennsylvania Fish and Boat Commission | Division of Environmental Services

595 East Rolling Ridge Drive | Bellefonte, PA 16823

Mobile: 717.836.2134 | Office: 814.359.2219

[fishandboat.com](http://fishandboat.com)

---

**From:** Dickey, Justin <judickey@pa.gov>

**Sent:** Monday, February 5, 2024 9:44 AM

**To:** Blakeslee, Carrie J <carrie\_blakeslee@fws.gov>; Urban, Chris <curban@pa.gov>; Kratina, Garret <gkratina@pa.gov>; Brancato, Joseph <jbrancato@pa.gov>; Brown, Joshua <joshubrown@pa.gov>; Welte, Nevin <c-nwelte@pa.gov>

**Cc:** McCauley, Stephen <smccauley@pa.gov>

**Subject:** Tionesta Borough WWTP - PA0047201 - Draft Permit Documents (Tionesta Borough, Forest County)

Please find attached the DRAFT NPDES Permit documents for the Tionesta Borough WWTP facility located in Woodcock Township, Crawford County (NPDES Permit No. PA0003026). The subject discharges are existing discharges to Allegheny River. Please note that page 7 of the Fact Sheet summarizes the Department's concerns and considerations for threatened and endangered mussel species. The Draft Permit notification should get published in the Pennsylvania Bulletin on February 17, 2024 with the 30-day public comment period ending on March 18, 2024.

If you have any questions or need additional information, please call or email me or Stephen McCauley.

Thank you,

**Justin C. Dickey, P.E.** | Environmental Program Manager

Department of Environmental Protection | Clean Water Program

Northwest Regional Office

230 Chestnut Street | Meadville, PA 16335

Phone: 814.332.6352 | Fax: 814.332.6121

[www.dep.pa.gov](http://www.dep.pa.gov)

Attachment 6

Re: [EXTERNAL] Tionesta Borough WWTP - PA0047201 - Draft Permit Documents  
(Tionesta Borough, Forest County)

Blakeslee, Carrie J <carrie\_blakeslee@fws.gov>

Wed 3/13/2024 9:51 AM

To: Dickey, Justin <judickey@pa.gov>; Urban, Chris <curban@pa.gov>; Kratina, Garret <gkratina@pa.gov>; Brancato, Joseph <jbrancato@pa.gov>; Brown, Joshua <joshubrown@pa.gov>; Welte, Nevin <c-nwelte@pa.gov>  
Cc: McCauley, Stephen <smccauley@pa.gov>

Justin,

The Fish and Wildlife Service has reviewed this permit and we request that monitoring for all parameters of concern, ammonia-nitrogen, chloride, total nickel, and total zinc, continue over the next permit cycle. Given the importance of the Allegheny River to federally and state listed mussel species, we would like to continue to gather data to provide a valid baseline in making monitoring decisions.

To ensure we are collecting meaningful data and that we have a clear picture of the concentrations of these parameters at the outfall, we would request monthly, and at the very least quarterly, monitoring throughout the permit cycle. Without this type of data, we do not have the information we need to determine if it is appropriate to discontinue monitoring for a given parameter.

If you have questions or would like to discuss this topic further, we would be happy to arrange a meeting for further discussion. Thank you.

Carrie

---

*Carrie Blakeslee*

U.S. Fish and Wildlife Service  
Pennsylvania Field Office  
110 Radnor Rd., Suite 101  
State College, PA 16801  
carrie\_blakeslee@fws.gov  
Cell phone: (814) 470-2736  
Office phone: (814) 206-7471 (Mondays & Tuesdays)

---

**From:** Dickey, Justin <judickey@pa.gov>

**Sent:** Monday, February 5, 2024 9:44 AM

**To:** Blakeslee, Carrie J <carrie\_blakeslee@fws.gov>; Urban, Chris <curban@pa.gov>; Kratina, Garret <gkratina@pa.gov>; Brancato, Joseph <jbrancato@pa.gov>; Brown, Joshua <joshubrown@pa.gov>; Welte, Nevin <c-nwelte@pa.gov>

**Cc:** McCauley, Stephen <smccauley@pa.gov>

**Subject:** [EXTERNAL] Tionesta Borough WWTP - PA0047201 - Draft Permit Documents (Tionesta Borough, Forest County)

<p>This email has been received from outside of DOI - Use caution before clicking on links, opening attachments, or responding.</p>
---

Please find attached the DRAFT NPDES Permit documents for the Tionesta Borough WWTP facility located in Woodcock Township, Crawford County (NPDES Permit No. PA0003026). The subject discharges are existing discharges to Allegheny River. Please note that page 7 of the Fact Sheet summarizes the Department's concerns and considerations for threatened and endangered mussel species. The Draft Permit notification should get published in the Pennsylvania Bulletin on February 17, 2024 with the 30-day public comment period ending on March 18, 2024.

If you have any questions or need additional information, please call or email me or Stephen McCauley.

Thank you,

**Justin C. Dickey, P.E.** | Environmental Program Manager  
Department of Environmental Protection | Clean Water Program  
Northwest Regional Office  
230 Chestnut Street | Meadville, PA 16335  
Phone: 814.332.6352 | Fax: 814.332.6121  
[www.dep.pa.gov](http://www.dep.pa.gov)