

Application Type Renewal  
Facility Type Municipal  
Major / Minor Minor

## NPDES PERMIT FACT SHEET INDIVIDUAL SEWAGE

Application No. PA0110361  
APS ID 370  
Authorization ID 1398158

### Applicant and Facility Information

<p>Applicant Name <u>Freedom Township Water &amp; Sewer Authority</u></p> <p>Applicant Address <u>131 Municipal Street</u> <u>East Freedom, PA 16637-8158</u></p> <p>Applicant Contact <u>Melvin Edmundson</u></p> <p>Applicant Phone <u>(814) 695-8051</u></p> <p>Client ID <u>77220</u></p> <p>Ch 94 Load Status <u>Not Overloaded</u></p> <p>Connection Status <u>No Limitations</u></p> <p>Date Application Received <u>May 31, 2022</u></p> <p>Date Application Accepted <u>June 6, 2022</u></p> <p>Purpose of Application <u>This is an application for NPDES renewal.</u></p>	<p>Facility Name <u>Freedom Township STP</u></p> <p>Facility Address <u>60 Standish Lane</u> <u>Duncansville, PA 16635</u></p> <p>Facility Contact <u>Rick Miller</u></p> <p>Facility Phone <u>(814) 696-0498</u></p> <p>Site ID <u>451887</u></p> <p>Municipality <u>Freedom Township</u></p> <p>County <u>Blair</u></p> <p>EPA Waived? <u>No</u></p> <p>If No, Reason <u>Significant CB Discharge</u></p>
------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

### Summary of Review

The application submitted by the applicant requests a NPDES renewal permit for the Freedom Township WWTP located at 60 Standish Lane, Duncansville, PA 16635 in Blair County, municipality of Freedom Township. The existing permit became effective on February 1, 2017 and expires(d) on November 30, 2022. The application for renewal was received by DEP Southcentral Regional Office (SCRO) on May 31, 2022.

The purpose of this Fact Sheet is to present the basis of information used for establishing the proposed NPDES permit effluent limitations. The Fact Sheet includes a description of the facility, a description of the facility's receiving waters, a description of the facility's receiving waters attainment/non-attainment assessment status, and a description of any changes to the proposed monitoring/sampling frequency. Section 6 provides the justification for the proposed NPDES effluent limits derived from technology based effluent limits (TBEL), water quality based effluent limits (WQBEL), total maximum daily loading (TMDL), antidegradation, anti-backsliding, and/or whole effluent toxicity (WET). A brief summary of the outlined descriptions has been included in the Summary of Review section.

The subject facility is a 0.97 MGD design flow treatment facility. The applicant does not anticipate any proposed upgrades to the treatment facility in the next five years. The NPDES application has been processed as a Minor Sewage Facility (Level 2) due to the type of sewage and the design flow rate for the facility. The applicant disclosed the Act 14 requirement to Blair County Commissioners, Greenfield Township Supervisors, Newry Borough Council, Blair Township Supervisors, and Freedom Township Supervisors and the notice was received by the parties in April 2022. A planning approval letter was not necessary as the facility is neither new or expanding.

Approve	Deny	Signatures	Date
X		Nicholas Hong, P.E. / Environmental Engineer Nick Hong (via electronic signature)	September 14, 2022
X		Daniel W. Martin, P.E. / Environmental Engineer Manager Daniel W. Martin	September 22, 2022

### Summary of Review

Utilizing the DEP's web-based Emap-PA information system, the receiving waters for Outfall 001 has been determined to be Frankstown Branch Juniata River. The sequence of receiving streams that the Frankstown Branch Juniata River discharges into are Juniata River and the Susquehanna River which eventually drains into the Chesapeake Bay. The subject site is subject to the Chesapeake Bay implementation requirements. The receiving water has protected water usage for trout stocking fish (TSF) and migratory fish (MF). No Class A Wild Trout fisheries are impacted by this discharge. The absence of high quality and/or exceptional value surface waters removes the need for an additional evaluation of anti-degradation requirements.

The Frankstown Branch Juniata River is a Category 2 stream listed in the 2022 Integrated List of All Waters (formerly 303d Listed Streams). This stream is an attaining stream that supports aquatic life and fish consumption. The receiving waters is not subject to a total maximum daily load (TMDL) plan to improve water quality in the subject facility's watershed.

The existing permit and proposed permit differ as follows:

- For Outfall 001, monitoring for E. coli shall be required.
- For Outfall 002, the dissolved oxygen shall be at least 6.0 mg/l. The previous Fact Sheet recommended the effluent limit but was typographically mistaken in the permit table.
- For Outfall 002, UV monitoring shall be daily during discharging
- For Outfall 001, monitoring for total copper and total zinc shall be on a 1x/quarter basis.
- For Outfall 002, monitoring for total copper and total zinc shall be on a 1x/week when discharging.

Sludge use and disposal description and location(s): Sewage sludge/biosolids disposed at the following locations: (1) Laurel Highlands Landfill in Johnstown Township, Cambria County, (2) Gary Stiffler Farm in Freedom Township, Blair County, (3) Frank Musselman Farm in Freedom/Greenfield Township in Blair County.

The proposed permit will expire five (5) years from the effective date.

Based on the review in this report, it is recommended that the permit be drafted. DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Any additional information or public review of documents associated with the discharge or facility may be available at PA DEP Southcentral Regional Office (SCRO), 909 Elmerton Avenue, Harrisburg, PA 17110. To make an appointment for file review, contact the SCRO File Review Coordinator at 717.705.4700.

## **1.0 Applicant**

### **1.1 General Information**

This fact sheet summarizes PA Department of Environmental Protection's review for the NPDES renewal for the following subject facility.

Facility Name: Freedom Township WWTP

NPDES Permit # PA0110361

Physical Address: 60 Standish Lane  
Duncansville, PA 16635

Mailing Address: 131 Municipal Street  
East Freedom, PA 16637

Contact: Richard Miller  
Chief Operator  
[ftwsa@atlanticbb.net](mailto:ftwsa@atlanticbb.net)

Consultant: Tobias Nagle  
Senior Environmental Scientist  
Stiffler, McGraw and Associates, Inc.  
1731 North Juniata Street  
Hollidaysburg, PA 16648  
(814) 696-6280  
[tnagle@stiffler-mcgraw.com](mailto:tnagle@stiffler-mcgraw.com)

### **1.2 Permit History**

#### **Description of Facility**

Primary discharge from the UV disinfection system flows to Outfall 001 located on the Frankstown Branch of the Juniata River approximately 350 feet downstream from the UV system outlet. A secondary outfall from the UV system exists to enable overflow from the end of the UV tank to be discharged to an outfall located immediately beside the UV tank. The secondary outfall discharges to Tributary 16564 To McDonald Run and is intended for use only in the event of extreme peak flows through the system that would exceed the hydraulic capacity of the Outfall 001 discharge line.

Permit submittal included the following information.

- NPDES Application
- Flow Diagrams
- Influent Sample Data
- Effluent Sample Data

## 2.0 Treatment Facility Summary

### 2.1.1 Site location

The physical address for the facility is 60 Standish Lane, Duncansville, PA 16635. A topographical and an aerial photograph of the facility are depicted as Figure 1 and Figure 2.

Figure 1: Topographical map of the subject facility





Figure 2: Aerial Photograph of the subject facility



**2.1.2 Sources of Wastewater/Stormwater**

The table summarizes the sources of wastewater contributions the facility receives. The flow contribution is slightly less than 100% due to rounding.

<b>Municipalities Served</b>	<b>Flow Contribution</b>	<b>Population</b>
Freedom Township	80%	2308
Blair Township	14%	1012
Newry Borough-Greenfield Township	5%	270
Total	99%	

The facility did not receive hauled-in wastes in the past three years and does not anticipate receiving hauled in wastes in the next five years.

The facility does not have an EPA-approved pretreatment program.



**NPDES Permit Fact Sheet  
Freedom Township STP**

**NPDES Permit No. PA0110361**

The table summarizes the facilities' commercial and industrial user list.

**Freedom Township Water and Sewer Authority  
Non-Residential Sewer Customer List**

Metered Sewer Customers				
Customer Name	Use	Gallons per Day	Municipal Service Area	2021 Water Usage
Walmart	Retail sales	3256	FTWSA	1,188,400
St Patricks School	School	740	Newry Borough	270,000
Inlows Drive-in Rest	Restaurant	619	BTWSA	226,000
Daisy McCoy-Apts above bar only	Bar	71	Newry Borough	26,000
Harkens	Business office	452	Newry Borough	165,000
Eds Furniture & Apts	Retail sales	268	Newry Borough	98,000
Mauk	Beauty shop	205	Newry Borough	75,000
Kenyon-Restaurant	Restaurant	52	Newry Borough	19,000
Leighty's Flea Market	Retail sales	125	BTWSA	45,648
Leamersville Grace Breth Chrch	Church	173	FTWSA	63,000
Gentry Antiques & Apt	Retail sales	318	Newry Borough	116,000
Season-Aire	HVAC sales/service	124	FTWSA	45,389
Wonder Bar & Apt	Bar	272	Newry Borough	99,190
Leamersville Grace Breth Parsonage	Church	170	FTWSA	62,000
Puzzletown Church	Church	47	FTWSA	17,000
Keystone Kawasaki	Motorcycle sales	4	BTWSA	1,622
St Patricks Church	Church	14	Newry Borough	5,000
Northwestern Mutual Financial	Financial Advising	21	Newry Borough	7,495
Benton Insurance	Business office	19	Newry Borough	7,000
Bettwey Electric	Electrician	30	FTWSA	11,000
Outreach Puzzletown Church	Church	47	FTWSA	17,000
Wagners Garage	Auto repairs	0	Newry Borough	0
Ritchey Pump House	Pump sales/service	22	Newry Borough	8,000
Allegheny Forklift	Sales	186	BTWSA	68,000
Bills Used Furniture	Furniture sales	0	Newry Borough	
Burchfield - Junk Yard	Office	74	BTWSA	26,850
US Post Office	Post Office	3	Newry Borough	1,000
Kneezle Fuel Terminal	Office	30	BTWSA	11,000
Newry Lutheran Church	Church	3	Newry Borough	1,000
Yingling	Business office	110	Newry Borough	40,000
Burchfield-fire station	Emergency service	0	BTWSA	0
Yeckley Electric	Electrician	3	FTWSA	1,000
Scranton-Altoona Terminal	Office	0	BTWSA	0
Teppco	Office	2	BTWSA	682
Through Inc.	Clinic/social services	263	FTWSA	96,000
Creekside Inn	Restaurant	274	FTWSA	100,000
Bickel's Surplus Two	Discount Store	14	Duncansville	5000
Freedom Metals	Roofing/Siding	33	Duncansville?	12,000
Mamma Mia's Pizza	Restaurant	195	Newry Borough	71,000
Freedom Twp Municipal Bld	Gov	77	East Freedom	28,000
Freedom Twp Vol. Fire	Emergency service	82	East Freedom	30,000

**Freedom Township Non-Metered Sewer Customers**

Customer Name	Use	EDU's	Municipal Service Area	
Backyard Burgers	Restaurant	5	FTWSA	Gone
Schneider & Speck Car Wash	Car Wash	4	FTWSA	
Little Rock & Herbs	Herb sales	3	FTWSA	
Leightys Farm Market	Farm market	3	FTWSA	
Best Way Pizza	Pizza Shop	3	FTWSA	
Wyland Car Wash	Car Wash	3	FTWSA	
Shirleys Cookies	Bakery	1	FTWSA	
Blair Tools and Plastic	Machine shop	2	FTWSA	21,000
Tussey Mtn Mulch	Business office	1	FTWSA	
Insurance Auto Auctions	Sales office	1	FTWSA	
Lake View Sheds	Sales office	1	FTWSA	
Jed Claar Garage	Auto repairs	1	FTWSA	
Beavertown Block	Concrete products	1	FTWSA	
East Freedom Chapel	Church	1	FTWSA	
McKee Electric	Electric sales/supply	1	FTWSA	
McKee Playground	Playground/Bingo Hall	1	FTWSA	
St Pauls Lutheran Church	Church	1	FTWSA	
East Freedom Post Office	Post Office	1	FTWSA	
Dragon Print (vacant)	Stitching company	1	FTWSA	
Suburban Propane	Sales/service office	1	FTWSA	
United Methodist Church	Church	1	FTWSA	
Imlers Garage	Auto repairs	1	FTWSA	
Rt 220 Distributors	Beer Distributor	1	FTWSA	
Get Go Gas Station	Gas Station	1	FTWSA	
Thomas Auto Sales (vacant)	Auto sales	1	FTWSA	
Becky's School of Dance	Dance studio	1	FTWSA	
Clay Hoover Pizza	Pizza Shop	1	FTWSA	12,000
Leamersville Bretheran Church	Church	1	FTWSA	0
Loren Keith Garage	Truck repair shop	1	FTWSA	22,000
Wyant restaurant	Restaurant	1	FTWSA	
Wyant auto sales	Auto sales	1	FTWSA	
Leighty NIC	Gas/Tobacco sales	1	FTWSA	
Keystone Auto	Auto parts sales	1	FTWSA	
Buzzy's Car Sales	Auto sales	1	FTWSA	
Leighty's Hunting Outlet	Retail sales	1	FTWSA	
Golf World	Driving range/sales	1	FTWSA	
Milky Way	Ice Cream Stand	1	FTWSA	
Schneider & Speck Rentals	Rental Office	1	FTWSA	

## **2.2 Description of Wastewater Treatment Process**

The subject facility is a 0.97 MGD design flow facility. The subject facility treats wastewater using an equalization tank, anoxic tank, aerobic tank, aerobic/anoxic unit, clarifier, and uv disinfection prior to discharge through the outfall. Primary discharge occurs through Outfall 001 on the Frankstown Branch Juniata River. The secondary outfall (Outfall 002) is used in the event of extreme peak flows that exceed the hydraulic capacity of Outfall 001.

The application lists Outfall 002 as discharging to UNT to Frankstown Branch. Using eMAP, Outfall 002 appears to discharge to Tributary 16564 To McDonald Run. This receiving name stream was also consistent with the previous Fact Sheet.

The facility is being evaluated for flow, pH, dissolved oxygen, CBOD5, TSS, fecal coliform, UV residual, nitrogen species, and phosphorus. The existing permits limits for the facility is summarized in Section 2.4.

The treatment process is summarized in the table.

Treatment Facility Summary				
Treatment Facility Name: Freedom Township - STP				
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary With Ammonia Reduction	Extended Aeration	Ultraviolet	0.97
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.97	1620	Not Overloaded	Aerobic Digestion	Land Application

A schematic of the process is depicted.

## NPDES Permit No. PA0110361





### 2.3 Facility Outfall Information

The facility has the following outfall information for wastewater.

<b>Outfall No.</b>	<u>001</u>	<b>Design Flow (MGD)</b>	<u>.97</u>
<b>Latitude</b>	<u>40° 22' 34.57"</u>	<b>Longitude</b>	<u>-78° 25' 34.74"</u>
<b>Wastewater Description:</b>	<u>Sewage Effluent</u>		

<b>Outfall No.</b>	<u>002</u>	<b>Design Flow (MGD)</b>	<u>.97</u>
<b>Latitude</b>	<u>40° 22' 34.45"</u>	<b>Longitude</b>	<u>-78° 25' 37.71"</u>
<b>Wastewater Description:</b>	<u>Sewage Effluent</u>		

The subject facility outfall is within the vicinity of another sewage/wastewater outfall. Other outfalls include Greenfield, Roaring Springs, and Hollidaysburg. The Appvion outfall location was included in the modeling without discharge flow rates and discharge limits for CBOD and ammonia. The NPDES permit for Appvion is pending termination. It may be replaced with a new permit with the new facility owner. It is unclear what permit limits the new owner of the Appvion facility will contain.

#### 2.3.1 Operational Considerations- Chemical Additives

Chemical additives are chemical products introduced into a waste stream that is used for cleaning, disinfecting, or maintenance and which may be detected in effluent discharged to waters of the Commonwealth. Chemicals excluded are those used for neutralization of waste streams, the production of goods, and treatment of wastewater.

The subject facility utilizes the following chemicals as part of their treatment process.

- Sodium hydroxide for alkalinity adjustment for enhanced nutrient removal.
- Aluminum sulfate for phosphorus precipitation in clarifiers and digestors
- Polymer for phosphorus precipitation and sludge dewatering
- Micro C 2000 for carbon source and nitrogen removal process
- PAX-14 (Polyaluminum chloride) for filamentous foam control.

## 2.4 Existing NPDES Permits Limits

The existing NPDES permit limits are summarized in the table.

### PART A - EFFLUENT LIMITATIONS, MONITORING, RECORDKEEPING AND REPORTING REQUIREMENTS

I. A. For Outfall 001, Latitude 40° 22' 34.57", Longitude 78° 25' 34.82", River Mile Index 38.9, Stream Code 16061

Receiving Waters: Franktown Branch Juniata River

Type of Effluent: Sewage Effluent

1. The permittee is authorized to discharge during the period from December 1, 2017 through November 30, 2022.
2. Based on the anticipated wastewater characteristics and flows described in the permit application and its supporting documents and/or amendments, the following effluent limitations and monitoring requirements apply (see also Additional Requirements and Footnotes).

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	9.0 Max	XXX	1/day	Grab
Dissolved Oxygen	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) Nov 1 - Apr 30	162	243	XXX	20.0	30.0	40	1/week	24-Hr Composite
Carbonaceous Biochemical Oxygen Demand (CBOD5) May 1 - Oct 31	202	324	XXX	25.0	40.0	50	1/week	24-Hr Composite
Biochemical Oxygen Demand (BOD5) Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	24-Hr Composite
Total Suspended Solids	243	364	XXX	30.0	45.0	60	1/week	24-Hr Composite
Total Suspended Solids Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	24-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2,000 Geo Mean	XXX	10,000	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1,000	1/week	Grab

Outfall001, Continued (from December 1, 2017 through November 30, 2022)

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Ammonia-Nitrogen Nov 1 - Apr 30	145	XXX	XXX	18.0	XXX	36	2/week	24-Hr Composite
Ammonia-Nitrogen May 1 - Oct 31	49	XXX	XXX	6.0	XXX	12	2/week	24-Hr Composite
Ultraviolet light dosage (mJoules/cm <sup>2</sup> )	XXX	XXX	Report	XXX	XXX	XXX	1/day	Recorded

Samples taken in compliance with the monitoring requirements specified above shall be taken at the following location(s):

at Outfall 001

**NPDES Permit Fact Sheet**  
**Freedom Township STP**

**NPDES Permit No. PA0110361**

**PART A - EFFLUENT LIMITATIONS, MONITORING, RECORDKEEPING AND REPORTING REQUIREMENTS**

I. B. For Outfall 002\*, Latitude 40° 22' 34.45", Longitude 78° 25' 37.71", River Mile Index 0.0300, Stream Code 16564

Receiving Waters: Unnamed Tributary to Frankstown Branch Juniata River

Type of Effluent: Sewage Effluent

1. The permittee is authorized to discharge during the period from **December 1, 2017** through **November 30, 2022**.
2. Based on the anticipated wastewater characteristics and flows described in the permit application and its supporting documents and/or amendments, the following effluent limitations and monitoring requirements apply (see also Additional Requirements and Footnotes).

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Daily when Discharging	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	9.0 Max	XXX	Daily when Discharging	Grab
Dissolved Oxygen	XXX	XXX	5.0	XXX	XXX	XXX	Daily when Discharging	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5)	80	121	XXX	10.0	15.0	20	Weekly when Discharging	24-Hr Composite
Total Suspended Solids	80	121	XXX	10.0	15.0	20	Weekly when Discharging	24-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2,000 Geo Mean	XXX	10,000	Weekly when Discharging	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1,000	Weekly when Discharging	Grab
Total Nitrogen	40	XXX	XXX	5.0	XXX	10	Weekly when Discharging	Calculation
Ammonia-Nitrogen Nov 1 - Apr 30	31.5	XXX	XXX	3.9	XXX	7.8	Weekly when Discharging	24-Hr Composite
Ammonia-Nitrogen May 1 - Oct 31	10.5	XXX	XXX	1.3	XXX	2.6	Weekly when Discharging	24-Hr Composite
Total Phosphorus	4.0	XXX	XXX	0.5	XXX	1	Weekly when Discharging	24-Hr Composite

Samples taken in compliance with the monitoring requirements specified above shall be taken at the following location(s): at Outfall 002

\*Outfall 002 shall be used only under emergency.

**NPDES Permit Fact Sheet**  
**Freedom Township STP**

**NPDES Permit No. PA0110361**

**PART A - EFFLUENT LIMITATIONS, MONITORING, RECORDKEEPING AND REPORTING REQUIREMENTS**

I. C. For Outfall 001, Latitude 40° 22' 34.57", Longitude 78° 25' 34.82", River Mile Index 38.9, Stream Code 16061

Receiving Waters: Frankstown Branch Juniata River

Type of Effluent: Sewage Effluent

1. The permittee is authorized to discharge during the period from December 1, 2017 through November 30, 2022.
2. Based on the anticipated wastewater characteristics and flows described in the permit application and its supporting documents and/or amendments, the following effluent limitations and monitoring requirements apply (see also Additional Requirements and Footnotes).

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Monthly	Annual	Monthly	Monthly Average	Maximum	Instant. Maximum		
Ammonia--N	Report	Report	XXX	Report	XXX	XXX	2/week	24-Hr Composite
Kjeldahl--N	Report	XXX	XXX	Report	XXX	XXX	2/week	24-Hr Composite
Nitrate-Nitrite as N	Report	XXX	XXX	Report	XXX	XXX	2/week	24-Hr Composite
Total Nitrogen	Report	Report	XXX	Report	XXX	XXX	1/month	Calculation
Total Phosphorus	Report	Report	XXX	Report	XXX	XXX	2/week	24-Hr Composite
Net Total Nitrogen	Report	10,959	XXX	XXX	XXX	XXX	1/month	Calculation
Net Total Phosphorus	Report	1,461	XXX	XXX	XXX	XXX	1/month	Calculation

Samples taken in compliance with the monitoring requirements specified above shall be taken at the following location(s):

at Outfalls 001 and Outfall 002

**Footnotes:**

(1) See Part C for Chesapeake Bay Requirements.

(2) This is the minimum number of sampling events required. Permittees are encouraged, and it may be advantageous in demonstrating compliance, to perform more than the minimum number of sampling events required.

### **3.0 Facility NPDES Compliance History**

#### **3.1 Summary of Inspections**

A summary of the most recent inspections during the existing permit review cycle is as follows.

The DEP inspector noted the following during the inspection.

02/14/2018: One (of three) influent pump was out of service and currently being repaired. One clarifier blower was also being repaired. The SOP was updated to include general checks of the plant conducted by non-certified operators. The facility accepted 12,000 gallons of tank wash water in November 2017 and reported it as hauled in waste on the DMR supplemental form. Plant does not usually accept septage waste or sewage sludge.

12/02/2019: The inspection was precipitated by a report of a sewage overflow. The facility stated that on the morning of November 28th an operator called him to report that one of the aeration tanks foamed up and overflowed onto the ground and into an unnamed tributary of the Frankstown Branch. The facility thinks that a petroleum product, likely home heating oil, entered the waste stream and caused a malfunction of the DO sensor in the aeration tanks leading to excessive aeration and foaming. Foam from the #2 tank overflowed the tank in several spots and some of it flowed into the unnamed tributary that runs along the edge of the treatment plant property. The facility stated that the foam was very thick and could be collected off the ground with a skid loader. Foam was also removed from the stream bank. The foam was placed in roll off container used for dewatered sludge. There was also excessive foam in the #1 aeration tank, but it did not overflow. Because of the solids loss, the facility has ordered some bioaugmentation products to help enhance the bug life in the aeration tanks. A defoaming agent was also purchased.

12/18/2019: The plant experienced an upset on November 28, 2019, likely due to petroleum contamination. This resulted in one of the aeration tanks foaming over and discharging partially treated sewage on to the ground and into unnamed tributary of the Frankstown Branch. Sewage solids was observed along the stream bank and in the tributary. The operator has been adding freeze-dried bugs and a defoaming agent to the treatment system since the upset began. A recent lab test for fecal coliform had a high result and operators have since cleaned the UV bulb sleeves.

03/06/2020: The facility was in the process of repairing an anoxic mixer. The facility also planned on replacing ballasts and lights in second unit. The facility was cited for failure to monitor pollutants as required by the permit and failure to properly operate the facility in compliance with the WQM permit.

01/05/2021: The facility was consulted about the stream bank being eroded at Lions Club park. The facility should find a solution to stabilize the stream bank. Possible assistance may be sought at the Blair County Conservation for technical assistance.

03/09/2022: There was nothing significant to report.

#### **3.2 Summary of DMR Data**

A review of approximately 1-year of DMR data shows that the monthly average flow data for the facility below the design capacity of the treatment system. The maximum average flow data for the DMR reviewed was 0.75 MGD in February 2022. The design capacity of the treatment system is 0.97 MGD.

The off-site laboratory used for the analysis of the parameters was Fairway Laboratories located at 2019 9<sup>th</sup> Avenue, Altoona, PA.

**NPDES Permit Fact Sheet  
Freedom Township STP**

**NPDES Permit No. PA0110361**

**DMR Data for Outfall 001 (from July 1, 2021 to June 30, 2022)**

Parameter	JUN-22	MAY-22	APR-22	MAR-22	FEB-22	JAN-22	DEC-21	NOV-21	OCT-21	SEP-21	AUG-21	JUL-21
Flow (MGD) Average Monthly	0.4	0.69	0.57	0.44	0.75	0.43	0.42	0.31	0.33	0.59	0.29	0.32
Flow (MGD) Daily Maximum	1.18	2.72	1.12	0.58	2.12	0.91	1.48	0.44	0.79	3.02	0.51	0.55
pH (S.U.) Minimum	7.2	7.0	7.1	7.0	6.9	7.0	7.1	7.5	7.4	7.0	7.5	7.3
pH (S.U.) Maximum	7.8	7.7	7.6	7.4	7.4	7.3	7.9	7.9	8.0	7.9	7.8	7.8
DO (mg/L) Minimum	9.9	8.2	7.7	8.9	9.7	8.3	8.3	7.7	7.1	6.6	6.7	6.4
CBOD5 (lbs/day) Average Monthly	< 14	< 18	19	< 15	< 41	< 18	< 11	< 8	< 8	< 9	< 7	< 8
CBOD5 (lbs/day) Weekly Average	18	< 32	23	18	118	25	< 19	< 11	< 9	< 12	< 7	< 13
CBOD5 (mg/L) Average Monthly	< 4.9	< 3.9	5.0	< 4.2	< 9.1	< 5.4	< 3.4	< 3.2	< 3.0	< 3.0	< 3.0	< 3.0
CBOD5 (mg/L) Weekly Average	8.1	5.4	7.8	4.9	26.1	9.2	5.0	< 3.0	< 3.0	< 3.0	< 3.0	< 3.0
BOD5 (lbs/day) Raw Sewage Influent   Average Monthly	260	280	281	331	213	261	427	297	200	157	391	277
BOD5 (lbs/day) Raw Sewage Influent   Daily Maximum	330	393	354	496	298	355	538	498	255	211	662	357
BOD5 (mg/L) Raw Sewage Influent   Average Monthly	97	83	84	110	57	91	157	127	88	60	158	99
TSS (lbs/day) Average Monthly	< 7	24	22	< 14	< 13	< 21	< 15	< 5	< 10	12	12	10
TSS (lbs/day) Raw Sewage Influent   Average Monthly	174	186	141	169	106	101	209	141	194	879	339	192



**NPDES Permit Fact Sheet  
Freedom Township STP**

**NPDES Permit No. PA0110361**

TSS (lbs/day) Raw Sewage Influent   Daily Maximum	228	290	213	295	137	158	359	241	272	3163	424	246
TSS (lbs/day) Weekly Average	13	50	60	25	19	56	33	7	16	23	20	15
TSS (mg/L) Average Monthly	< 2.3	5.0	7.0	< 4.3	< 2.9	< 6.6	< 4.1	< 2.1	< 4.0	3.7	5.3	4.4
TSS (mg/L) Raw Sewage Influent   Average Monthly	68	53	41	58	29	36	88	62	88	424	135	64
TSS (mg/L) Weekly Average	3.2	8.8	21.0	8.0	5.2	17.2	6.0	3.0	6.0	7.0	11.0	7.0
Fecal Coliform (No./100 ml) Geometric Mean	< 1.0	< 1.0	< 1.0	< 1.0	< 1.0	< 1	< 1	< 2	< 1	< 3.0	< 2	< 2
Fecal Coliform (No./100 ml) Instantaneous Maximum	< 1.0	1.0	1.0	1.0	4.1	1	1	8.5	2	8.4	2	5.2
Nitrate-Nitrite (mg/L) Average Monthly	< 5.868	3.527	< 3.796	5.492	< 4.9	4.953	7.241	5.903	< 5.399	< 9.343	< 3.231	< 1.838
Nitrate-Nitrite (lbs) Total Monthly	< 645	557	< 517	603	< 584	523	692	435	< 417	< 1116	< 281	< 153
Total Nitrogen (mg/L) Average Monthly	< 6.391	< 4.155	< 4.585	< 6.007	< 5.588	< 5.547	< 7.741	< 6.607	< 6.106	< 9.872	< 3.87	< 2.338
Total Nitrogen (lbs) Effluent Net   Total Monthly	< 697	< 646	< 613	< 657	< 670	< 586	< 753	< 488	< 471	< 1220	< 328	< 195
Total Nitrogen (lbs) Total Monthly	< 697	< 646	< 613	< 657	< 670	< 586	< 753	< 488	< 471	< 1220	< 328	< 195
Total Nitrogen (lbs) Effluent Net   Total Annual										< 7040		
Total Nitrogen (lbs) Total Annual										< 7040		
Ammonia (lbs/day) Average Monthly	< 0.2	< 0.2	< 0.8	< 0.2	< 0.2	< 0.2	< 0.4	< 0.3	< 0.2	< 0.6	< 0.3	< 0.3
Ammonia (mg/L) Average Monthly	< 0.0475	< 0.0475	< 0.2082	< 0.0475	< 0.0475	< 0.0592	< 0.1	< 0.1	< 0.1	< 0.123	< 0.12	< 0.112

**NPDES Permit Fact Sheet  
Freedom Township STP**

**NPDES Permit No. PA0110361**

Ammonia (lbs) Total Monthly	< 5	< 7	< 24	< 5	< 6	< 7	< 12	< 8	< 8	< 19	< 328	< 9
Ammonia (lbs) Total Annual										< 139		
TKN (mg/L) Average Monthly	< 0.523	< 0.627	< 0.788	< 0.571	< 0.688	< 0.594	< 0.5	< 0.704	< 0.706	< 0.529	< 0.639	< 0.5
TKN (lbs) Total Monthly	< 53	< 89	< 96	< 62	< 86	< 2	< 61	< 53	< 54	< 104	< 47	< 42
Total Phosphorus (mg/L) Average Monthly	3.96	2.086	2.04	2.24	2.13	2.06	2.76	2.62	3.48	2.99	3.59	2.48
Total Phosphorus (lbs) Effluent Net   Total Monthly	412	256	279	240	247	212	275	197	266	498	272	207
Total Phosphorus (lbs) Total Monthly	412	256	279	240	247	212	275	197	266	498	272	207
Total Phosphorus (lbs) Effluent Net   Total Annual										1453		
Total Phosphorus (lbs) Total Annual										1453		
UV Dosage (mjoules/cm²) Minimum	300	240	300	300	300	300	300	300	300	300	300	300

### 3.2.1 Chesapeake Bay Truing

The table summarizes the facility's compliance/noncompliance with Chesapeake Bay cap loads. The facility did not meet their cap loads in 2019 for phosphorus.

The facility was in violation with the phosphorus cap load in 2019.

Chesapeake Bay Annual Nutrient Summary								
Freedom Township WWTP								
PA0110361								
Year for Truing Period (Oct 1 - Sept 30)	Nitrogen (lbs)			Phosphorus (lbs)			Compliant with Permit Limits (Yes/No)	
	Annual Total Mass	Credits Purchased	Net Mass Load	Annual Total Mass	Credits Purchased	Net Mass Load	Nitrogen	Phosphorus
			10,959			1,461		
2017	11585	626	10,959	1,817	358	1,459	Yes	Yes
2018	10516	0	10,516	2,517	1,057	1,460	Yes	Yes
2019	8758	0	8,758	1,902	0	1,902	Yes	No
2020	6239	0	6,239	2,011	576	1,435	Yes	Yes

### 3.3 Non-Compliance

#### 3.3.1 Non-Compliance- NPDES Effluent

A summary of the non-compliance to the permit limits for the existing permit cycle is as follows.

From the DMR data beginning in February 1, 2017 to August 23, 2022, the following were observed effluent non-compliances.

NON_COMPLIANCE_DATE	NON_COMPL_TYPE_DESC	NON_COMPL_CATEGORY_DESC	PARAMETER	SAMPLE_VALUE	VIOLATION_CONDITION	PERMIT_VALUE	UNIT_OF_MEASURE	STAT_BASE_CODE	DISCHARGE_COMMENTS	FACILITY_COMMENTS
6/21/2017		Unauthorized Discharges								
8/22/2017	Violation of permit condition	Effluent	Carbonaceous Biochemical Oxygen Demand (CBOD5)	53	>	40	mg/L	Weekly Average		It is unknown why my CBOD was out of compliance for the week of 07/02/2017. There was no process changes, no equipment failure, no high flows and I also contacted Fairway Labs to confirm the test results. All results for the following weeks were back to normal. We will continue to monitor all test results.
3/23/2018		Unauthorized Discharges							Pump Failure	
2/20/2019	Violation of permit condition	Effluent	total Suspended Solid	463	>	364	lbs/day	Weekly Average		
2/20/2019	Violation of permit condition	Effluent	total Suspended Solid	56.0	>	45.0	mg/L	Weekly Average		
8/26/2019	Violation of permit condition	Effluent	Fecal Coliform	2419.6	>	1000	No./100 ml	Instantaneous Maximum		Power outage occurred during time of sampling. When the outage was discovered the system was reset and came back up full operation. We did a grab sample on 7/31/19 for a follow up and the sample result came back normal.
7/30/2020	Late DMR Submission	Other Violations								

#### 3.3.2 Non-Compliance- Enforcement Actions

A summary of the non-compliance enforcement actions for the current permit cycle is as follows:

Beginning in February 1, 2017 to August 23, 2022, there were no observed enforcement actions.

### **3.4 Summary of Biosolids Disposal**

A summary of the biosolids disposed of from the facility is as follows.

2021						
Sewage Sludge / Biosolids Production Information						
Hauled Off-Site						
2021	Gallons	% Solids	Dry Tons	Tons Dewatered	% Solids	Dry Tons
January						
February						
March				16.23	10.42	1.69
April	31,024	1.7	2.199			
May	110,501		7.833			
June						
July						
August						
September	16,050	1.9	1.272			
October	21,965	1.8	1.649			
November	143,385	1.8	10.762			
December						
Notes:						
Sewage sludge/biosolids disposed at						
- Laurel Highlands Landfill in Johnstown Township, Cambria County						
- Gary Stiffler Farm in Freedom Township, Blair County						
- Frank Musselman Farm in Freedom/Greenfield Township in Blair County						

### **3.5 Open Violations**

No open violations existed as of September 2022.

### **4.0 Receiving Waters and Water Supply Information Detail Summary**

#### **4.1 Receiving Waters**

The receiving waters has been determined to be Frankstown Branch Juniata River. The sequence of receiving streams that the Frankstown Branch Juniata River discharges into are Juniata River and the Susquehanna River which eventually drains into the Chesapeake Bay.

#### **4.2 Public Water Supply (PWS) Intake**

The closest PWS to the subject facility is Mifflintown Municipal Authority (PWS ID #4340008) located approximately 103 miles downstream of the subject facility on the Juniata River. Based upon the distance and the flow rate of the facility, the PWS should not be impacted.

#### **4.3 Class A Wild Trout Streams**

Class A Wild Trout Streams are waters that support a population of naturally produced trout of sufficient size and abundance to support long-term and rewarding sport fishery. DEP classifies these waters as high-quality coldwater fisheries.

The information obtained from EMAP suggests that no Class A Wild Trout Fishery will be impacted by this discharge.

#### **4.4 2022 Integrated List of All Waters (303d Listed Streams)**

Section 303(d) of the Clean Water Act requires States to list all impaired surface waters not supporting uses even after appropriate and required water pollution control technologies have been applied. The 303(d) list includes the reason for impairment which may be one or more point sources (i.e. industrial or sewage discharges) or non-point sources (i.e. abandoned mine lands or agricultural runoff and the pollutant causing the impairment such as metals, pH, mercury or siltation).

States or the U.S. Environmental Protection Agency (EPA) must determine the conditions that would return the water to a condition that meets water quality standards. As a follow-up to listing, the state or EPA must develop a Total Maximum Daily Load (TMDL) for each waterbody on the list. A TMDL identifies allowable pollutant loads to a waterbody from both point and non-point sources that will prevent a violation of water quality standards. A TMDL also includes a margin of safety to ensure protection of the water.

The water quality status of Pennsylvania's waters uses a five-part categorization (lists) of waters per their attainment use status. The categories represent varying levels of attainment, ranging from Category 1, where all designated water uses are met to Category 5 where impairment by pollutants requires a TMDL for water quality protection.

**For Outfall 001, the receiving waters is listed in the 2022 Pennsylvania Integrated Water Quality Monitoring and Assessment Report as a Category 2 waterbody. The surface waters is an attaining stream that supports aquatic life and fish consumption. The designated use has been classified as protected waters for trout stocking fishes (TSF) and migratory fishes (MF).**

**Since Outfall 002 is used for emergency purposes, this Fact Sheet does not detail the classification on the Outfall 002 for the 2022 Pennsylvania Integrated Water Quality Monitoring and Assessment Report.**

#### **4.5 Low Flow Stream Conditions**

Water quality modeling estimates are based upon conservative data inputs. The data are typically estimated using either a stream gauge or through USGS web based StreamStats program. The NPDES effluent limits are based upon the combined flows from both the stream and the facility discharge.

A conservative approach to estimate the impact of the facility discharge using values which minimize the total combined volume of the stream and the facility discharge. The volumetric flow rate for the stream is based upon the seven-day, 10-year low flow (Q710) which is the lowest estimated flow rate of the stream during a 7 consecutive day period that occurs once in 10 -year time period. The facility discharge is based upon a known design capacity of the subject facility.

The closest WQN station to the subject facility is the Frankstown Branch Juniata station (WQN224). This WQN station is located approximately 22 miles downstream of the subject facility.

The closest gauge station to the subject facility is the Frankstown Branch Juniata River at Williamsburg, PA (USGS station number 1556000). This gauge station is located approximately 20 miles downstream of the subject facility.

For WQM modeling, pH and stream water temperature data from the water quality network station was used. pH was estimated to be 7.84 and the stream water temperature was estimated to be 22 C.

The hardness of the stream was estimated from the water quality network to be 135 mg/l CaCO<sub>3</sub>.



For Outfall 001, the low flow yield and the Q710 for the subject facility was estimated as shown below.

Gauge Station Data		
USGS Station Number	1556000	
Station Name	Frankstown Branch Juniata River at Williamsburg, PA	
Q710	47.8	ft <sup>3</sup> /sec
Drainage Area (DA)	291	mi <sup>2</sup>
<b>Calculations</b>		
The low flow yield of the gauge station is:		
Low Flow Yield (LFY) = Q710 / DA		
LFY = ( 47.8 ft <sup>3</sup> /sec / 291 mi <sup>2</sup> )		
LFY =	0.1643	ft <sup>3</sup> /sec/mi <sup>2</sup>
The low flow at the subject site is based upon the DA of		
	55.5	mi <sup>2</sup>
Q710 = (LFY@gauge station)(DA@Subject Site)		
Q710 = (0.1643 ft <sup>3</sup> /sec/mi <sup>2</sup> )(55.5 mi <sup>2</sup> )		
Q710 =	9.116	ft <sup>3</sup> /sec

For Outfall 002, the low flow yield and the Q710 for the subject facility was estimated as shown below.

Gauge Station Data		
USGS Station Number	1556000	
Station Name	Frankstown Branch Juniata River at Williamsburg, PA	
Q710	47.8	
Drainage Area (DA)	291	
<b>Calculations</b>		
The low flow yield of the gauge station is:		
Low Flow Yield (LFY) = Q710 / DA		
LFY = ( 47.8 ft <sup>3</sup> /sec / 291 mi <sup>2</sup> )		
LFY =	0.1643	ft <sup>3</sup> /sec/mi <sup>2</sup>
The low flow at the subject site is based upon the DA of		0.38 mi <sup>2</sup>
Q710 = (LFY@gauge station)(DA@Subject Site)		
Q710 = (0.1643 ft <sup>3</sup> /sec/mi <sup>2</sup> )(0.38 mi <sup>2</sup> )		
Q710 =	0.062	ft <sup>3</sup> /sec

For Outfall 002, the rationale for development of effluent limits shall continue as described by the Fact Sheet dated from August 2017.

For a discharge of 0.97 MGD, the ratio of Q7-10 to discharge is 1 to 24. DEP requires compliance with advance treatment limitations recommended in DEP's *Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers* (391-2000-014) whenever the ratio of Q7-10 to discharge is less than 3 parts stream flow (Q7-10) to 1 part effluent discharge flow.

The permittee is required to comply with the following advance treatment requirements:

- CBOD5 - 10 mg/L as a monthly average;
- TSS - 10 mg/L as a monthly average;
- Total N - 5 mg/L as a monthly average;
- Dissolved oxygen - minimum 6 mg/L at all times;
- Phosphorus – 0.5 mg/L as a monthly average.

**4.6.1 Summary of Discharge, Receiving Waters and Water Supply Information**

Outfall No.	<u>001</u>	Design Flow (MGD)	<u>.97</u>
Latitude	<u>40° 22' 33.99"</u>	Longitude	<u>-78° 25' 33.68"</u>
Quad Name	<u></u>	Quad Code	<u></u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Frankstown Branch Juniata River (TSF, MF)</u>	Stream Code	<u>16061</u>
NHD Com ID	<u></u>	RMI	<u>39.63</u>
Drainage Area	<u>55.5</u>	Yield (cfs/mi <sup>2</sup> )	<u>0.1643</u>
Q <sub>7-10</sub> Flow (cfs)	<u>9.116</u>	Q <sub>7-10</sub> Basis	<u>StreamStats/Streamgauge</u>
Elevation (ft)	<u>987</u>	Slope (ft/ft)	<u></u>
Watershed No.	<u>11-A</u>	Chapter 93 Class.	<u>TSF, MF</u>
Existing Use	<u>Same as Chapter 93 class</u>	Existing Use Qualifier	<u></u>
Exceptions to Use	<u></u>	Exceptions to Criteria	<u></u>
Assessment Status	<u>Attaining Use(s) for aquatic life/fish consumption</u>		
Cause(s) of Impairment	<u>Not applicable</u>		
Source(s) of Impairment	<u>Not applicable</u>		
TMDL Status	<u>Not applicable</u>	Name	<u></u>
Background/Ambient Data		Data Source	
pH (SU)	<u>7.84</u>	<u>WQN224; median July to Sept</u>	
Temperature (°C)	<u>22</u>	<u>WQN224; median July to Sept</u>	
Hardness (mg/L)	<u>135</u>	<u>WQN224; historical median</u>	
Other:	<u></u>	<u></u>	
Nearest Downstream Public Water Supply Intake		<u>Mifflintown MA</u>	
PWS Waters	<u>Juniata River</u>	Flow at Intake (cfs)	<u></u>
PWS RMI	<u>37</u>	Distance from Outfall (mi)	<u>103</u>

**4.6.2 Summary of Discharge, Receiving Waters and Water Supply Information**

Outfall No.	<u>002</u>	Design Flow (MGD)	<u>.97</u>
Latitude	<u>40° 22' 32.51"</u>	Longitude	<u>-78° 25' 37.35"</u>
Quad Name	<u></u>	Quad Code	<u></u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Tributary 16564 To McDonald Run</u>	Stream Code	<u>16564</u>
NHD Com ID	<u>65609644</u>	RMI	<u>0.0300</u>
Drainage Area	<u>0.38</u>	Yield (cfs/mi <sup>2</sup> )	<u>0.1643</u>
Q <sub>7-10</sub> Flow (cfs)	<u>0.062</u>	Q <sub>7-10</sub> Basis	<u>StreamStats/streamgauge</u>
Elevation (ft)	<u>992</u>	Slope (ft/ft)	<u></u>
Watershed No.	<u>11-A</u>	Chapter 93 Class.	<u>WWF, MF</u>
Existing Use	<u>Same as Chapter 93 class</u>	Existing Use Qualifier	<u></u>
Exceptions to Use	<u></u>	Exceptions to Criteria	<u></u>
Assessment Status	<u>Attaining Use(s)</u>		
Cause(s) of Impairment	<u>Not applicable</u>		
Source(s) of Impairment	<u>Not applicable</u>		
TMDL Status	<u>Not applicable</u>	Name	<u></u>
Background/Ambient Data		Data Source	
pH (SU)	<u>7.84</u>		<u>WQN224; median July to Sept</u>
Temperature (°C)	<u>22</u>		<u>WQN224; median July to Sept</u>
Hardness (mg/L)	<u>135</u>		<u>WQN224; historical median</u>
Other:	<u></u>		<u></u>
Nearest Downstream Public Water Supply Intake	<u>Mifflintown MA</u>		
PWS Waters	<u>Juniata River</u>	Flow at Intake (cfs)	<u></u>
PWS RMI	<u>37</u>	Distance from Outfall (mi)	<u>103</u>

## **5.0: Overview of Presiding Water Quality Standards**

### **5.1 General**

There are at least six (6) different policies which determines the effluent performance limits for the NPDES permit. The policies are technology based effluent limits (TBEL), water quality based effluent limits (WQBEL), antidegradation, total maximum daily loading (TMDL), anti-backsliding, and whole effluent toxicity (WET). The effluent performance limitations enforced are the selected permit limits that is most protective to the designated use of the receiving waters. An overview of each of the policies that are applicable to the subject facility has been presented in Section 6.

#### **5.2.1 Technology-Based Limitations**

TBEL treatment requirements under section 301(b) of the Act represent the minimum level of control that must be imposed in a permit issued under section 402 of the Act (40 CFR 125.3). Available TBEL requirements for the state of Pennsylvania are itemized in PA Code 25, Chapter 92a.47.

The presiding sources for the basis for the effluent limitations are governed by either federal or state regulation. The reference sources for each of the parameters is itemized in the tables. The following technology-based limitations apply, subject to water quality analysis and best professional judgement (BPJ) where applicable:

Parameter	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

#### **5.2.2 Mass Based Limits**

For publicly owned treatment works (POTW), mass loadings are calculated based upon design flow rate of the facility and the permit limit concentration. The generalized calculation for mass loadings is shown below:

$$Quantity \left( \frac{lb}{day} \right) = (MGD)(Concentration)(8.34)$$

### **5.3 Water Quality-Based Limitations**

WQBEL are based on the need to attain or maintain the water quality criteria and to assure protection of designated and existing uses (PA Code 25, Chapter 92a.2). The subject facility that is typically enforced is the more stringent limit of either the TBEL or the WQBEL.

Determination of WQBEL is calculated by spreadsheet analysis or by a computer modeling program developed by DEP. DEP permit engineers utilize the following computing programs for WQBEL permit limitations: (1) MS Excel worksheet for Total Residual Chlorine (TRC); (2) WQM 7.0 for Windows Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen Version 1.1 (WQM Model) and (3) Toxics using DEP Toxics Management Spreadsheet for Toxics pollutants.

The modeling point nodes utilized for this facility are summarized below.

Nodes for Outfall 001							
<i>Parameter</i>	<i>Modeling Point #1 Furthest Point Downstream</i>	<i>Modeling Point #2 Hollidaysburg</i>	<i>Modeling Point #3 Formerly Appvion</i>	<i>Modeling Point #4 Freedom</i>	<i>Modeling Point #5 Roaring Springs</i>	<i>Modeling Point #6 Greenfield</i>	<i>Units</i>
Stream Code	16061	16061	16061	39.74	16061	16061	
River Mile Index	32.23	33.3	39.09	16061	41.91	45.3	miles
Elevation	911	913	974	987	1009	1096	feet
Latitude	40.443959	40.43024	40.378966	40.376269	40.354737	40.311424	
Longitude	-78.35364	-78.360807	-78.415911	-78.426339	-78.427562	-78.443612	
Drainage Area	215	116	90.7	55.5	47.1	37.1	sq miles
Low Flow Yield	0.1643	0.1643	0.1643	0.1643	0.1643	0.1643	cfs/sq mile

Nodes for Outfall 002			
<i>General Data 1</i>	<i>Modeling Point #1</i>	<i>Modeling Point #2</i>	<i>Units</i>
Stream Code	16564	16564	
River Mile Index	0.08	0	miles
Elevation	992	987	feet
Latitude	40.376236	40.377164	
Longitude	-78.427142	-78.4263	
Drainage Area	0.38	55.5	sq miles
Low Flow Yield	0.1643	0.1643	cfs/sq mile

### 5.3.1 Water Quality Modeling 7.0

The WQM Model is a computer model that is used to determine NPDES discharge effluent limitations for Carbonaceous BOD (CBOD5), Ammonia Nitrogen (NH<sub>3</sub>-N), and Dissolved Oxygen (DO) for single and multiple point source discharges scenarios. WQM Model is a complete-mix model which means that the discharge flow and the stream flow are assumed to instantly and completely mixed at the discharge node.

WQM recommends effluent limits for DO, CBOD5, and NH<sub>3</sub>-N in mg/l for the discharge(s) in the simulation.

Four types of limits may be recommended. The limits are

- (a) a minimum concentration for DO in the discharge as 30-day average;
- (b) a 30-day average concentration for CBOD5 in the discharge;
- (c) a 30-day average concentration for the NH<sub>3</sub>-N in the discharge;
- (d) 24-hour average concentration for NH<sub>3</sub>-N in the discharge.

The WQM Model requires several input values for calculating output values. The source of data originates from either EMAP, the National Map, or Stream Stats. Data for stream gauge information, if any, was abstracted from USGS Low-Flow, Base-Flow, and Mean-Flow Regression Equations for Pennsylvania Streams authored by Marla H. Stuckey (Scientific Investigations Report 2006-5130).

The applicable WQM Effluent Limit Type are discussed in Section 6 under the corresponding parameter which is either DO, CBOD, or ammonia-nitrogen.



### **5.3.2 Toxics Modeling**

The Toxics Management Spreadsheet model is a computer model that is used to determine effluent limitations for toxics (and other substances) for single discharge wasteload allocations. This computer model uses a mass-balance water quality analysis that includes consideration for mixing, first-order decay, and other factors used to determine recommended water quality-based effluent limits. Toxics Management Spreadsheet does not assume that all discharges completely mix with the stream. The point of compliance with water quality criteria are established using criteria compliance times (CCTs). The available CCTs are either acute fish criterion (AFC), chronic fish criterion (CFC), or human health criteria (THH & CRL).

**Acute Fish Criterion (AFC)** measures the criteria compliance time as either the maximum criteria compliance time (i.e. 15 minutes travel time downstream of the current discharge) or the complete mix time whichever comes first. AFC is evaluated at Q710 conditions.

**Chronic Fish Criterion (CFC)** measures the criteria compliance time as either the maximum criteria compliance time (i.e. 12 hours travel time downstream of the current discharge) or the complete mix time whichever comes first. CFC is evaluated at Q710 conditions.

**Threshold Human Health (THH)** measures the criteria compliance time as either the maximum criteria compliance time (i.e. 12 hours travel time downstream of the current discharge) or the estimated travel time downstream to the nearest potable water supply intake whichever comes first. THH is evaluated at Q710 conditions.

**Cancer Risk Level (CRL)** measures the criteria compliance time as either the maximum criteria compliance time (i.e. 12 hours travel time downstream of the current discharge) or the complete mix time whichever comes first. CRL is evaluated at Qh (harmonic mean or normal flow) conditions.

The Toxics Model requires several input values for calculating output values. The source of data originates from either EMAP, the National Map, or Stream Stats. Data for stream gauge information, if any, was abstracted from USGS Low-Flow, Base-Flow, and Mean-Flow Regression Equations for Pennsylvania Streams authored by Marla H. Stuckey (Scientific Investigations Report 2006-5130).

#### **5.3.2.1 Determining if NPDES Permit Will Require Monitoring/Limits in the Proposed Permit for Toxic Pollutants**

To determine if Toxics modeling is necessary, DEP has developed a Toxics Management Spreadsheet to identify toxics of concern. Toxic pollutants whose maximum concentrations as reported in the permit application or on DMRs are greater than the most stringent applicable water quality criterion are pollutants of concern. A Reasonable Potential Analysis was utilized to determine (a) if the toxic parameters modeled would require monitoring or (b) if permit limitations would be required for the parameters. The toxics reviewed for reasonable potential were the following pollutants: TDS, chloride, bromide, sulfate, total copper, total lead, and total zinc.

Based upon the SOP- Establishing Water Quality-Based Effluent Limitations (WQBELs) and Permit Conditions for Toxic Pollutants (Revised January 10, 2019), monitoring and/or limits will be established as follows.

- (a) When reasonable potential is demonstrated, establish limits where the maximum reported concentration equals or exceeds 50% of the WQBEL.
- (b) For non-conservative pollutants, establish monitoring requirements where the maximum reported concentration is between 25% - 50% of the WQBEL.
- (c) For conservative pollutants, establish monitoring requirements where the maximum reported concentration is between 10% - 50% of the WQBEL.

**Applicable monitoring or permit limits for toxics are summarized in Section 6.**

**The Toxics Management Spreadsheet output has been included in Attachment B.**

### **5.3.3 Whole Effluent Toxicity (WET)**

The facility is not subject to WET.

## **5.4 Total Maximum Daily Loading (TMDL)**

### **5.4.1 TMDL**

The goal of the Clean Water Act (CWA), which governs water pollution, is to ensure that all of the Nation's waters are clean and healthy enough to support aquatic life and recreation. To achieve this goal, the CWA created programs designed to regulate and reduce the amount of pollution entering United States waters. Section 303(d) of the CWA requires states to assess their waterbodies to identify those not meeting water quality standards. If a waterbody is not meeting standards, it is listed as impaired and reported to the U.S. Environmental Protection Agency. The state then develops a plan to clean up the impaired waterbody. This plan includes the development of a Total Maximum Daily Load (TMDL) for the pollutant(s) that were found to be the cause of the water quality violations. A Total Maximum Daily Load (TMDL) calculates the maximum amount of a specific pollutant that a waterbody can receive and still meet water quality standards.

A TMDL for a given pollutant and waterbody is composed of the sum of individual wasteload allocations (WLAs) for point sources and load allocations (LAs) for nonpoint sources and natural background levels. In addition, the TMDL must include an implicit or explicit margin of safety (MOS) to account for the uncertainty in the relationship between pollutant loads and the quality of the receiving waterbody. The TMDL components are illustrated using the following equation:

$$\text{TMDL} = \Sigma \text{WLAs} + \Sigma \text{LAs} + \text{MOS}$$

Pennsylvania has committed to restoring all impaired waters by developing TMDLs and TMDL alternatives for all impaired waterbodies. The TMDL serves as the starting point or planning tool for restoring water quality.

#### **5.4.1.1 Local TMDL**

The subject facility does not discharge into a local TMDL.

#### **5.4.1.2 Chesapeake Bay TMDL Requirement**

The Chesapeake Bay Watershed is a large ecosystem that encompasses approximately 64,000 square miles in Maryland, Delaware, Virginia, West Virginia, Pennsylvania, New York and the District of Columbia. An ecosystem is composed of interrelated parts that interact with each other to form a whole. All of the plants and animals in an ecosystem depend on each other in some way. Every living thing needs a healthy ecosystem to survive. Human activities affect the Chesapeake Bay ecosystem by adding pollution, using resources and changing the character of the land.

Most of the Chesapeake Bay and many of its tidal tributaries have been listed as impaired under Section 303(d) of the federal Water Pollution Control Act ("Clean Water Act"), 33 U.S.C. § 1313(d). While the Chesapeake Bay is outside the boundaries of Pennsylvania, more than half of the State lies within the watershed. Two major rivers in Pennsylvania are part of the Chesapeake Bay Watershed. They are (a) the Susquehanna River and (b) the Potomac River. These two rivers total 40 percent of the entire Chesapeake Bay watershed.

The overall management approach needed for reducing nitrogen, phosphorus and sediment are provided in the Bay TMDL document and the Phase I, II, and III WIPs which is described in the Bay TMDL document and Executive Order 13508.

The Bay TMDL is a comprehensive pollution reduction effort in the Chesapeake Bay watershed identifying the necessary pollution reductions of nitrogen, phosphorus and sediment across the seven Bay watershed jurisdictions of Delaware, Maryland, New York, Pennsylvania, Virginia, West Virginia and the District of Columbia to meet applicable water quality standards in the Bay and its tidal waters.

The Watershed Implementation Plans (WIPs) provides objectives for how the jurisdictions in partnership with federal and local governments will achieve the Bay TMDL's nutrient and sediment allocations.

Phase 3 WIP provides an update on Chesapeake Bay TMDL implementation activities for point sources and DEP's current implementation strategy for wastewater. The latest revision of the supplement was September 13, 2021.

The Chesapeake Bay TMDL (Appendix Q) categorizes point sources into four sectors:

- Sector A- significant sewage dischargers;
- Sector B- significant industrial waste (IW) dischargers;
- Sector C- non-significant dischargers (both sewage and IW facilities); and

- Sector D- combined sewer overflows (CSOs).

All sectors contain a listing of individual facilities with NPDES permits that were believed to be discharging at the time the TMDL was published (2010). All sectors with the exception of the non-significant dischargers have individual wasteload allocations (WLAs) for TN and TP assigned to specific facilities. Non-significant dischargers have a bulk or aggregate allocation for TN and TP based on the facilities in that sector that were believed to be discharging at that time and their estimated nutrient loads.

Cap Loads will be established in permits as Net Annual TN and TP loads (lbs/yr) that apply during the period of October 1 – September 30. For facilities that have received Cap Loads in any other form, the Cap Loads will be modified accordingly when the permits are renewed.

Offsets have been incorporated into Cap Loads in several permits issued to date. From this point forward, permits will be issued with the WLAs as Cap Loads and will identify Offsets separately to facilitate nutrient trading activities and compliance with the TMDL.

**Based upon the supplement the subject facility has been categorized as a Sector A discharger. The supplement defines Sector A as a sewage facility is considered significant if it has a design flow of at least 0.4 MGD.**

Table 5 of the Phase 3 WIP (revised September 13, 2021) presents all NPDES permits for Significant Sewage dischargers with Cap Loads. The NPDES Permit No., phase, facility name, latest permit issuance date, expiration date, Cap Load compliance start date, TN and TP Cap Loads, and TN and TP Delivery Ratios are presented. In addition, if TN Offsets were incorporated into the TN Cap Loads when the permit was issued, the amount is shown; these Offsets will be removed from Cap Loads upon issuance of renewed permits to implement Section IV of this document (i.e., a facility may use Offsets for compliance but may not register them as credits).

The total nitrogen (TN) and total phosphorus (TP) cap loads itemized by Table 5 for the subject facility are as follows:

TN Cap Load (lbs/yr)	10,959
TN Delivery Ratio	0.763
TP Cap Load (lbs/yr)	1,461
TP Delivery Ratio	0.519

Expansions by any Significant Sewage discharger will not result in any increase in Cap Loads. Where non-significant facilities expand to a design flow of 0.4 MGD or greater, the lesser of baseline Cap Loads of 7,306 lbs/yr TN and 974 lbs/yr TP or existing performance will be used for permits, and the load will be moved from the Non-Significant sector load to the Significant Sewage sector load. If considered necessary for environmental protection, DEP may decide to move load from the Point Source Reserve to the Significant Sewage sector in the future.

The minimum monitoring frequency for TN species and TP in new or renewed NPDES permits for Significant Sewage dischargers is 2/week.

This facility is subject to Sector A monitoring requirements. Monitoring shall be required at least 2x/week.

#### *Reporting*

Cap Loads will be established in permits as Net Annual TN and TP loads (lbs/yr) that apply during the period of October 1 – September 30.

Facilities with NPDES permits must use DEP's eDMR system for reporting, except small flow treatment facilities. An Annual DMR must be submitted by the end of the Truing Period, November 28. As attachments to the Annual DMR a facility must submit a completed Annual Chesapeake Bay Spreadsheet, available through DEP's Supplemental Reports website, which contains an Annual Nutrient Monitoring worksheet and an Annual Nutrient Budget worksheet. This Spreadsheet will be submitted once per Compliance Year only, and reflect all nutrient sample results (for the period October 1 – September 30), Credit transactions (including the Truing Period) and Offsets applied during the Compliance Year.

### **5.5 Anti-Degradation Requirement**

Chapter 93.4a of the PA regulations requires that surface water of the Commonwealth of Pennsylvania may not be degraded below levels that protect the existing uses. The regulations specifically state that *Existing instream water uses and the level of water quality necessary to protect the existing uses shall be maintained and protected*. Antidegradation requirements are implemented through DEP's guidance manual entitled Water Quality Antidegradation Implementation Guidance (Document #391-0300-02).

The policy requires DEP to protect the existing uses of all surface waters and the existing quality of High Quality (HQ) and Exceptional Value (EV) Waters. Existing uses are protected when DEP makes a final decision on any permit or approval for an activity that may affect a protected use. Existing uses are protected based upon DEP's evaluation of the best available information (which satisfies DEP protocols and Quality Assurance/Quality Control (QA/QC) procedures) that indicates the protected use of the waterbody.

For a new, additional, or increased point source discharge to an HQ or EV water, the person proposing the discharge is required to utilize a nondischarge alternative that is cost-effective and environmentally sound when compared with the cost of the proposed discharge. If a nondischarge alternative is not cost-effective and environmentally sound, the person must use the best available combination of treatment, pollution prevention, and wastewater reuse technologies and assure that any discharge is nondegrading. In the case of HQ waters, DEP may find that after satisfaction of intergovernmental coordination and public participation requirements lower water quality is necessary to accommodate important economic or social development in the area in which the waters are located. In addition, DEP will assure that cost-effective and reasonable best management practices for nonpoint source control in HQ and EV waters are achieved.

**The subject facility's discharge will be to a non-special protection waters and the permit conditions are imposed to protect existing instream water quality and uses. Neither HQ waters or EV waters is impacted by this discharge.**

### **5.6 Anti-Backsliding**

Anti-backsliding is a federal regulation which prohibits a permit from being renewed, reissued, or modified containing effluent limitations which are less stringent than the comparable effluent limitations in the previous permit (40 CFR 122.I.1 and 40 CFR 122.I.2). A review of the existing permit limitations with the proposed permit limitations confirm that the facility is consistent with anti-backsliding requirements. The facility has proposed effluent limitations that are as stringent as the existing permit.

## **6.0 NPDES Parameter Details**

The basis for the proposed sampling and their monitoring frequency that will appear in the permit for each individual parameter are itemized in this Section. The final limits are the more stringent of technology based effluent treatment (TBEL) requirements, water quality based (WQBEL) limits, TMDL, antidegradation, anti-degradation, or WET.

The reader will find in this section:

- a) a justification of recommended permit monitoring requirements and limitations for each parameter in the proposed NPDES permit;
- b) a summary of changes from the existing NPDES permit to the proposed permit; and
- c) a summary of the proposed NPDES effluent limits.

### **6.1 Recommended Monitoring Requirements and Effluent Limitations**

A summary of the recommended monitoring requirements and effluent limitations are itemized in the tables. The tables are categorized by (a) Conventional Pollutants and Disinfection, (b) Nitrogen Species and Phosphorus, and (c) Toxics.

### 6.1.1 Outfall 001- Conventional Pollutants and Disinfection

Summary of Proposed NPDES Parameter Details for Conventional Pollutants and Disinfection Freedom Township WWTP; PA0110361; Outfall 001			
Parameter	Permit Limitation Required by <sup>1</sup> :	Recommendation	
pH (S.U.)	TBEL	Monitoring:	The monitoring frequency shall be daily as a grab sample (Table 6-3).
		Effluent Limit:	Effluent limits may range from pH = 6.0 to 9.0
		Rationale:	The monitoring frequency has been assigned in accordance with Table 6-3 and the effluent limits assigned by Chapter 95.2(1).
Dissolved Oxygen	BPJ	Monitoring:	The monitoring frequency shall be daily as a grab sample (Table 6-3).
		Effluent Limit:	Effluent limits shall be greater than 5.0 mg/l.
		Rationale:	The monitoring frequency has been assigned in accordance with Table 6-3 and the effluent limits assigned by best professional judgement.
CBOD	WQBEL/Anti-backsliding	Monitoring:	The monitoring frequency shall be 1x/wk as 24-hr composite sample (Table 6-3).
		Effluent Limit:	During the months of November 1 to April 30, effluent limits shall not exceed 162 lbs/day and 20 mg/l as an average monthly. During the months of May 1 to October 31, effluent limits shall not exceed 202 lbs/day and 25 mg/l as an average monthly.
		Rationale:	The monitoring frequency has been assigned in accordance with Table 6-3. WQM modeling indicates that the WQBEL is more stringent than the TBEL. Thus, the permit limit is confined to WQBEL. Due to anti-backsliding the current permit limits shall continue the proposed permit.
TSS	TBEL	Monitoring:	The monitoring frequency shall be 1x/wk as 24-hr composite sample (Table 6-3).
		Effluent Limit:	Effluent limits shall not exceed 243 lbs/day and 30 mg/l as an average monthly.
		Rationale:	The monitoring frequency has been assigned in accordance with Table 6-3 and the effluent limits assigned by Chapter 92a.47(a)(1). While there is no WQM modeling for this parameter, the permit limit for TSS is generally assigned similar effluent limits as CBOD or BOD. Since the TBEL is more stringent than WQBEL, TBEL will apply.
UV disinfection	SOP	Monitoring:	The monitoring frequency is 1/day. The facility will be required to record the UV dosage.
		Effluent Limit:	No effluent requirements.
		Rationale:	Consistent with the SOP- Establishing Effluent Limitations for Individual Sewage Permits (Revised January 10, 2019), the facility will be required to have routine monitoring for UV transmittance, UV dosage, or UV intensity.
Fecal Coliform	TBEL	Monitoring:	The monitoring frequency shall be 1x/wk as a grab sample (Table 6-3).
		Effluent Limit:	Summer effluent limits shall not exceed 200 No./100 mL as a geometric mean. Winter effluent limits shall not exceed 2000 No./100 mL as a geometric mean.
		Rationale:	The monitoring frequency has been assigned in accordance with Table 6-3 and the effluent limits assigned by Chapter 92a.47(a)(4) and 92a.47(a)(5).
E. Coli	SOP; Chapter 92a.61	Monitoring:	The monitoring frequency shall be 1x/quarter as a grab sample (SOP).
		Effluent Limit:	No effluent requirements.
		Rationale:	Consistent with the SOP- Establishing Effluent Limitations for Individual Sewage Permits (Revised March 22, 2019) and under the authority of Chapter 92a.61, the facility will be required to monitor for E.Coli.

**Notes:**

1 The NPDES permit was limited by (a) anti-Backsliding, (b) Anti-Degradation, (c) SOP, (d) TBEL, (e) TMDL, (f) WQBEL, (g) WET, or (h) Other

2 Monitoring frequency based on flow rate of 0.97 MGD.

3 Table 6-3 (Self Monitoring Requirements for Sewage Discharges) in Technical Guidance for the Development and Specification of Effluent Limitations and Other Permit Conditions in NPDES Permits (Document # 362-0400-001) Revised 10/97

4 Water Quality Antidegradation Implementaton Guidance (Document # 391-0300-002)

5 Chesapeake Bay Phase 3 Watershed Implementation Plan Wastewater Supplement, Revised September 13, 2021

### 6.1.2 Outfall 001- Nitrogen Species and Phosphorus

Summary of Proposed NPDES Parameter Details for Nitrogen Species and Phosphorus			
Freedom Township WWTP; PA0110361; Outfall 001			
Parameter	Permit Limitation Required by <sup>1</sup> :	Recommendation	
Ammonia-Nitrogen	WQBEL	Monitoring:	The monitoring frequency shall be 2x/wk as a 24-hr composite sample
		Effluent Limit:	During the months of November 1 to April 30, effluent limits shall not exceed 145 lbs/day and 18 mg/l as an average monthly. During the months of May 1 to October 31, effluent limits shall not exceed 49 lbs/day and 6.0 mg/l as an average monthly.
		Rationale:	Modeling recommends water quality based effluent limits. Modeling resulted in a limit of 6.34 mg/l in the summer. Mathematical rounding places the effluent limit at 6.0 mg/l. The winter limit is 3x the summer limit.
Nitrate-Nitrite as N	Chesapeake Bay TMDL	Monitoring:	The monitoring frequency shall be 2x/wk as a 24-hr composite sample
		Effluent Limit:	No effluent requirements.
		Rationale:	Due to the Chesapeake Bay Implementation Plan, the facility is required to be monitored on a frequency at least 2x/wk.
Total Nitrogen	Chesapeake Bay TMDL	Monitoring:	The monitoring frequency shall be 1x/mo as a calculation
		Effluent Limit:	No effluent requirements.
		Rationale:	Due to the Chesapeake Bay Implementation Plan, the facility is required to be monitored on a frequency at least 1x/mo.
TKN	Chesapeake Bay TMDL	Monitoring:	The monitoring frequency shall be 2x/wk as a 24-hr composite sample
		Effluent Limit:	No effluent requirements.
		Rationale:	Due to the Chesapeake Bay Implementation Plan, the facility is required to be monitored on a frequency at least 2x/wk.
Total Phosphorus	Chesapeake Bay TMDL	Monitoring:	The monitoring frequency shall be 2x/wk as a 24-hr composite sample
		Effluent Limit:	No effluent requirements.
		Rationale:	Due to the Chesapeake Bay Implementation Plan, the facility is required to be monitored on a frequency at least 2x/wk.
Net Total Nitrogen	Chesapeake Bay TMDL	Monitoring:	The monitoring frequency shall be 1x/yr as a calculation
		Effluent Limit:	Effluent limits shall not exceed 10,959 lbs/yr.
		Rationale:	Due to the Chesapeake Bay Implementation Plan, the facility is required to be monitored on a frequency at least 1x/yr.
Net Total Phosphorus	Chesapeake Bay TMDL	Monitoring:	The monitoring frequency shall be 1x/yr as a calculation
		Effluent Limit:	Effluent limits shall not exceed 1,461 lbs/yr.
		Rationale:	Due to the Chesapeake Bay Implementation Plan, the facility is required to be monitored on a frequency at least 1x/yr.

**Notes:**

1 The NPDES permit was limited by (a) anti-Backsliding, (b) Anti-Degradation, (c) SOP, (d) TBEL, (e) TMDL, (f) WQBEL, (g) WET, or (h) Other

2 Monitoring frequency based on flow rate of 0.97 MGD.

3 Table 6-3 (Self Monitoring Requirements for Sewage Discharges) in Technical Guidance for the Development and Specification of Effluent Limitations and Other Permit Conditions in NPDES Permits) (Document # 362-0400-001) Revised 10/97

4 Water Quality Antidegradation Implementaton Guidance (Document # 391-0300-002)

5 Chesapeake Bay Phase 3 Watershed Implementation Plan Wastewater Supplement, Revised September 13, 2021



**6.1.3 Outfall 001- Toxics**

Summary of Proposed NPDES Parameter Details for Toxics			
Freedom Township WWTP; PA0110361; Outfall 001			
Parameter	Permit Limitation Required by <sup>1</sup> :	Recommendation	
Total Copper	WQBEL	Monitoring:	The monitoring frequency shall be 1x/quarter as a 24-hr composite sample
		Effluent Limit:	No effluent requirement
		Rationale:	Pending favorable results from monitoring, future renewals may reduce or eliminate monitoring.
Total Zinc	WQBEL	Monitoring:	The monitoring frequency shall be 1x/quarter as a 24-hr composite sample
		Effluent Limit:	No effluent requirement
		Rationale:	Pending favorable results from monitoring, future renewals may reduce or eliminate monitoring.
Notes:			
1 The NPDES permit was limited by (a) anti-Backsliding, (b) Anti-Degradation, (c) SOP, (d) TBEL, (e) TMDL, (f) WQBEL, (g) WET, or (h) Other			
2 Monitoring frequency based on flow rate of 0.97 MGD.			
3 Table 6-3 (Self Monitoring Requirements for Sewage Discharges) in Technical Guidance for the Development and Specification of Effluent Limitations and Other Permit Conditions in NPDES Permits) (Document # 362-0400-001) Revised 10/97			
4 Water Quality Antidegradation Implementaton Guidance (Document # 391-0300-002)			
5 Chesapeake Bay Phase 3 Watershed Implementation Plan Wastewater Supplement, Revised September 13, 2021			

### 6.1.4 Outfall 002- Conventional Pollutants and Disinfection

Summary of Proposed NPDES Parameter Details for Conventional Pollutants and Disinfection Freedom Township WWTP; PA0110361; Outfall 002			
Parameter	Permit Limitation Required by <sup>1</sup> :	Recommendation	
pH (S.U.)	TBEL	Monitoring:	The monitoring frequency shall be daily as a grab sample when discharging.
		Effluent Limit:	Effluent limits may range from pH = 6.0 to 9.0
		Rationale:	The monitoring frequency has been assigned in accordance with best professional judgement (BPJ) and the effluent limits assigned by Chapter 95.2(1).
Dissolved Oxygen	BPJ	Monitoring:	The monitoring frequency shall be daily as a grab sample when discharging.
		Effluent Limit:	Effluent limits shall be greater than 6.0 mg/l.
		Rationale:	The monitoring frequency has been assigned in accordance with BPJ. Effluent limits consistent with Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers (391-2000-014)
CBOD	TBEL	Monitoring:	The monitoring frequency shall be 1x/wk as a 24-hr composite sample when discharging.
		Effluent Limit:	Effluent limits shall not exceed 80 lbs/day and 10.0 mg/l as an average monthly.
		Rationale:	Effluent limits consistent with Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers (391-2000-014)
TSS	TBEL	Monitoring:	The monitoring frequency shall be 1/wk as a 24-hr composite sample when discharging
		Effluent Limit:	Effluent limits shall not exceed 80 lbs/day and 10.0 mg/l as an average monthly.
		Rationale:	Effluent limits consistent with Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers (391-2000-014)
UV disinfection	SOP	Monitoring:	The monitoring frequency is 1x/day when discharging. The facility will be required to record UV dosage.
		Effluent Limit:	No effluent requirements.
		Rationale:	Consistent with the SOP- Establishing Effluent Limitations for Individual Sewage Permits (Revised January 10, 2019), the facility will be required to have routine monitoring for UV transmittance, UV dosage, or UV intensity.
Fecal Coliform	TBEL	Monitoring:	The monitoring frequency shall be 1x/wk as a grab sample when discharging
		Effluent Limit:	Summer effluent limits shall not exceed 200 No./100 mL as a geometric mean. Winter effluent limits shall not exceed 2000 No./100 mL as a geometric mean.
		Rationale:	The monitoring frequency has been assigned in accordance with BPJ and the effluent limits assigned by Chapter 92a.47(a)(4) and 92a.47(a)(5).

**Notes:**

1 The NPDES permit was limited by (a) anti-Backsliding, (b) Anti-Degradation, (c) SOP, (d) TBEL, (e) TMDL, (f) WQBEL, (g) WET, or (h) Other

2 Monitoring frequency based on flow rate of 0.97 MGD.

3 Table 6-3 (Self Monitoring Requirements for Sewage Discharges) in Technical Guidance for the Development and Specification of Effluent Limitations and Other Permit Conditions in NPDES Permits) (Document # 362-0400-001) Revised 10/97

4 Water Quality Antidegradation Implementaton Guidance (Document # 391-0300-002)

5 Chesapeake Bay Phase 3 Watershed Implementation Plan Wastewater Supplement, Revised September 13, 2021

### 6.1.5 Outfall 002- Nitrogen Species and Phosphorus

Summary of Proposed NPDES Parameter Details for Nitrogen Species and Phosphorus			
Freedom Township WWTP; PA0110361; Outfall 002			
Parameter	Permit Limitation Required by <sup>1</sup> :	Recommendation	
Ammonia-Nitrogen	WQBEL/Anti-backsliding	Monitoring:	The monitoring frequency shall be 1/wk as a 24-hr composite sample when discharging
		Effluent Limit:	During the months of November 1 to April 30, effluent limits shall not exceed 31.5 lbs/day and 3.9 mg/l as an average monthly. During the months of May 1 to October 31, effluent limits shall not exceed 10.5 lbs/day and 1.3 mg/l as an average monthly.
		Rationale:	Due to anti-backsliding, the current effluent limits shall continue to the proposed permit
	Chesapeake Bay TMDL	Monitoring:	The monitoring frequency shall be 2x/yr as a 24-hr composite sample
		Effluent Limit:	No effluent requirements.
		Rationale:	Due to the Chesapeake Bay Implementation Plan, the facility is required to be monitored on a frequency at least 2x/yr.
Nitrate-Nitrite as N	Chesapeake Bay TMDL	Monitoring:	The monitoring frequency shall be 2x/wk as a 24-hr composite sample
		Effluent Limit:	No effluent requirements.
		Rationale:	Due to the Chesapeake Bay Implementation Plan, the facility is required to be monitored on a frequency at least 2x/wk.
Total Nitrogen	WQBEL	Monitoring:	The monitoring frequency shall be 1/wk as a 24-hr composite sample when discharging
		Effluent Limit:	Effluent limits shall not exceed 40 lbs/day and 5 mg/l.
		Rationale:	Effluent limits consistent with Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers (391-2000-014)
	Chesapeake Bay TMDL	Monitoring:	The monitoring frequency shall be 1x/mo as a 24-hr composite sample
		Effluent Limit:	No effluent requirements.
		Rationale:	Due to the Chesapeake Bay Implementation Plan, the facility is required to be monitored on a frequency at least 1x/mo.
TKN	Chesapeake Bay TMDL	Monitoring:	The monitoring frequency shall be 2x/wk as a 24-hr composite sample
		Effluent Limit:	No effluent requirements.
		Rationale:	Due to the Chesapeake Bay Implementation Plan, the facility is required to be monitored on a frequency at least 2x/wk.
Total Phosphorus	TBEL	Monitoring:	The monitoring frequency shall be 1/wk as a 24-hr composite sample when discharging
		Effluent Limit:	Effluent limits shall not exceed 4 lbs/day and 0.5 mg/l.
		Rationale:	Effluent limits consistent with Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers (391-2000-014)
	Chesapeake Bay TMDL	Monitoring:	The monitoring frequency shall be 2x/wk as a 24-hr composite sample
		Effluent Limit:	No effluent requirements.
		Rationale:	Due to the Chesapeake Bay Implementation Plan, the facility is required to be monitored on a frequency at least 2x/wk.
Net Total Nitrogen	Chesapeake Bay TMDL	Monitoring:	The monitoring frequency shall be 1x/yr as a calculation
		Effluent Limit:	Effluent limits shall not exceed 10,959 lbs/yr
		Rationale:	Due to the Chesapeake Bay Implementation Plan, the facility is required to be monitored on a frequency at least 1x/yr.
Net Total Phosphorus	Chesapeake Bay TMDL	Monitoring:	The monitoring frequency shall be 1x/yr as a calculation
		Effluent Limit:	Effluent limits shall not exceed 1,461 lbs/yr
		Rationale:	Due to the Chesapeake Bay Implementation Plan, the facility is required to be monitored on a frequency at least 1x/yr.
Notes:			

1 The NPDES permit was limited by (a) anti-Backsliding, (b) Anti-Degradation, (c) SOP, (d) TBEL, (e) TMDL, (f) WQBEL, (g) WET, or (h) Other

2 Monitoring frequency based on flow rate of 0.97 MGD.

3 Table 6-3 (Self Monitoring Requirements for Sewage Discharges) in Technical Guidance for the Development and Specification of Effluent Limitations and Other Permit Conditions in NPDES Permits) (Document # 362-0400-001) Revised 10/97

4 Water Quality Antidegradation Implementaton Guidance (Document # 391-0300-002)

5 Chesapeake Bay Phase 3 Watershed Implementation Plan Wastewater Supplement, Revised September 13, 2021

### 6.1.6 Outfall 002- Toxics

Summary of Proposed NPDES Parameter Details for Toxics			
Freedom Township WWTP; PA0110361; Outfall 002			
Parameter	Permit Limitation Required by <sup>1</sup> :	Recommendation	
Total Copper	WQBEL	Monitoring:	The monitoring frequency shall be 1x/week during discharge as a 24-hr composite sample
		Effluent Limit:	No effluent requirement
		Rationale:	Pending favorable results from monitoring, future renewals may reduce or eliminate monitoring.
Total Zinc	WQBEL	Monitoring:	The monitoring frequency shall be 1x/week during discharge as a 24-hr composite sample
		Effluent Limit:	No effluent requirement
		Rationale:	Pending favorable results from monitoring, future renewals may reduce or eliminate monitoring.
Notes:			
1 The NPDES permit was limited by (a) anti-Backsliding, (b) Anti-Degradation, (c) SOP, (d) TBEL, (e) TMDL, (f) WQBEL, (g) WET, or (h) Other			
2 Monitoring frequency based on flow rate of 0.97 MGD.			
3 Table 6-3 (Self Monitoring Requirements for Sewage Discharges) in Technical Guidance for the Development and Specification of Effluent Limitations and Other Permit Conditions in NPDES Permits) (Document # 362-0400-001) Revised 10/97			
4 Water Quality Antidegradation Implementaton Guidance (Document # 391-0300-002)			
5 Chesapeake Bay Phase 3 Watershed Implementation Plan Wastewater Supplement, Revised September 13, 2021			

### 6.1.3.1 Implementation of Regulation- Chapter 92a.61

Chapter 92a.61 provides provisions to DEP to monitor for pollutants that may have an impact on the quality of waters of the Commonwealth. Based upon DEP policy directives issued on March 22, 2021 and in conjunction with EPA's 2017 Triennial Review, monitoring for E. Coli shall be required.

## 6.2 Summary of Changes From Existing Permit to Proposed Permit

A summary of how the proposed NPDES permit differs from the existing NPDES permit is summarized as follows.

Changes in Permit Monitoring or Effluent Quality- Outfall 001		
Parameter	Existing Permit	Draft Permit
E. Coli	No monitoring or effluent requirement	Due to EPA triennial review, monitoring shall be required 1x/quarter
Total Copper	No monitoring or effluent requirement	Monitoring shall be 1x/quarter
Total Zinc	No monitoring or effluent requirement	Monitoring shall be 1x/quarter
Changes in Permit Monitoring or Effluent Quality- Outfall 002		
Parameter	Existing Permit	Draft Permit
Dissolved Oxygen	Minimum effluent limit is 5.0 mg/l	The prior Fact Sheet recommended 6.0 mg/l. The NPDES erroneously listed it at 5.0 mg/l. Consistent with Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers (391-2000-014) the minimum effluent limit shall be 6.0 mg/l
UV disinfection	No monitoring or effluent requirement	Monitoring shall be 1x/day when discharging
Total Copper	No monitoring or effluent requirement	Monitoring shall be 1x/week when discharging
Total Zinc	No monitoring or effluent requirement	Monitoring shall be 1x/week when discharging

### 6.3.1 Summary of Proposed NPDES Effluent Limits

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

The proposed NPDES effluent limitations are summarized in the table below.

#### PART A - EFFLUENT LIMITATIONS, MONITORING, RECORDKEEPING AND REPORTING REQUIREMENTS

I. A. For Outfall 001, Latitude 40° 22' 34.57", Longitude 78° 25' 34.74", River Mile Index 39.74, Stream Code 16061

Receiving Waters: Frankstown Branch Juniata River (TSF, MF)

Type of Effluent: Sewage Effluent

1. The permittee is authorized to discharge during the period from **Permit Effective Date** through **Permit Expiration Date**.
2. Based on the anticipated wastewater characteristics and flows described in the permit application and its supporting documents and/or amendments, the following effluent limitations and monitoring requirements apply (see also Additional Requirements and Footnotes).

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Instantaneous Minimum	Concentrations (mg/L)			Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average		Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
Dissolved Oxygen	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) Nov 1 - Apr 30	162	243	XXX	20.0	30.0	40	1/week	24-Hr Composite
Carbonaceous Biochemical Oxygen Demand (CBOD5) May 1 - Oct 31	202	324	XXX	25.0	40.0	50	1/week	24-Hr Composite
Biochemical Oxygen Demand (BOD5) Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	24-Hr Composite
Total Suspended Solids	243	364	XXX	30.0	45.0	60	1/week	24-Hr Composite
Total Suspended Solids Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	24-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/week	Grab

Outfall 001 , Continued (from Permit Effective Date through Permit Expiration Date)

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Instantaneous Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/week	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/quarter	Grab
Ammonia-Nitrogen Nov 1 - Apr 30	145	XXX	XXX	18.0	XXX	36	2/week	24-Hr Composite
Ammonia-Nitrogen May 1 - Oct 31	49	XXX	XXX	6.0	XXX	12	2/week	24-Hr Composite
Copper, Total	Report Avg Qrtly	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	24-Hr Composite
Zinc, Total	Report Avg Qrtly	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	24-Hr Composite
Ultraviolet light dosage (mjoules/cm <sup>2</sup> )	XXX	XXX	Report	XXX	XXX	XXX	1/day	Recorded

Samples taken in compliance with the monitoring requirements specified above shall be taken at the following location(s):

at Outfall 001

**PART A - EFFLUENT LIMITATIONS, MONITORING, RECORDKEEPING AND REPORTING REQUIREMENTS**

I. B. For Outfall 002\*, Latitude 40° 22' 34.45", Longitude 78° 25' 37.71", River Mile Index 0.08, Stream Code 16564

Receiving Waters: Unnamed Tributary to Frankstown Branch Juniata River (WWF, MF)

Type of Effluent: Sewage Effluent

- The permittee is authorized to discharge during the period from **Permit Effective Date** through **Permit Expiration Date**.
- Based on the anticipated wastewater characteristics and flows described in the permit application and its supporting documents and/or amendments, the following effluent limitations and monitoring requirements apply (see also Additional Requirements and Footnotes).

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Instantaneous Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Daily when Discharging	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	Daily when Discharging	Grab
Dissolved Oxygen	XXX	XXX	6.0	XXX	XXX	XXX	Daily when Discharging	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5)	80	121	XXX	10.0	15.0	20	Weekly when Discharging	24-Hr Composite
Total Suspended Solids	80	121	XXX	10.0	15.0	20	Weekly when Discharging	24-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	Weekly when Discharging	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	Weekly when Discharging	Grab
Total Nitrogen	40	XXX	XXX	5.0	XXX	10	Weekly when Discharging	Calculation
Ammonia-Nitrogen Nov 1 - Apr 30	31.5	XXX	XXX	3.9	XXX	7.8	Weekly when Discharging	24-Hr Composite
Ammonia-Nitrogen May 1 - Oct 31	10.5	XXX	XXX	1.3	XXX	2.6	Weekly when Discharging	24-Hr Composite
Total Phosphorus	4.0	XXX	XXX	0.5	XXX	1	Weekly when Discharging	24-Hr Composite

Outfall 002 , Continued (from Permit Effective Date through Permit Expiration Date)

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Instantaneous Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Copper, Total	Report	XXX	XXX	Report	XXX	XXX	Weekly when Discharging	24-Hr Composite
Zinc, Total	Report	XXX	XXX	Report	XXX	XXX	Weekly when Discharging	24-Hr Composite
Ultraviolet light dosage (mjoules/cm <sup>2</sup> )	XXX	XXX	Report	XXX	XXX	XXX	1/discharge	Recorded

Samples taken in compliance with the monitoring requirements specified above shall be taken at the following location(s):

\*Outfall 002 shall be used only under emergency.

**PART A - EFFLUENT LIMITATIONS, MONITORING, RECORDKEEPING AND REPORTING REQUIREMENTS**

I. C. For Outfall 001, Latitude 40° 22' 34.57", Longitude 78° 25' 34.74", River Mile Index 39.74, Stream Code 16061

Receiving Waters: Frankstown Branch Juniata River (TSF, MF)

Type of Effluent: Sewage Effluent

1. The permittee is authorized to discharge during the period from **Permit Effective Date** through **Permit Expiration Date**.
2. Based on the anticipated wastewater characteristics and flows described in the permit application and its supporting documents and/or amendments, the following effluent limitations and monitoring requirements apply (see also Additional Requirements and Footnotes).

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Monthly	Annual	Monthly	Monthly Average	Maximum	Instant. Maximum		
Ammonia--N	Report	Report	XXX	Report	XXX	XXX	2/week	24-Hr Composite
Kjeldahl--N	Report	XXX	XXX	Report	XXX	XXX	2/week	24-Hr Composite
Nitrate-Nitrite as N	Report	XXX	XXX	Report	XXX	XXX	2/week	24-Hr Composite
Total Nitrogen	Report	Report	XXX	Report	XXX	XXX	1/month	Calculation
Total Phosphorus	Report	Report	XXX	Report	XXX	XXX	2/week	24-Hr Composite
Net Total Nitrogen	XXX	10959	XXX	XXX	XXX	XXX	1/year	Calculation
Net Total Phosphorus	XXX	1461	XXX	XXX	XXX	XXX	1/year	Calculation

Samples taken in compliance with the monitoring requirements specified above shall be taken at the following location(s):

at Outfall 001 and Outfall 002

Footnotes:

- (1) See Part C for Chesapeake Bay Requirements.
- (2) This is the minimum number of sampling events required. Permittees are encouraged, and it may be advantageous in demonstrating compliance, to perform more than the minimum number of sampling events required.

**6.3.2 Summary of Proposed Permit Part C Conditions**

The subject facility has the following Part C conditions.

- Peak Flow Management Plan
- Hauled-in Waste Restrictions
- Chesapeake Bay Nutrient Definitions
- Solids Management for Non-Lagoon Treatment Systems





Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment <span style="background-color: yellow;">      </span> )
<input checked="" type="checkbox"/>	Toxics Management Spreadsheet (see Attachment <span style="background-color: yellow;">      </span> )
<input type="checkbox"/>	TRC Model Spreadsheet (see Attachment <span style="background-color: yellow;">      </span> )
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment <span style="background-color: yellow;">      </span> )
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 385-2000-011, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 391-2000-006, 9/97.
<input type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 391-2000-023, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97.
<input type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input checked="" type="checkbox"/>	SOP: New and Reissuance Sewage Individual NPDES Permit Applications, rev 2/3/2022
<input type="checkbox"/>	Other: <span style="background-color: yellow;">      </span>

# Attachment A

## Stream Stats/Gauge Data

Table 1 13

Table 1. List of U.S. Geological Survey streamgage locations in and near Pennsylvania with updated streamflow statistics.—Continued

[Latitude and Longitude in decimal degrees; mi<sup>2</sup>, square miles]

Streamgage number	Streamgage name	Latitude	Longitude	Drainage area (mi <sup>2</sup> )	Regulated <sup>1</sup>
01541303	West Branch Susquehanna River at Hyde, Pa.	41.005	-78.457	474	Y
01541308	Bradley Run near Ashville, Pa.	40.509	-78.584	6.77	N
01541500	Clearfield Creek at Dimeling, Pa.	40.972	-78.406	371	Y
01542000	Moshannon Creek at Osceola Mills, Pa.	40.850	-78.268	68.8	N
01542500	WB Susquehanna River at Karthaus, Pa.	41.118	-78.109	1,462	Y
01542810	Waldy Run near Emporium, Pa.	41.579	-78.293	5.24	N
01543000	Driftwood Branch Sinnemahoning Creek at Sterling Run, Pa.	41.413	-78.197	272	N
01543500	Sinnemahoning Creek at Sinnemahoning, Pa.	41.317	-78.103	685	N
01544000	First Fork Sinnemahoning Creek near Sinnemahoning, Pa.	41.402	-78.024	245	Y
01544500	Kettle Creek at Cross Fork, Pa.	41.476	-77.826	136	N
01545000	Kettle Creek near Westport, Pa.	41.320	-77.874	233	Y
01545500	West Branch Susquehanna River at Renovo, Pa.	41.325	-77.751	2,975	Y
01545600	Young Womans Creek near Renovo, Pa.	41.390	-77.691	46.2	N
01546000	North Bald Eagle Creek at Milesburg, Pa.	40.942	-77.794	119	N
01546400	Spring Creek at Houserville, Pa.	40.834	-77.828	58.5	N
01546500	Spring Creek near Axemann, Pa.	40.890	-77.794	87.2	N
01547100	Spring Creek at Milesburg, Pa.	40.932	-77.786	142	N
01547200	Bald Eagle Creek below Spring Creek at Milesburg, Pa.	40.943	-77.786	265	N
01547500	Bald Eagle Creek at Blanchard, Pa.	41.052	-77.604	339	Y
01547700	Marsh Creek at Blanchard, Pa.	41.060	-77.606	44.1	N
01547800	South Fork Beech Creek near Snow Shoe, Pa.	41.024	-77.904	12.2	N
01547950	Beech Creek at Monument, Pa.	41.112	-77.702	152	N
01548005	Bald Eagle Creek near Beech Creek Station, Pa.	41.081	-77.549	562	Y
01548500	Pine Creek at Cedar Run, Pa.	41.522	-77.447	604	N
01549000	Pine Creek near Waterville, Pa.	41.313	-77.379	750	N
01549500	Blockhouse Creek near English Center, Pa.	41.474	-77.231	37.7	N
01549700	Pine Creek below Little Pine Creek near Waterville, Pa.	41.274	-77.324	944	Y
01550000	Lycoming Creek near Trout Run, Pa.	41.418	-77.033	173	N
01551500	WB Susquehanna River at Williamsport, Pa.	41.236	-76.997	5,682	Y
01552000	Loyalsock Creek at Loyalsockville, Pa.	41.325	-76.912	435	N
01552500	Muncy Creek near Sonestown, Pa.	41.357	-76.535	23.8	N
01553130	Sand Spring Run near White Deer, Pa.	41.059	-77.077	4.93	N
01553500	West Branch Susquehanna River at Lewisburg, Pa.	40.968	-76.876	6,847	Y
01553700	Chillisquaque Creek at Washingtonville, Pa.	41.062	-76.680	51.3	N
01554000	Susquehanna River at Sunbury, Pa.	40.835	-76.827	18,300	Y
01554500	Shamokin Creek near Shamokin, Pa.	40.810	-76.584	54.2	N
01555000	Penns Creek at Penns Creek, Pa.	40.867	-77.048	301	N
01555500	East Mahantango Creek near Dalmatia, Pa.	40.611	-76.912	162	N
01556000	Frankstown Branch Juniata River at Williamsburg, Pa.	40.463	-78.200	291	N
01557500	Bald Eagle Creek at Tyrone, Pa.	40.684	-78.234	44.1	N
01558000	Little Juniata River at Spruce Creek, Pa.	40.613	-78.141	220	N
01559000	Juniata River at Huntingdon, Pa.	40.485	-78.019	816	LF
01559500	Standing Stone Creek near Huntingdon, Pa.	40.524	-77.971	128	N
01559700	Sulphur Springs Creek near Manns Choice, Pa.	39.978	-78.619	5.28	N
01560000	Dunning Creek at Belden, Pa.	40.072	-78.493	172	N

## 26 Selected Streamflow Statistics for Streamgauge Locations in and near Pennsylvania

**Table 2.** Selected low-flow statistics for streamgauge locations in and near Pennsylvania.—Continued

[ft<sup>3</sup>/s; cubic feet per second; —, statistic not computed; <, less than]

Streamgauge number	Period of record used in analysis <sup>1</sup>	Number of years used in analysis	1-day, 10-year (ft <sup>3</sup> /s)	7-day, 10-year (ft <sup>3</sup> /s)	7-day, 2-year (ft <sup>3</sup> /s)	30-day, 10-year (ft <sup>3</sup> /s)	30-day, 2-year (ft <sup>3</sup> /s)	90-day, 10-year (ft <sup>3</sup> /s)
01546000	1912–1934	17	1.8	2.2	6.8	3.7	12.1	11.2
01546400	1986–2008	23	13.5	14.0	19.6	15.4	22.3	18.7
01546500	1942–2008	67	26.8	29.0	41.3	31.2	44.2	33.7
01547100	1969–2008	40	102	105	128	111	133	117
01547200	1957–2008	52	99.4	101	132	106	142	115
01547500	<sup>2</sup> 1971–2008	38	28.2	109	151	131	172	153
01547500	<sup>3</sup> 1956–1969	14	90.0	94.9	123	98.1	131	105
01547700	1957–2008	52	.5	.6	2.7	1.1	3.9	2.2
01547800	1971–1981	11	1.6	1.8	2.4	2.1	2.9	3.5
01547950	1970–2008	39	12.1	13.6	28.2	17.3	36.4	23.8
01548005	<sup>2</sup> 1971–2000	25	142	151	206	178	241	223
01548005	<sup>3</sup> 1912–1969	58	105	114	147	125	165	140
01548500	1920–2008	89	21.2	24.2	50.1	33.6	68.6	49.3
01549000	1910–1920	11	26.0	32.9	78.0	46.4	106	89.8
01549500	1942–2008	67	.6	.8	2.5	1.4	3.9	2.6
01549700	1959–2008	50	33.3	37.2	83.8	51.2	117	78.4
01550000	1915–2008	94	6.6	7.6	16.8	11.2	24.6	18.6
01551500	<sup>2</sup> 1963–2008	46	520	578	1,020	678	1,330	919
01551500	<sup>3</sup> 1901–1961	61	400	439	742	523	943	752
01552000	1927–2008	80	20.5	22.2	49.5	29.2	69.8	49.6
01552500	1942–2008	67	.9	1.2	3.1	1.7	4.4	3.3
01553130	1969–1981	13	1.0	1.1	1.5	1.3	1.8	1.7
01553500	<sup>2</sup> 1968–2008	41	760	838	1,440	1,000	1,850	1,470
01553500	<sup>3</sup> 1941–1966	26	562	619	880	690	1,090	881
01553700	1981–2008	28	9.1	10.9	15.0	12.6	17.1	15.2
01554000	<sup>2</sup> 1981–2008	28	1,830	1,990	3,270	2,320	4,210	3,160
01554000	<sup>3</sup> 1939–1979	41	1,560	1,630	2,870	1,880	3,620	2,570
01554500	1941–1993	53	16.2	22.0	31.2	25.9	35.7	31.4
01555000	1931–2008	78	33.5	37.6	58.8	43.4	69.6	54.6
01555500	1931–2008	78	4.9	6.5	18.0	9.4	24.3	16.6
01556000	1918–2008	91	43.3	47.8	66.0	55.1	75.0	63.7
01557500	1946–2008	63	2.8	3.2	6.3	4.2	8.1	5.8
01558000	1940–2008	69	56.3	59.0	79.8	65.7	86.2	73.7
01559000	1943–2008	66	104	177	249	198	279	227
01559500	1931–1958	28	9.3	10.5	15.0	12.4	17.8	15.8
01559700	1963–1978	16	.1	.1	.2	.1	.3	.2
01560000	1941–2008	68	8.5	9.4	15.6	12.0	20.2	16.2
01561000	1932–1958	27	.4	.5	1.6	.8	2.5	1.7
01562000	1913–2008	96	64.1	67.1	106	77.4	122	94.5
01562500	1931–1957	27	1.1	1.6	3.8	2.3	5.4	3.7
01563200	<sup>2</sup> 1974–2008	35	—	—	—	112	266	129
01563200	<sup>3</sup> 1948–1972	25	10.3	28.2	86.1	64.5	113	95.5
01563500	<sup>2</sup> 1974–2008	35	384	415	519	441	580	493
01563500	<sup>3</sup> 1939–1972	34	153	242	343	278	399	333
01564500	1940–2008	69	3.6	4.2	10.0	6.2	14.4	10.6


## StreamStats Report

Region ID: PA

Workspace ID: PA20220907141509481000

Clicked Point (Latitude, Longitude): 40.43032, -78.36063

Time: 2022-09-07 10:15:30 -0400



Freedom WWTP PA0110361 Modeling Point # Hollidaysburg September 2022

 Collapse All



➤ Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
CARBON	Percentage of area of carbonate rock	24.24	percent
DRNAREA	Area that drains to a point on a stream	116	square miles
PRECIP	Mean Annual Precipitation	38	inches
ROCKDEP	Depth to rock	4.6	feet
STRDEN	Stream Density -- total length of streams divided by drainage area	2.3	miles per square mile

➤ Low-Flow Statistics

Low-Flow Statistics Parameters [100.0 Percent (116 square miles) Low Flow Region 2]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	116	square miles	4.93	1280
PRECIP	Mean Annual Precipitation	38	inches	35	50.4
STRDEN	Stream Density	2.3	miles per square mile	0.51	3.1
ROCKDEP	Depth to Rock	4.6	feet	3.32	5.65
CARBON	Percent Carbonate	24.24	percent	0	99

Low-Flow Statistics Flow Report [100.0 Percent (116 square miles) Low Flow Region 2]

PIl: Prediction Interval-Lower, PIu: Prediction Interval-Upper, ASEp: Average Standard Error of Prediction, SE: Standard Error (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	12.8	ft <sup>3</sup> /s	38	38

Statistic	Value	Unit	SE	ASEp
30 Day 2 Year Low Flow	16.3	ft <sup>3</sup> /s	33	33
7 Day 10 Year Low Flow	7.21	ft <sup>3</sup> /s	51	51
30 Day 10 Year Low Flow	9.15	ft <sup>3</sup> /s	46	46
90 Day 10 Year Low Flow	12.6	ft <sup>3</sup> /s	36	36

*Low-Flow Statistics Citations*

**Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)**

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.10.1


StreamStats Services Version: 1.2.22

NSS Services Version: 2.2.1



StreamStats Report

Region ID: PA  
Workspace ID: PA20220907142206746000  
Clicked Point (Latitude, Longitude): 40.37908, -78.41590  
Time: 2022-09-07 10:22:27 -0400



Freedom WWTP PA0110361 Modeling Point # Formerly Appvion September 2022

Collapse All

➤ Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
CARBON	Percentage of area of carbonate rock	29.93	percent
DRNAREA	Area that drains to a point on a stream	90.7	square miles
PRECIP	Mean Annual Precipitation	38	inches
ROCKDEP	Depth to rock	4.7	feet
STRDEN	Stream Density -- total length of streams divided by drainage area	2.3	miles per square mile

➤ Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 2]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	90.7	square miles	4.93	1280
PRECIP	Mean Annual Precipitation	38	inches	35	50.4
STRDEN	Stream Density	2.3	miles per square mile	0.51	3.1
ROCKDEP	Depth to Rock	4.7	feet	3.32	5.65
CARBON	Percent Carbonate	29.93	percent	0	99

Low-Flow Statistics Flow Report [Low Flow Region 2]

PII: Prediction Interval-Lower, PIu: Prediction Interval-Upper, ASEp: Average Standard Error of Prediction, SE: Standard Error (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	10.8	ft <sup>3</sup> /s	38	38

Statistic	Value	Unit	SE	ASEp
30 Day 2 Year Low Flow	13.6	ft <sup>3</sup> /s	33	33
7 Day 10 Year Low Flow	6.27	ft <sup>3</sup> /s	51	51
30 Day 10 Year Low Flow	7.8	ft <sup>3</sup> /s	46	46
90 Day 10 Year Low Flow	10.5	ft <sup>3</sup> /s	36	36

*Low-Flow Statistics Citations*

**Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)**

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.10.1

StreamStats Services Version: 1.2.22

NSS Services Version: 2.2.1


## StreamStats Report

Region ID: PA

Workspace ID: PA20220907142446523000

Clicked Point (Latitude, Longitude): 40.37601, -78.42614

Time: 2022-09-07 10:25:07 -0400



Freedom WWTP PA0110361 Modeling Point # Freedom September 2022

[+ Collapse All](#)

➤ Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
CARBON	Percentage of area of carbonate rock	9.27	percent
DRNAREA	Area that drains to a point on a stream	55.5	square miles
PRECIP	Mean Annual Precipitation	39	inches
ROCKDEP	Depth to rock	4.3	feet
STRDEN	Stream Density -- total length of streams divided by drainage area	2.46	miles per square mile

➤ Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 2]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	55.5	square miles	4.93	1280
PRECIP	Mean Annual Precipitation	39	inches	35	50.4
STRDEN	Stream Density	2.46	miles per square mile	0.51	3.1
ROCKDEP	Depth to Rock	4.3	feet	3.32	5.65
CARBON	Percent Carbonate	9.27	percent	0	99

Low-Flow Statistics Flow Report [Low Flow Region 2]

PII: Prediction Interval-Lower, PIu: Prediction Interval-Upper, ASEp: Average Standard Error of Prediction, SE: Standard Error (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	4.33	ft <sup>3</sup> /s	38	38

Statistic	Value	Unit	SE	ASEp
30 Day 2 Year Low Flow	5.9	ft <sup>3</sup> /s	33	33
7 Day 10 Year Low Flow	2.05	ft <sup>3</sup> /s	51	51
30 Day 10 Year Low Flow	2.81	ft <sup>3</sup> /s	46	46
90 Day 10 Year Low Flow	4.36	ft <sup>3</sup> /s	36	36

*Low-Flow Statistics Citations*

**Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)**

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.10.1


StreamStats Services Version: 1.2.22

NSS Services Version: 2.2.1




StreamStats Report

Region ID: PA  
Workspace ID: PA20220907142834774000  
Clicked Point (Latitude, Longitude): 40.35482, -78.42745  
Time: 2022-09-07 10:28:54 -0400



Freedom WWTP PA0110361 Modeling Point #Roaring Springs September 2022

 Collapse All

➤ Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
CARBON	Percentage of area of carbonate rock	10.93	percent
DRNAREA	Area that drains to a point on a stream	47.1	square miles
PRECIP	Mean Annual Precipitation	39	inches
ROCKDEP	Depth to rock	4.3	feet
STRDEN	Stream Density -- total length of streams divided by drainage area	2.38	miles per square mile

➤ Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 2]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	47.1	square miles	4.93	1280
PRECIP	Mean Annual Precipitation	39	inches	35	50.4
STRDEN	Stream Density	2.38	miles per square mile	0.51	3.1
ROCKDEP	Depth to Rock	4.3	feet	3.32	5.65
CARBON	Percent Carbonate	10.93	percent	0	99

Low-Flow Statistics Flow Report [Low Flow Region 2]

PIl: Prediction Interval-Lower, PIu: Prediction Interval-Upper, ASEp: Average Standard Error of Prediction, SE: Standard Error (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	3.81	ft <sup>3</sup> /s	38	38



Statistic	Value	Unit	SE	ASEp
30 Day 2 Year Low Flow	5.17	ft <sup>3</sup> /s	33	33
7 Day 10 Year Low Flow	1.8	ft <sup>3</sup> /s	51	51
30 Day 10 Year Low Flow	2.46	ft <sup>3</sup> /s	46	46
90 Day 10 Year Low Flow	3.81	ft <sup>3</sup> /s	36	36

*Low-Flow Statistics Citations*

**Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)**

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.10.1

StreamStats Services Version: 1.2.22

NSS Services Version: 2.2.1


## StreamStats Report

Region ID: PA

Workspace ID: PA20220907143159117000

Clicked Point (Latitude, Longitude): 40.31137, -78.44376

Time: 2022-09-07 10:32:18 -0400



Freedom WWTP PA0110361 Modeling Point # Greenfield September 2022

 Collapse All

➤ Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
CARBON	Percentage of area of carbonate rock	12.85	percent
DRNAREA	Area that drains to a point on a stream	37.1	square miles
PRECIP	Mean Annual Precipitation	39	inches
ROCKDEP	Depth to rock	4.3	feet
STRDEN	Stream Density -- total length of streams divided by drainage area	2.28	miles per square mile

➤ Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 2]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	37.1	square miles	4.93	1280
PRECIP	Mean Annual Precipitation	39	inches	35	50.4
STRDEN	Stream Density	2.28	miles per square mile	0.51	3.1
ROCKDEP	Depth to Rock	4.3	feet	3.32	5.65
CARBON	Percent Carbonate	12.85	percent	0	99

Low-Flow Statistics Flow Report [Low Flow Region 2]

PII: Prediction Interval-Lower, Plu: Prediction Interval-Upper, ASEp: Average Standard Error of Prediction, SE: Standard Error (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	3.12	ft <sup>3</sup> /s	38	38

Statistic	Value	Unit	SE	ASEp
30 Day 2 Year Low Flow	4.23	ft <sup>3</sup> /s	33	33
7 Day 10 Year Low Flow	1.47	ft <sup>3</sup> /s	51	51
30 Day 10 Year Low Flow	2.01	ft <sup>3</sup> /s	46	46
90 Day 10 Year Low Flow	3.1	ft <sup>3</sup> /s	36	36

*Low-Flow Statistics Citations*

**Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)**

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.


Application Version: 4.10.1

StreamStats Services Version: 1.2.22

NSS Services Version: 2.2.1

StreamStats Report

Region ID: PA  
Workspace ID: PA20220907152552538000  
Clicked Point (Latitude, Longitude): 40.44375, -78.35355  
Time: 2022-09-07 11:26:13 -0400



Freedom WWTP PA0110361 Modeling Point # Furthest Point Downstream September 2022

Collapse All

➤ Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
CARBON	Percentage of area of carbonate rock	16.3	percent
DRNAREA	Area that drains to a point on a stream	215	square miles
PRECIP	Mean Annual Precipitation	40	inches
ROCKDEP	Depth to rock	4.6	feet
STRDEN	Stream Density -- total length of streams divided by drainage area	2.1	miles per square mile

➤ Low-Flow Statistics

Low-Flow Statistics Parameters [100.0 Percent (215 square miles) Low Flow Region 2]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	215	square miles	4.93	1280
PRECIP	Mean Annual Precipitation	40	inches	35	50.4
STRDEN	Stream Density	2.1	miles per square mile	0.51	3.1
ROCKDEP	Depth to Rock	4.6	feet	3.32	5.65
CARBON	Percent Carbonate	16.3	percent	0	99

Low-Flow Statistics Flow Report [100.0 Percent (215 square miles) Low Flow Region 2]

Pll: Prediction Interval-Lower, Plu: Prediction Interval-Upper, ASEp: Average Standard Error of Prediction, SE: Standard Error (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	30.4	ft <sup>3</sup> /s	38	38

<b>Statistic</b>	<b>Value</b>	<b>Unit</b>	<b>SE</b>	<b>ASEp</b>
30 Day 2 Year Low Flow	38.2	ft <sup>3</sup> /s	33	33
7 Day 10 Year Low Flow	17.7	ft <sup>3</sup> /s	51	51
30 Day 10 Year Low Flow	22.1	ft <sup>3</sup> /s	46	46
90 Day 10 Year Low Flow	30	ft <sup>3</sup> /s	36	36

*Low-Flow Statistics Citations*

**Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)**

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.10.1

StreamStats Services Version: 1.2.22

NSS Services Version: 2.2.1



## Outfall 002


### StreamStats Report

Region ID: PA

Workspace ID: PA20220906120915513000

Clicked Point (Latitude, Longitude): 40.37571, -78.42700

Time: 2022-09-06 08:09:36 -0400



Freedom Township STP PA0110361 Modeling Point #1- Outfall 002 September 2022

[+ Collapse All](#)



➤ Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
CARBON	Percentage of area of carbonate rock	0	percent
DRNAREA	Area that drains to a point on a stream	0.38	square miles
PRECIP	Mean Annual Precipitation	37	inches
ROCKDEP	Depth to rock	5.1	feet
STRDEN	Stream Density -- total length of streams divided by drainage area	2.94	miles per square mile

➤ Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 2]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	0.38	square miles	4.93	1280
PRECIP	Mean Annual Precipitation	37	inches	35	50.4
STRDEN	Stream Density	2.94	miles per square mile	0.51	3.1
ROCKDEP	Depth to Rock	5.1	feet	3.32	5.65
CARBON	Percent Carbonate	0	percent	0	99

Low-Flow Statistics Disclaimers [Low Flow Region 2]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [Low Flow Region 2]

Statistic	Value	Unit
7 Day 2 Year Low Flow	0.015	ft <sup>3</sup> /s
30 Day 2 Year Low Flow	0.0216	ft <sup>3</sup> /s
7 Day 10 Year Low Flow	0.00621	ft <sup>3</sup> /s
30 Day 10 Year Low Flow	0.00865	ft <sup>3</sup> /s
90 Day 10 Year Low Flow	0.0149	ft <sup>3</sup> /s

*Low-Flow Statistics Citations*

**Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)**

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.10.1

StreamStats Services Version: 1.2.22

NSS Services Version: 2.2.1


## StreamStats Report

Region ID: PA

Workspace ID: PA20220906121528442000

Clicked Point (Latitude, Longitude): 40.37674, -78.42562

Time: 2022-09-06 08:15:49 -0400



Freedom Township STP PA0110361 Modeling Point #2 - Outfall 002 September 2022

[+ Collapse All](#)

➤ Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
CARBON	Percentage of area of carbonate rock	9.27	percent
DRNAREA	Area that drains to a point on a stream	55.5	square miles
PRECIP	Mean Annual Precipitation	39	inches
ROCKDEP	Depth to rock	4.3	feet
STRDEN	Stream Density -- total length of streams divided by drainage area	2.46	miles per square mile

➤ Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 2]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	55.5	square miles	4.93	1280
PRECIP	Mean Annual Precipitation	39	inches	35	50.4
STRDEN	Stream Density	2.46	miles per square mile	0.51	3.1
ROCKDEP	Depth to Rock	4.3	feet	3.32	5.65
CARBON	Percent Carbonate	9.27	percent	0	99

Low-Flow Statistics Flow Report [Low Flow Region 2]

PIl: Prediction Interval-Lower, PIu: Prediction Interval-Upper, ASEp: Average Standard Error of Prediction, SE: Standard Error (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	4.33	ft <sup>3</sup> /s	38	38

Statistic	Value	Unit	SE	ASEp
30 Day 2 Year Low Flow	5.9	ft <sup>3</sup> /s	33	33
7 Day 10 Year Low Flow	2.05	ft <sup>3</sup> /s	51	51
30 Day 10 Year Low Flow	2.81	ft <sup>3</sup> /s	46	46
90 Day 10 Year Low Flow	4.36	ft <sup>3</sup> /s	36	36

*Low-Flow Statistics Citations*

**Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)**

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.10.1

StreamStats Services Version: 1.2.22

NSS Services Version: 2.2.1

## Attachment B

# WQM 7.0 Modeling Output Values Toxics Management Spreadsheet Output Values

**Outfall 001**

**WQM 7.0 Effluent Limits**

<u>SWP Basin</u>		<u>Stream Code</u>	<u>Stream Name</u>				
11A		16061	FRANKSTOWN BRANCH JUNIATA RIVER				
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
45.300	Greenfield	PA0029106-22	0.800	CBOD5	25		
				NH3-N	5.45	10.9	
				Dissolved Oxygen			5
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
41.910	Roaring Springs	PA0020249-22	0.700	CBOD5	25		
				NH3-N	7.16	14.32	
				Dissolved Oxygen			5
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
39.740	Freedom	PA0110361-22	0.970	CBOD5	25		
				NH3-N	6.34	12.68	
				Dissolved Oxygen			5
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
33.300	Hollidaysburg	PA0043273-22	6.000	CBOD5	16.53		
				NH3-N	4.08	8.16	
				Dissolved Oxygen			5

### WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
11A	16061	FRANKSTOWN BRANCH JUNIATA RIVER

#### NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
45.300	Greenfield	7.24	39.61	7.24	33.94	3	14
41.910	Roaring Springs	6.62	49.57	7.95	42.47	3	14
39.740	Freedom	6.88	44.84	8.56	38.42	3	14
39.090		NA	NA	7.66	NA	NA	NA
33.300	Hollidaysburg	8.82	25.28	9.38	25.28	0	0

#### NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
45.300	Greenfield	1.12	7.47	1.12	5.45	3	27
41.910	Roaring Springs	1.07	9.81	1.18	7.16	3	27
39.740	Freedom	1.09	8.7	1.23	6.34	3	27
39.090		NA	NA	1.16	NA	NA	NA
33.300	Hollidaysburg	1.26	4.22	1.3	4.08	5	3

#### Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
45.30	Greenfield	25	25	5.45	5.45	5	5	0	0
41.91	Roaring Springs	25	25	7.16	7.16	5	5	0	0
39.74	Freedom	25	25	6.34	6.34	5	5	0	0
39.09		NA	NA	NA	NA	NA	NA	NA	NA
33.30	Hollidaysburg	16.53	16.53	4.08	4.08	5	5	0	0



### Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
11A	16061	FRANKSTOWN BRANCH JUNIATA R	45.300	1096.00	37.10	0.00000	0.00	<input checked="" type="checkbox"/>

#### Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	pH	Stream Temp (°C)	pH
	(cfsm)	(cfs)	(cfs)									
Q7-10	0.164	0.00	0.00	0.000	0.000	0.0	0.00	0.00	22.00	7.84	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

#### Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Greenfield	PA0029106-22	0.8000	0.8000	0.8000	0.000	25.00	7.00

#### Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	5.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

### Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
11A	16061	FRANKSTOWN BRANCH JUNIATA R	41.910	1009.00	47.10	0.00000	0.00	<input checked="" type="checkbox"/>

#### Stream Data

Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream pH	Stream Temp (°C)	Stream pH
Q7-10	0.164	0.00	0.00	0.000	0.000	0.0	0.00	0.00	22.00	7.84	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

#### Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Roaring Springs	PA0020249-22	0.7000	0.7000	0.7000	0.000	25.00	7.00

#### Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	5.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

### Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
11A	16061	FRANKSTOWN BRANCH JUNIATA R	39.740	987.00	55.50	0.00000	0.00	<input checked="" type="checkbox"/>

#### Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	pH	Stream Temp	pH
	(cfs)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.164	0.00	0.00	0.000	0.000	0.0	0.00	0.00	22.00	7.84	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

#### Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Freedom	PA0110361-22	0.9700	0.9700	0.9700	0.000	25.00	7.00

#### Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	5.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

### Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
11A	16061	FRANKSTOWN BRANCH JUNIATA R	39.090	974.00	90.70	0.00000	0.00	<input checked="" type="checkbox"/>

#### Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	pH	Stream Temp (°C)	pH
	(cfsm)	(cfs)	(cfs)									
Q7-10	0.164	0.00	0.00	0.000	0.000	0.0	0.00	0.00	22.00	7.84	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

#### Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	0.00	7.00

#### Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	5.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

### Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
11A	16061	FRANKSTOWN BRANCH JUNIATA R	33.300	913.00	116.00	0.00000	0.00	<input checked="" type="checkbox"/>

#### Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	pH	Stream Temp (°C)	pH
	(cfsm)	(cfs)	(cfs)									
Q7-10	0.164	0.00	0.00	0.000	0.000	0.0	0.00	0.00	22.00	7.84	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

#### Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Hollidaysburg	PA0043273-22	6.0000	6.0000	6.0000	0.000	25.00	7.00

#### Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	5.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

### Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
11A	16061	FRANKSTOWN BRANCH JUNIATA R	32.230	911.00	215.00	0.00000	0.00	<input checked="" type="checkbox"/>

#### Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream Temp (°C)	pH
	(cfsm)	(cfs)	(cfs)								
Q7-10	0.164	0.00	0.00	0.000	0.000	0.0	0.00	0.00	22.00	7.84	0.00
Q1-10		0.00	0.00	0.000	0.000						
Q30-10		0.00	0.00	0.000	0.000						

#### Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	0.00	7.00

#### Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	5.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

### WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
11A	16061	FRANKSTOWN BRANCH JUNIATA RIVER		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
45.300	0.800	22.507	7.539	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
36.207	0.701	51.675	0.289	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
5.89	0.869	0.92	0.849	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
7.695	14.146	Tsivoglou	5	
<u>Reach Travel Time (days)</u>	<b>Subreach Results</b>			
0.718	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
	0.072	5.49	0.87	7.84
	0.144	5.12	0.82	7.87
	0.215	4.77	0.77	7.87
	0.287	4.45	0.72	7.87
	0.359	4.15	0.68	7.87
	0.431	3.87	0.64	7.87
	0.502	3.61	0.60	7.87
	0.574	3.36	0.57	7.87
	0.646	3.14	0.53	7.87
	0.718	2.92	0.50	7.87

<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
41.910	1.500	22.693	7.466	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
44.575	0.745	59.865	0.303	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
5.15	0.926	1.14	0.861	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
7.624	4.227	Tsivoglou	5	
<u>Reach Travel Time (days)</u>	<b>Subreach Results</b>			
0.438	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
	0.044	4.92	1.09	7.32
	0.088	4.70	1.05	7.08
	0.131	4.49	1.01	6.91
	0.175	4.29	0.98	6.78
	0.219	4.10	0.94	6.70
	0.263	3.91	0.91	6.64
	0.307	3.74	0.87	6.61
	0.351	3.57	0.84	6.61
	0.394	3.41	0.81	6.61
	0.438	3.26	0.78	6.64

### WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
11A	16061	FRANKSTOWN BRANCH JUNIATA RIVER		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
39.740	2.470	22.887	7.401	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
47.678	0.762	62.560	0.356	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
5.65	1.098	1.34	0.874	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
6.617	9.845	Tsivoglou	5	
<u>Reach Travel Time (days)</u>	<b>Subreach Results</b>			
0.112	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.011	5.57	1.33	6.66
	0.022	5.49	1.32	6.71
	0.034	5.41	1.30	6.75
	0.045	5.34	1.29	6.79
	0.056	5.27	1.28	6.83
	0.067	5.19	1.27	6.87
	0.078	5.12	1.25	6.90
	0.089	5.05	1.24	6.93
	0.101	4.98	1.23	6.96
	0.112	4.91	1.22	6.99

---

<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
39.090	2.470	22.613	7.496	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
61.259	0.820	74.714	0.372	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
4.01	0.573	0.84	0.856	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
7.379	5.392	Tsivoglou	5	
<u>Reach Travel Time (days)</u>	<b>Subreach Results</b>			
0.951	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.095	3.77	0.78	7.41
	0.190	3.55	0.71	7.46
	0.285	3.34	0.66	7.52
	0.380	3.14	0.61	7.59
	0.475	2.95	0.56	7.66
	0.570	2.78	0.52	7.73
	0.665	2.61	0.48	7.79
	0.760	2.46	0.44	7.86
	0.856	2.31	0.40	7.86
	0.951	2.17	0.37	7.86



## WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
11A	16061	FRANKSTOWN BRANCH JUNIATA RIVER		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
33.300	8.470	23.224	7.307	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
84.345	0.921	91.598	0.414	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
6.30	0.782	1.40	0.897	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
7.083	0.737	Tsivoglou	5	
<u>Reach Travel Time (days)</u>	<b>Subreach Results</b>			
0.158	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
	0.016	6.21	1.38	6.88
	0.032	6.12	1.36	6.68
	0.047	6.03	1.34	6.48
	0.063	5.95	1.32	6.30
	0.079	5.86	1.30	6.11
	0.095	5.78	1.28	5.93
	0.111	5.70	1.26	5.76
	0.126	5.62	1.25	5.59
	0.142	5.54	1.23	5.43
	0.158	5.46	1.21	5.27

### WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
11A		16061				FRANKSTOWN BRANCH JUNIATA RIVER						
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
<b>Q7-10 Flow</b>												
45.300	6.08	0.00	6.08	1.2376	0.00486	.701	36.21	51.68	0.29	0.718	22.51	7.54
41.910	7.72	0.00	7.72	2.3205	0.00192	.745	44.57	59.86	0.30	0.438	22.69	7.47
39.740	9.10	0.00	9.10	3.8211	0.00379	.762	47.68	62.56	0.36	0.112	22.89	7.40
39.090	14.87	0.00	14.87	3.8211	0.00200	.82	61.26	74.71	0.37	0.951	22.61	7.50
33.300	19.02	0.00	19.02	13.1031	0.00035	.921	84.35	91.6	0.41	0.158	23.22	7.31
<b>Q1-10 Flow</b>												
45.300	5.54	0.00	5.54	1.2376	0.00486	NA	NA	NA	0.28	0.750	22.55	7.52
41.910	7.03	0.00	7.03	2.3205	0.00192	NA	NA	NA	0.29	0.456	22.74	7.45
39.740	8.28	0.00	8.28	3.8211	0.00379	NA	NA	NA	0.34	0.116	22.95	7.38
39.090	13.54	0.00	13.54	3.8211	0.00200	NA	NA	NA	0.36	0.991	22.66	7.48
33.300	17.31	0.00	17.31	13.1031	0.00035	NA	NA	NA	0.40	0.163	23.29	7.29
<b>Q30-10 Flow</b>												
45.300	7.00	0.00	7.00	1.2376	0.00486	NA	NA	NA	0.31	0.672	22.45	7.56
41.910	8.88	0.00	8.88	2.3205	0.00192	NA	NA	NA	0.32	0.412	22.62	7.49
39.740	10.47	0.00	10.47	3.8211	0.00379	NA	NA	NA	0.38	0.106	22.80	7.43
39.090	17.11	0.00	17.11	3.8211	0.00200	NA	NA	NA	0.40	0.892	22.55	7.52
33.300	21.88	0.00	21.88	13.1031	0.00035	NA	NA	NA	0.43	0.151	23.12	7.33

### WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.91	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.15	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

**Outfall 002**

**WQM 7.0 Effluent Limits**

<u>SWP Basin</u>		<u>Stream Code</u>	<u>Stream Name</u>				
11A		16564	Trib 16564 to McDonald Run				
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
0.080	Freedom 002	PA0110361-02	0.970	CBOD5	25		
				NH3-N	1.58	3.16	
				Dissolved Oxygen			5

### WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
11A	16564	Trib 16564 to McDonald Run

#### NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.080	Freedom 002	10.74	11.15	10.74	11.15	0	0

#### NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.080	Freedom 002	1.51	1.58	1.51	1.58	0	0

#### Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
0.08	Freedom 002	25	25	1.58	1.58	5	5	0	0

### Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
11A	16564	Trib 16564 to McDonald Run	0.080	992.00	0.38	0.00000	0.00	<input checked="" type="checkbox"/>

#### Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary		Stream	
	(cfsm)	(cfs)	(cfs)						Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.164	0.00	0.00	0.000	0.000	0.0	0.00	0.00	22.00	7.84	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

#### Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Freedom 002	PA0110361-02	0.9700	0.9700	0.9700	0.000	20.00	7.38

#### Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	5.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

### Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
11A	16564	Trib 16564 to McDonald Run	0.000	987.00	55.50	0.00000	0.00	<input checked="" type="checkbox"/>

#### Stream Data

Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	pH	Stream Temp (°C)	pH
Q7-10	0.164	0.00	0.00	0.000	0.000	0.0	0.00	0.00	22.00	7.84	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

#### Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00

#### Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

### WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
11A	16564	Trib 16564 to McDonald Run		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
0.080	0.970	20.080	7.391	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
7.597	0.574	13.238	0.359	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
24.08	1.495	1.52	0.704	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
5.130	40.404	Tsivoglou	5	
<u>Reach Travel Time (days)</u>	<b>Subreach Results</b>			
0.014	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
	0.001	24.03	1.52	5.27
	0.003	23.98	1.52	5.40
	0.004	23.93	1.52	5.52
	0.005	23.89	1.51	5.64
	0.007	23.84	1.51	5.75
	0.008	23.79	1.51	5.85
	0.010	23.74	1.51	5.95
	0.011	23.69	1.51	6.04
	0.012	23.64	1.51	6.13
	0.014	23.59	1.50	6.22



### WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
11A		16564				Trib 16564 to McDonald Run						
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
<b>Q7-10 Flow</b>												
0.080	0.06	0.00	0.06	1.5006	0.01184	.574	7.6	13.24	0.36	0.014	20.08	7.39
<b>Q1-10 Flow</b>												
0.080	0.06	0.00	0.06	1.5006	0.01184	NA	NA	NA	0.36	0.014	20.07	7.39
<b>Q30-10 Flow</b>												
0.080	0.07	0.00	0.07	1.5006	0.01184	NA	NA	NA	0.36	0.014	20.09	7.39

### WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.91	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.15	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		



## Discharge Information

Instructions Discharge Stream

Facility: Freedom Township WWTP NPDES Permit No.: PA0110361 Outfall No.: 001

Evaluation Type Major Sewage / Industrial Waste Wastewater Description: Sewage effluent

Discharge Characteristics								
Design Flow (MGD)*	Hardness (mg/l)*	pH (SU)*	Partial Mix Factors (PMFs)				Complete Mix Times (min)	
			AFC	CFC	THH	CRL	Q <sub>7-10</sub>	Q <sub>n</sub>
0.97	100	7.43						

				0 if left blank		0.5 if left blank		0 if left blank			1 if left blank			
Discharge Pollutant				Units	Max Discharge Conc	Trib Conc	Stream Conc	Daily CV	Hourly CV	Stream CV	Fate Coeff	FOS	Criteria Mod	Chem Transl
Group 1	Total Dissolved Solids (PWS)	mg/L		498										
	Chloride (PWS)	mg/L		150										
	Bromide	mg/L	<	0.2										
	Sulfate (PWS)	mg/L		38.4										
	Fluoride (PWS)	mg/L												
Group 2	Total Aluminum	µg/L												
	Total Antimony	µg/L												
	Total Arsenic	µg/L												
	Total Barium	µg/L												
	Total Beryllium	µg/L												
	Total Boron	µg/L												
	Total Cadmium	µg/L												
	Total Chromium (III)	µg/L												
	Hexavalent Chromium	µg/L												
	Total Cobalt	µg/L												
	Total Copper	µg/L		8										
	Free Cyanide	µg/L												
	Total Cyanide	µg/L												
	Dissolved Iron	µg/L												
	Total Iron	µg/L												
	Total Lead	µg/L		0.3										
	Total Manganese	µg/L												
	Total Mercury	µg/L												
	Total Nickel	µg/L												
	Total Phenols (Phenolics) (PWS)	µg/L												
	Total Selenium	µg/L												
	Total Silver	µg/L												
	Total Thallium	µg/L												
	Total Zinc	µg/L		95.4										
	Total Molybdenum	µg/L												
	Acrolein	µg/L	<											
	Acrylamide	µg/L	<											
	Acrylonitrile	µg/L	<											
	Benzene	µg/L	<											
	Bromoform	µg/L	<											
	Carbon Tetrachloride	µg/L	<											
	Chlorobenzene	µg/L												
	Chlorodibromomethane	µg/L	<											
	Chloroethane	µg/L	<											
	2-Chloroethyl Vinyl Ether	µg/L	<											



## Stream / Surface Water Information

Freedom Township WWTP, NPDES Permit No. PA0110361, Outfall 001

Instructions Discharge **Stream**

Receiving Surface Water Name: **Frankstown Branch Juniata River**

No. Reaches to Model: **1**

- ☒ Statewide Criteria  
☐ Great Lakes Criteria  
☐ ORSANCO Criteria

Location	Stream Code*	RMI*	Elevation (ft)*	DA (mi <sup>2</sup> )*	Slope (ft/ft)	PWS Withdrawal (MGD)	Apply Fish Criteria*
Point of Discharge	016061	39.74	987	55.5			Yes
End of Reach 1	016061	32.23	911	215			Yes

**Q<sub>7-10</sub>**

Location	RMI	LFY (cfs/mi <sup>2</sup> )*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness*	pH*	Hardness	pH
Point of Discharge	39.74	0.1643										135	7.84		
End of Reach 1	32.23	0.1643										135	7.84		

**Q<sub>n</sub>**

Location	RMI	LFY (cfs/mi <sup>2</sup> )	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness	pH	Hardness	pH
Point of Discharge	39.74														
End of Reach 1	32.23														



## Model Results

Freedom Township WWTP, NPDES Permit No. PA0110361, Outfall 001

Instructions

Results

RETURN TO INPUTS

SAVE AS PDF

PRINT

All

Inputs

Results

Limits

☐ Hydrodynamics

☒ Wasteload Allocations

☒ AFC

CCT (min): 15

PMF: 0.442

Analysis Hardness (mg/l): 125.51

Analysis pH: 7.69

Pollutants	Stream Conc	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Total Copper	0	0		0	16.647	17.3	64.0	Chem Translator of 0.96 applied
Total Lead	0	0		0	82.633	109	402	Chem Translator of 0.758 applied
Total Zinc	0	0		0	142.057	145	536	Chem Translator of 0.978 applied

☒ CFC

CCT (min): 76.670

PMF: 1

Analysis Hardness (mg/l): 130.05

Analysis pH: 7.75

Pollutants	Stream Conc	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Total Copper	0	0		0	11.210	11.7	82.6	Chem Translator of 0.96 applied
Total Lead	0	0		0	3.346	4.45	31.5	Chem Translator of 0.753 applied
Total Zinc	0	0		0	147.602	150	1,059	Chem Translator of 0.986 applied

☒ THH

CCT (min): 76.670

PMF: 1

Analysis Hardness (mg/l): N/A

Analysis pH: N/A

Pollutants	Stream Conc	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	500,000	500,000	N/A	
Chloride (PWS)	0	0		0	250,000	250,000	N/A	
Sulfate (PWS)	0	0		0	250,000	250,000	N/A	
Total Copper	0	0		0	N/A	N/A	N/A	
Total Lead	0	0		0	N/A	N/A	N/A	
Total Zinc	0	0		0	N/A	N/A	N/A	

☒ **CRL** CCT (min): 34.062 PMF: 1 Analysis Hardness (mg/l): N/A Analysis pH: N/A

Pollutants	Stream Conc	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Total Copper	0	0		0	N/A	N/A	N/A	
Total Lead	0	0		0	N/A	N/A	N/A	
Total Zinc	0	0		0	N/A	N/A	N/A	

☒ **Recommended WQBELs & Monitoring Requirements**

No. Samples/Month: 4

Pollutants	Mass Limits		Concentration Limits				Governing WQBEL	WQBEL Basis	Comments
	AML (lbs/day)	MDL (lbs/day)	AML	MDL	IMAX	Units			
Total Copper	Report	Report	Report	Report	Report	µg/L	41.0	AFC	Discharge Conc > 10% WQBEL (no RP)
Total Zinc	Report	Report	Report	Report	Report	µg/L	343	AFC	Discharge Conc > 10% WQBEL (no RP)

☒ **Other Pollutants without Limits or Monitoring**

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., <= Target QL).

Pollutants	Governing WQBEL	Units	Comments
Total Dissolved Solids (PWS)	N/A	N/A	PWS Not Applicable
Chloride (PWS)	N/A	N/A	PWS Not Applicable
Bromide	N/A	N/A	No WQS
Sulfate (PWS)	N/A	N/A	PWS Not Applicable
Total Lead	31.5	µg/L	Discharge Conc ≤ 10% WQBEL



## Discharge Information

Instructions Discharge Stream

Facility: Freedom Township WWTP NPDES Permit No.: PA0110361 Outfall No.: 002

Evaluation Type: Major Sewage / Industrial Waste Wastewater Description: Emergency sewage effluent

Discharge Characteristics								
Design Flow (MGD)*	Hardness (mg/l)*	pH (SU)*	Partial Mix Factors (PMFs)				Complete Mix Times (min)	
			AFC	CFC	THH	CRL	Q <sub>7-10</sub>	Q <sub>h</sub>
0.97	100	7.43						

				0 if left blank		0.5 if left blank		0 if left blank			1 if left blank				
Discharge Pollutant				Units	Max Discharge Conc	Trib Conc	Stream Conc	Daily CV	Hourly CV	Stream CV	Fate Coeff	FOS	Criteria Mod	Chem Trans	
Group 1	Total Dissolved Solids (PWS)	mg/L	498												
	Chloride (PWS)	mg/L	150												
	Bromide	mg/L	< 0.2												
	Sulfate (PWS)	mg/L	38.4												
	Fluoride (PWS)	mg/L													
Group 2	Total Aluminum	µg/L													
	Total Antimony	µg/L													
	Total Arsenic	µg/L													
	Total Barium	µg/L													
	Total Beryllium	µg/L													
	Total Boron	µg/L													
	Total Cadmium	µg/L													
	Total Chromium (III)	µg/L													
	Hexavalent Chromium	µg/L													
	Total Cobalt	µg/L													
	Total Copper	µg/L	8												
	Free Cyanide	µg/L													
	Total Cyanide	µg/L													
	Dissolved Iron	µg/L													
	Total Iron	µg/L													
	Total Lead	µg/L	0.3												
	Total Manganese	µg/L													
	Total Mercury	µg/L													
	Total Nickel	µg/L													
	Total Phenols (Phenolics) (PWS)	µg/L													
	Total Selenium	µg/L													
	Total Silver	µg/L													
	Total Thallium	µg/L													
	Total Zinc	µg/L	95.4												
	Total Molybdenum	µg/L													
	Acrolein	µg/L	<												
	Acrylamide	µg/L	<												
	Acrylonitrile	µg/L	<												
	Benzene	µg/L	<												
	Bromoform	µg/L	<												



## Stream / Surface Water Information

Freedom Township WWTP, NPDES Permit No. PA0110361, Outfall 002

Instructions Discharge **Stream**

Receiving Surface Water Name: **Trib 16564 To McDonald Run**

No. Reaches to Model: **1**

- ☒ Statewide Criteria  
☐ Great Lakes Criteria  
☐ ORSANCO Criteria

Location	Stream Code*	RMI*	Elevation (ft)*	DA (mi <sup>2</sup> )*	Slope (ft/ft)	PWS Withdrawal (MGD)	Apply Fish Criteria*
Point of Discharge	016564	0.08	992	0.38			Yes
End of Reach 1	016564	0	987	55.5			Yes

**Q<sub>7-10</sub>**

Location	RMI	LFY (cfs/mi <sup>2</sup> )*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness*	pH*	Hardness	pH
Point of Discharge	0.08	0.1643										135	7.84		
End of Reach 1	0	0.1643										135	7.84		

**Q<sub>n</sub>**

Location	RMI	LFY (cfs/mi <sup>2</sup> )	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness	pH	Hardness	pH
Point of Discharge	0.08														
End of Reach 1	0														





## Model Results

Freedom Township WWTP, NPDES Permit No. PA0110361, Outfall 002

Instructions

Results

RETURN TO INPUTS

SAVE AS PDF

PRINT

☒ All

☐ Inputs

☐ Results

☐ Limits

☐ Hydrodynamics

☒ Wasteload Allocations

☒ AFC

CCT (min): 0.003

PMF: 1

Analysis Hardness (mg/l): 101.4

Analysis pH: 7.44

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Total Copper	0	0		0	13.616	14.2	14.8	Chem Translator of 0.96 applied
Total Lead	0	0		0	65.565	83.1	86.6	Chem Translator of 0.789 applied
Total Zinc	0	0		0	118.567	121	126	Chem Translator of 0.978 applied

☒ CFC

CCT (min): 0.003

PMF: 1

Analysis Hardness (mg/l): 101.4

Analysis pH: 7.44

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Total Copper	0	0		0	9.063	9.44	9.83	Chem Translator of 0.96 applied
Total Lead	0	0		0	2.555	3.24	3.37	Chem Translator of 0.789 applied
Total Zinc	0	0		0	119.537	121	126	Chem Translator of 0.986 applied

☒ THH

CCT (min): 0.003

PMF: 1

Analysis Hardness (mg/l): N/A

Analysis pH: N/A

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	500,000	500,000	N/A	
Chloride (PWS)	0	0		0	250,000	250,000	N/A	
Sulfate (PWS)	0	0		0	250,000	250,000	N/A	

Model Results

9/9/2022

Page 5

**NPDES Permit Fact Sheet  
Freedom Township STP**

**NPDES Permit No. PA0110361**

Total Copper	0	0		0	N/A	N/A	N/A	
Total Lead	0	0		0	N/A	N/A	N/A	
Total Zinc	0	0		0	N/A	N/A	N/A	

☒ **CRL**

CCT (min): **0.126**

PMF: **1**

Analysis Hardness (mg/l): **N/A**

Analysis pH: **N/A**

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Total Copper	0	0		0	N/A	N/A	N/A	
Total Lead	0	0		0	N/A	N/A	N/A	
Total Zinc	0	0		0	N/A	N/A	N/A	

☒ **Recommended WQBELs & Monitoring Requirements**

No. Samples/Month: **4**

Pollutants	Mass Limits		Concentration Limits				Governing WQBEL	WQBEL Basis	Comments
	AML (lbs/day)	MDL (lbs/day)	AML	MDL	IMAX	Units			
Total Copper	0.08	0.12	9.83	14.8	14.8	µg/L	9.83	CFC	Discharge Conc ≥ 50% WQBEL (RP)
Total Zinc	0.98	1.02	121	126	126	µg/L	121	AFC	Discharge Conc ≥ 50% WQBEL (RP)

☒ **Other Pollutants without Limits or Monitoring**

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., <= Target QL).

Pollutants	Governing WQBEL	Units	Comments
Total Dissolved Solids (PWS)	N/A	N/A	PWS Not Applicable
Chloride (PWS)	N/A	N/A	PWS Not Applicable
Bromide	N/A	N/A	No WQS
Sulfate (PWS)	N/A	N/A	PWS Not Applicable
Total Lead	3.37	µg/L	Discharge Conc ≤ 10% WQBEL