

Application Type Renewal
 Facility Type Non-Municipal
 Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0111368
 APS ID 1118944
 Authorization ID 1494199



Applicant and Facility Information

Applicant Name	<u>Jersey Shore Area School District</u>	Facility Name	<u>Jersey Shore Area School District STP</u>
Applicant Address	<u>175 A And P Drive</u> <u>Jersey Shore, PA 17740-7814</u>	Facility Address	<u>2490 Route 287 Highway</u> <u>Jersey Shore, PA 17740</u>
Applicant Contact	<u>Mark Wall</u>	Facility Contact	<u>Mark Wall</u>
Applicant Phone	<u>(570) 398-5055</u>	Facility Phone	<u>(570) 398-5055</u>
Client ID	<u>172</u>	Site ID	<u>259556</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Mifflin Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Lycoming</u>
Date Application Received	<u>August 1, 2024</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>August 7, 2024</u>	If No, Reason	<u></u>
Purpose of Application	<u>Renewal of an existing NPDES permit for the discharge of treated sewage.</u>		

Summary of Review

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

The Salladasburg Elementary School Wastewater Treatment Plant is a package extended aeration treatment plant with an annual average design flow and hydraulic design capacity of 0.0047 MGD and an organic capacity of 33.3 lbs BOD5/day, owned and operated by the Jersey Shore Area School District.

Approve	Deny	Signatures	Date
X		 Jonathan P. Peterman / Project Manager	April 1, 2026
X		 Nicholas W. Hartranft, P.E. / Environmental Engineer Manager	April 3, 2026

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.0047</u>
Latitude	<u>41° 15' 55.93"</u>	Longitude	<u>-77° 13' 54.81"</u>
Quad Name	<u>Salladasburg</u>	Quad Code	<u>0828</u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Larrys Creek (EV (existing use))</u>	Stream Code	<u>21014</u>
NHD Com ID	<u>66915667</u>	RMI	<u>4.24</u>
Drainage Area	<u>62.49</u>	Yield (cfs/mi ²)	<u>0.034</u>
Q ₇₋₁₀ Flow (cfs)	<u>2.11</u>	Q ₇₋₁₀ Basis	<u>Gage No. 01549780</u>
Elevation (ft)	<u>618</u>	Slope (ft/ft)	<u>n/a</u>
Watershed No.	<u>10-A</u>	Chapter 93 Class.	<u>WWF</u>
Existing Use	<u>Exceptional Value (EV)</u>	Existing Use Qualifier	<u>RBP - Antidegradation</u>
Exceptions to Use	<u>n/a</u>	Exceptions to Criteria	<u>n/a</u>
Assessment Status	<u>Attaining Use(s)</u>		
Cause(s) of Impairment	<u>n/a</u>		
Source(s) of Impairment	<u>n/a</u>		
TMDL Status	<u>n/a</u>	Name	<u>n/a</u>
Nearest Downstream Public Water Supply Intake	<u>PA American White Deer</u>		
PWS Waters	<u>West Branch Susquehanna River</u>	Flow at Intake (cfs)	<u>680</u>
PWS RMI	<u>10.5</u>	Distance from Outfall (mi)	<u>36</u>

Changes Since Last Permit Issuance: None.

Other Comments: None.

DEP has evaluated information indicating that the existing use of the receiving waters is different than the designated use under 25 Pa. Code § 93.9. In developing the draft NPDES permit, DEP is proposing to protect the existing use of the receiving waters. Following DEP's notice of the receipt of the application and the draft permit in the Pennsylvania Bulletin, DEP will accept written comments during the public comment period regarding DEP's tentative determination to protect the existing use. DEP will make a final determination on existing use protection for the receiving waters as part of the final permit action.

Treatment Facility Summary				
Treatment Facility Name: Jersey Shore Area School District				
WQM Permit No.	Issuance Date	Comments		
4115401	2/22/2016	UV disinfection		
266S014	5/25/1966	Original Construction		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary	Extended Aeration	Ultraviolet	0.0047
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.0047	33.3	Not Overloaded	Holding Tank	Other WWTP

Treatment System Components:

- One (1) comminutor
- One (1) manual bar screen
- One (1) aeration tank
- One (1) clarifier tank
- Two (2) ultraviolet disinfection units
- One (1) sludge holding tank

Disinfected effluent is ultimately discharged via Outfall 001 to Larry's Creek.

Changes Since Last Permit Issuance: None.
 Other Comments: None.

TMDL Impairment

The Department's Geographic Information System (GIS) shows that Larry's Creek is not impaired and a TMDL doesn't exist for the stream segment. No further review is required.

Chesapeake Bay Requirements

Since this facility's annual average design flow is 0.0047 MGD, the permittee will be required to monitor and report TN and TP throughout the permit term at a frequency no less than annually in accordance with the Phase III WIP Chesapeake Bay Strategy for Phase V facilities (0.002 MGD to 0.2 MGD) unless 1) the facility has already conducted at least two years of nutrient monitoring and 2) a summary of the monitoring results are included in the next permit's fact sheet. Monitoring for these parameters was conducted over the previous permit term and the yearly monitoring requirements for nutrients will be removed accordingly. No further monitoring is required at this time.

The facility has completed five years' worth of sampling for total nitrogen and total phosphorus. The sample results are as follows:

Monitoring Period	Concentrations (mg/l)	
	Total Nitrogen	Total Phosphorus
2015	24.1	2.1
2016	11	2.68
2017	22.88	0.2
2018	8.83	1.89
AVG	16.70	1.72

Anti-Backsliding

In accordance with 40 CFR 122.44(l)(1) and (2), this permit does not contain effluent limitations, standards, or conditions that are less stringent than the previous permit.

Biosolids Use/Disposal

Sludge is hauled to the Tiadaghton Valley Municipal Authority (TVMA) Wastewater Treatment Plant (NPDES Permit No. PA0234079).

Existing Effluent Limitations and Monitoring Requirements

Existing Limits

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Instantaneous Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	5/week	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	5/week	Grab
Dissolved Oxygen	XXX	XXX	5.0	XXX	XXX	XXX	5/week	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5)	XXX	XXX	XXX	25.0	XXX	50.0	1/month	Grab
Total Suspended Solids	XXX	XXX	XXX	30.0	XXX	60.0	1/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/month	Grab
Ultraviolet light transmittance (%)	XXX	XXX	Report	XXX	XXX	XXX	5/week	Grab
Ammonia-Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	1/month	Grab

*The existing effluent limits for Outfall 001 were based on a design flow of 0.0047 MGD.

Development of Effluent Limitations

Outfall No. <u>001</u>	Design Flow (MGD) <u>0.0047</u>
Latitude <u>41° 15' 55.93"</u>	Longitude <u>-77° 13' 54.81"</u>
Wastewater Description: <u>Sewage Effluent</u>	

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Water Quality-Based Limitations

To establish whether or not water-quality based effluent limitations (WQBELs) are required, the Department models in-stream conditions. In order to determine limitations for CBOD₅, ammonia-N and dissolved oxygen, the Department utilizes the WQM 7.0 v1.0b model and in order to determine limitations for toxics, the Department utilizes Toxics Management Spreadsheet (TMS). The TMS was not utilized or this review.

WQM 7.0 for Windows, Version 1.0b, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen

The model was run using the Q7-10 stream flow, background water quality, average annual design flow, and other discharge characteristics. The previously existing technology-based effluent limits for CBOD₅ (25 mg/l) and NH₃-N (3 mg/l) were used as inputs for the modeling. The DO minimum daily average criterion from §93.7 (6.0 mg/L for CWF) was used for the in-stream objective for the model. The summary of the output is as follows:

Parameter	Effluent Limit		
	30 Day Average	Maximum	Minimum
CBOD₅	25	N/A	N/A
Ammonia-N	25	50	N/A
Dissolved Oxygen	N/A	N/A	3

The model does not recommend more stringent water-quality based effluent limitations with regards to CBOD₅ and dissolved oxygen, and ammonia-nitrogen. Refer to Appendix B for the WQM 7.0 inputs and results.

Best Professional Judgment (BPJ) Limitations

See Dissolved Oxygen section below.

Additional Considerations

None

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst the abovementioned technology, water quality, and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001) and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Instantaneous Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	5/week	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	5/week	Grab
Dissolved Oxygen	XXX	XXX	5.0	XXX	XXX	XXX	5/week	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5)	XXX	XXX	XXX	25.0	XXX	50.0	1/month	Grab
Total Suspended Solids	XXX	XXX	XXX	30.0	XXX	60.0	1/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/month	Grab
Ultraviolet light transmittance (%)	XXX	XXX	Report	XXX	XXX	XXX	5/week	Grab
Ammonia-Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	1/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab

*The proposed effluent limits for Outfall 001 were based on a design flow of 0.0047 MGD.

General Information

All of the limits proposed above are consistent with other permits issued for wastewater treatment plants in the region. The associated mass-based limits (lbs/day) for all parameters were based on the formula: design flow (average annual) (MGD) x concentration limit (mg/L) at design flow x conversion factor (8.34). All effluent limits were then rounded down in accordance with the rounding rules established in the *Technical Guidance for the Development and Specification of Effluent Limitations (362-0400-001)*, Chapter 5 - Specifying Effluent Limitations in NPDES Permits.

Flow

The existing monitoring frequency (5/week) and sample type (Measured) will remain.

Carbonaceous Biochemical Oxygen Demand (CBOD₅)

The results of the WQM 7.0 model showed that the previously applied advanced treatment requirements for CBOD₅ were protective of water quality and will remain.

Total Suspended Solids (TSS)

The previously applied advanced treatment requirements for TSS will remain as well.

pH

CFR Title 40 §133.102(c) and 25 PA Code §95.2(1) provide the basis of effluent limitations for pH.

Fecal Coliforms

The existing fecal coliform limits with I-max limits were updated from the previous Chapter 92 code to correspond with what is specified in the updated 25 PA Code § 92a.47 (a)(4)&(5).

U.V. Transmittance

The facility uses a meter for this monitoring and the daily sample type (Meter) is appropriate. The output of the existing meter has been verified to report ultraviolet light transmittance. The facility no longer uses chlorine disinfection.

Ammonia-Nitrogen (NH₃-N)

The WQM 7.0 model indicated that the existing water quality-based limits for ammonia were adequate. These limits were previously assigned in accordance with the *Implementation Guidance of Section 93.7 Ammonia Criteria* (391-2000-013) which states that a multiplier of 2.0 times the average monthly concentration limit (3 mg/L) was used to establish the I-max concentration limit (6 mg/L). The existing effluent limits will remain.

Dissolved Oxygen (DO)

Given results of the WQM 7.0 model, a discharge of effluent from this facility with a DO concentration of 3 mg/l would not result in an exceedance of water quality requirements for this stream. It is anticipated, that the DO concentration in the effluent would be greater than 3.0 mg/l. Therefore, based on BPJ, only monitoring will be required for this facility.

E. Coli

25 PA Code § 92a.61 provides the basis of monitoring requirements for E. Coli. Yearly monitoring will be required going forward.

Compliance History

Summary of Inspections -The last inspection of the facility was conducted by the Department on 10/29/25. The inspection indicates that the facility is operating normally and no violations were noted.

WMS Query Summary - A WMS Query was run at *Reports - Violations & Enforcements – Open Violations for Client Report* to determine whether there are any unresolved violations associated with the client that will affect issuance of the permit (per CSL Section 609). This query revealed no open violations.

eDMRs Summary - Upon review of the eDMR results, the facility is operating within their effluent limits which are listed below.

Compliance History

DMR Data for Outfall 001 (from February 1, 2025 to January 31, 2026)

Parameter	JAN-26	DEC-25	NOV-25	OCT-25	SEP-25	AUG-25	JUL-25	JUN-25	MAY-25	APR-25	MAR-25	FEB-25
Flow (MGD) Average Monthly									0.00177	0.00185	0.00188	0.00177
Flow (MGD) Daily Maximum									0.00215	0.00211	0.00208	0.00242
pH (S.U.) Instantaneous Minimum									6.63	6.03	6.62	6.63
pH (S.U.) Instantaneous Maximum									7.13	7.20	7.18	7.26
DO (mg/L) Instantaneous Minimum									9.3	9.3	9.7	10.0
CBOD5 (mg/L) Average Monthly									< 3.0	4.0	6.4	1.8
CBOD5 (mg/L) Instantaneous Maximum									< 3.0	4.0	6.4	1.8
TSS (mg/L) Average Monthly									4.0	< 4.0	8.0	4.0
TSS (mg/L) Instantaneous Maximum									4.0	< 4.0	8.0	4.0
Fecal Coliform (No./100 ml) Geometric Mean									< 1.0	< 1.0	< 1.0	< 1.0
Fecal Coliform (No./100 ml) Instantaneous Maximum									< 1.0	< 1.0	< 1.0	< 1.0
UV Transmittance (%) Instantaneous Minimum									62.4	61.5	63.6	63.5
Ammonia (mg/L) Average Monthly									< 0.10	< 0.10	< 0.10	< 0.10

APPENDIX A

PREVIOUS Q7-10 ANALYSIS AND STREAM DATA

Low-Flow (Q₇₋₁₀) Calculation

Facility: Jersey Shore Area School District WWTP
NPDES Permit No. PA0111368

Gage Information

Drainage Area: 6.8 mi²
Q₇₋₁₀: 0.23 cfs
LFY: 0.034 cfsm

Outfall Information

Drainage Area: 62.49 mi²
Q₇₋₁₀: 2.11 cfs

Downstream Locations

RMI: 3.08
Drainage Area: 81.13 mi²
Q₇₋₁₀: 2.744 cfs

RMI: _____
Drainage Area: _____ mi²
Q₇₋₁₀: _____ cfs

RMI: _____
Drainage Area: _____ mi²
Q₇₋₁₀: _____ cfs

RMI: _____
Drainage Area: _____ mi²
Q₇₋₁₀: _____ cfs

RMI: _____
Drainage Area: _____ mi²
Q₇₋₁₀: _____ cfs

RMI: _____
Drainage Area: _____ mi²
Q₇₋₁₀: _____ cfs

RMI: _____
Drainage Area: _____ mi²
Q₇₋₁₀: _____ cfs

RMI: _____
Drainage Area: _____ mi²
Q₇₋₁₀: _____ cfs

APPENDIX B

WQM 7.0 MODEL INPUT/OUTPUT

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
10A	21014	LARRYS CREEK	3.080	580.00	81.13	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.034	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
10A	21014	LARRYS CREEK	4.240	620.00	62.49	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary		Stream	
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.034	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
JSASD WWTP	PA0111368	0.0047	0.0047	0.0047	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>			<u>Stream Name</u>							
10A		21014			LARRYS CREEK							
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
Q7-10 Flow												
4.240	2.12	0.00	2.12	.0073	0.00653	.625	25.8	41.26	0.13	0.536	20.02	7.00
Q1-10 Flow												
4.240	1.19	0.00	1.19	.0073	0.00653	NA	NA	NA	0.10	0.741	20.03	7.00
Q30-10 Flow												
4.240	3.04	0.00	3.04	.0073	0.00653	NA	NA	NA	0.16	0.439	20.01	7.00

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.56	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.43	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		

WQM 7.0 Wasteload Allocations

SWP Basin Stream Code Stream Name
 10A 21014 LARRYS CREEK

NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
4.240	JSASD WWTP	9.65	50	9.65	50	0	0

NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
4.240	JSASD WWTP	1.92	25	1.92	25	0	0

Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
4.24	JSASD WWTP	25	25	25	25	3	3	0	0

WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
10A	21014	LARRYS CREEK		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>		<u>Analysis pH</u>
4.240	0.005	20.017		7.000
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>		<u>Reach Velocity (fps)</u>
25.799	0.625	41.259		0.132
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>		<u>Reach Kn (1/days)</u>
2.08	0.043	0.09		0.701
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>		<u>Reach DO Goal (mg/L)</u>
8.225	8.204	Tsivoglou		6
<u>Reach Travel Time (days)</u>	Subreach Results			
0.536	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.054	2.07	0.08	8.24
	0.107	2.07	0.08	8.24
	0.161	2.06	0.08	8.24
	0.215	2.06	0.07	8.24
	0.268	2.05	0.07	8.24
	0.322	2.05	0.07	8.24
	0.375	2.05	0.07	8.24
	0.429	2.04	0.06	8.24
	0.483	2.04	0.06	8.24
	0.536	2.03	0.06	8.24

WQM 7.0 Effluent Limits

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>			
10A		21014		LARRYS CREEK			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
4.240	JSASD WWTP	PA0111368	0.005	CBOD5	25		
				NH3-N	25	50	
				Dissolved Oxygen			3

APPENDIX C

FACILITY MAP