

Northcentral Regional Office CLEAN WATER PROGRAM

Application Type

Renewal

Non
Facility Type

Major / Minor

Minor

NPDES PERMIT FACT SHEET INDIVIDUAL SEWAGE

 Application No.
 PA0113221

 APS ID
 1020927

 Authorization ID
 1322433

Applicant Name	Youth	Challenge Int Bible Institution	Facility Name	Youth Challenge International
Applicant Address	155 N	Williamson Road	Facility Address	1810 Snydertown Road
	Blossl	burg, PA 16912-1215		Sunbury, PA 17801
Applicant Contact	John	Rakow (jrrakow@yahoo.com)	Facility Contact	John Rakow
Applicant Phone	(570)	850-0526	Facility Phone	(570) 850-0526
Client ID	53079)	Site ID	241954
Ch 94 Load Status	Not O	verloaded	Municipality	Upper Augusta Township
Connection Status	No Lir	nitations	County	Northumberland
Date Application Rece	eived	August 4, 2020	EPA Waived?	Yes
Date Application Acce	pted	August 10, 2020	If No, Reason	N/A

Summary of Review

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
Χ		Jonathan P. Peterman	
Λ		Jonathan P. Peterman / Project Manager	January 28, 2021
Χ		Nicholas W. Hartranft	
Λ		Nicholas W. Hartranft, P.E. / Environmental Engineer Manager	January 29, 2021

	Discharge, Receiving Wate	ers and Water Supply Informa	tion
Outfall No. 001		Design Flow (MGD)	0.019
Latitude 40° 5	2' 17.40"	Longitude	76° 43' 50.70"
Quad Name Trevorton		Quad Code	1232
Wastewater Descrip	otion: <u>Sewage</u>		
Receiving Waters	Unnamed Tributary of Shamokin Creek (CWF)	Stream Code	18549
NHD Com ID	54961209	RMI	0.06
Drainage Area	0.34	Yield (cfs/mi²)	0.4
Q ₇₋₁₀ Flow (cfs)	0.138	Q ₇₋₁₀ Basis	Gage No. 1554500
Elevation (ft)	567	Slope (ft/ft)	0.003
Watershed No.	6-B	Chapter 93 Class.	CWF
Existing Use	CWF	Existing Use Qualifier	N/A
Exceptions to Use	None.	Exceptions to Criteria	None
Assessment Status	_Impaired		
Cause(s) of Impairn	ment Metals, pH		
Source(s) of Impair	ment AMD		
TMDL Status	Final, 04/09/2001	Name Shamokin C	reek Watershed
	m Public Water Supply Intake Susquehanna River	Harrisburg Municipal Water A	uthority 2610
PWS RMI 7	74	Distance from Outfall (mi)	65

Changes Since Last Permit Issuance: Changes Since Last Permit Issuance: The updated Q_{7-10} data was obtained from the updated stream gage information obtained from *Stuckey, M.H., and Roland, M.A., 2011, Selected Streamflow Statistics for Streamgage Locations In and Near Pennsylvania.* A Q_{7-10} analysis was conducted using an upstream stream gage (01554500) as the reference stream gage. The Q_{7-10} calculations, which are attached in Appendix A, indicate that the Q_{7-10} is 0.138 cfs.

In order to determine the Q_{7-10} low flow for the West Branch of the Susquehanna River, which is considered the point of first use given that Shamokin Creek is considered § 95.5(a), a local stream gage was utilized. The Q_{7-10} of the stream gage located slightly up river from the confluence was used directly in the analysis. The Q_{7-10} calculations are attached in Appendix A.

Other Comments: None.

Treatment Facility Summary

Treatment Facility Name: Youth Challenge International Bible Institution

WQM Permit No.	Issuance Date	Notes:
4986408	9/3/1987	Initial construction.

Waste Type	Degree of Treatment	Process Type	Disinfection	Design Flow (MGD)
Sewage	Secondary	Extended Aeration	Hypochlorite	0.019
Hydraulic Capacity	Organic Capacity			Biosolids
(MGD)	(lbs/day)	Load Status	Biosolids Treatment	Use/Disposal
0.025		Not Overloaded		Other WWTP

Treatment System Components for Outfall 001:

- One (1) Influent Bar Screen.
- One (1) 26,700 Gallon Aeration Tank.
- One (1) 4,900 Gallon Clarifier.
- One (1) Tablet Erosion Chlorinator.
- One (1) Chlorine Contact Tank.
- One (1) Outfall 001 to Unnamed Tributary of Shamokin Creek.

Sludge use and disposal description and location(s): Other WWTP

Changes Since Last Permit Issuance: None.

Other Comments: None.

Anti-Backsliding

In accordance with 40 CFR 122.44(I)(1) and (2), this permit does not contain effluent limitations, standards, or conditions that are less stringent than the previous permit.

TMDL Impairment

Shamokin Creek TMDL

The Department's Geographic Information System (GIS) shows that Shamokin Creek is impaired and a TMDL does exist for the stream segment. High levels of metals caused these impairments (iron, manganese, aluminum). All impairments resulted from acid mine drainage. The TMDL addresses the three primary metals associated with acid mine drainage (iron, manganese, aluminum) as well as depressed pH. There is currently no industrial waste being discharged into the treatment plant and this discharge is not expected to contribute to the level of metals in the stream. The system does receive effluent from rental businesses and restaurants, but the flow contribution from these combined businesses account for less than 1% of the total flow. Given the regulations contained in 40 CFR §122.44(d)(1)(ii)&(iii), it can be determined that the type of effluent from this facility has no "Reasonable potential to cause, or contributes to an in-stream excursion above the allowable ambient concentration of a State numeric criteria within a State water quality standard for an individual pollutant." Therefore, the permit will not be required to contain effluent limits for the pollutant addressed in the TMDL. Since the TMDL does not assign any wasteload allocations to this facility, it is not authorized to discharge these metals of concern. To ensure that this facility is not discharging these pollutants in levels that will contribute to the impairment of the stream, yearly monitoring for these parameters will be placed in the permit.

Chesapeake Bay Requirements

Since this facility's annual average design flow is 0.025 MGD, the permittee will be required to monitor and report TN and TP throughout the permit term at a frequency no less than annually in accordance with the Phase II WIP Chesapeake Bay Strategy for Phase V facilities (0.002 MGD to 0.2 MGD) unless 1) the facility has already conducted at least two years of nutrient monitoring and 2) a summary of the monitoring results are included in the next permit's fact sheet. Since the permittee has not discharged, this monitoring has not been completed and the nutrient monitoring will remain until completed.

Existing Effluent Limitations and Monitoring Requirements

Existing Limits – Outfall 001

	Effluent Limitations					Monitoring Requirements		
Parameter	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾	Required
	Annual Average	Total Annual	Minimum	Average Monthly	Daily Maximum	Instant. Maximum	Measurement Frequency	Sample Type
Flow (MGD)	Report Avg Mo	XXX	XXX	XXX	XXX	XXX	1/week	Metered
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
Dissolved Oxygen	XXX	XXX	Report	XXX	XXX	XXX	1/day	Grab
Total Residual Chlorine	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD5	XXX	XXX	XXX	25	XXX	50	2/month	Grab
Total Suspended Solids	XXX	XXX	XXX	30	XXX	60	2/month	Grab
Fecal Coliform (CFU/100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1,000	2/month	Grab
Fecal Coliform (CFU/100 ml) Oct 1 - Apr 30	xxx	XXX	xxx	2,000 Geo Mean	xxx	10,000	2/month	Grab
Ammonia-Nitrogen	XXX	XXX	XXX	Report	XXX	Report	1/6 months	Grab
Total Aluminum	XXX	XXX	XXX	Report	Report	XXX	1/year	Grab
Total Iron	XXX	XXX	XXX	Report	Report	XXX	1/year	Grab
Total Manganese	XXX	XXX	XXX	Report	Report	XXX	1/year	Grab

^{*}The existing effluent limits for Outfall 001 were based on a design flow of 0.019 MGD.

Development of Effluent Limitations

Outfall No.001Design Flow (MGD)0.019Latitude40° 52' 17.40"Longitude76° 43' 50.70"Wastewater Description: Treated Sewage Effluent

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
CBOD5	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
Solids	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform				
(5/1 - 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform	1,000 / 100 ml	IMAX	-	92a.47(a)(4)

(5/1 - 9/30)				
Fecal Coliform				
(10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform				
(10/1 - 4/30)	10,000 / 100 ml	IMAX	=	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Water Quality-Based Limitations

Water quality-based limits are not necessary to protect the receiving stream under chapter 95.5 of the Department's rules and regulations when significant impairment from AMD exists. 25 PA Code § 95.5(a) stipulates that water quality modeling is not necessary and secondary limits (technology based) will apply for discharges to AMD-impaired streams where "the applicable water quality criteria are not being met and designated water uses are no being achieved to the extent that aquatic communities are essentially excluded." The stream is listed on the 303(d) list for AMD impairment and the condition of the Shamokin Creek has been previously verified. The stream is not expected to improve significantly and no further downstream waters would be affected by the existing discharges.

Comments: None.

Best Professional Judgment (BPJ) Limitations

See Dissolved Oxygen section below.

Comments: None.

Additional Considerations

None

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst the abovementioned technology, water quality, and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001) and/or BPJ.

Proposed Limits - Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date

	Effluent Limitations					Monitoring Requirements		
Parameter	Mass Units (Ibs/day) (1) Annual Total Average Annual		Concentrations (mg/L)				Minimum ⁽²⁾	Required
			Instant. Minimum	Average Monthly	Daily Maximum	Instant. Maximum	Measurement Frequency	Sample Type
Flow (MGD)	Report Avg Mo	XXX	XXX	XXX	XXX	XXX	1/week	Metered
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
Dissolved Oxygen	XXX	XXX	Report	XXX	XXX	XXX	1/day	Grab
Total Residual Chlorine	XXX	XXX	xxx	0.5	XXX	1.6	1/day	Grab
CBOD5	XXX	XXX	XXX	25	XXX	50	2/month	Grab
Total Suspended Solids	XXX	XXX	XXX	30	XXX	60	2/month	Grab
Fecal Coliform (No./100 ml)				200 Geo				
May 1 - Sep 30	XXX	XXX	XXX	Mean	XXX	1,000	2/month	Grab

	Effluent Limitations					Monitoring Requirements		
Parameter	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾	Required
	Annual Total Average Annual		Instant. Minimum	Average Monthly	Daily Maximum	Instant. Maximum	Measurement Frequency	Sample Type
Fecal Coliform				2,000				
(No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	Geo Mean	XXX	10,000	2/month	Grab
Ammonia-Nitrogen	XXX	XXX	XXX	Report	XXX	Report	1/6 months	Grab
Total Nitrogen	Report	Report	XXX	Report Annl Avg	XXX	XXX	1/year	Grab
Total Phosphorus	Report	Report	XXX	Report Annl Avg	XXX	XXX	1/year	Grab
Total Aluminum	XXX	XXX	XXX	Report	Report	XXX	1/year	Grab
Total Iron	XXX	XXX	XXX	Report	Report	XXX	1/year	Grab
Total Manganese	XXX	XXX	XXX	Report	Report	XXX	1/year	Grab

^{*}The proposed effluent limits for Outfall 001 were based on a design flow of 0.019 MGD.

Effluent Limit Determination for Outfall 001

General Information

The associated mass-based limits (lbs/day) for all parameters were based on the formula: design flow (average annual) (MGD) x concentration limit (mg/L) at design flow x conversion factor (8.34). All effluent limits were then rounded down in accordance with the rounding rules established in the *Technical Guidance for the Development and Specification of Effluent Limitations* (362-0400-001), Chapter 5 - Specifying Effluent Limitations in NPDES Permits. The existing monitoring frequencies and sample types for these parameters generally correspond with the *Technical Guidance for the Development and Specification of Effluent Limitations* (362-0400-001) Table 6-3 and will remain.

Flow

Reporting of the average monthly flow is consistent with monitoring requirements for other treatment plants of this size.

Carbonaceous Biochemical Oxygen Demand (CBOD₅)

The previously applied technology-based secondary treatment standards (25 PA Code §92a.47 (a) (1&2)) for CBOD₅ will remain as water quality-based limits are not required given that the stream is void of aquatic life. The existing limits will remain.

<u>Total Suspended Solids (TSS)</u>

The previously applied technology-based secondary treatment standards (25 PA Code §92a.47 (a) (1&2)) for TSS will remain as well.

nН

CFR Title 40 §133.102(c) and 25 PA Code §95.2(1) provide the basis of effluent limitations for pH. The existing limits will remain.

Total Residual Chlorine (TRC)

A TRC model evaluation was conducted by using the technology-based effluent limitation as input and the West Branch of the Susquehanna River as the point of first use. In accordance with 25 Pa. Code 92a.48(b)(2), a BAT value of 0.5 mg/l was used. The attached TRC model indicates that the technology based effluent limit of 0.5 mg/L (Average Monthly) and 1.6 mg/L (Instantaneous Maximum) are protective of water quality and will remain.

Fecal Coliforms

The existing fecal coliform limits with I-max limits were updated from the previous Chapter 92 code to correspond with what is specified in the updated 25 PA Code § 92a.47 (a)(4)&(5).

Ammonia-Nitrogen (NH3-N)

Based on BPJ, monitoring for NH3-N is proposed. However, since it is anticipated that the treatment method utilized at this facility will consistently meet the technology based effluent limits, a monitoring frequency of 1/6 months was previously implemented. The existing monitoring requirements will remain.

Dissolved Oxygen (DO)

Based on BPJ, only monitoring will be required for this facility. This will also provide historical data to establish baseline DO levels in the effluent for future reviews.

Compliance History

<u>Summary of Inspections</u> -The most recent Clean Water Program onsite inspections for this facility were a Compliance Evaluation Inspection on 12/31/19. The inspection stated that there had been no discharge from the system at that time and no operational issues were noted.

<u>WMS Query Summary</u> - A WMS Query was run at *Reports - Violations & Enforcements - Open Violations for Client Report* to determine whether there are any unresolved violations associated with the client that will affect issuance of the permit (per CSL Section 609). This query revealed no open violations.

Attachments



Appendices

	Tools and References Used to Develop Permit
	WQM for Windows Model (see Attachment)
	PENTOXSD for Windows Model (see Attachment)
$\overline{\boxtimes}$	TRC Model Spreadsheet (see Attachment B)
	Temperature Model Spreadsheet (see Attachment)
	Toxics Screening Analysis Spreadsheet (see Attachment)
	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
	Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97.
	Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98.
\boxtimes	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96.
	Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97.
	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97.
	Pennsylvania CSO Policy, 385-2000-011, 9/08.
	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97.
	Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97.
	Implementation Guidance Design Conditions, 391-2000-006, 9/97.
	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004.
	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997.
	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99.
	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004.
\boxtimes	Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97.
	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008.
\boxtimes	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994.
	Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09.
	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97.
	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97.
	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99.
	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999.
\boxtimes	Design Stream Flows, 391-2000-023, 9/98.
	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98.
	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97.
\boxtimes	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
	SOP:
	Other:

APPENDIX A Q₇₋₁₀ ANALYSIS AND STREAM DATA

	Q ₇₋₁₀	Analysis
Facility		
Outfal	1: 001	
Reference Stre	am Gage Information	- Was I
Stream Name	Shamokin Creek	Correlati
Reference Gage	1554500	
Station Name	Shamokin Creek near Shamokin, PA	500 200 and 100
Gage Drainage Area (sq. ml.)	54.2	Discharge
Q ₇₋₁₀ at gage (cfs)	22	
Yleid Ratio (cfs/mi²)	0.4059	Diluti
Drainage Area at site (sq. ml.) Q ₇₋₁₀ at discharge site (cfs) Q ₇₋₁₀ at discharge site (mgd)	0.34 0.1380 0.0892	Drainage Are RMI Q ₇₋₁₀ at react
Low Flow Yield Ratio of 0.1	cfs/mi² (For Approx, Comparison Only)	Q ₇₋₁₀ at reach
Q ₇₋₁₀ at discharge site (cfs)	0.0340	
Q _{7-te} at discharge site (mgd)	0.0220	
Q _{7:10} at Dow	nstream Reach #2	6-77 E-25
TO THE RESIDENCE OF THE PROPERTY AND ASSESSMENT OF THE PARTY OF THE PA	[Drainage Area @ Reach #2]	Drainage Ar
Drainage Area at Reach (sq. ml.)		
Drainage Area at Reach (sq. ml.) RMI	[RMI @ Reach #2]	RMI
		RMI Q ₇₋₁₀ at read Q ₇₋₁₀ at read

Date: Thurs Oct 22, 2015 9:46:21 AM GMT-4 NAD 1983 Latitude: 40.8713 (40 52 17) NAD 1983 Longitude: -76.7334 (-76 44 01)

OUTLETY 208535 LONG_OUT -76.7335 BSLOPDRAW 13.46 FOREST 69 PRECIP 41 URBAN 0 GLACIATED 0 ROCKOEP 3.3 CARBON 0 STORAGE 1 ELEV 693.8 MAXTEMP 59 DRN 3.1 IMPNILCD01 0 LC01DEV 3 LC11IMP 0.35		
STRDEN 3.44 BSLOPD 13.2 CENTROIDX 106633.9 CENTROIDY 209219.7 OUTLETX 106745 OUTLETY 208535 LONG_OUT -76.7335 BSLOPDRAW 13.46 FOREST 69 PRECIP 41 URBAN 0 GLACIATED 0 ROCKOEP 3.3.3 CARBON 0 STORAGE 1 ELEV 693.8 MAXTEMP 59 DRN 3.1 IMPNILCD01 1 LC01DEV 1.006633.9 IMPNILCD01 1 IMPNILCD01 1 LC01DEV 1.006633.9 IMPNILCD01 1	DRIVAREA	0.34
SINCENT 13.2	STRMTOT	1.17
DSIGNO	STRDEN	
CENTROIDY 209219.7 OUTLETX 106745 OUTLETY 208535 LONG_OUT -76.7335 BSLOPDRAW 13.46 FOREST 69 PRECIP 41 URBAN 0 GLACIATED 0 ROCKOEP 3.3 CARBON 0 STORAGE 1 ELEV 693.8 MAXTEMP 59 DRN 3.1 IMPNILCD01 0 LC01DEV 3 LC11IMP 0,35	BSLOPD	
CETTROIDT 106745 OUTLETY 208535 LONG_OUT -76.7335 BSLOPDRAW 13.46 FOREST 69 PRECIP 41 URBAN 0 GLACIATED 0 ROCKDEP 3.3 CARBON 0 STORAGE 1 ELEV 693.8 MAXTEMP 59 DRN 3.1 IMPNILCD01 C LC01DEV 3 LC11IMP 0.35	CENTROIDX	106633.9
OUTLETY 208535 LONG_OUT -76.7335 BSLOPDRAW 13.46 FOREST 69 PRECIP 41 URBAN 0 GLACIATED 0 ROCKDEP 3.3 CARBON 0 STORAGE 1 ELEV 693.8 MAXTEMP 59 DRN 3.1 IMPNILCD01 0 LC01DEV 3 LC11IMP 0.35	CENTROIDY	
CONTEST CONT	OUTLETX	106745
STORAGE	OUTLETY	208535
SSCOPIONITY 69	LONG_OUT	
PRECIP	BSLOPDRAW	13.46
RECEIT CONTINUE	FOREST	
GLACIATED O GLACIATED	PRECIP	41
CACAGRED 3.3	URBAN	0
CARBON	GLACIATED	
CARDIN 1 1 1 1 1 1 1 1 1	ROCKDEP	
ELEY 693.8 MAXTEMP 59 DRN 3.1 IMPNICO01 C LC01DEV 3 LC11IMP 0.35	CARBON	0
DRN 3.1 IMPNICOO1 C C C C C C C C C	STORAGE	1
DRN 3.1	ELEV	
IMPNLCD01	MAXTEMP	59
LC01DEV 3.1511MP 0.39	DRN	
LC11IMP 0.39	IMPNLC001	0
LCT time	LC01DEV	3
LC11DEV 2.41	LC11IMP	
	LC11DEV	2.41

NPDES Permit No.:	PA0113221	_
RMI at Outfall:	0.06	Elev. 567
_		<u>.</u>

Was Ecoflows Used? No	
Correlation From Ecoflows	

Check D	Ilution Ratio	
Discharge at Outfall (wf) (mgd)	0.0	003
	sf (cfs)	wf (cfs)
Dilution Ratio = sf/wf	0.1380	0.004641686
Dilution Ratio =	29.73216467	to 1

Q ₇₋₁₀ at Down	stream Reach #1
Drainage Area at Reach (sq. ml.)	103
RMI	0
Q ₇₋₁₀ at reach (cfs)	41.8081
	27.0213
	Elev.

Q ₇₋₁₀ at Down	stream Reach #3
Drainage Area at Reach (sq. ml.)	[Drainage Area @ Reach #3]
	(RMI @ Reach #3]
Q ₇₋₁₀ at reach (cfs)	#VALUEI
	#VALUE!




Table 1 13

Table 1. List of U.S. Geological Survey streamgage locations in and near Pennsylvania with updated streamflow statistics.—Continued [Latitude and Longitude in decimal degrees; mi², square miles]

Streamgage number	Streamgage name	Latitude	Longitude	Drainage area (mi²)	Regulated
01541303	West Branch Susquehanna River at Hyde, Pa.	41.005	-78.457	474	Y
01541308	Bradley Run near Ashville, Pa.	40.509	-78.584	6.77	N
01541500	Clearfield Creek at Dimeling, Pa.	40.972	-78.406	371	Y
01542000	Moshannon Creek at Osceola Mills, Pa.	40.850	-78.268	68.8	N
01542500	WB Susquehanna River at Karthaus, Pa.	41.118	-78.109	1,462	Y
01542810	Waldy Run near Emporium, Pa.	41.579	-78.293	5.24	N
01543000	Driftwood Branch Sinnemahoning Creek at Sterling Run, Pa.	41,413	-78.197	272	N .
01543500	Sinnemahoning Creek at Sinnemahoning, Pa.	41.317	-78.103	685	N
01544000	First Fork Sinnemahoning Creek near Sinnemahoning, Pa.	41.402	-7 8.024	. 245	Y.
01544500	Kettle Creek at Cross Fork, Pa.	41,476	-77.826	136	N
01545000	Kettle Creek near Westport, Pa.	41.320	-77.874	233	Y
01545500	West Branch Susquehanna River at Renovo, Pa.	41.325	-77.751	2,975	Y
01545600	Young Womans Creek near Renovo, Pa.	41.390	-77.691	46.2	N
01546000	North Bald Eagle Creek at Milesburg, Pa.	40.942	<i>-77.7</i> 94	119	N
01546400	Spring Creek at Houserville, Pa.	40.834	-77.828	58.5	N
01546500	Spring Creek near Axemann, Pa.	40.890	-77,794	87.2	N
01547100	Spring Creek at Milesburg, Pa.	40.932	-77,786	142	N
	Bald Eagle Creek below Spring Creek at Milesburg, Pa.	40,943	-77,786	265	N
01547200	Bald Eagle Creek at Blanchard, Pa.	41.052	-77.604	339	Ý
01547500	Marsh Creek at Blanchard, Pa.	41.060	-77,606	44.1	Ń
01547700	South Fork Beech Creek near Snow Shoe, Pa.	41.024	-77.904	12.2	N
01547800	Beech Creek at Monument, Pa.	41.112	-77.702	152	N
01547950	Bald Eagle Creek near Beech Creek Station, Pa.	41.081	-77.549	562	Y
01548005	Pine Creek at Cedar Run, Pa.	41.522	-77.447	604	N
01548500		41,313	-77.379	750	N
01549000	Pine Creek near Waterville, Pa. Blockhouse Creek near English Center, Pa.	41,474	-77.231	37.7	N
01549500	Pine Creek below Little Pine Creek near Waterville, Pa.	41,274	-77.324	944	Y
01549700		41,418	-77.033	173	N
01550000	Lycoming Creek near Trout Run, Pa:	41.236	-76.997	5,682	Y
01551500	WB Susquehanna River at Williamsport, Pa.	41.325	-76.912	435	N.
01552000	Loyalsock Creek at Loyalsockville, Pa.	41,357	-76.535	23.8	N
01552500	Muncy Creek near Sonestown, Pa.	41.059	-77.077	4.93	
01553130	Sand Spring Run near White Deer, Pa.	40.968	-76.876	6,847	Y
01553500	West Branch Susquehanna River at Lewisburg, Pa.	41.062	-76.680	51.3	N
01553700	Chillisquaque Creek at Washingtonville, Pa.	40.835	-76.827	18,300	Y
01554000	Susquehanna River at Sunbury, Pa.	40.810	-76.58 <u>4</u>	54.2	N
01554500	Shamokin Creek near Shamokin, Pa.	40.867	-77.048	301	N
01555000	Penns Creek at Penns Creek, Pa.	40.611	-76.912	162	N
01555500	East Mahantango Creek near Dahmatia, Pa.	40.463	-78.200	291	N.
01556000	Frankstown Branch Juniala River at Williamsburg, Pa.	40.484	-78.234	44.1	N.
01557500	Bald Eagle Creek at Tyrone, Pa.	aud New Art and the State of the Control of the State of the Control of the State o	-78.141	220	N
01558000	Little Juniata River at Spruce Creek, Pa.	40.613 40.485	-78.141 -78.019	816	LF
01559000	Juniata River at Huntingdon, Pa.		-78.019 -77.971	128	N
01559500	Standing Stone Creek near Huntingdon, Pa.	40.524		5.28	
01559700	Sulphur Springs Creek near Manns Choice, Pa.	39,978	-78.619		N N
01560000	Dunning Creek at Belden, Pa.	40.072	- 78.493	172	14

26 Selected Streamflow Statistics for Streamgage Locations in and near Pennsylvania

Table 2. Selected low-flow statistics for streamgage locations in and near Pennsylvania.—Continued

[ft³/s; cubic feet per second; —, statistic not computed; <, less than]

Streamgage number	Period of record used in analysis¹	Number of years used in analysis	1-day, 10-year (ft³/s)	7-day, 10-year (ft³/s)	7-day, 2-year (ft³/s)	30-day, 10-year (ft³/s)	30-day, 2-year (ft³/s)	90-day, 10-year (ft³/s)
01546000	1912–1934	17	1.8	2.2	6.8	3.7	12,1	11.2
01546400	1986–2008	23	13.5	14.0	19.6	15,4	22.3	18.7
01546500	1942-2008	67	26.8	29.0	41,3	31,2	44.2	33,7
01547100	1969-2008	40	102	105	128	111	133	117
01547100 0154 72 00	1957–2008	52	99.4	101	132	106	142	115
01547200	² 1971–2008	38	28.2	109	151	131	172	153
01547500	³ 1956–1969	14	90.0	94.9	123	98.1	131	105
01547300	1957–2008	52	.5	.6	2.7	1.1	3.9	2.2
01547700	1971–1981	11	1,6	1.8	2.4	2.1	2.9	3.5
01547800	1970–2008	39	12.1	13.6	28.2	17.3	36.4	23.8
01548005	² 1971–2000	25	142	151	206	178	241	223
01548005	³ 1912–1969	58	105	114	147	125	165	-140
**************************************	1920-2008	89	21.2	24.2	50.1	33,6	68.6	49.3
01548500	1910-1920	11	26.0	32.9	78.0	46.4	106	89.8
01549000	1942-2008	67	.6	.8	2.5	1.4	3.9	2.6
01549500	1942-2008	50	33.3	37.2	83.8	51.2	117	78.4
01549700	1915–2008	94	6.6	7.6	16.8	11.2	24.6	18.6
01550000		46	520	578	1,020	678	1,330	919
01551500	² 1963–2008	61	400	439	742	523	943	752
01551500	³1901–1961	80	20.5	22.2	49.5	29.2	69.8	49.6
01552000	1927-2008	67	.9	1,2	3.1	1.7	4.4	3.3
01552500	1942-2008	13	1.0	1,1	1.5	1.3	1.8	1,7
01553130	1969–1981	CANAL SERVICE CONTRACTOR OF SERVICE	760	838	1,440	1,000	1,850	1,470
01553500	² 1968–2008	41 26	760 562	619	880	690	1,090	881
01553500	31941-1966	20 28	9.1	10.9	15.0	12.6	17,1	15,7
01553700	. 1981–2008	NOSECKET STOOT FLATOUR FOR STOOT	1,830	1,990	3,270	2,320	4,210	3,160
01554000	² 1981–2008	28	1,650	1,630	2,870	1,880	3,620	2,570
01554000	31939–1979	41	1,300	22.0	31.2	25.9	35.7	31.
01554500	1941–1993	53	33.5	37.6	58.8	43.4	69.6	54.
01555000	1931–2008	78	33. <i>3</i> 4.9	6.5	18.0	9.4	24.3	16.
01555500	1931–2008	78		47.8	66.0	55.1	75.0	63.
01556000	1918–2008	91	43.3	47.6 3.2	6.3	4.2	8.1	5.
01557500	1946–2008	63	2.8	59.0	79.8	65.7	86.2	73.
01558000	1940–2008	69	56.3		79.8 249	198	279	227
01559000	1943-2008	66	104	177	THE PARTY OF THE P	12.4	17.8	15.
01559500	1931–1958	28	9.3	: : : 10.5	15.0	.i	.3	
01559700	1963–1978	16	.1	.1	.2 15.6	12.0	20.2	16.
01560000	1941–2008	68	8.5	9,4		.8	2.5	1.
01561000	1932–1958	27	.4	.5	1.6	.8 77.4	122	94.
01562000	1913–2008	96	64.1	67.1	106	2.3	5.4	3.
01562500	1931–1957	27	1.1	1.6	3. 8	112	266	129
01563200	21974–2008	35, 11	ar (7 ar (5 g		$(0.5),(3.5),\overline{3.5},$		200 113	95
01563200	³1948–1972	25	10,3	28.2	86.1	64.5	THE PROPERTY OF THE PROPERTY OF THE	93 493
01563500	² 1974–2008	35	384	415	519	441	580	333
01563500	31939-1972	34	153	242	343	278 6.2	399 14.4	ددد 10



Low-Flow Statistics for Pennsylvania Streams



Developed by the U.S. Geological Survey for the Pennsylvania Department of Environmental Protection

Pennsylvania Low-Flow Statistics - Query Results

LOW-FLOW STATISTICS

[All flow statistics in cubic feet per second (ft³/s)]

Mouse over or click on table headings to view definition of statistic

STREAM NAME: Susquehanna

River

GAGE OR BRIDGE SITE: gage

REFERENCE GAGE:1

01554000

COUNTY: Northumberland USGS QUAD: Sunbury

STATION NAME:

Susquehanna River at

Sunbury, PA

LATITUDE: 405115 LONGITUDE: 764821 DRAINAGE AREA (sq.

mi.): 18300

Entire Period of Record ²	Q _{1,10}	Q _{7,10}	<u>Q30,10</u>	MEAN	MEDIAN	<u>HARMONIC</u> <u>MEAN</u>
1938-95	1650	1740	2030	26800	15710	9470

FLOW DURATION TABLE (Probability of Exceedance)											
P5 P10 P20 P30 P40 P50 P60 P70 P80 P90 P9									P95		
87100	61810	39810	28690	21200	15710	11770	8650	6100	3810	2840	

Pre-Regulation Period of Record ³	Q _{1,10}	<u>Q_{2,10}</u>	Q30,10	<u>MEAN</u>	MEDIAN	HARMONIC MEAN
1938-70	1470	1530	1740	24200	13890	8210

	FLOW DURATION TABLE (Probability of Exceedance)											
P5	P10	P20	P30	P40	P50	P60	P70	P80	P90	P95		
82370	56070	38300	27040	19190	13890	10180	7470	5120	3200	2500		

Post-Regulation Period of Record	Q _{1,10}	Q _{7,10}	<u>Q_{39,10}</u>	<u>MEAN</u>	<u>MEDIAN</u>	HARMONIC MEAN
1971-95	2200	2430	2940	28250	18030	11800

FLOW DURATION TABLE (Probability of Exceedance)										
P5	P10	P20	P30	P40	P50	P60	P70	P80	P90	P95
92160	64470	41900	30500	23470	18030	13940	10480	7580	4930	3670

Reference Gage indicates which USGS gage was used in the computation of lowflow statistics for the specified locations

Period of Record for climatic year, April 1 through March 31

Period of record refers to pre-regulation conditions

APPENDIX B TRC ANALYSIS SPREADSHEET

1A	В	С	D	Е	F	G			
2	TRC EVALU	ATION	Youth Challenge PA0	113221					
3	3 Input appropriate values in B4:B8 and E4:E7								
4		= Q stream (•		= CV Daily				
5					= CV Hourly				
6					= AFC_Partial Mix Factor				
7					= CFC_Partial Mix Factor				
8	•				5 = AFC_Criteria Compliance Time (min)				
9					= CFC_Criteria Compliance Time (min)				
40	0 = % Factor of Safety (FOS)				=Decay Coefficient (K)				
10	Source	Reference	AFC Calculations		Reference	CFC Calculations			
11	TRC	1.3.2.iii	WLA afc =		1.3.2.iii	WLA cfc = ########			
	PENTOXSD TRG PENTOXSD TRG		LTAMULT afc = LTA afc=		5.1c 5.1d	LTAMULT cfc = 0.581 LTA cfc = ########			
14	PENTOX3D TRG	5.16	LTA_aic-	******	5.10	LTA_cic = #########			
15									
16	PENTOXSD TRG	5.1f	AM	1.231					
	7 PENTOXSD TRG 5.1g AVG MON LIMIT (mg/l) =				0.500	BAT/BPJ			
18	INST MAX LIMIT (mg/l) = 1.635								
	WLA afc (.019/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k*AFC_tc)) + Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)								
	LTAMULT afc EXP((0.5*LN(cvh^2+1))-2.326*LN(cvh^2+1)^0.5)								
	LTA_afc wla_afc*LTAMULT_afc								
	WLA_cfc (.011/e(-k*CFC_tc) + [(CFC_Yc*Qs*.011/Qd*e(-k*CFC_tc)) + Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)								
	LTAMULT_cfc EXP((0.5*LN(cvd^2/no_samples+1))-2.326*LN(cvd^2/no_samples+1)^0.5)								
	LTA_cfc wla_cfc*LTAMULT_cfc								
	AML MULT EXP(2.326*LN((cvd^2/no_samples+1)^0.5)-0.5*LN(cvd^2/no_samples+1))								
	AVG MON LIMIT MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT)								
	INST MAX LIMIT 1.5*((av_mon_limit/AML_MULT)/LTAMULT_afc)								

APPENDIX C FACILITY MAP AND SCHEMATIC

