

## Southwest Regional Office CLEAN WATER PROGRAM

Application Type

Renewal

Non
Facility Type

Maior / Minor

Minor

# NPDES PERMIT FACT SHEET INDIVIDUAL SEWAGE

Application No. **PA0204625**APS ID **1045497** 

Authorization ID 1365309

	Applicant and	Facility Information	
Applicant Name	Feather Family Revocable Trust	Facility Name	Feather Nest MHP STP
applicant Address	1510 Dark Shade Drive	Facility Address	1510 Dark Shade Drive
	Windber, PA 15963-6223	<u></u>	Windber, PA 15963-6223
plicant Contact	Robert Feather	Facility Contact	Same as Applicant
plicant Phone	(814) 467-5612	Facility Phone	Same as Applicant
ient ID	364852	Site ID	257601
94 Load Status	Not Overloaded	Municipality	Paint Township
nnection Status	No Limitations	County	Somerset
te Application Rece	eived August 10, 2021	EPA Waived?	Yes
ate Application Acce	epted August 16, 2021	If No, Reason	

#### **Summary of Review**

The permittee has applied for a renewal and transfer of NPDES Permit No. PA0204625. NPDES Permit No. PA0204625 was previously issued by the PA Department of Environmental Protection (DEP) on August 23, 2016and expired on August 31, 2021. The renewal application was submitted in a timely manner; therefore, the permit was granted administrative extension.

The permit is being transferred from Robert Feather to Feather Family Revocable Trust.

Sewage from this facility is treated by extended aeration, final clarification, rapid sand filtration and chlorination before discharging to Trib 45277 of Shade Creek. Trib 45277 of Shade Creek is classified as a Cold-Water Fishery per Chapter 93 Designated Use.

The new permittee has applied for eDMR and intends to use it.

The Act-14 PL 834 Municipal Notification was provided by the February 4, 2021 letters from Robert Feather. No comments were received.

WQM Permit No. 5673413 is also being transferred upon approval from the department.

#### **Public Participation**

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*,

Approve	Deny	Signatures	Date
Х		It al	
		Stephanie Conrad / Environmental Engineering Specialist	June 2, 2022
х		Chke	
		Christopher Kriley, P.E. / Environmental Program Manager	June 2, 2022

Summary	of R	eview
---------	------	-------

DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

scharge, Receivin	g Wate	rs and Water Supply Informa	ition	
Outfall No. 001			Design Flow (MGI	O)02
Latitude 40°	11' 43"		Longitude	-78° 50' 49"
Quad Name W	indber		Quad Code	1715
Wastewater Descr	iption:	Sewage Effluent		
Receiving Waters	_Trib 4	45277 of Shade Creek (CWF)	Stream Code	45277
NHD Com ID	1237	26472	_ RMI	0.4
Drainage Area	0.29		Yield (cfs/mi²)	0.04379
Q <sub>7-10</sub> Flow (cfs)	0.012	27	Q <sub>7-10</sub> Basis	USGS Stream Stats
Elevation (ft)	1860		_ Slope (ft/ft)	
Watershed No.	18-E		_ Chapter 93 Class.	CWF
Existing Use			Existing Use Qualifier	r
Exceptions to Use			Exceptions to Criteria	a
Assessment Status	s	Attaining Use(s)		
Cause(s) of Impair	ment	N/A		
Source(s) of Impai	rment	N/A		
TMDL Status		Final		etas-Conemaugh River eds TMDL
Background/Ambie	ent Data		Data Source	
Temperature (°F) Hardness (mg/L)				_
Other:				
	am Publ	ic Water Supply Intake	Saltsburg Municipal Water	works
PWS Waters _	Conem	augh River	Flow at Intake (MGD)	0.602
PWS RMI	27.4		Distance from Outfall (m	ni) 62.36

Changes Since Last Permit Issuance: None.

Other Comments: None.

## **Treatment Facility Summary**

Treatment Facility Name: Feather Nest MHP STP

WQM Permit No.	Issuance Date
5673413	May 24, 1974

Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Tertiary	Extended Aeration	Chlorination	0.02
Hydraulic Capacity	Organic Capacity			Biosolids
(MGD)	(lbs/day)	Load Status	Biosolids Treatment	Use/Disposal
0.02	86.4	Not Overloaded	Pump and Haul	Other STP

Changes Since Last Permit Issuance: None

Other Comments: None

## **Compliance History**

## **Operations Compliance Check Summary Report**

Facility: Feather Nest MHP STP

NPDES Permit No.: PA0204625

Compliance Review Period: 09/2016 - 09/2021

## Inspection Summary:

INSP ID	INSPECTED DATE	INSP TYPE	AGENCY	INSPECTION RESULT DESC
3140312	01/25/2021	Compliance Evaluation	PA Dept of Environmental Protection	No Violations Noted
3004359	02/27/2020	Compliance Evaluation	PA Dept of Environmental Protection	No Violations Noted
2834607	01/08/2019	Compliance Evaluation	PA Dept of Environmental Protection	No Violations Noted
2700130	02/21/2018	Compliance Evaluation	PA Dept of Environmental Protection	No Violations Noted
2573829	02/14/2017	Compliance Evaluation	PA Dept of Environmental Protection	No Violations Noted

## **Violation Summary:**

No violations

## Open Violations by Client ID:

No CW violations for client ID 44897

## **Enforcement Summary:**

No enforcements

## DMR Violation Summary:

No DMR violations

## Compliance Status:

Permittee is in Clean Water compliance.

Completed by: John Murphy

Completed date: 9/14/2021

## **Compliance History**

## DMR Data for Outfall 001 (from August 1, 2020 to July 31, 2021)

Parameter	JUL-21	JUN-21	MAY-21	APR-21	MAR-21	FEB-21	JAN-21	DEC-20	NOV-20	OCT-20	SEP-20	AUG-20
Flow (MGD)												
Average Monthly	0.005	0.003	0.004	0.004	0.004	0.005	0.005	0.006	0.005	0.005	0.006	0.005
pH (S.U.)												
Minimum	6.6	6.8	6.8	7.0	6.8	6.9	6.8	7.0	6.5	6.9	6.9	6.6
pH (S.U.)												
Maximum	7.5	7.1	7.3	7.6	7.4	7.3	7.6	7.6	7.4	7.4	7.7	7.8
DO (mg/L)												
Minimum	4.3	4.6	4.9	5.1	5.4	6.0	5.2	5.2	5.0	5.0	5.0	4.5
TRC (mg/L)												
Average Monthly	0.42	0.34	0.38	0.36	0.31	0.3	0.27	0.29	0.27	0.32	0.27	0.31
TRC (mg/L)												
Instantaneous												
Maximum	1.12	1.20	0.90	1.1	0.90	0.71	0.57	0.98	0.44	0.85	0.68	0.66
CBOD₅ (mg/L)			_	_		_	_	_	_	_		
Average Monthly	8.4	3.5	2	2	4	2	2	2	3	3	4.5	4.5
CBOD <sub>5</sub> (mg/L)												
Instantaneous		_	_		_	_	_	_			_	
Maximum	10.1	5	2	2	6	2	2	2	4	4	7	6
TSS (mg/L)	400									_		_
Average Monthly	10.0	7.5	2	2	3	2.5	2	3	4	5	4.5	7
TSS (mg/L)												
Instantaneous	45.0	0			4	_					_	
Maximum	15.0	8	2	2	4	3	2	4	6	6	5	9
Fecal Coliform												
(CFU/100 ml) Geometric Mean	35.2	1.0	28.3	3.3	5.9	1.0	3.5	1.4	87.8	67.7	6	1.0
Total Nitrogen (mg/L)	33.2	1.0	20.3	3.3	5.9	1.0	3.5	1.4	07.0	67.7	0	1.0
Daily Maximum								2.4				
Ammonia (mg/L)								2.4				
Average Monthly	0.8	2.44	0.14	0.15	0.56	1.3	0.23	0.68	0.14	1.37	0.47	1.7
Total Phosphorus	0.0	2.77	0.14	0.10	0.00	1.0	0.20	0.00	0.17	1.07	0.47	1.7
(mg/L)												
Daily Maximum								7.44				
Total Aluminum												
(mg/L)												
Daily Maximum								0.1				

## NPDES Permit Fact Sheet Feather Nest MHP STP

## NPDES Permit No. PA0204625

Total Iron (mg/L) Daily Maximum				0.05		
Total Manganese						
(mg/L)						
Daily Maximum				0.03		

Summary of Inspections: The facility was last inspected by PADEP as a Compliance Evaluation on January 25, 2021. There were no violations.

Other Comments:

Development of Effluent Limitations						
Outfall No.	004	Design Flow (MCD)	02			
	001	Design Flow (MGD)	.02			
Latitude	40º 11' 43.00"	Longitude	-78° 50' 49.00"			
Wastewater D	escription: Sewage Effluent					

#### **Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
CBOD <sub>5</sub>	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
Solids	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
рН	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform				
(5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform				
(5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform				
(10/1 - 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform				
(10/1 - 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

#### **Water Quality-Based Limitations**

Pursuant to EPA's approval of Pennsylvania's 2017 Triennial Review of Water Quality Standards and corresponding regulatory changes published in the *Pennsylvania Bulletin* on July 11, 2020, new water quality criteria for ammonia-nitrogen apply to waters of the commonwealth. Therefore, WQBELs for Outfall 001 are being re-evaluated even though there have been no changes to the STP.

The effluent was modeled using WQM 7.0 to evaluate the CBOD<sub>5</sub>, Ammonia-Nitrogen, and Dissolved Oxygen parameters. Modeling confirmed that technology based effluent limitations are appropriate for CBOD<sub>5</sub>. The modeling also confirmed that water quality based Dissolved Oxygen and Ammonia-Nitrogen limits are necessary to meet in-stream water quality criterion. In accordance with the SOP's, winter Ammonia-Nitrogen limits were assessed by comparing the winter WQM 7.0 output value with one calculated from the summer limit using a seasonal multiplier of three. The more restrictive of the two values is then imposed. For this facility, the winter Ammonia-Nitrogen limit to be imposed was generated using WQM 7.0 modeling. WQM 7.0 output files are provided in Attachment A.

Total Residual Chlorine was modeled with PADEP's TRC Spreadsheet, and it was determined that a stricter limit should be imposed. The TRC Spreadsheet output file is provided in Attachment B.

Dissolved Oxygen, TRC, and Summer and Winter Ammonia-Nitrogen limits are becoming more restrictive. Based on eDMR data, the facility as operating should be able to meet the new, more restrictive Ammonia-Nitrogen limit. The facility is not, however, able to meet the new, more restrictive dissolved oxygen and TRC limits. A compliance period of three years will therefore be established.

Parameter	Limit (mg/l)	SBC	Model
Total Residual Chlorine	0.07	Average Monthly	TRC Spreadsheet

Dissolved Oxygen	5.0	Instantaneous Minimum	WQM 7.0
Ammonia-Nitrogen (winter)	8.5	Average Monthly	WQM 7.0
Ammonia-Nitrogen (summer)	3.0	Average Monthly	WQM 7.0

#### **Anti-Backsliding**

Section 402(o) of the Clean Water Act (CWA), enacted in the Water Quality Act of 1987, establishes anti-backsliding rules governing two situations. The first situation occurs when a permittee seeks to revise a Technology-Based effluent limitation based on BPJ to reflect a subsequently promulgated effluent guideline which is less stringent. The second situation addressed by Section 402(o) arises when a permittee seeks relaxation of an effluent limitation which is based upon a State treatment standard of water quality standard.

Previous limits can be used pursuant to EPA's anti-backsliding regulation 40 CFR 122.44 (I) Reissued permits. (1) Except as provided in paragraph (I)(2) of this section when a permit is renewed or reissued. Interim effluent limitations, standards or conditions must be at least as stringent as the final effluent limitations, standards, or conditions in the previous permit (unless the circumstances on which the previous permit was based have materially and substantially changed since the time the permit was issued and would constitute cause for permit modification or revocation and reissuance under §122.62). (2) In the case of effluent limitations established on the basis of Section 402(a)(1)(B) of the CWA, a permit may not be renewed, reissued, or modified on the basis of effluent guidelines promulgated under section 304(b) subsequent to the original issuance of such permit, to contain effluent limitations which are less stringent than the comparable effluent limitations in the previous permit.

The facility is not seeking to revise the previously permitted effluent limits.

## **Additional Considerations**

Pursuant to EPA's approval of Pennsylvania's 2017 Triennial Review of Water Quality Standards and corresponding regulatory changes published in the *Pennsylvania Bulletin* on July 11, 2020, sewage, discharges will include monitoring, at a minimum, for E. coli, in new and reissued permits, with a monitoring frequency of 1/year for design flows of 0.002 – 0.05 MGD.

For pH, Dissolved Oxygen (DO) and TRC, a monitoring frequency of 1/day has been imposed.

The receiving stream is not impaired for nutrients, therefore, annual sampling for nitrogen and phosphorus will be imposed per 25 PA Code §92a.61.

Monitoring frequency for the proposed effluent limits are based upon Table 6-3, Self-Monitoring Requirements for Sewage Dischargers, from the Departments Technical Guidance for the Development and Specification of Effluent Limitations. Please note that Monitoring Requirements were changed for pH, DO, and TRC to 1/day to be consistent with the guidance. Mr. Feather requested to keep less frequent monitoring in an email dated November 24, 2021. He was informed that the frequency would be changed to 1/day per the above stated guidance. He was also made aware that the daily samples are not required to be taken by a certified operator and that DO, pH, and TRC probes can be used for continuous measurements. These measurements may be used for daily reporting provided that the probe is installed at the proper location and meets the requirements of 40 CFR 136.

#### **Kiskiminetas-Conemaugh River Watershed TMDL**

Section 303(d) of the Clean Water Act and the U.S. Environmental Protection Agency's Water Quality Planning and Management Regulation (codified at Title 40 of the Code of Federal Regulations Part 130) requires states to develop a TMDL for impaired water bodies. A TMDL establishes the amount of a pollutant that a water body can assimilate without exceeding water quality criteria for the pollutant. TMDLs also provide a scientific basis for States to establish water

quality-based controls for reducing pollution from both point and non-point sources in order to restore and maintain the quality of the state's water resources (USEPA 1991a). Stream reaches within the Kiskiminetas-Conemaugh River Watershed are included in the state's 2008 Section 303(d) list because of various impairments including metals, pH, and sediment.

Feather Nest MHP STP (PA0204625) discharges to the Kiskiminetas-Conemaugh River Watershed, for which a TMDL was finalized on January 29, 2010. The TMDL addresses metals, pH, and sediment impairments associated with abandoned mine drainage. This facility is listed as a negligible discharger in Appendix C of the approved TMDL and is covered under the aggregate WLA for negligible dischargers in Appendix G. The WLA for this facility was based on a flow of 0.02 and the in-stream water quality for each pollutant of concern (aluminum, iron and manganese).

The previous permit imposed a monitor and report requirement for aluminum, iron, and manganese. The highest reported value for the last three years of eDMR data is reported below along with the in-stream water quality criteria for each pollutant of concern.

Parameter	Highest Reported Value (mg/l)	Criteria (mg/L)
Aluminum, Total	0.1	0.75
Iron, Total	0.1	1.5
Manganese, Total	0.03	1.0

In accordance with 25 PA Code §92a.61, a 1/year monitoring requirement for iron, manganese, and aluminum will again be imposed in the permit to continue verification that the sewage discharge is not contributing to stream impairment.

A "Reasonable Potential Analysis" was conducted using PADEP's Toxic Management Spreadsheet Version 1.3. The output files are included in Attachment C

The maximum reported value for the last three years and each pollutant of concern was input into the TMS Spreadsheet. The analysis determined that a monitor and report requirement for Aluminum is necessary on the basis that the reported discharge concentration is greater than 10% of the governing WQBEL based on the Acute Fish Criteria.

Total Aluminum concentrations for the last three years were all reported as a detection at a concentration of 0.1 mg/L. If the permittee believes that the measured values were actually "non-detect" they can submit lab reports for the last three years and the monitoring requirement will be reevaluated accordingly.

## **Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Three Years Following Permit Issuance through Permit Expiration Date.

				Monitoring Red	quirements			
Parameter	Mass Units	(lbs/day) <sup>(1)</sup>		Concentrat	ions (mg/L)		Minimum <sup>(2)</sup>	Required
r ai ainetei	Average Monthly	Average Average Inst					Measurement Frequency	Sample Type
DO	XXX	XXX	5.0 Inst Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.06	XXX	0.22	1/day	Grab

Compliance Sampling Location: Outfall 001

Other Comments:

## **Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

## Outfall 001, Effective Period: Permit Effective Date through Three Years Following Permit Issuance.

			Monitoring Red	quirements				
Parameter	Mass Units	(lbs/day) <sup>(1)</sup>		Concentrat	Minimum <sup>(2)</sup>	Required		
raiametei	Average Average Average Monthly Weekly Minimum Monthly Maximum						Measurement Frequency	Sample Type
	2007	2007	4.0	2004	2007	2004	471	0 -
DO	XXX	XXX	Inst Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab

Compliance Sampling Location: Outfall 001

Other Comments:

## **Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

#### Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

			Effluent L	imitations			Monitoring Red	quirements
Parameter	Mass Units	(lbs/day) <sup>(1)</sup>		Concentrat	ions (mg/L)		Minimum <sup>(2)</sup>	Required
Farameter	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum	Measurement Frequency	Sample Type
Flow (MGD)	0.02	XXX	XXX	XXX	XXX	XXX	2/month	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
CBOD5	XXX	XXX	XXX	25	XXX	50	2/month	Grab
TSS	XXX	XXX	XXX	30	XXX	60	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Ammonia-Nitrogen Nov 1 - Apr 30	XXX	XXX	XXX	8.6	XXX	17.2	2/month	Grab
Ammonia-Nitrogen May 1 - Oct 31	XXX	XXX	XXX	2.9	XXX	5.9	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Total Nitrogen	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab
Total Phosphorus	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab
Total Aluminum	XXX	XXX	Report Avg Mo	XXX	Report Daily Max	Report	1/week	Grab
Total Iron	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab

## Outfall 001, Continued (from Permit Effective Date through Permit Expiration Date)

			Effluent L	imitations			Monitoring Red	quirements
Parameter	Mass Units	(lbs/day) (1)		Concentrat	Minimum <sup>(2)</sup>	Required		
Farameter	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum	Measurement Frequency	Sample Type
		-			Report			
Total Manganese	XXX	XXX	XXX	XXX	Daily Max	XXX	1/year	Grab

Compliance Sampling Location: Outfall 001

Other Comments:

# ATTACHMENT A

WQM 7.0 Modeling Results

# Summer

## Input Data WQM 7.0

	SWP Basin			Stre	eam Name		RMI		ration ft)	Drainag Area (sq mi		(ft/ft)	PW Withda (mg	rawal	Apply FC
	18E	452	277 Trib 45	277 to SI	hade Creek		0.40	00 1	860.00	0	.29 0.	.00000		0.00	<b>✓</b>
					St	ream Dat	a								
Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Ten	Tributan Ip	<u>y</u> pH	Tem	Stream p	pH	
cona.	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C	)		(°C	)		
Q7-10 Q1-10 Q30-10	0.044	0.00 0.00 0.00	0.00	0.000 0.000 0.000		10.0	0.00	0.00	) 2	0.00	7.00	(	0.00	0.00	
					Di	scharge	Data								
			Name	Per	rmit Number	Disc	Permitto Disc Flow (mgd)	Disc Flow	Res v Fa	erve	Disc Temp (°C)		sc H		
		Feath	ner Nest Mi	H PAG	0204625	0.020	0.000	0.00	000	0.000	20.0	10	7.00		
					Pa	rameter	Data								
				<sup>p</sup> aramete	- Nama			Trib S Conc	Stream Conc	Fate Coef					
				aramete	rvanie	(m	g/L) (n	ng/L)	(mg/L)	(1/days	i)				
			CBOD5				25.00	2.00	0.00	1.5	0				
			Dissolved	Oxygen			4.00	9.01	0.00	0.0	0				
			NH3-N				25.00	0.00	0.00	0.7	0				

## Input Data WQM 7.0

	SWP Basin			Stre	eam Name		RMI		evation (ft)	Drainage Area (sq mi)		ope /ft)	PWS Withdrawal (mgd)	Apply FC
	18E	452	277 Trib 45	5277 to Sh	nade Creek		0.0	10	1660.00	0.4	43 0.0	0000	0.00	<b>v</b>
					St	ream Dat	a							
Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth		Tributary p p	н	Temp	Stream pH	
cona.	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C	)		(°C)		
Q7-10 Q1-10 Q30-10	0.044	0.00 0.00 0.00	0.00 0.00 0.00	0.000 0.000 0.000	0.000 0.000 0.000	10.0	0.00	0.0	00 2	0.00	7.00	0.	.00 0.00	)
					Di	scharge	Data							
			Name	Per	mit Number	Disc	Permitt Disc Flow (mgd	Dis Flo	sc Res	erve T ctor	Disc emp (°C)	Dis pH		
						0.000	0.000	0.0	0000	0.000	25.00	) 7	7.00	
					Pa	rameter	Data							
				<sup>o</sup> arametei	r Name			Trib Conc	Stream Conc	Fate Coef				
						(m	ng/L) (r	ng/L)	(mg/L)	(1/days)				
			CBOD5				25.00	2.00	0.00	1.50	)			
			Dissolved	Oxygen			3.00	8.24	0.00	0.00	)			
			NH3-N				25.00	0.00	0.00	0.70				

## WQM 7.0 Hydrodynamic Outputs

	SW	P Basin 18E		m Code 5277				Stream 5277 to	<u>Name</u> Shade Cr	eek		
RMI	Stream Flow	PWS With	Net Stream Flow		Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
Q7-1	0 Flow											
0.400	0.01	0.00	0.01	.0309	0.09713	.351	2.03	5.8	0.06	0.390	20.00	7.00
Q1-1	0 Flow											
0.400	0.01	0.00	0.01	.0309	0.09713	NA	NA	NA	0.06	0.415	20.00	7.00
Q30-	10 Flow	1										
0.400	0.02	0.00	0.02	.0309	0.09713	NA	NA	NA	0.06	0.369	20.00	7.00

## WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<b>~</b>
WLA Method	EMPR	Use Inputted W/D Ratio	
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<b>~</b>
D.O. Saturation	90.00%	Use Balanced Technology	<b>v</b>
D.O. Goal	6		

RMI

Discharge Name

0.40 Feather Nest MH

(mg/L)

25

(mg/L)

## WQM 7.0 Wasteload Allocations

		am Code		_	ream Name		
	18E	45277		Trib 4527	77 to Shade C	reek	
IH3-N	Acute Allocation	ns					
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.4	00 Feather Nest MH	9.67	12.21	9.67	12.21	0	0
	00 Feather Nest MH Chronic Allocati			9.67		0	0
			Baseline WLA (mg/L)	9.67 Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction

Baseline Multiple Baseline Multiple Baseline Multiple

(mg/L)

2.99

(mg/L)

2.99

(mg/L)

(mg/L)

5

Reach

0

Reduction

0

## WQM 7.0 D.O.Simulation

SWP Basin St 18E	ream Code 45277		Trib 4	Stream Name 15277 to Shade Cr	eek
<u>RMI</u>	Total Discharge	Flow (mgd	) Anal	ysis Temperature	°C) Analysis pH
0.400	0.02	0		20.000	7.000
Reach Width (ft)	Reach De	pth (ft)		Reach WDRatio	Reach Velocity (fps)
2.035	0.35	1		5.795	0.061
Reach CBOD5 (mg/L)	Reach Kc (	1/days)	R	each NH3-N (mg/L	Reach Kn (1/days)
18.31	1.43	_		2.12	0.700
Reach DO (mg/L)	Reach Kr (			Kr Equation	Reach DO Goal (mg/L)
6.167	23.12	21		Owens	6
Reach Travel Time (days)		Subreach	Results		
0.390	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)	
	0.039	17.31	2.06	6.79	
	0.078	16.37	2.01	7.10	
	0.117	15.47	1.95	7.29	
	0.156	14.63	1.90	7.41	
	0.195	13.83	1.85	7.51	
	0.234	13.08	1.80	7.60	
	0.273	12.37	1.75	7.68	
	0.312	11.69	1.70	7.75	
	0.351	11.06	1.66	7.82	
	0.390	10.45	1.61	7.89	

## WQM 7.0 Effluent Limits

	SWP Basin Stream		Stream Name Trib 45277 to Shade Creek									
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)					
0.400	Feather Nest MH	PA0204625	0.020	CBOD5	25							
				NH3-N	2.99	5.98						
				Dissolved Oxygen			5					

## Winter

## Input Data WQM 7.0

	SWP Basir			Stre	eam Name		RMI	Eleva (f		Drainage Area (sq mi)		Witho	VS Irawal gd)	Apply
	18E	452	277 Trib 45	5277 to SI	hade Creek		0.4	00 18	360.00	0.3	29 0.0	0000	0.00	<b>v</b>
					St	ream Dat	a							
Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tem	Tributary p p	н	Stream Temp	m pH	
oona.	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C	)		(°C)		
Q7-10 Q1-10 Q30-10	0.088	0.00 0.00 0.00	0.00	0.000 0.000 0.000	0.000	10.0	0.00	0.00		5.00	7.00	0.00	0.00	
					Di	scharge	Data						1	
			Name	Per	rmit Number	Disc	Disc Flow	Flow	Res Fa	erve T ctor	Disc emp (°C)	Disc pH		
		Feath	ner Nest Mi	H PAG	0204625	0.020	0.00	0.00	00 (	0.000	15.00	7.00		
					Pa	arameter	Data							
				Paramete	- Nama				tream Conc	Fate Coef				
				aramete	rvanie	(m	ng/L) (i	mg/L) (	mg/L)	(1/days)				
			CBOD5				25.00	2.00	0.00	1.50				
			Dissolved	Oxygen			4.00	12.51	0.00	0.00	)			
			NH3-N				25.00	0.00	0.00	0.70	)			

## Input Data WQM 7.0

	SWP Basin			Stre	eam Name		RMI		vation (ft)	Drainag Area (sq mi		lope ft/ft)	PW Withda (mg	rawal	Apply FC
	18E	452	277 Trib 45	5277 to Sh	nade Creek		0.0	10 1	1660.00	0	.43 0.0	00000		0.00	<b>~</b>
					St	ream Dat	a								
Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Ten	Tributan np	<u>v</u> pH	Tem	<u>Stream</u> p	pH	
cona.	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C	)		(°C	)		
Q7-10 Q1-10 Q30-10	0.088	0.00 0.00 0.00	0.00 0.00 0.00	0.000 0.000 0.000	0.000 0.000 0.000	10.0	0.00	0.0	0	5.00	7.00	(	0.00	0.00	
					Di	scharge l	Data								
			Name	Per	mit Number	Disc	Permitto Disc Flow (mgd)	Dis Flo	c Res w Fa	erve	Disc Temp (°C)	Dis pi	sc H		
						0.000	0.000	0.0	000	0.000	25.0	0	7.00		
					Pa	rameter l	Data								
			ı	Parameter	r Name	С	onc C	Conc	Stream Conc	Fate Coef					
	_					(m	ig/L) (n	ng/L)	(mg/L)	(1/days	)				
			CBOD5				25.00	2.00	0.00	1.5	0				
			Dissolved	Oxygen			3.00	8.24	0.00	0.0	0				
			NH3-N				25.00	0.00	0.00	0.7	0				

## WQM 7.0 Hydrodynamic Outputs

	SW	P Basin	Strea	m Code		Stream Name									
		18E	4	5277			Trib 45	277 to 9	Shade Cre	eek					
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH			
Q7-1	0 Flow														
0.400		0.00	0.03	.0309	0.09713	.368	2.17	5.9	0.07	0.338	10.49	7.00			
Q1-1	0 Flow														
0.400	0.02	0.00	0.02	.0309	0.09713	NA	NA	NA	0.06	0.373	11.56	7.00			
Q30-	10 Flow														
0.400	0.03	0.00	0.03	.0309	0.09713	NA	NA	NA	0.08	0.311	9.72	7.00			

## WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<b>~</b>
WLA Method	EMPR	Use Inputted W/D Ratio	
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<b>~</b>
D.O. Saturation	90.00%	Use Balanced Technology	<b>~</b>
D.O. Goal	6		

## WQM 7.0 Wasteload Allocations

	SWP Basin	Stream	n Code			Stream	Name			
	18E	45	277		Trib 45	277 to \$	hade C	reek		
NH3-N	Acute Alloc	ations	;							
RMI	Discharge l	Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	V	ltiple /LA ng/L)	Critical Reach	Percent Reductio	
0.40	0 Feather Nest	МН	18.23	27.82	18.2	3	27.82	0	0	_
NH3-N	Chronic Alle		ns Jaseline	Baseline	Multiple	Multi	ple	Critical	Percent	_
RMI	Discharge Na		Criterion (mg/L)	WLA (mg/L)	Criterion (mg/L)	WL (mg		Reach	Reduction	
0.40	0 Feather Nest	МН	4.08	8.64	4.0	18	8.64	0	0	_
Dissolve	ed Oxygen	Alloca	tions							_
RMI	Discharg	je Name	_	BOD5 ne Multiple ) (mg/L)		_			Critical Reach	Percent Reduction
0.4	In Feather Nest	МН	2	5 25	8 84	8.64	4	4	0	0

## WQM 7.0 D.O.Simulation

	am Code 15277		Trib 4	Stream Name 15277 to Shade Creek	
RMI	Total Discharge	Flow (mgd	) Anal	ysis Temperature (°C)	Analysis pH
0.400	0.020	)		10.492	7.000
Reach Width (ft)	Reach Dep	oth (ft)		Reach WDRatio	Reach Velocity (fps)
2.171	0.368	3		5.898	0.070
Reach CBOD5 (mg/L)	Reach Kc (1	1/days)	R	each NH3-N (mg/L)	Reach Kn (1/days)
14.63	1.392	-		4.74	0.337
Reach DO (mg/L)	Reach Kr (1			Kr Equation	Reach DO Goal (mg/L)
7.837	18.59	7		Owens	6
Reach Travel Time (days). 0.338	TravTime	Subreach CBOD5	Results NH3-N	D.O.	
	(days)	(mg/L)	(mg/L)	(mg/L)	
	0.034	14.19	4.69	8.71	
	0.068	13.77	4.64	9.19	
	0.101	13.35	4.58	9.46	
	0.135	12.95	4.53	9.62	
	0.169	12.57	4.48	9.73	
	0.203	12.19	4.43	9.79	
	0.237	11.83	4.38	9.85	
	0.271	11.47	4.33	9.89	
	0.304	11.13	4.28	9.92	
	0.338	10.79	4.23	9.96	

## WQM 7.0 Effluent Limits

		am <u>Code</u> 15277					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
0.400	Feather Nest MH	PA0204625	0.020	CBOD5	25		
				NH3-N	8.64	17.28	
				Dissolved Oxygen			4

# ATTACHMENT B TRC Modeling Results

TRC Spreadsheet\_Feather Nest MHP STP

TRC EVALUA	TRC EVALUATION											
Input appropria	te values in /	A3:A9 and D3:D9										
0.0127	= Q stream (	cfs)	0.5	= CV Daily								
0.02	= Q discharg	e (MGD)	0.5	= CV Hourly								
30	= no. sample	s	1	= AFC_Partial N	lix Factor							
0.3	= Chlorine D	emand of Stream	1	= CFC_Partial N	lix Factor							
0	= Chlorine D	emand of Discharge	15	= AFC_Criteria Compliance Time (min)								
0.5	= BAT/BPJ V	alue	720	= CFC_Criteria	Compliance Time (min)							
0	= % Factor o	of Safety (FOS)		=Decay Coefficient (K)								
Source	Reference	Reference	CFC Calculations									
TRC	1.3.2.iii	WLA afc =	0.150	1.3.2.iii	WLA cfc = 0.139							
PENTOXSD TRG	5.1a	LTAMULT afc =	0.373	5.1c	LTAMULT cfc = 0.581							
PENTOXSD TRG	5.1b	LTA_afc=	0.056	5.1d	LTA_cfc = 0.081							
Source Effluent Limit Calculations												
Source Effluent Limit Calculations PENTOXSD TRG 5 1f AMI MULT = 1 231												
PENTOXSD TRG 5.1f AML MULT = 1.231  PENTOXSD TRG 5.1g AVG MON LIMIT (mg/l) = 0.069 AFC												
PENTOXSD ING	5.1g		LIMIT (mg/l) =		Aro							
l			(g)									
1												
WLA afc		C_tc)) + [(AFC_Yc*Qs*.019/	-	tc))								
	•	C_Yc*Qs*Xs/Qd)]*(1-FOS/100	•									
LTAMULT afc		cvh^2+1))-2.326*LN(cvh^2+	1)^0.5)									
LTA_afc	wla_afc*LTA	MULT_afc										
WLA_cfc	( 011/e/-k*C	FC_tc) + [(CFC_Yc*Qs*.011/0	od*e/-k*CEC	te))								
		C_Yc*Qs*Xs/Qd)]*(1-FOS/10										
LTAMULT_cfc	•	cvd^2/no_samples+1))-2.32		samples+1)^0	.5)							
LTA_cfc	wla_cfc*LTA		•	,	-							
AML MULT	•	N((cvd^2/no_samples+1)^0.5		^2/no_samples+	1))							
AVG MON LIMIT		J,MIN(LTA_afc,LTA_cfc)*AM	_									
INST MAX LIMIT	1.5*((av_mor	_limit/AML_MULT)/LTAMUL	T_afc)									

# ATTACHMENT C TMS Spreadsheet Output

3800-PM-BPNPSM0011 Rev. 10/2014 Permit

Permit No. PA0204625



Toxics Management Spreadsheet Version 1.3, March 2021

## Discharge Information

Instructions	Disch	Stream				
Facility:	Feather	Nest MHP STP		NPDES Permit No.: PA0	204625	Outfall No.: 001
Evaluation T	ype:	Major Sewage / Ind	ustrial Waste	Wastewater Description:	Treated Sewage	

	Discharge Characteristics												
Design Flow	Hardness (mg/l)*	pH (SU)*	F	artial Mix Fa	actors (PMF	5)	Complete Mix Times (min						
(MGD)*	naruness (mg/l)	pn (30)	CRL	Q <sub>7-10</sub>	Qh								
0.02 100 7													

					-	0 If I	eft I	blank	0.5 M le	ft blank	0	If left blan	k	1 If left	t blank
	Discharge Pollutant	Units	Ma	x Discharge Conc		rib onc		Stream Conc	Daily CV	Hourly CV	Strea m CV	Fate Coeff	FOS	Criteri a Mod	
	Total Dissolved Solids (PWS)	mg/L			T		î								
7	Chloride (PWS)	mg/L			T	T	Π								
1 8	Bromide	mg/L				Т	Î								
Group	Sulfate (PWS)	mg/L			Į	Į									
	Fluoride (PWS)	mg/L			Ţ	Ţ	Į.								
П	Total Aluminum	μg/L		100	7	F	H								
	Total Antimony	μg/L			$\top$	$\top$	Н								
	Total Arsenic	μg/L			7	$\top$	H								
	Total Barium	μg/L					Ħ								
	Total Beryllium	μg/L			T	T	î								
	Total Boron	μg/L													
	Total Cadmium	μg/L			Į	I									
	Total Chromium (III)	µg/L			4	F	Н								
	Hexavalent Chromium	μg/L			-	F	H								
	Total Cobalt	μg/L			$\mp$	$\top$	Н								
	Total Copper	μg/L			7	$\top$									
2	Free Cyanide	μg/L			T	Т	î								
Group	Total Cyanide	μg/L			Т	Т	Î								
ြင်	Dissolved Iron	μg/L			Ţ	I									
	Total Iron	μg/L		100	ļ	Ţ	Ш								
	Total Lead	μg/L			7	F	Н								
	Total Manganese	μg/L		30	+	H	Н								
	Total Mercury	μg/L			7	$\top$									
	Total Nickel	μg/L				Т	Ħ								
	Total Phenols (Phenolics) (PWS)	μg/L			$\top$	Т	Π								
	Total Selenium	μg/L													
	Total Silver	μg/L			Д	I	П								
	Total Thallium	μg/L			Ţ	Ţ	Ш								
	Total Zinc	μg/L			7	F	H								
	Total Molybdenum	μg/L			+		H								
	Acrolein	µg/L	<				Н								
	Acrylamide	µg/L	<				Ì								
	Acrylonitrile	μg/L	<				Î								
	Benzene	μg/L	<												
	Bromoform	μg/L	<		I		Ц								

Discharge Information 5/31/2022 Page 1

	Carbon Tetrachloride	μg/L	<		+	-	-						$\dashv$	+	H
	Chlorobenzene	μg/L			H								-	1	7
	Chlorodibromomethane	µg/L	<		H									+	7
	Chloroethane	μg/L	<		Ħ	₹	⇉						Ħ	┿	7
	2-Chloroethyl Vinyl Ether	µg/L	<		₩	+	+						H	+	۲
	Chloroform		<		Н	+	+						Н	+	Н
		μg/L	-		₩	4	+						H	+	Н
	Dichlorobromomethane	μg/L	<		H	7	$\Rightarrow$						Ħ	+	=
	1,1-Dichloroethane	μg/L	<		H	4	$\Rightarrow$						H	4	
2	1,2-Dichloroethane	μg/L	<		$\vdash$	⇉	$\Rightarrow$							$\pm$	
Group	1,1-Dichloroethylene	μg/L	<		H	7	$\dashv$						$\vdash$	$\pm$	
ē	1,2-Dichloropropane	µg/L	<		H	7	7						Ħ	Ŧ	7
ן פ	1,3-Dichloropropylene	µg/L	<		Ħ	₹	7						Ħ	Ť	Ħ
	1,4-Dioxane	μg/L	<		H	╗	7						H	+	۲
	Ethylbenzene	μg/L	<		H	7	-						H	+	H
			-		H	⇉	7	_					H	÷	H
	Methyl Bromide	μg/L	<		H	4	$\Rightarrow$						H	+	4
	Methyl Chloride	μg/L	<		H	4	$\Rightarrow$						Ħ	$\Rightarrow$	
	Methylene Chloride	μg/L	<		H	⇉	_						$\vdash$	$\pm$	4
	1,1,2,2-Tetrachloroethane	μg/L	<		H	7	7						H	7	7
	Tetrachloroethylene	µg/L	<		H		7						+	1	7
	Toluene	μg/L	<		$\uparrow$								1	1	7
	1,2-trans-Dichloroethylene	μg/L	<											1	1
	1,1,1-Trichloroethane		<		+	-							+	+	-
	• •	μg/L	⊢		H		7						H	+	
	1,1,2-Trichloroethane	μg/L	<		H									+	
	Trichloroethylene	µg/L	<											1	
	Vinyl Chloride	μg/L	<		$\vdash$	1							+	+	+
7	2-Chlorophenol	μg/L	<		H								H		
	2,4-Dichlorophenol	μg/L	<			T	T							T	T
	2,4-Dimethylphenol	μg/L	<											1	
	4,6-Dinitro-o-Cresol	µg/L	<												
4	2,4-Dinitrophenol		<										1	+	7
		µg/L	_		H	7							H	+	
9 1	2-Nitrophenol	µg/L	<		H								1	+	
5	4-Nitrophenol	μg/L	<		H										
	p-Chloro-m-Cresol	μg/L	<		H										
	Pentachlorophenol	μg/L	<		H			1							
	Phenol	µg/L	<		Ħ	Ì	T						Ť	Ť	T
	2,4,6-Trichlorophenol	μg/L	<												1
_	Acenaphthene	µg/L	<		T								1		
			<		H	7							H	+	7
	Acenaphthylene	µg/L	_		H								H	+	7
	Anthracene	μg/L	<		Ħ								T	7	7
	Benzidine	μg/L	<											1	
	Benzo(a)Anthracene	μg/L	<												
	Benzo(a)Pyrene	μg/L	<			j		1							
	3,4-Benzofluoranthene	μg/L	<		Ħ								1	1	T
	Benzo(ghi)Perylene	μg/L	<											1	1
	Benzo(k)Fluoranthene	μg/L	<											1	T
			<		H									+	T
	Bis(2-Chloroethoxy)Methane	µg/L	_		H								H	+	7
	Bis(2-Chloroethyl)Ether	μg/L	<		H									1	
	Bis(2-Chloroisopropyl)Ether	μg/L	<												
	Bis(2-Ethylhexyl)Phthalate	μg/L	<											Ť	
	4-Bromophenyl Phenyl Ether	μg/L	<												
	Butyl Benzyl Phthalate	μg/L	<												
	2-Chloronaphthalene	μg/L	<		T	Ť							T	Ť	Ť
	4-Chlorophenyl Phenyl Ether	μg/L	<			Ì							Ì	1	Ť
	Chrysene		<		Ĥ								Ĥ	Ť	Ť
	•	μg/L	_		H	Ť							Ĥ	Ť	7
	Dibenzo(a,h)Anthrancene	μg/L	<		Ĥ								T	Ť	I
	1,2-Dichlorobenzene	μg/L	<												
	1,3-Dichlorobenzene	μg/L	<											Ì	
	1,4-Dichlorobenzene	μg/L	<			Ī								T	
	3,3-Dichlorobenzidine	μg/L	<												1
	Diethyl Phthalate	μg/L	<			Ť							T	1	Ť
5	Dimethyl Phthalate		<											1	T
		μg/L											H	+	7
	Di-n-Butyl Phthalate													1	
	2,4-Dinitrotoluene	V T	1	<b>①</b>	$\overline{}$	•		2	16	$\odot$	0			1	

	Osmotic Pressure	mOs/kg							
9	Total Uranium	μg/L	<					Щ	Ţ
dronb	Total Strontium	μg/L	<						
	Radium 226/228	pCi/L	<					+	+
	Total Beta	pCi/L	<						+
	Gross Alpha	pCi/L							
	2,3,7,8-TCDD	μg/L ng/L	<						+
	PCBs, Total Toxaphene	µg/L	<					+	+
	PCB-1260	μg/L	<						1
	PCB-1254	µg/L	<					П	Į
	PCB-1248	µg/L	<						
	PCB-1242	μg/L	<						T
	PCB-1232	µg/L	<					H	-
	PCB-1221	μg/L	<						
	PCB-1016	μg/L	<						
	Heptachlor Epoxide	μg/L	<						
	Heptachlor	µg/L	<						1
ś	Endrin Aldehyde	µg/L	<					+	+
2	Endrin	µg/L	<						+
•	Endosulfan Sulfate	µg/L	<					Ħ	Ţ
	beta-Endosulfan	µg/L	<						
	alpha-Endosulfan	µg/L	<						
	4,4-DDD Dieldrin	μg/L μg/L	<					++	+
	4,4-DDE 4,4-DDD	µg/L µg/l	<					++	+
	4,4-DDT 4.4-DDE	µg/L	<					H	1
	Chlordane 4.4-DDT	µg/L	<						
	delta BHC	µg/L	<						
	gamma-BHC	μg/L	<					#	
		µg/L	<						+
	alpha-BHC beta-BHC	μg/L	<					-	4
	Aldrin	µg/L	<						1
	1,2,4-Trichlorobenzene	μg/L	<					Щ	1
	Pyrene	μg/L	<						
	Phenanthrene	µg/L	<						1
	n-Nitrosodiphenylamine	μg/L	<					#	4
	n-Nitrosodi-n-Propylamine	μg/L	<					H	Ţ
	n-Nitrosodimethylamine	μg/L	<					Ш	I
	Nitrobenzene	μg/L	<						
	Naphthalene	μg/L	<					П	Ť
	Isophorone	µg/L	<						
	Indeno(1,2,3-cd)Pyrene	µg/L	<					+	+
	Hexachloroethane	µg/L	<					H	Ţ
	Hexachlorocyclopentadiene	µg/L	<					$\forall$	Ť
	Hexachlorobutadiene	µg/L µg/L	<				<del> </del>	₩	+
	Hexachlorobenzene	µg/L	<	-				₩	+
	Fluoranthene Fluorene	µg/L	<	-			$\vdash$	₩	4
	1,2-Diphenylhydrazine	μg/L	<				_	ш	#
	Di-n-Octyl Phthalate	μg/L	<					$\Rightarrow$	#



Toxics Management Spreadsheet Version 1.3, March 2021

## Stream / Surface Water Information

Feather Nest MHP STP, NPDES Permit No. PA0204625, Outfall 001

Instructions Disch	arge Str	eam													
Receiving Surface V	/ater Name:						No. Rea	aches to	Model:	1	~	tewide Criteri at Lakes Crit			
Location	Stream Co	de* RMI	Elevat	DA (mai	²)* Slo	pe (ft/ft)		Withdrav MGD)	val Apply F Criteri		OR	SANCO Crite	eria		
Point of Discharge	045277	0.4	186	0 0.29	1				Yes	;					
End of Reach 1	045277	0.01	1 166	0 0.43					Yes	;					
Q 7-10	5141	LFY	Flov	v (cfs)	W/D	Width	Depth	Velocit	iravei	Tributa	ary	Strea	m	Analys	sis
Location	RMI	(cfs/mi <sup>2</sup> )*	Stream	Tributary	Ratio	(ft)	(ft)	y (fps)	Time (days)	Hardness	pН	Hardness*	pH*	Hardness	pН
Point of Discharge	0.4	0.044				2.03	0.351		1112021			100	7		
End of Reach 1	0.01	0.044													
Qh			•											•	
Location	RMI	LFY	Flov	v (cfs)	W/D	Width	Depth	Velocit	Time	Tributa	ary	Strea	m	Analys	sis
Location	TXIVII	(cfs/mi <sup>2</sup> )	Stream	Tributary	Ratio	(ft)	(ft)	y (fps)	(days)	Hardness	pН	Hardness	pН	Hardness	pН
Point of Discharge	0.4														
End of Reach 1	0.01														



Toxics Management Spreadsheet Version 1.3, March 2021

## **Model Results**

#### Feather Nest MHP STP, NPDES Permit No. PA0204625, Outfall 001

Instructions Results	RETURN TO INPUTS	SAVE AS PDF	PRINT • A	All Onputs OResults OLimits
☐ Hydrodynamics				
✓ Wasteload Allocations				
✓ AFC	CCT (min): 0.007 PMF:	. 1 A	nalysis Hardness (mg/l):	100 Analysis pH: 7.00
Pollutants	Conc Stream Trib Cor (ug/L) CV (µg/L)	Coef (µg/L)	WQ Obj (µg/L) WLA (µg/L)	Comments
Total Aluminum	0 0	0 750	750 1,059	
Total Iron	0 0	0 N/A 0 N/A	N/A N/A	
Total Manganese	0 0	0 N/A	N/A N/A	
✓ CFC	CCT (min): 0.007 PMF	: <u>1</u> A	nalysis Hardness (mg/l):	100 Analysis pH: 7.00
Pollutants	Conc CV (µg/L)	Coef (µg/L)	WQ Obj (µg/L) WLA (µg/L)	Comments
Total Aluminum	0 0	0 N/A	N/A N/A	
Total Iron	0 0	0 1,500	1,500 2,119	WQC = 30 day average; PMF = 1
Total Manganese	0 0	0 N/A	N/A N/A	
✓ THH	CCT (min): 0.007 PMF	: <u>1</u> A	nalysis Hardness (mg/l):	N/A Analysis pH: N/A
Pollutants	Conc Stream Trib Cor (ug/L) CV (µg/L)		WQ Obj (µg/L) WLA (µg/L)	Comments
Total Aluminum	0 0	0 N/A	N/A N/A	
Total Iron	0 0	0 N/A	N/A N/A	
Total Manganese	0 0	0 1,000	1,000 1,412	
√ CRL	CCT (min): 0.023 PMF	: <u>1</u> A	nalysis Hardness (mg/l):	N/A Analysis pH: N/A
Pollutants	Conc Stream Trib Cor (ug/L) CV (µg/L)		WQ Obj (µg/L) WLA (µg/L)	Comments
Total Aluminum	0 0	0 N/A	N/A N/A	

Total Iron	0	0	0	N/A	N/A	N/A	
Total Manganese	0	0	0	N/A	N/A	N/A	

#### ☑ Recommended WQBELs & Monitoring Requirements

No. Samples/Month:

|--|

	Mass	Limits		Concentra	tion Limits				
Pollutants	AML (lbs/dav)	MDL (lbs/day)	AML	MDL	IMAX	Units	Governing WQBEL	WQBEL Basis	Comments
Total Aluminum	Report	Report	Report	Report	Report	μg/L	750	AFC	Discharge Conc > 10% WQBEL (no RP)

#### Other Pollutants without Limits or Monitoring

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., <= Target QL).

Pollutants	Governing WQBEL	Units	Comments
Total Iron	2,119	μg/L	Discharge Conc ≤ 10% WQBEL
Total Manganese	1,412	μg/L	Discharge Conc ≤ 10% WQBEL

# ATTACHMENT D USGS Stream Stats Output

Point of Discharge


# StreamStats Report

Region ID: PA

Workspace ID: PA20210908122433795000

Clicked Point (Latitude, Longitude): 40.19786, -78.85516

Time: 2021-09-08 08:24:52 -0400



Parameter			
Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	0.29	square miles
STORAGE	Percentage of area of storage (lakes ponds reservoirs wetlands)	0	percent
ELEV	Mean Basin Elevation	2007	feet
PRECIP	Mean Annual Precipitation	43	inches
FOREST	Percentage of area covered by forest	39.2833	percent
URBAN	Percentage of basin with urban development	0.3245	percent

Low-Flow Statistics Parameters [Low Flow Region 3]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	0.29	square miles	2.33	1720
ELEV	Mean Basin Elevation	2007	feet	898	2700
PRECIP	Mean Annual Precipitation	43	inches	38.7	47.9

Low-Flow Statistics Disclaimers [Low Flow Region 3]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors

Low-Flow Statistics Flow Report [Low Flow Region 3]

Statistic	Value	Unit
7 Day 2 Year Low Flow	0.0345	ft^3/s
30 Day 2 Year Low Flow	0.0513	ft^3/s
7 Day 10 Year Low Flow	0.0127	ft^3/s
30 Day 10 Year Low Flow	0.0183	ft^3/s
90 Day 10 Year Low Flow	0.028	ft^3/s

Low-Flow Statistics Citations

Stuckey, M.H.,2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (http://pubs.usgs.gov/sir/2006/5130/)

## Downstream of Discharge

## StreamStats Report

Region ID: PA
Workspace ID: PA20210908123458835000

Clicked Point (Latitude, Longitude): 40.19836, •78.86162 Time: 2021-09-08 08:35:17 -0400

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	0.43	square miles
ELEV	Mean Basin Elevation	1969	feet
PRECIP	Mean Annual Precipitation	43	inches

.ow-Flow Statistics P	arameters [Low Flow Region 3]				
Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit

ittps://streamstats.usgs.gov/ss/

39 AM			StreamState			
Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit	
DRNAREA	Drainage Area	0.43	square miles	2.33	1720	
ELEV	Mean Basin Elevation	1969	feet	898	2700	
PRECIP	Mean Annual Precipitation	43	inches	38.7	47.9	