

Application Type Renewal
Facility Type Municipal
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0209058
APS ID 1027309
Authorization ID 1334156

Applicant and Facility Information

| | | | |
|---------------------------|---|------------------|---|
| Applicant Name | <u>Montour Township</u> | Facility Name | <u>Montour Township WWTF</u> |
| Applicant Address | <u>195 Rupert Drive</u> <u>Bloomsburg, PA 17815-9627</u> | Facility Address | <u>195 Rupert Drive</u> <u>Bloomsburg, PA 17815-9627</u> |
| Applicant Contact | <u>Lori Ebright</u> | Facility Contact | <u>Alec Engelman</u> |
| Applicant Phone | <u>570-784-4222</u> | Facility Phone | <u>570-238-2465</u> |
| Client ID | <u>44706</u> | Site ID | <u>258008</u> |
| Ch 94 Load Status | <u>Not Overloaded</u> | Municipality | <u>Montour Township</u> |
| Connection Status | <u>No Limitations</u> | County | <u>Columbia</u> |
| Date Application Received | <u>November 17, 2020</u> | EPA Waived? | <u>Yes</u> |
| Date Application Accepted | <u>December 08, 2020</u> | If No, Reason | <u>N/A</u> |
| Purpose of Application | <u>Renewal of NPDES Permit</u> | | |

Summary of Review

INTRODUCTION

Lori Ebright, the Township Secretary, applied to renew the existing NPDES permit authorizing the discharge from the Montour Township wastewater treatment facility (WWTF) in Columbia County.

APPLICATION



Ebright submitted the *NPDES Application for Individual Permit to Discharge Sewage Effluent from Minor Sewage Facilities* (DEP #3800-PM-BCW0342b). This application was received by the Department on November 17, 2020 and was considered administratively complete on December 08, 2020. Ebright is the client contact. Her additional contact information is (email) lorie@montourtownship.org. The site contact is Alec Engelman, certified operator with Phoenix Water and Wastewater Operations of Milton, PA. His contact information is (phone) 570-238-2465 and (email) alecengelman@phoenixwawo.com. The engineering consultant who submitted the application on behalf of Montour Township is Raelene Gabriel, Project Engineer with Glace Associates, Inc. of Camp Hill, PA. Her contact information is (phone) 717-731-1579 and (email) raelene@glaceeng.com.

PUBLIC PARTICIPATION

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

The case file, permit application package and draft permit will be available for public review at Department's Northcentral Regional Office. The address for this office is 208 West Third Street, Suite 101, Williamsport, PA 17701. An appointment can be made to review these materials during the comment period by calling the file coordinator at 570-327-3636.

CONTINUED on the next page.

| Approve | Deny | Signatures | | Date |
|---------|------|---------------------------|---|------------|
| X | | Jeffrey J. Gocek, EIT |  Project Manager | 02/17/2022 |
| X | | Nicholas W. Hartranft, PE |  Environmental Engineer Manager | 02/17/2022 |

DISCHARGE, RECEIVING WATERS AND WATER SUPPLY INFORMATION

| | | | |
|---|------------------------------------|------------------------------|-----------------|
| Outfall No. | 001 | Design Flow (MGD) | 0.10 |
| Latitude | 40° 58' 52.99" | Longitude | -76° 28' 21.53" |
| Quad Name | Catawissa, PA | Quad Code | 1134 |
| Wastewater Description: | | Sewage Effluent | |
| Receiving Waters | Fishing Creek (WWF) | Stream Code | 27623 |
| NHD Com ID | 65640875 | RMI | 0.47 |
| Drainage Area | 385 | Yield (cfs/mi ²) | 0.0871 |
| Q ₇₋₁₀ Flow (cfs) | 33.55 | Q ₇₋₁₀ Basis | USGS #01540500 |
| Elevation (ft) | 455 | Slope (ft/ft) | N/A |
| Watershed No. | 5-C | Chapter 93 Class. | WWF |
| Existing Use | None | Existing Use Qualifier | None |
| Exceptions to Use | None | Exceptions to Criteria | None |
| Assessment Status | Attaining Use(s) | | |
| Cause(s) of Impairment | N/A | | |
| Source(s) of Impairment | N/A | | |
| TMDL Status | N/A | Name | N/A |
| Nearest Downstream Public Water Supply Intake | Danville Municipal Water Authority | | |
| PWS Waters | Susquehanna River | Flow at Intake (cfs) | 975 |
| PWS RMI | 137 | Distance from Outfall (mi) | 10 |

Q_{7,10} DETERMINATION

The Q_{7,10} is the lowest seven consecutive days of flow in a 10 year period and is used for modeling wastewater treatment plant discharges. 25 PA § 96.1 defines Q_{7,10} as "the actual or estimated lowest seven consecutive day average flow that occurs once in 10 years for a stream with unregulated flow or the estimated minimum flow for a stream with regulated flow".

A nearby stream gage, "Susquehanna River at Danville, PA" (USGS #01540500), is located downstream of the discharge. A Q_{7,10} flow for that gage (978 CFS) was obtained from "Selected Streamflow Statistics for Streamflow Locations in and near Pennsylvania" (USGS Open Files Report 2011-1070). Knowing the drainage area at the discharge (385 mi²) and both the drainage area (11,220 mi²) and Q_{7,10} (978 CFS) at the reference gage, the Q_{7,10} at the discharge was calculated to be 33.55 CFS.

See Attachment 01 for the Q_{7,10} determination.

CONTINUED on the next page.

TREATMENT FACILITY

The WWTP treats domestic wastewater from the Village of Rupert. Rupert is located to the southwest of Bloomsburg, along Route 42.

The treatment system consists of five pump stations (within the collection system), an influent flow box, an equalization tank, a distribution box, two aeration tanks, two secondary clarifiers, three erosion chlorinators, a chlorine contact tank, and a flow meter prior to the outfall. The treatment system also includes a sludge holding tank and an aerated sludge holding (not in use).

See Attachment 02 for a map of the WWTF location. See Attachment 03 for a process flow diagram.

The WWTF characteristics are as follows.

| Waste Type | Degree of Treatment | Process Type | Disinfection | Average Annual Flow (MGD) |
|--------------------------|---------------------------------|-------------------|---------------------|---------------------------|
| Sewage | Secondary with NH3 Reduction | Extended Aeration | Hypochlorite | 0.1 |
| Hydraulic Capacity (MGD) | Organic Capacity (lbs BOD5/day) | Load Status | Biosolids Treatment | Biosolids Use/Disposal |
| 0.1 | 185 | Not Overloaded | Aerobic Digestion | Other WWTP |

The above design was first approved by Water Quality Management (WQM) permit #1995402, first issued May 11, 1995. This permit was amended by letter on December 17, 2002 for the enhancement of solids handling capabilities. The organic rerate, which should have coincided with the letter amendment, was finally issued September 8, 2003. At this time, the organic loading rate of the plant was rerated to 417 pounds BOD5 per day. A formal permit amendment was issued November 16, 2005 and authorized the construction of a manual bar screen and erosion chlorination.

The NPDES permit was first issued January 18, 1995. The permit was renewed on July 18, 2000, April 18, 2005, July 21, 2010 and June 01, 2016. The annual average design flow for the WWTP is 0.1 MGD.

The annual average flow for the year prior to application submission was 0.07 MGD. The highest month during that year was 0.0889 MGD and occurred in January (2019).

COMPLIANCE HISTORY

The WMS Query *Open Violations by Client* revealed no unresolved violations for the Township.

The most recent Department inspection, a Compliance Evaluation Inspection (CEI), was conducted August 11, 2021. At the time of the inspection, all required treatment units appeared online and operational. The effluent appeared clear and there were no observed problems in the receiving stream downstream of the outfall. Corrosion on some of the metal treatment tank walls was noted, as well as work to renovate these issues. Infiltration and Inflow within the township collection system was also noted.

Recent Discharge Monitoring Report (DMR) data, from December 2020 to November 2021 is below.

CONTINUED on the next page.

| Parameter | NOV-21 | OCT-21 | SEP-21 | AUG-21 | JUL-21 | JUN-21 | MAY-21 | APR-21 | MAR-21 | FEB-21 | JAN-21 | DEC-20 |
|-------------------------------------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| Flow (MGD) | | | | | | | | | | | | |
| Average Monthly | 0.0721 | 0.0618 | 0.0767 | 0.0583 | 0.0585 | 0.0527 | 0.0414 | 0.0625 | 0.075 | 0.0615 | 0.0668 | 0.0624 |
| Flow (MGD) | | | | | | | | | | | | |
| Weekly Average | 0.0817 | 0.0748 | 0.0828 | 0.0700 | 0.0736 | 0.0578 | 0.0519 | 0.0718 | 0.0859 | 0.0698 | 0.0818 | 0.078 |
| pH (S.U.) | | | | | | | | | | | | |
| Minimum | 7.0 | 6.9 | 7.0 | 7.0 | 6.9 | 6.6 | 6.3 | 6.5 | 6.9 | 6.9 | 7.1 | 6.7 |
| pH (S.U.) | | | | | | | | | | | | |
| Instantaneous Maximum | 7.3 | 7.5 | 7.3 | 7.2 | 7.2 | 7.2 | 7.3 | 7.2 | 7.3 | 7.7 | 7.6 | 7.4 |
| DO (mg/L) | | | | | | | | | | | | |
| Minimum | 5.2 | 5.1 | 5.6 | 5.5 | 4.4 | 4.8 | 4.2 | 5.1 | 9.4 | 10.9 | 9.7 | 7.0 |
| TRC (mg/L) | | | | | | | | | | | | |
| Average Monthly | 0.20 | 0.3 | 0.3 | 0.4 | 0.4 | 0.4 | 0.4 | 0.3 | 0.4 | 0.30 | 0.1 | 0.3 |
| TRC (mg/L) | | | | | | | | | | | | |
| Instantaneous Maximum | 0.35 | 0.46 | 0.55 | 0.51 | 0.51 | 0.57 | 0.99 | 0.95 | 0.6 | 0.41 | 0.36 | 0.55 |
| CBOD5 (lbs/day) | | | | | | | | | | | | |
| Average Monthly | < 3.0 | < 2.0 | < 3.0 | < 2.0 | < 3.0 | < 3.0 | < 1.0 | < 4.0 | < 4.0 | < 3.0 | < 4.0 | < 3.0 |
| CBOD5 (lbs/day) | | | | | | | | | | | | |
| Weekly Average | < 4.0 | < 3.0 | < 4.0 | < 2.0 | < 3.0 | < 3.0 | < 3.0 | < 5.0 | < 5.0 | < 3.0 | < 5.0 | < 3.0 |
| CBOD5 (mg/L) | | | | | | | | | | | | |
| Average Monthly | < 6.0 | < 6.0 | < 6.0 | < 6.0 | < 6.0 | < 6.0 | < 6.0 | < 6.0 | < 6.0 | < 6.0 | < 6.0 | < 6.0 |
| CBOD5 (mg/L) | | | | | | | | | | | | |
| Weekly Average | < 6.0 | < 6.0 | < 6.0 | < 6.0 | < 6.0 | < 6.0 | < 6.0 | < 6.0 | < 6.0 | < 6.0 | < 6.0 | < 6.0 |
| BOD5 (lbs/day) | | | | | | | | | | | | |
| Raw Sewage Influent Average Monthly | 56 | 47 | 45 | 44 | 103 | 73 | 79 | 101 | 117 | 100.0 | 113.0 | 41.0 |
| BOD5 (lbs/day) | | | | | | | | | | | | |
| Raw Sewage Influent Weekly Average | 106 | 85 | 56 | 52 | 142 | 84 | 145 | 147 | 157 | 104.0 | 157.0 | 41.1 |
| BOD5 (mg/L) | | | | | | | | | | | | |
| Raw Sewage Influent Average Monthly | 138 | 110 | 86 | 120 | 253 | 160 | 237 | 159 | 170 | 234.0 | 164.0 | 91 |
| TSS (lbs/day) | | | | | | | | | | | | |
| Average Monthly | < 7.0. | 3.0 | < 3.0 | 4.0 | 4.0 | 9.0 | 2.0 | 70 | 5.0 | 5.0 | 5.0 | 5.0 |
| TSS (lbs/day) | | | | | | | | | | | | |
| Raw Sewage Influent Average Monthly | 100 | 40 | 73 | 66 | 152 | 134 | 31 | 84 | 105 | 85.0 | 98.0 | 32.0 |
| TSS (lbs/day) | | | | | | | | | | | | |
| Raw Sewage Influent Weekly Average | 186 | 64 | 98 | 69 | 154 | 183 | 47 | 97 | 146 | 94.0 | 107.0 | 32.0 |
| TSS (lbs/day) | | | | | | | | | | | | |
| Weekly Average | 11 | 4.0 | < 3.0 | 4.0 | 4.0 | 11 | 4.0 | 10 | 5.0 | 8.0 | 6.0 | 5.0 |
| TSS (mg/L) | | | | | | | | | | | | |
| Average Monthly | < 11.0 | 9.0 | < 6.0 | 11.0 | 9.0 | 21.0 | 12.0 | 11.0 | 8.0 | 12.0 | 9.0 | 11.0 |
| TSS (mg/L) | | | | | | | | | | | | |
| Raw Sewage Influent Average Monthly | 245 | 97 | 141 | 176 | 343 | 290 | 137 | 145 | 150 | 197.0 | 156.0 | 72.0 |
| TSS (mg/L) | | | | | | | | | | | | |
| Weekly Average | 17.0 | 9.0 | 6.1 | 11.0 | 12.0 | 26.0 | 15.0 | 13.0 | 10.0 | 17.0 | 10.0 | 11.0 |
| Fecal Coliform (No./100 ml) | | | | | | | | | | | | |
| Geometric Mean | 810 | 7.0 | < 2.0 | 17 | 8.0 | 56 | 15 | 7.0 | 10 | < 1.0 | < 2.0 | > 1.0 |
| Total Nitrogen (lbs/day) | | | | | | | | | | | | |
| Average Monthly | | | | | | | | | | | | 14 |
| Total Nitrogen (lbs/day) | | | | | | | | | | | | |
| Weekly Average | | | | | | | | | | | | 14 |
| Total Nitrogen (mg/L) | | | | | | | | | | | | |
| Average Monthly | | | | | | | | | | | | 28.1 |
| Ammonia (mg/L) | | | | | | | | | | | | |
| Average Monthly | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.2 | < 0.20 | < 0.2 | < 0.2 |
| Total Phosphorus (lbs/day) | | | | | | | | | | | | |
| Average Monthly | | | | | | | | | | | | 1.0 |
| Total Phosphorus (lbs/day) | | | | | | | | | | | | |
| Weekly Average | | | | | | | | | | | | 1.0 |
| Total Phosphorus (mg/L) | | | | | | | | | | | | |
| Average Monthly | | | | | | | | | | | | 2.85 |

CONTINUED on the next page.

EXISTING EFFLUENT LIMITATIONS

The following effluent limitations and monitoring requirements were established at the permit issuance/renewal on June 01, 2016.

| Discharge Parameter | Mass Limits (lb/day) | | Concentration Limits (mg/L) | | | | Monitoring Requirements | |
|---|----------------------|----------------|-----------------------------|-------------------------|----------------|--------|-------------------------------|----------------------|
| | Monthly Average | Weekly Average | Minimum | Monthly Average | Weekly Average | IMAX | Minimum Measurement Frequency | Required Sample Type |
| Flow (MGD) | Report | Report | XXX | XXX | XXX | XXX | Continuous | Metered |
| pH (SU) | XXX | XXX | 6.0 | XXX | XXX | 9.0 | 1/Day | Grab |
| Dissolved Oxygen | XXX | XXX | Report | XXX | XXX | XXX | 1/Day | Grab |
| Total Residual Chlorine | XXX | XXX | XXX | 0.5 | XXX | 1.6 | 1/Day | Grab |
| CBOD ₅ | 20 | 33 | XXX | 25 | 40 | 50 | 2/Month | 8 Hour Composite |
| BOD ₅ Influent | Report | Report | XXX | Report | XXX | XXX | 2/Month | 8 Hour Composite |
| Total Suspended Solids | 25 | 37 | XXX | 30 | 45 | 60 | 2/Month | 8 Hour Composite |
| TSS Influent | Report | Report | XXX | Report | XXX | XXX | 2/Month | 8 Hour Composite |
| Fecal Coliform (CFU/100mL) (05/01-09/30) | XXX | XXX | XXX | 200 Geometric Mean | XXX | 1,000 | 2/Month | Grab |
| Fecal Coliform (CFU /100mL) (10/01-04/30) | XXX | XXX | XXX | 2,000 Geometric Mean | XXX | 10,000 | 2/Month | Grab |
| Ammonia-Nitrogen | XXX | XXX | XXX | Report | XXX | XXX | 1/Month | 8 Hour Composite |
| Total Nitrogen | Report | XXX | XXX | Report | XXX | XXX | 1/Year | 8 Hour Composite |
| Total Phosphorus | Report | XXX | XXX | Report | XXX | XXX | 1/Year | 8 Hour Composite |

DEVELOPMENT OF EFFLUENT LIMITATIONS (OUTFALL 001)Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

| Pollutant | Limit (mg/l) | SBC | Federal Regulation | State Regulation |
|------------------------------|-----------------|-----------------|--------------------|------------------|
| CBOD ₅ | 25 | Average Monthly | 133.102(a)(4)(i) | 92a.47(a)(1) |
| | 40 | Average Weekly | 133.102(a)(4)(ii) | 92a.47(a)(2) |
| Total Suspended Solids | 30 | Average Monthly | 133.102(b)(1) | 92a.47(a)(1) |
| | 45 | Average Weekly | 133.102(b)(2) | 92a.47(a)(2) |
| pH | 6.0 – 9.0 S.U. | Min – Max | 133.102(c) | 95.2(1) |
| Fecal Coliform (5/1 – 9/30) | 200 / 100 ml | Geo Mean | - | 92a.47(a)(4) |
| Fecal Coliform (5/1 – 9/30) | 1,000 / 100 ml | IMAX | - | 92a.47(a)(4) |
| Fecal Coliform (10/1 – 4/30) | 2,000 / 100 ml | Geo Mean | - | 92a.47(a)(5) |
| Fecal Coliform (10/1 – 4/30) | 10,000 / 100 ml | IMAX | - | 92a.47(a)(5) |
| Total Residual Chlorine | 0.5 | Average Monthly | - | 92a.48(b)(2) |

CONTINUED on the next page.

Total Residual Chlorine

The Department's TRC_CALC spreadsheet is a model used to evaluate Total Residual Chlorine (TRC) effluent limitations. This model determines applicable acute and chronic wasteload allocations (WLAs) for TRC based on the data supplied by the user and then compares the WLAs to the technology-based average monthly limit using the procedures described in the EPA Technical Support Document for Water Quality-Based Toxics Control.

This model recommended the following limitations.

| Parameter | Effluent Limitations (mg/L) | |
|-------------------------|-----------------------------|------|
| | Monthly Average | IMAX |
| Total Residual Chlorine | 0.5 | 1.6 |

See Attachment 04 for the TRC_CALC model results.

Water Quality-Based LimitationsCBOD₅, NH₃-N and DO

WQM 7.0 for Windows (version 1.1) is a DEP computer model used to determine wasteload allocations and effluent limitations for CBOD₅, NH₃-N and DO for single and multiple point source discharge scenarios. This model simulates two basic processes. The NH₃-N module simulates the mixing and degradation of NH₃-N in the stream and compares calculated instream NH₃-N concentrations to the water quality criteria. The DO module simulates the mixing and consumption of DO in the stream due to degradation of CBOD₅ and NH₃-N and compares the calculated instream DO concentrations to the water quality criteria. The model then determines the highest pollutant loading the stream can assimilate and still meet water quality under design conditions.

This model recommended the following limitations.

| Parameter | Effluent Limitations (mg/L) | | |
|--------------------|-----------------------------|---------|---------|
| | 30 Day Average | Maximum | Minimum |
| CBO D ₅ | 25 | | |
| NH ₃ -N | 25 | 50 | |
| DO | | | 3.0 |

See Attachment 05 for the WQM model output.

Best Professional Judgment (BPJ) Limitations

In the absence of applicable effluent guidelines for the discharge or pollutant, permit writers must identify and/or develop needed technology-based effluent limitations (TBELs) TBELs on a case-by-case basis, in accordance with the statutory factors specified in the Clean Water Act.

No BPJ limitations have been proposed for this draft.

Anti-Backsliding

In order to comply with 40 CFR § 122.44(l)(1) (anti-backsliding requirements), the Department must issue a renewed permit with limitations as stringent as that the of the previous permit.

No less stringent limitations have been proposed for this draft.

CONTINUED on the next page.

DEVELOPMENT OF EFFLUENT MONITORING (OUTFALL 001)Ammonia Nitrogen

Since the *WQM 7.0 for Windows* model recommended a technology-based requirement of 25 mg/L for Ammonia Nitrogen, a continued year-round monitoring requirement will suffice. This is in accordance with the Department's *Standard Operating Procedure for Clean Water Program Establishing Effluent Limitations for Individual Sewage Permits* (SOP #BCW-PMT-033).

Dissolved Oxygen

This permit will require a monitoring requirement for Dissolved Oxygen (DO), to ensure that the effluent is well oxygenated at the point of discharge and ensures adequate operation and maintenance of the WWTF.

Influent Monitoring

In order to adequately characterize the influent wastewater, monitoring of influent Biochemical Oxygen Demand (BOD₅) and Total Suspended Solids (TSS) will be required at the same frequency of effluent CBOD₅ and TSS (2/Month). This is in accordance with Department procedure.

E.coli

The Department is requiring the monitoring of *Escherichia coli* (E. coli), a pathogenic bacterium normally found in the intestines of healthy people and animals which is used as a fecal contamination indicator in freshwater ecosystems. Section 303(c)(1) of the Clean Water Act requires that Pennsylvania periodically review and revise water quality standards, if necessary. The 2017 triennial review final form rulemaking, published in 2020, has revised the Chapter 93 water quality standards regulations for bacteria to include E. coli. To further characterize fecal contamination of surface waters during the swimming season, the Department is requiring the quarterly reporting of effluent E. coli effluent values. In accordance with 25 PA § 92a.61, the Department may impose reasonable monitoring requirements on pollutants which could have impact on the quality of the Commonwealth's waters or the quality of waters in other states.

REMOVAL OF EFFLUENT MONITORINGChesapeake Bay TMDL for Nutrients and Sediment

Despite 25 years of extensive restoration efforts, the Chesapeake Bay Total Maximum Daily Load (TMDL) was prompted by insufficient progress and continued poor water quality in the Chesapeake Bay and its tidal tributaries. This TMDL, required by the Clean Water Act, is the largest ever developed by the Environmental Protection Agency (EPA). This document identifies the necessary pollution reductions of nitrogen, phosphorus and sediment across Delaware, Maryland, New York, Virginia, West Virginia, District of Columbia and Pennsylvania. It also sets pollution limits necessary to meet applicable water quality standards in the Bay, tidal rivers and embayments.

Pennsylvania explains how and when it will meet its pollution allocations in its Watershed Implementation Plan (WIP), which is incorporated into the TMDL. Pennsylvania's permitting strategy for significant dischargers has been outlined in the Phase I WIP and incorporated in the Phase III WIP by reference, and imposes Total Nitrogen (TN) and Total Phosphorus (TP) cap loads on the significant dischargers.

Because the design of this facility is less than 0.2 MGD, the Department considers this an existing Phase 5 sewage facility for the purposes of implementing the Chesapeake Bay TMDL. This system has a design flow of 0.10 MGD. According to the Department's Wastewater Supplement to Phase III WIP (last revised September 13, 2021), renewed Phase 5 facilities are required to contain monitoring and reporting for TN and TP throughout the permit term at a frequency of no less than annually unless the facility has already conducted at least two years of nutrient monitoring.

Nutrient data was collected during the previous permit term. That data is summarized below.

| Year | Parameter | Concentration (mg/L) | Loading (lb/day) |
|------|------------------|----------------------|------------------|
| 2019 | Total Nitrogen | 24.13 | 9.0 |
| 2019 | Total Phosphorus | 2.59 | 1.0 |
| 2020 | Total Nitrogen | 28.10 | 14 |
| 2020 | Total Phosphorus | 2.85 | 1.0 |

CONTINUED on the next page.

RECEIVING STREAM

Stream Characteristics

The receiving stream is Fishing Creek, a tributary to the Susquehanna River. According to 25 PA § 93.9K, this stream is protected for *Warm Water Fishes (WWF)* and *Migratory Fishes (MF)*. These are the streams *Designated Uses*, which is defined in 25 PA § 93.1 as “those uses specified in §§ 93.9a – 93.9z for each waterbody or segment whether or not the use is being attained”. Designated uses are regulations promulgated by the Environmental Quality Board (EQB) throughout the rulemaking process. This stream currently has no *Existing Use*, which is defined in 25 PA § 93.1 as “those uses actually attained in the waterbody on or after November 28, 1975 whether or not they are included in the water quality standards”. Fishing Creek is identified by stream code 27623. This stream is in (Chapter 93) drainage list K and State Water Plan watershed 5C (Fishing Creek).

Impairment/TMDL

This section of Fishing Creek is attaining its designated uses aquatic life and fish consumption.

An upstream tributary to Fishing Creek, Montour Run, is impaired for aquatic life due to Turbidity, Total Suspended Solids and Siltation due to non-point sources (crop production). Total Maximum Daily Loads (TMDLs) addressing this impairment were approved by EPA in 2013. The Susquehanna River downstream is impaired for fish consumption by polychlorinated biphenyls (PCBs) from an unknown source. A TMDL addressing this impairment was approved by EPA in 1999.

ADDITIONAL CONSIDERATIONS

Hauled-In Wastes

According to the application materials, the Township does not accept hauled-in wastes.

Mass Limitations

Existing mass limitations for CBOD₅ and TSS are calculated by multiplying the concentration (mg/L) by the flow (MGD) by the conversion (8.34).

Rounding of Limitations

Limitations have been rounded down in accordance with the Department's *Technical Guidance for the Development and Specification of Effluent Limitations and Other Permit Conditions in NPDES Permits* (#362-0400-001).

Limit Multipliers

The instantaneous maximum limitations have been calculated using multipliers of 2.0 (for sewage discharges) for determining the IMAX. This practice is in accordance with the Department's *Technical Guidance for the Development and Specification of Effluent Limitations and Other Permit Conditions in NPDES Permits* (#362-0400-001).

Sample Frequencies and Types

The sample type and minimum measurement frequencies are in accordance with the Department's *Technical Guidance for the Development and Specification of Effluent Limitations and Other Permit Conditions in NPDES Permits* (#362-0400-001). The minimum measurement frequencies of the nutrient parameters are in accordance with the Department's *Phase III Watershed Implementation Plan* of the Chesapeake Bay TMDL.

Special Permit Conditions

Stormwater Prohibition
Approval Contingencies
Proper Waste Disposal
Municipal Treatment Availability
Solids Management for Non-Lagoon Treatment Systems

CONTINUED on the next page.

Supplemental Discharge Monitoring Reports

Daily Effluent Monitoring
 Non-Compliance Reporting
 Biosolids Production and Disposal
 Hauled-in Municipal Waste
 Influent and Process Control
 Lab Accreditation

PROPOSED EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date

| Discharge Parameter | Mass Limits (lb/day) | | Concentration Limits (mg/L) | | | | Monitoring Requirements | |
|--|-----------------------------|----------------|---------------------------------|-------------------------|----------------|--------|-------------------------------|----------------------|
| | Monthly Average | Weekly Average | Minimum | Monthly Average | Weekly Average | IMAX | Minimum Measurement Frequency | Required Sample Type |
| Flow (MGD) | Report | Report | XXX | XXX | XXX | XXX | Continuous | Metered |
| pH (SU) | XXX | XXX | 6.0 Instantaneous Minimum | XXX | XXX | 9.0 | 1/Day | Grab |
| Dissolved Oxygen | XXX | XXX | Report Instantaneous Minimum | XXX | XXX | XXX | 1/Day | Grab |
| Total Residual Chlorine | XXX | XXX | XXX | 0.5 | XXX | 1.6 | 1/Day | Grab |
| CBOD ₅ | 20 | 33 | XXX | 25 | 40 | 50 | 2/Month | 8 Hour Composite |
| BOD ₅ Influent | Report | Report | XXX | Report | XXX | XXX | 2/Month | 8 Hour Composite |
| Total Suspended Solids | 25 | 37 | XXX | 30 | 45 | 60 | 2/Month | 8 Hour Composite |
| TSS Influent | Report | Report | XXX | Report | XXX | XXX | 2/Month | 8 Hour Composite |
| Fecal Coliform (CFU/100mL) (05/01-09/30) | XXX | XXX | XXX | 200 Geometric Mean | XXX | 1,000 | 2/Month | Grab |
| Fecal Coliform (CFU /100mL) (10/01-04/30) | XXX | XXX | XXX | 2,000 Geometric Mean | XXX | 10,000 | 2/Month | Grab |
| Ammonia-Nitrogen | Report Average Quarterly | XXX | XXX | Report | XXX | XXX | 1/Month | Grab |
| E. coli (No./100mL) | XXX | XXX | XXX | XXX | XXX | Report | 1/Quarter | Grab |

END of Fact Sheet.

ATTACHMENT 01

Q₇₋₁₀ Analysis

| | |
|-------------------|------------------|
| Facility: | Montour Township |
| Outfall: | 001 |
| NPDES Permit No.: | PA0209058 |
| RMI at Outfall: | 0.47 |

Reference Stream Gage Information

| | |
|------------------------------------|-----------------------------------|
| Stream Name | Fishing Creek |
| Reference Gage | 01540500 |
| Station Name | Susquehanna River at Danville, PA |
| Gage Drainage Area (sq. mi.) | 11,220 |
| Q ₇₋₁₀ at gage (cfs) | 978 |
| Yield Ratio (cfs/mi ²) | 0.0872 |

Q₇₋₁₀ at Outfall

| | |
|---|---------|
| Drainage Area at site (sq. mi.) | 385.00 |
| Q ₇₋₁₀ at discharge site (cfs) | 33.559 |
| Q ₇₋₁₀ at discharge site (mgd) | 21.6896 |

12 Selected Streamflow Statistics for Streamgage Locations in and near Pennsylvania

Table 1. List of U.S. Geological Survey streamgage locations in and near Pennsylvania with updated streamflow statistics.—Continued

[Latitude and Longitude in decimal degrees; mi², square miles]


| Streamgage number | Streamgage name | Latitude | Longitude | Drainage area (mi ²) | Regulated ¹ |
|-------------------|---|----------|-----------|----------------------------------|------------------------|
| 01508803 | West Branch Tioughnioga River at Homer, N.Y. | 42.638 | -76.176 | 71.5 | N |
| 01509000 | Tioughnioga River at Cortland, N.Y. | 42.603 | -76.159 | 292 | N |
| 01510000 | Otselic River at Cincinnatus, N.Y. | 42.541 | -75.900 | 147 | N |
| 01512500 | Chenango River near Chenango Forks, N.Y. | 42.218 | -75.848 | 1,483 | N |
| 01515000 | Susquehanna River near Waverly, N.Y. | 41.985 | -76.501 | 4,773 | N |
| 01516350 | Tioga River near Mansfield, Pa. | 41.797 | -77.080 | 153 | N |
| 01516500 | Corey Creek near Mainesburg, Pa. | 41.791 | -77.015 | 12.2 | N |
| 01518000 | Tioga River at Tioga, Pa. | 41.908 | -77.129 | 282 | Y |
| 01518700 | Tioga River at Tioga Junction, Pa. | 41.953 | -77.115 | 446 | Y |
| 01518862 | Cowanesque River at Westfield, Pa. | 41.923 | -77.532 | 90.6 | N |
| 01520000 | Cowanesque River near Lawrenceville, Pa. | 41.997 | -77.140 | 298 | Y |
| 01520500 | Tioga River at Lindley, N.Y. | 42.029 | -77.132 | 771 | Y |
| 01521500 | Canisteo River at Arkport, N.Y. | 42.396 | -77.711 | 30.6 | Y |
| 01523500 | Canacadea Creek near Hornell, N.Y. | 42.335 | -77.683 | 57.9 | Y |
| 01524500 | Canisteo River below Canacadea Creek at Hornell, N.Y. | 42.314 | -77.651 | 158 | Y |
| 01526500 | Tioga River near Erwins, N.Y. | 42.121 | -77.129 | 1,377 | Y |
| 01527000 | Cohocton River at Cohocton, N.Y. | 42.500 | -77.500 | 52.2 | N |
| 01527500 | Cohocton River at Avoca, N.Y. | 42.398 | -77.417 | 152 | N |
| 01528000 | Fivemile Creek near Kanona, N.Y. | 42.388 | -77.358 | 66.8 | N |
| 01529000 | Mud Creek near Savona, N.Y. | 42.308 | -77.197 | 76.6 | Y |
| 01529500 | Cohocton River near Campbell, N.Y. | 42.253 | -77.217 | 470 | N |
| 01529950 | Chemung River at Corning, N.Y. | 42.146 | -77.057 | 2,006 | Y |
| 01530332 | Chemung River at Elmira, N.Y. | 42.086 | -76.801 | 2,162 | Y |
| 01530500 | Newtown Creek at Elmira, N.Y. | 42.105 | -76.798 | 77.5 | Y |
| 01531000 | Chemung River at Chemung, N.Y. | 42.002 | -76.635 | 2,506 | Y |
| 01531500 | Susquehanna River at Towanda, Pa. | 41.765 | -76.441 | 7,797 | Y |
| 01532000 | Towanda Creek near Monroeton, Pa. | 41.707 | -76.485 | 215 | N |
| 01532850 | MB Wyalusing Creek near Birchardville, Pa. | 41.863 | -76.007 | 5.67 | N |
| 01533400 | Susquehanna River at Meshoppen, Pa. | 41.607 | -76.050 | 8,720 | Y |
| 01533500 | North Branch Mehoopany Creek near Lovelton, Pa. | 41.531 | -76.156 | 35.2 | N |
| 01533950 | SB Tunkhannock Creek near Montdale, Pa. | 41.575 | -75.642 | 12.6 | N |
| 01534000 | Tunkhannock Creek near Tunkhannock, Pa. | 41.558 | -75.895 | 383 | N |
| 01534300 | Lackawanna River near Forest City, Pa. | 41.680 | -75.472 | 38.8 | Y |
| 01534500 | Lackawanna River at Archbald, Pa. | 41.505 | -75.542 | 108 | Y |
| 01536000 | Lackawanna River at Old Forge, Pa. | 41.359 | -75.744 | 332 | Y |
| 01536500 | Susquehanna River at Wilkes-Barre, Pa. | 41.251 | -75.881 | 9,960 | Y |
| 01537000 | Toby Creek at Luzerne, Pa. | 41.281 | -75.896 | 32.4 | Y |
| 01537500 | Solomon Creek at Wilkes-Barre, Pa. | 41.228 | -75.904 | 15.7 | N |
| 01538000 | Wapwallopen Creek near Wapwallopen, Pa. | 41.059 | -76.094 | 43.8 | N |
| 01539000 | Fishing Creek near Bloomsburg, Pa. | 41.078 | -76.431 | 274 | N |
| 01539500 | Little Fishing Creek at Eysers Grove, Pa. | 41.080 | -76.511 | 56.5 | N |
| 01540200 | Trexler Run near Ringtown, Pa. | 40.853 | -76.280 | 1.77 | N |
| 01540500 | Susquehanna River at Danville, Pa. | 40.958 | -76.619 | 11,220 | Y |
| 01541000 | West Branch Susquehanna River at Bower, Pa. | 40.897 | -78.677 | 315 | N |
| 01541200 | West Branch Susquehanna River near Curwensville, Pa. | 40.961 | -78.519 | 367 | Y |

Table 2 25


Table 2. Selected low-flow statistics for streamgage locations in and near Pennsylvania.—Continued

[ft³/s; cubic feet per second; —, statistic not computed; <, less than]


| Streamgage number | Period of record used in analysis ¹ | Number of years used in analysis | 1-day, 10-year (ft ³ /s) | 7-day, 10-year (ft ³ /s) | 7-day, 2-year (ft ³ /s) | 30-day, 10-year (ft ³ /s) | 30-day, 2-year (ft ³ /s) | 90-day, 10-year (ft ³ /s) |
|-------------------|--|----------------------------------|-------------------------------------|-------------------------------------|------------------------------------|--------------------------------------|-------------------------------------|--------------------------------------|
| 01530500 | 1940–2008 | 69 | 5.0 | 6.1 | 11.0 | 7.6 | 13 | 9.0 |
| 01531000 | ² 1981–2008 | 28 | 138 | 147 | 237 | 169 | 296 | 203 |
| 01531000 | ³ 1905–1979 | 68 | 86.3 | 97.0 | 175 | 116 | 219 | 161 |
| 01531500 | ² 1981–2008 | 28 | 550 | 592 | 1,030 | 733 | 1,340 | 952 |
| 01531500 | ³ 1915–1979 | 65 | 539 | 571 | 990 | 675 | 1,230 | 928 |
| 01532000 | 1915–2008 | 94 | 2.2 | 2.8 | 9.7 | 4.6 | 14.4 | 9.4 |
| 01532850 | 1967–1979 | 13 | .1 | .2 | .4 | .3 | .8 | .7 |
| 01533400 | ² 1981–2008 | 28 | 602 | 648 | 1,110 | 790 | 1,430 | 1,060 |
| 01533500 | 1942–1958 | 17 | .4 | .6 | 1.5 | .8 | 2.0 | 1.7 |
| 01533950 | 1962–1978 | 17 | .2 | .3 | 1.0 | .6 | 1.4 | 1.0 |
| 01534000 | 1915–2008 | 94 | 15.2 | 17.3 | 35.9 | 24.2 | 51.0 | 38.7 |
| 01534300 | 1960–2008 | 49 | 1.1 | 1.7 | 5.1 | 2.8 | 7.6 | 4.8 |
| 01534500 | ² 1961–2008 | 48 | 16.7 | 18.8 | 29.2 | 21.9 | 35.8 | 27.6 |
| 01534500 | ³ 1941–1959 | 19 | 18.8 | 23.0 | 33.3 | 25.6 | 39.2 | 34.9 |
| 01536000 | ² 1961–2008 | 48 | 28.7 | 32.7 | 51.7 | 40.8 | 68.1 | 54.3 |
| 01536000 | ³ 1940–1959 | 20 | 77.8 | 93.9 | 119 | 105 | 138 | 124 |
| 01536500 | ² 1981–2008 | 28 | 828 | 872 | 1,450 | 1,030 | 1,830 | 1,350 |
| 01536500 | ³ 1901–1979 | 79 | 778 | 811 | 1,350 | 927 | 1,640 | 1,260 |
| 01537000 | 1943–1993 | 51 | 1.3 | 2.0 | 4.9 | 3.1 | 6.4 | 4.7 |
| 01537500 | 1941–1990 | 50 | .2 | .3 | 1.9 | .5 | 3.1 | 1.6 |
| 01538000 | 1921–2008 | 88 | 3.1 | 3.6 | 7.1 | 5.0 | 9.3 | 7.5 |
| 01539000 | 1940–2008 | 69 | 15.4 | 16.8 | 36.8 | 21.1 | 51.1 | 36.8 |
| 01539500 | 1942–1958 | 17 | .1 | .3 | 1.4 | 1.0 | 3.3 | 2.3 |
| 01540200 | 1965–1981 | 17 | 0 | 0 | .3 | .1 | .3 | .1 |
| 01540500 | ² 1981–2008 | 28 | 1,080 | 1,120 | 1,870 | 1,320 | 2,330 | 1,690 |
| 01540500 | ³ 1906–1979 | 74 | 927 | 978 | 1,660 | 1,160 | 2,050 | 1,590 |
| 01541000 | 1915–2008 | 94 | 25.3 | 27.9 | 50.7 | 35.3 | 66.6 | 49.6 |
| 01541200 | ² 1967–2008 | 40 | 34.6 | 45.2 | 66.0 | 63.1 | 100 | 92.4 |
| 01541200 | ³ 1957–1965 | 9 | 22.9 | 24.7 | 44.7 | 27.7 | 58.2 | 36.4 |
| 01541303 | 1980–2008 | 29 | 53.4 | 58.5 | 94.0 | 74.4 | 123 | 102 |
| 01541308 | 1969–1979 | 11 | 1.3 | 1.3 | 1.9 | 1.6 | 2.4 | 2.1 |
| 01541500 | ² 1962–2008 | 47 | 39.0 | 41.9 | 66.5 | 51.9 | 86.3 | 70.6 |
| 01541500 | ³ 1915–1960 | 46 | 14.9 | 21.3 | 41.9 | 28.5 | 55.0 | 42.9 |
| 01542000 | 1942–1993 | 52 | 8.1 | 9.1 | 14.8 | 11.3 | 17.8 | 14.6 |
| 01542500 | ² 1967–2008 | 33 | 216 | 235 | 326 | 285 | 435 | 402 |
| 01542500 | ³ 1941–1965 | 20 | — | 131 | 189 | 152 | 243 | 221 |
| 01542810 | 1966–2008 | 43 | .1 | .1 | .3 | .2 | .5 | .3 |
| 01543000 | 1915–2008 | 94 | 2.9 | 4.2 | 16.0 | 9.6 | 27.4 | 19.2 |
| 01543500 | 1940–2008 | 69 | 10.7 | 14.5 | 44.9 | 26.6 | 74.9 | 50.5 |
| 01544000 | ² 1957–2008 | 52 | 3.3 | 6.9 | 19.0 | 11.2 | 31.1 | 19.0 |
| 01544500 | 1942–2008 | 67 | 4.2 | 4.9 | 12.5 | 7.5 | 17.4 | 11.7 |
| 01545000 | ² 1964–2008 | 45 | 6.8 | 8.2 | 21.2 | 12.0 | 32.7 | 20.7 |
| 01545500 | ² 1963–2008 | 46 | 217 | 238 | 446 | 306 | 629 | 428 |
| 01545500 | ³ 1909–1961 | 53 | 125 | 141 | 278 | 190 | 387 | 296 |
| 01545600 | 1966–2008 | 43 | 1.2 | 1.5 | 4.4 | 2.4 | 6.7 | 4.2 |



ATTACHMENT 02



ATTACHMENT 03



ATTACHMENT 04

TRC_CALC.xls

| TRC EVALUATION | | | | |
|---|---|-------------------------------|--------------------------------------|---------------------|
| Input appropriate values in A3:A9 and D3:D9 | | | | |
| 33.55 | = Q stream (cfs) | 0.5 | = CV Daily | |
| 0.1 | = Q discharge (MGD) | 0.5 | = CV Hourly | |
| 30 | = no. samples | 1 | = AFC_Partial Mix Factor | |
| 0.3 | = Chlorine Demand of Stream | 1 | = CFC_Partial Mix Factor | |
| 0 | = Chlorine Demand of Discharge | 15 | = AFC_Criteria Compliance Time (min) | |
| 0.5 | = BAT/BPJ Value | 720 | = CFC_Criteria Compliance Time (min) | |
| 0 | = % Factor of Safety (FOS) | | = Decay Coefficient (K) | |
| Source | Reference | AFC Calculations | Reference | CFC Calculations |
| TRC | 1.3.2.iii | WLA afc = 69.201 | 1.3.2.iii | WLA cfc = 67.458 |
| PENTOXSD TRG | 5.1a | LTAMULT afc = 0.373 | 5.1c | LTAMULT cfc = 0.581 |
| PENTOXSD TRG | 5.1b | LTA_afc = 25.786 | 5.1d | LTA_cfc = 39.217 |
| Source | Effluent Limit Calculations | | | |
| PENTOXSD TRG | 5.1f | AML MULT = 1.231 | | |
| PENTOXSD TRG | 5.1g | AVG MON LIMIT (mg/l) = 0.500 | | BAT/BPJ |
| | | INST MAX LIMIT (mg/l) = 1.635 | | |
| WLA afc | $(.019/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k*AFC_tc))... \\ ...+Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$ | | | |
| LTAMULT afc | $EXP((0.5*LN(cvh^2+1))-2.326*LN(cvh^2+1)^0.5)$ | | | |
| LTA_afc | wla_afc*LTAMULT_afc | | | |
| WLA_cfc | $(.011/e(-k*CFC_tc)) + [(CFC_Yc*Qs*.011/Qd*e(-k*CFC_tc))... \\ ...+Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$ | | | |
| LTAMULT_cfc | $EXP((0.5*LN(cvd^2/no_samples+1))-2.326*LN(cvd^2/no_samples+1)^0.5)$ | | | |
| LTA_cfc | wla_cfc*LTAMULT_cfc | | | |
| AML MULT | $EXP(2.326*LN((cvd^2/no_samples+1)^0.5)-0.5*LN(cvd^2/no_samples+1))$ | | | |
| AVG MON LIMIT | MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT) | | | |
| INST MAX LIMIT | $1.5*((av_mon_limit/AML_MULT)/LTAMULT_afc)$ | | | |

ATTACHMENT 05

WQM 7.0 Effluent Limits

| <u>SWP Basin</u> | | <u>Stream Code</u> | <u>Stream Name</u> | | | | |
|------------------|-------------|--------------------|--------------------|------------------|--------------------------------|----------------------------|----------------------------|
| 05C | | 27623 | FISHING CREEK | | | | |
| RMI | Name | Permit Number | Disc Flow (mgd) | Parameter | Effl. Limit 30-day Ave. (mg/L) | Effl. Limit Maximum (mg/L) | Effl. Limit Minimum (mg/L) |
| 0.600 | Montour Twp | PA0209058 | 0.100 | CBOD5 | 25 | | |
| | | | | NH3-N | 25 | 50 | |
| | | | | Dissolved Oxygen | | | 3 |

Input Data WQM 7.0

| SWP Basin | Stream Code | Stream Name | RMI | Elevation (ft) | Drainage Area (sq mi) | Slope (ft/ft) | PWS Withdrawal (mgd) | Apply FC |
|--------------|----------------|---------------|-------|-------------------|-----------------------------|------------------|----------------------------|-------------------------------------|
| 05C | 27623 | FISHING CREEK | 0.600 | 455.00 | 385.00 | 0.00000 | 0.00 | <input checked="" type="checkbox"/> |

Stream Data

| Design Cond. | LFY | Trib Flow | Stream Flow | Rch Trav Time | Rch Velocity | WD Ratio | Rch Width | Rch Depth | Tributary | | Stream | |
|-----------------|--------|--------------|----------------|---------------------|-----------------|-------------|--------------|--------------|--------------|------|--------------|------|
| | (cfsm) | (cfs) | (cfs) | (days) | (fps) | | (ft) | (ft) | Temp (°C) | pH | Temp (°C) | pH |
| Q7-10 | 0.100 | 0.00 | 33.55 | 0.000 | 0.000 | 0.0 | 0.00 | 0.00 | 20.00 | 7.00 | 0.00 | 0.00 |
| Q1-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |
| Q30-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |

Discharge Data

| Name | Permit Number | Existing Disc Flow (mgd) | Permitted Disc Flow (mgd) | Design Disc Flow (mgd) | Reserve Factor | Disc Temp (°C) | Disc pH |
|-------------|---------------|-----------------------------------|------------------------------------|---------------------------------|-------------------|----------------------|------------|
| Montour Twp | PA0209058 | 0.1000 | 0.1000 | 0.1000 | 0.000 | 25.00 | 7.00 |

Parameter Data

| Parameter Name | Disc Conc (mg/L) | Trib Conc (mg/L) | Stream Conc (mg/L) | Fate Coef (1/days) |
|------------------|------------------------|------------------------|--------------------------|--------------------------|
| CBOD5 | 25.00 | 2.00 | 0.00 | 1.50 |
| Dissolved Oxygen | 3.00 | 8.24 | 0.00 | 0.00 |
| NH3-N | 25.00 | 0.00 | 0.00 | 0.70 |

Input Data WQM 7.0

| SWP Basin | Stream Code | Stream Name | RMI | Elevation (ft) | Drainage Area (sq mi) | Slope (ft/ft) | PWS Withdrawal (mgd) | Apply FC |
|--------------|----------------|---------------|-------|-------------------|-----------------------------|------------------|----------------------------|-------------------------------------|
| 05C | 27623 | FISHING CREEK | 0.100 | 448.00 | 386.00 | 0.00000 | 0.00 | <input checked="" type="checkbox"/> |

Stream Data

| Design Cond. | LFY | Trib Flow | Stream Flow | Rch Trav Time (days) | Rch Velocity (fps) | WD Ratio | Rch Width (ft) | Rch Depth (ft) | <u>Tributary</u> Temp | <u>Stream</u> pH | Temp | pH |
|-----------------|--------|--------------|----------------|-------------------------------|--------------------------|-------------|----------------------|----------------------|--------------------------|---------------------|------|------|
| | (cfsm) | (cfs) | (cfs) | | | | | | (°C) | | (°C) | |
| Q7-10 | 0.100 | 0.00 | 33.64 | 0.000 | 0.000 | 0.0 | 0.00 | 0.00 | 20.00 | 7.00 | 0.00 | 0.00 |
| Q1-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |
| Q30-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |

Discharge Data

| Name | Permit Number | Existing Disc Flow (mgd) | Permitted Disc Flow (mgd) | Design Disc Flow (mgd) | Reserve Factor | Disc Temp (°C) | Disc pH |
|------|---------------|-----------------------------------|------------------------------------|---------------------------------|-------------------|----------------------|------------|
| | | 0.0000 | 0.0000 | 0.0000 | 0.000 | 25.00 | 7.00 |

Parameter Data

| Parameter Name | Disc Conc (mg/L) | Trib Conc (mg/L) | Stream Conc (mg/L) | Fate Coef (1/days) |
|------------------|------------------------|------------------------|--------------------------|--------------------------|
| CBOD5 | 25.00 | 2.00 | 0.00 | 1.50 |
| Dissolved Oxygen | 3.00 | 8.24 | 0.00 | 0.00 |
| NH3-N | 25.00 | 0.00 | 0.00 | 0.70 |

WQM 7.0 Hydrodynamic Outputs

| <u>SWP Basin</u> | | <u>Stream Code</u> | | | | <u>Stream Name</u> | | | | | | |
|--------------------|-------------|--------------------|-----------------|--------------------|-------------|--------------------|-------|-----------|----------|-----------------|---------------|-------------|
| 05C | | 27623 | | | | FISHING CREEK | | | | | | |
| RMI | Stream Flow | PWS With | Net Stream Flow | Disc Analysis Flow | Reach Slope | Depth | Width | W/D Ratio | Velocity | Reach Trav Time | Analysis Temp | Analysis pH |
| | (cfs) | (cfs) | (cfs) | (cfs) | (ft/ft) | (ft) | (ft) | | (fps) | (days) | (°C) | |
| Q7-10 Flow | | | | | | | | | | | | |
| 0.600 | 33.55 | 0.00 | 33.55 | .1547 | 0.00265 | .946 | 92.42 | 97.74 | 0.39 | 0.079 | 20.02 | 7.00 |
| Q1-10 Flow | | | | | | | | | | | | |
| 0.600 | 21.47 | 0.00 | 21.47 | .1547 | 0.00265 | NA | NA | NA | 0.30 | 0.102 | 20.04 | 7.00 |
| Q30-10 Flow | | | | | | | | | | | | |
| 0.600 | 45.63 | 0.00 | 45.63 | .1547 | 0.00265 | NA | NA | NA | 0.46 | 0.067 | 20.02 | 7.00 |

WQM 7.0 Modeling Specifications

| | | | |
|--------------------|--------|-------------------------------------|-------------------------------------|
| Parameters | Both | Use Inputted Q1-10 and Q30-10 Flows | <input checked="" type="checkbox"/> |
| WLA Method | EMPR | Use Inputted W/D Ratio | <input type="checkbox"/> |
| Q1-10/Q7-10 Ratio | 0.64 | Use Inputted Reach Travel Times | <input type="checkbox"/> |
| Q30-10/Q7-10 Ratio | 1.36 | Temperature Adjust Kr | <input checked="" type="checkbox"/> |
| D.O. Saturation | 90.00% | Use Balanced Technology | <input checked="" type="checkbox"/> |
| D.O. Goal | 6 | | |

WQM 7.0 Wasteload Allocations

| | | |
|-------------------------|---------------------------|---------------------------|
| <u>SWP Basin</u> | <u>Stream Code</u> | <u>Stream Name</u> |
| 05C | 27623 | FISHING CREEK |

NH3-N Acute Allocations

| RMI | Discharge Name | Baseline Criterion (mg/L) | Baseline WLA (mg/L) | Multiple Criterion (mg/L) | Multiple WLA (mg/L) | Critical Reach | Percent Reduction |
|-----|-------------------|---------------------------------|---------------------------|---------------------------------|---------------------------|-------------------|----------------------|
| | 0.600 Montour Twp | 16.71 | 50 | 16.71 | 50 | 0 | 0 |

NH3-N Chronic Allocations

| RMI | Discharge Name | Baseline Criterion (mg/L) | Baseline WLA (mg/L) | Multiple Criterion (mg/L) | Multiple WLA (mg/L) | Critical Reach | Percent Reduction |
|-----|-------------------|---------------------------------|---------------------------|---------------------------------|---------------------------|-------------------|----------------------|
| | 0.600 Montour Twp | 1.88 | 25 | 1.88 | 25 | 0 | 0 |

Dissolved Oxygen Allocations

| RMI | Discharge Name | <u>CBOD5</u> | | <u>NH3-N</u> | | <u>Dissolved Oxygen</u> | | Critical Reach | Percent Reduction |
|-----|------------------|--------------------|--------------------|--------------------|--------------------|-------------------------|--------------------|-------------------|----------------------|
| | | Baseline (mg/L) | Multiple (mg/L) | Baseline (mg/L) | Multiple (mg/L) | Baseline (mg/L) | Multiple (mg/L) | | |
| | 0.60 Montour Twp | 25 | 25 | 25 | 25 | 3 | 3 | 0 | 0 |

WQM 7.0 D.O.Simulation

| <u>SWP Basin</u> | <u>Stream Code</u> | <u>Stream Name</u> | | | |
|---------------------------------|-----------------------------------|----------------------------------|-----------------------------|----------------|--|
| 05C | 27623 | FISHING CREEK | | | |
| <u>RMI</u> | <u>Total Discharge Flow (mgd)</u> | <u>Analysis Temperature (°C)</u> | <u>Analysis pH</u> | | |
| 0.600 | 0.100 | 20.023 | 7.000 | | |
| <u>Reach Width (ft)</u> | <u>Reach Depth (ft)</u> | <u>Reach WDRatio</u> | <u>Reach Velocity (fps)</u> | | |
| 92.415 | 0.946 | 97.736 | 0.386 | | |
| <u>Reach CBOD5 (mg/L)</u> | <u>Reach Kc (1/days)</u> | <u>Reach NH3-N (mg/L)</u> | <u>Reach Kn (1/days)</u> | | |
| 2.11 | 0.077 | 0.11 | 0.701 | | |
| <u>Reach DO (mg/L)</u> | <u>Reach Kr (1/days)</u> | <u>Kr Equation</u> | <u>Reach DO Goal (mg/L)</u> | | |
| 8.219 | 4.773 | Tsivoglou | 6 | | |
| <u>Reach Travel Time (days)</u> | Subreach Results | | | | |
| 0.079 | TravTime (days) | CBOD5 (mg/L) | NH3-N (mg/L) | D.O. (mg/L) | |
| | 0.008 | 2.10 | 0.11 | 8.24 | |
| | 0.016 | 2.10 | 0.11 | 8.24 | |
| | 0.024 | 2.10 | 0.11 | 8.24 | |
| | 0.032 | 2.10 | 0.11 | 8.24 | |
| | 0.040 | 2.10 | 0.11 | 8.24 | |
| | 0.048 | 2.10 | 0.11 | 8.24 | |
| | 0.055 | 2.10 | 0.11 | 8.24 | |
| | 0.063 | 2.10 | 0.11 | 8.24 | |
| | 0.071 | 2.09 | 0.11 | 8.24 | |
| | 0.079 | 2.09 | 0.11 | 8.24 | |