

Application Type Renewal
Facility Type Industrial
Major / Minor Major

**NPDES PERMIT FACT SHEET
INDIVIDUAL INDUSTRIAL WASTE (IW)
AND IW STORMWATER**

Application No. PA0218863
APS ID 1033945
Authorization ID 1477908

Applicant and Facility Information

| | | | |
|---------------------------|---------------------------------------------------------------------------------------|------------------|---------------------------------------------------------------------------------------------|
| Applicant Name | <u>Fayette Power Company, LLC</u> | Facility Name | <u>Fayette Energy Facility</u> |
| Applicant Address | <u>100 Energy Drive</u> <u>Masontown, PA 15461-2588</u> | Facility Address | <u>100 Energy Drive</u> <u>Masontown, PA 15461-2588</u> |
| Applicant Contact | <u>Ronald George</u> | Facility Contact | <u>Aaron Kitzmiller</u> |
| Applicant Phone | <u>(724) 583-8003</u> | Facility Phone | <u>724-583-8034</u> |
| Applicant Email | <u>Ronald.George@vistracorp.com</u> | Facility Email | <u>Aaron.kitzmiller@vistracorp.com</u> |
| Client ID | <u>287448</u> | Site ID | <u>547636</u> |
| SIC Code | <u>4911</u> | Municipality | <u>German Township</u> |
| SIC Description | <u>Trans. & Utilities - Electric Services</u> | County | <u>Fayette</u> |
| Date Application Received | <u>January 30, 2012</u> | EPA Waived? | <u>No</u> |
| Date Application Accepted | <u>February 28, 2024</u> | If No, Reason | <u>Major</u> |
| Purpose of Application | <u>Renewal NPDES permit coverage</u> | | |

Summary of Review


Site Summary:

The Department received an NPDES permit renewal application from Duke Energy Fayette II, LLC on January 30, 2012 for continued coverage of its Fayette Energy Facility (Fayette). The Department received a name change amendment application on October 22, 2015 to change the permittee name from Duke Energy Fayette II, LLC to Dynegy Fayette II, LLC. The Department received another name change amendment application on February 19, 2021 to change the permittee name from Dynegy Fayette II, LLC to Fayette Power Company, LLC. The Department received an updated renewal application from Fayette Power Company, LLC on June 1, 2021.

Fayette is an electrical power generation station using two natural gas-fired combined-cycle advance firing combustion turbines capable of producing 620 MW of electric power. Two combustion turbines produce 160 MW of power each by burning natural gas. Heat is recovered from the combustion turbine exhaust using two duct-fired heat recovery steam generators (HRSG). HRSGs produce steam for use by 300 MW steam turbine generators. The site has a SIC code of 4911, Electric services/Fossil Fuel Electric Power Generation.

Currently the site is classified as a Minor IW Facility with ELG; however, after reviewing and completing the EPA's NPDES Permit Rating Work Sheet (Attachment A), the site should be classified as Major IW Facility <250 MGD. The NPDES Permit Rating Work Sheet classifies steam electric power plants that has a power output of 500 MW or greater as a Major Facility. The site is capable of producing 620 MW of electric power; therefore, the facility should be considered a Major Facility.

The site was last inspection on December 10, 2019; no violations were noted. The site has no open violations.

| Approve | Deny | Signatures | Date |
|---------|------|------------------------------------------------------------------------------------------------------------------------------------------------|----------------|
| X | |  Adam Olesnanik, P.E. / Environmental Engineer | April 9, 2024 |
| X | |  Michael E. Fifth, P.E. / Environmental Engineer Manager | April 12, 2024 |

Summary of Review

The site has two Outfalls and two internal monitor points (IMPs). Outfall 001 discharges wastewater from the two IMPs (HRSG and cooling tower blowdown, demineralizer drain, atmospheric drain tank to cooling tower basin, and oil/water separator wastewater) and treated raw water. IMP 101 is the internal monitoring point for the HRSG and cooling tower blowdown, demineralizer drain, and atmospheric drain tank to cooling tower basin. IMP 201 is the internal monitor point of the oil/water separator wastewater. Outfall 001 discharges to the Monongahela River, designated in 25 PA Code Chapter 93 as a Warm Water Fishery (WWF). Outfall 002 is the site stormwater discharge. Outfall 002 discharges to an unnamed tributary to the Monongahela River, designed in 25 PA Code Chapter 93 as a Warm Water Fishery (WWF).

The boiler feed water treatment wastewater is pH-adjusted in the neutralization tank then pumped to and blended with the incoming water going to the clarifier and used in the plant's make-up water system. Process wastewater and cooling tower blowdown are dechlorinated, if needed, prior to IMP 101. Non-process wastewater from facility drains passes through an oil/water separator prior to IMP 201. Effluent from IMP 101 and 201 then discharge from Outfall 001.

The current permit has an additional IMP to Outfall 001, IMP 301. IMP 301 has been permanently eliminated. The discharge line of IMP 301 was permanently blanked on January 14, 2020. IMP 301 has not discharged since 2012. The wastewater that discharged via IMP 301 was the regeneration discharge from the neutralization tank. The water from IMP 301 was re-routed to blend with the incoming raw water for treatment and plant use.

Station stormwater flows to a stormwater detention basin prior to discharge from Outfall 002.

The site has one surface water cooling water intake structure (CWIS) on the Monongahela River at River Mile 78.8. The CWIS is a nearshore submerged structure, located approximately 105 ft offshore. The CWIS withdraws Monongahela River water from the Maxwell Pool through a submerged wedge screen. The CWIS has a design intake flow of 8.0 MGD, an average intake flow of 3.6 MGD, an estimated through screen velocity of 0.36 fps and 95 to 98 percent of the water is used for cooling.

Cooling Water Intake Structure:

On August 15, 2014, EPA promulgated Clean Water Act Section 316(b) regulations applicable to cooling water intake structures. The regulations established best technology available ("BTA") standards to reduce impingement mortality and entrainment of all life stages of fish and shellfish at existing power generating and manufacturing facilities. The Final Rule took effect on October 14, 2014. Regulations implementing the 2014 Final Rule (and the previously promulgated Phase I Rule) are provided in 40 CFR Part 125, Subparts I and J for new facilities and existing facilities, respectively. Associated NPDES permit application requirements for facilities with cooling water intake structures are provided in 40 CFR Part 122, Subpart B – Permit Application and Special NPDES Program Requirements (§ 122.21(r)).

Fayette is a "new facility" as defined in 40 CFR § 125.83. As a new facility, the site is subject to 40 CFR Part 125, Subpart I – Requirements Applicable to Cooling Water Intake Structures for New Facilities Under Section 316(b) of the Clean Water Act (§§ 125.80 – 125.89) if the facility meets the rule's applicability criteria. Pursuant to the applicability criteria given by § 125.81(a), the Fayette Energy Facility is subject to the requirements of §§ 125.84 – 125.89 if:

- (1) The facility is a point source that uses or proposes to use a cooling water intake structure;
- (2) The facility has at least one cooling water intake structure that uses at least 25 percent of the water it withdraws for cooling purposes. The threshold requirement that at least 25 percent of water withdrawn be used for cooling purposes must be measured on an average monthly basis. A new facility meets the 25 percent cooling water threshold if, based on the new facility's design, any monthly average over a year for the percentage of cooling water withdrawn is expected to equal to exceed 25 percent of the total water withdrawn.
- (3) The facility has a design intake flow (DIF) greater than two (2) million gallons per day (MGD).

Fayette is a point source as defined in 40 CFR § 122.2. The site uses more than 25% of the water it withdraws for cooling purposes (98%). And the site uses a cooling water intake structure with a Design Intake Flow greater than 2 MGD (8.0 MGD). Therefore, the site is subject to the requirements of §§ 125.84 – 125.89.

Fayette has one cooling water intake structure which supplies the facility with water drawn from the Monongahela River. Fayette was designed and built to comply with the Federal Phase I Rule for BTA for CWIS as the facility construction began after January 17, 2002. Fayette has chosen to comply with the Track I requirements in §§ 125.84(b). Fayette has met the

Summary of Review

requirements in 40 CFR 125.84(b)(6) by submitting the required application information from 40 CFR 125.122.21(r) and §§ 125.86(b); Source Waterbody Physical Data Study, Cooling water Intake Structure Data Study, Source Waterbody Baseline Biological Characterization Study, Track I Application Requirements and Biological Monitoring. To meet the requirements in 40 CFR 125.84(b)(7) and (8), the NPDES permit will include the requirements to implement monitoring requirements specified in §§ 125.87 and record-keeping requirements specified in §§ 125.88.

The intake screen is located approximately 105 feet offshore and west of the pumphouse. The submerged screen is arranged into a tee section with the center line elevation of approximately 752 feet. The intake screen has a diameter of 33.27 in and is 98.25 in long with two screen sections having lengths of 34.25 in each. The screen is made out of Z-alloy, a copper-nickel alloy, to prevent bio-growth and is equipped with 0.125 in. slot openings that result in a percent open area of approximately 68.64 percent. The screen is mounted on a 24-in. diameter carbon steel intake pipe that leads approximately 370 feet into the pump house. The screen is equipped with a 4-in. air burst line system that is designed to blow debris off and away from the screen allowing water to flow more freely through the screen. The air burst system operates on a 24-hour cycle or when the head loss across the screen activates the system. Commercial divers are also brought in to inspect and remove any materials from the intake screen, as needed.

Based on the dimension of the intake screen, the total effective open area of the intake is 34.2 square feet. Velocity through the submerged intake screen was calculated based on the station's DIF flow of 5,600 gpm (8.0 MGD). The estimated intake through-screen velocity (TSV) under clean intake screen operation was calculated to be 0.36 fps. The air burst system typically activates cleaning well before TSV approaches 0.5 fps.

Inside the site's intake pump house, three raw water pumps are supplied by a 24-in waterline from the intake screen that delivers the river water to 20-in. waterlines that supply each pump. The raw water pumps supply water to the treatment system through a 20-in. force main. The water is treated by a clarifier and a multi-media gravity filter before being stored in the make-up water storage tank. It is then pumped and used for fire protection, service water, make-up water to the cooling tower, and make-up water to the HRSGs after being processed by the demineralizing system.

A maximum of two pumps are operated at a time, with the third acting as a spare. Each raw water pump is designed for 3,000 gpm at 430 ft total dynamic head. The maximum DIF of the CWIS is 5,600 gpm (8.0 MGD). Under normal operations, the maximum operating flow is limited by the treatment equipment hydraulically downstream of the raw water pumps. However, under rare or emergency conditions, the withdrawal rate can reach its DIF. The CWIS is in operation 24 hours per day, 7 days a week, 365 days a year.

Based on the average annual intake flows, the facility withdraws on average 0.05 percent of the Monongahela River flow, therefore, the site withdraws less than five percent of the Monongahela River flow and meets the requirements under 40 CFR 125.84(b)(3).

The steam turbine generator (STG) uses a wet mechanical draft cooling tower with a closed cycle recirculating system to remove waste heat. The heated water from the steam condenser is pumped to the distribution deck at the top of the cooling tower and flows down under gravity to a cold-water basin beneath the tower from which it is returned to the inlet of the condenser. The STG uses 10-cell linear, induced mechanical-draft, counter-flow cooling to remove waste heat from the condenser. This cooling tower utilizes ten single-speed, reversible, 30 feet wide motor-driven bladed fans and is 480 feet long, 48 feet wide, and approximately 43.5 ft high. Below the cooling tower is the cold-water basin that collects and stores water cascading through the tower. Water pumps within the circulating water system circulate cooling water from the cooling tower basin to the condenser and then return it to the cooling tower. The cooling tower circulation water is a closed-loop system that only requires make-up water gravity fed from the plant's 700,000-gallon storage tank. The operation of the cooling tower results in over 97% reduction in cooling water withdrawal when compared to a hypothetical unit operating once-through cooling mode. By using closed-cycle cooling, the site meets the requirements under 40 CFR 125.84(b)(1).

Submerged cylindrical wedge wire intake screens are classified as exclusion technologies, and the hydraulic area of influence (AOI) and through-screen velocity (TSV) should virtually eliminate impingement of healthy fish and shellfish classified by the USEPA to be of impingeable size. The TSV of the Fayette intake screen was calculated at 0.36 fps, below the 0.5 fps intake velocity at which the USEPA considers to be a de minimis value and meeting the requirement under 40 CFR 125.84(b)(2).

Entrainment is reduced due to the closed-cycle cooling towers. The physical and hydraulic conditions of wedge wire screen are considered to be biologically effective at reducing entrainment of fish and early life stage organisms in the makeup,

Summary of Review

service, and fire water. The low 0.36 fps TSV, and a sweeping current past the screens, reduces the probability of organism entrainment. In December 2019 ASA Analysis and Communication, Inc. (ASA) conducted a cooling water intake structure study at Fayette. ASA's report cited previous studies conducted by Electric Power Research Institute (EPRI) (2003) that identified that under 0.5 fps TSV conditions with adequate sweeping currents, the AOI of a wedge wire screen is approximately 20 in. from the screen face. Through Computational Fluid Dynamics modeling and laboratory evaluations, EPRI determined that an organism's probability of entrainment decreases with increasing distance from the screen face. Due to the limited mobility of early stage organisms that probability of exposure of entrainment is subject to this AOI. Larger larvae with active mobility are expected to have the swimming capability to actively avoid the AOI due to the TSV. Otto et al. speculated that early life stage larvae acquired the swimming capability to avoid entrainment at low velocities. This field evaluation found that larvae above length of 6 to 8 mm were not entrained through the 1-mm intake screen with a design TSV of slightly less than 0.4 fps. Relevant taxa and their susceptibility to impingement and entrainment at Fayette was determined through the Source Water Baseline Biological Characterization Data Report, required by 40 CFR 125.122.21(r)(4). With the potential presence of multiple sportfish and a PA-endangered species within the vicinity of Fayette, Fayette has installed and operates a wedge wire screen to meet the Design and Construction Technology Plan requirements under the Phase I Rule. With the implementation of the wedge wire screen, Fayette meets the requirements under 40 CFR 125.84(b)(4) and (5) to select and implement technologies or operational measures for minimizing impingement mortality and entrainment.

Recommendations:

Draft Permit Issuance is recommended.

Public Participation:

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Discharge, Receiving Waters and Water Supply Information

| | | | |
|-------------------------------------------------------------|------------------------------------------------------------|------------------------------|-------------------------------|
| Outfall No. | <u>001 (IMP 101 & 201)</u> | Design Flow (MGD) | <u>0.973</u> |
| Latitude | <u>39° 52' 01"</u> | Longitude | <u>-79° 55' 49"</u> |
| Quad Name | <u>Masontown</u> | Quad Code | <u>2006</u> |
| Wastewater Description: <u>IW Process Effluent with ELG</u> | | | |
| Receiving Waters | <u>Monongahela River (WWF)</u> | Stream Code | <u>37185</u> |
| NHD Com ID | <u>99416266</u> | RMI | <u>78.6</u> |
| Drainage Area | <u>4530</u> | Yield (cfs/mi ²) | <u>0.117</u> |
| Q ₇₋₁₀ Flow (cfs) | <u>530</u> | Q ₇₋₁₀ Basis | <u>USACE</u> |
| Elevation (ft) | <u>765</u> | Slope (ft/ft) | <u>0.0001</u> |
| Watershed No. | <u>19-C</u> | Chapter 93 Class. | <u>WWF</u> |
| Existing Use | <u></u> | Existing Use Qualifier | <u></u> |
| Exceptions to Use | <u></u> | Exceptions to Criteria | <u></u> |
| Assessment Status | <u>Attaining Use(s)</u> | | |
| Cause(s) of Impairment | <u></u> | | |
| Source(s) of Impairment | <u></u> | | |
| TMDL Status | <u>Final</u> | Name | <u>Monongahela River TMDL</u> |
| Nearest Downstream Public Water Supply Intake | <u>Municipal Authority of Carmichaels (1.0 MGD intake)</u> | | |
| PWS Waters | <u>Monongahela River</u> | Flow at Intake (cfs) | <u>530</u> |
| PWS RMI | <u>75.6</u> | Distance from Outfall (mi) | <u>3.0</u> |

| Discharge, Receiving Waters and Water Supply Information | | | |
|----------------------------------------------------------|------------------------------------------------------------|------------------------|---------------------|
| Outfall No. | <u>002</u> | Design Flow (MGD) | <u>0</u> |
| Latitude | <u>39° 51' 42"</u> | Longitude | <u>-79° 55' 00"</u> |
| Quad Name | <u>Masontown</u> | Quad Code | <u>2006</u> |
| Wastewater Description: <u>Stormwater</u> | | | |
| Receiving Waters | <u>Unnamed Tributary to Monongahela River (WWF)</u> | Stream Code | <u>41154</u> |
| NHD Com ID | <u>99416208</u> | RMI | <u>0.88</u> |
| Watershed No. | <u>19-C</u> | Chapter 93 Class. | <u>WWF</u> |
| Existing Use | <u></u> | Existing Use Qualifier | <u></u> |
| Exceptions to Use | <u></u> | Exceptions to Criteria | <u></u> |
| Assessment Status | <u>Impaired</u> | | |
| Cause(s) of Impairment | <u>SILTATION</u> | | |
| Source(s) of Impairment | <u>HABITAT MODIFICATION - OTHER THAN HYDROMODIFICATION</u> | | |
| TMDL Status | <u>Name</u> | | |

Development of Effluent Limitations

| | | | |
|--------------------------------------------------------------------------------------------------------------------------|-------------|--------------------------|--------------|
| Outfall No. | 001 | Design Flow (MGD) | 0.973 |
| Latitude | 39° 52' 01" | Longitude | -79° 55' 49" |
| Wastewater Description: IW Process Effluent with ELG – wastewater from IMP 101 and IMP 201, and treated raw water | | | |

Technology-Based Limitations

Federal Effluent Limitations Guidelines (ELGs)

The process wastewater related to 40 CFR 423 Steam Electric Generating Category that discharge via Outfall 001 is monitored at internal monitoring points. The ELGs applicable to this process discharge will be imposed at the IMPs.

Regulatory Effluent Standards and Monitoring Requirements

25 PA Code Chapter 92 requires pH requirements to be a minimum of 6.0 and a maximum of 9.0 S.U. for all industrial waste process and non-process discharges.

Flow Reporting requirements are in accordance with the 25 PA Code Chapter 92 regulations.

Temperature limits will be imposed per the Department’s “*Implementation Guidance for Temperature Criteria.*” As a policy, DEP normally imposes a maximum temperature limit of 110°F on discharges that contain residual heat. The limit is intended as a safety measure to protect sampling personnel or anyone who may come into contact with the heated discharge where it enters the receiving water.

Pennsylvania regulations at 25 Pa. Code § 92a.48(b) require the imposition of technology-based TRC limits for facilities that use chlorination and that are not already subject to TRC limits based on applicable federal ELGs or a facility-specific BPJ evaluation which is displayed in Table 1 below.

25 PA Code Chapter 95.10 requires Total Dissolved Solids (TDS) monitoring at a minimum if the TDS concentration in the discharge exceeds 1,000 mg/L. Per the application, the maximum discharge concentration of TDS was reported as 1,550 mg/L, therefore TDS monitoring will be imposed.

Table 1: Regulatory Effluent Standards and Monitoring Requirements

| Parameter | Monthly Average | Daily Maximum | Instantaneous Maximum | Units |
|-------------|---------------------|---------------|-----------------------|-------|
| Flow | Monitor and Report | | - | MGD |
| Temperature | - | - | 110 | °F |
| TRC | 0.5 | | 1.6 | mg/L |
| TDS | Monitor and Report | | | mg/L |
| pH | Between 6.0 and 9.0 | | | S.U. |

Per- and Polyfluoroalkyl Substances (PFAS)

In February 2024, DEP implemented a new monitoring initiative for PFAS consistent with an EPA memorandum that provides guidance to states for addressing PFAS discharges. PFAS are a family of thousands of synthetic organic chemicals that contain a chain of strong carbon-fluorine bonds. Many PFAS are highly stable, water- and oil-resistant, and exhibit other properties that make them useful in a variety of consumer products and industrial processes. PFAS are resistant to biodegradation, photooxidation, direct photolysis, and hydrolysis and do not readily degrade naturally; thus, many PFAS accumulate over time. According to the United States Department of Health and Human Services, Agency for Toxic Substances and Disease Registry (ATSDR), the environmental persistence and mobility of some PFAS, combined with decades of widespread use, have resulted in their presence in surface water, groundwater, drinking water, rainwater, soil, sediment, ice caps, outdoor and indoor air, plants, animal tissue, and human blood serum across the globe. ATSDR also reported that exposure to certain PFAS can lead to adverse human health impacts. Due to their durability, toxicity, persistence, and pervasiveness, PFAS have emerged as potentially significant pollutants of concern.

In accordance with Section II.I of DEP’s “Standard Operating Procedure (SOP) for Clean Water Program – Establishing Effluent Limitations for Individual Industrial Permits” [SOP No. BCW-PMT-032] and under the authority of 25 Pa. Code §

92a.61(b), DEP has determined that monitoring for a subset of common/well-studied PFAS including Perfluorooctanoic acid (PFOA), Perfluorooctanesulfonic acid (PFOS), Perfluorobutanesulfonic acid (PFBS), and Hexafluoropropylene oxide dimer acid (HFPO-DA) is necessary to help understand the extent of environmental contamination by PFAS in the Commonwealth and the extent to which point source dischargers are contributors. SOP BCW-PMT-032 directs permit writers to consider special monitoring requirements for PFOA, PFOS, PFBS, and HFPO-DA in the following instances:

- a. If sampling that is completed as part of the permit renewal application reveals a detection of PFOA, PFOS, HFPO-DA or PFBS (any of these compounds), the application manager will establish a quarterly monitoring requirement for PFOA, PFOS, HFPO-DA and PFBS (all of these compounds) in the permit.
- b. If sampling that is completed as part of the permit renewal application demonstrates non-detect values at or below the Target QLs for PFOA, PFOS, HFPO-DA and PFBS (all of these compounds in a minimum of 3 samples), the application manager will establish an annual monitoring requirement for PFOA, PFOS, HFPO-DA and PFBS in the permit.
- c. In all cases the application manager will include a condition in the permit that the permittee may cease monitoring for PFOA, PFOS, HFPO-DA and PFBS when the permittee reports non-detect values at or below the Target QL for four consecutive monitoring periods for each PFAS parameter that is analyzed. Use the following language: The permittee may discontinue monitoring for PFOA, PFOS, HFPO-DA, and PFBS if the results in 4 consecutive monitoring periods indicate non-detects at or below Quantitation Limits of 4.0 ng/L for PFOA, 3.7 ng/L for PFOS, 3.5 ng/L for PFBS and 6.4 ng/L for HFPO-DA. When monitoring is discontinued, permittees should enter a No Discharge Indicator (NODI) Code of "GG" on DMRs.

Fayette Power Company's application was submitted before the NPDES permit application forms were updated to require sampling for PFOA, PFOS, PFBS, and HFPO-DA. Also, according to EPA's guidance, Fayette Power Company does not operate in one of the industries EPA expects to be a source for PFAS. Therefore, annual reporting of PFOA, PFOS, PFBS, and HFPO-DA will be required consistent with Section II.I.b of SOP BCW-PMT-032. Even though Fayette Power Company did not report results for PFOA, PFOS, PFBS, and HFPO-DA on the permit application, as a facility operating in a suspected non-source industry, it is reasonable to conclude that if Fayette Power Company did report results for PFOA, PFOS, PFBS, and HFPO-DA on the application, the results may have been non-detect values, which would subject Fayette Power Company to the annual monitoring requirements described in Section II.I.b of the SOP.

As stated in Section II.I.c of the SOP, if non-detect values at or below DEP's Target QLs are reported for four consecutive monitoring periods (i.e., four consecutive annual results in Fayette Power Company's case), then the monitoring may be discontinued.

Toxics Management Spread Sheet

The Department of Environmental Protection (DEP) has developed the DEP Toxics Management Spreadsheet ("TMS") to facilitate calculations necessary for completing a reasonable potential (RP) analysis and determining water quality-based effluent limitations for discharges of toxic pollutants. The Toxics Management Spreadsheet is a macro-enabled Excel binary file that combines the functions of the PENTOXSD model and the Toxics Screening Analysis spreadsheet to evaluate the reasonable potential for discharges to cause excursions above water quality standards and to determine WQBELs. The Toxics Management Spread Sheet is a single discharge, mass-balance water quality calculation spread sheet that includes consideration for mixing, first-order decay and other factors to determine recommended WQBELs for toxic substances and several non-toxic substances. Required input data including stream code, river mile index, elevation, drainage area, discharge name, NPDES permit number, discharge flow rate and the discharge concentrations for parameters in the permit application or in DMRs, which are entered into the spread sheet to establish site-specific discharge conditions. Other data such as low flow yield, reach dimensions and partial mix factors may also be entered to further characterize the conditions of the discharge and receiving water. Discharge concentrations for the parameters are chosen to represent the "worst case" quality of the discharge (i.e., maximum reported discharge concentrations). The spread sheet then evaluates each parameter by computing a Waste Load Allocation for each applicable criterion, determining a recommended maximum WQBEL and comparing that recommended WQBEL with the input discharge concentration to determine which is more stringent. Based on this evaluation, the Toxics Management Spread sheet recommends average monthly and maximum daily WQBELs.

Reasonable Potential Analysis and WQBEL Development for Outfall 001

Discharges from Outfall 001 are evaluated based on concentrations reported on the application and on DMRs; data from those sources are entered into the Toxics Management Spread Sheet. The maximum reported value of the parameters from the application form or from previous DMRs is used as the input concentration in the Toxics Management Spread Sheet. All toxic pollutants whose maximum concentrations, as reported in the permit application or on DMRs, are greater than the most stringent applicable water quality criterion are considered to be pollutants of concern. [This includes pollutants reported as "Not Detectable" or as "<MDL" where the method detection limit for the analytical method used by the applicant is greater than the most stringent water quality criterion]. The Toxics Management Spread Sheet is run with the discharge and receiving stream characteristics shown in Table 2. For IW discharges, the design flow used in modeling is the average flow during production or operation taken from the permit application. Pollutants for which water quality standards have not been promulgated (e.g., TSS, oil and grease) are excluded from the analysis. All the parameters are evaluated using the model to determine the water quality-based effluent limits applicable to the discharge and the receiving stream. The spreadsheet then compares the reported discharge concentrations to the calculated water quality-based effluent limitations to determine if a reasonable potential exists to exceed the calculated WQBELs. Effluent limitations are established in the draft permit where a pollutant's maximum reported discharge concentration equals or exceeds 50% of the WQBEL. For non-conservative pollutants, monitoring requirements are established where the maximum reported concentration is between 25% - 50% of the WQBEL. For conservative pollutants, monitoring requirements are established where the maximum reported concentration is between 10% - 50% of the WQBEL. The information described above including the maximum reported discharge concentrations, the most stringent water quality criteria, the pollutant-of-concern (reasonable potential) determinations, the calculated WQBELs, and the WQBEL/monitoring recommendations are displayed in the Toxics Management Spread Sheet in Attachment C of this Fact Sheet. Based on the results from Toxics Management Spread Sheet no water quality-based effluent limitations or monitoring requirements are prescribed for the discharges from Outfall 001.

Table 2: TMS Inputs for Outfall 001

| Parameter | Value |
|---------------------------------------|--------|
| River Mile Index | 78.6 |
| Discharge Flow (MGD) | 0.67 |
| Basin/Stream Characteristics | |
| Parameter | Value |
| Area in Square Miles | 4530 |
| Q ₇₋₁₀ (cfs) | 530 |
| Low-flow yield (cfs/mi ²) | 0.117 |
| Elevation (ft) | 765 |
| Slope | 0.0001 |

Total Residual Chlorine

To determine if WQBELs are required for discharges containing total residual chlorine (TRC), a discharge evaluation is performed using a DEP program called TRC_CALC created with Microsoft Excel for Windows. TRC_CALC calculates TRC Waste Load Allocations (WLAs) through the application of a mass balance model which considers TRC losses due to stream and discharge chlorine demands and first-order chlorine decay. Input values for the program include flow rates and chlorine demands for the receiving stream and the discharge, the number of samples taken per month, coefficients of TRC variability, partial mix factors, and an optional factor of safety. The mass balance model calculates WLAs for acute and chronic criteria that are then converted to long term averages using calculated multipliers. The multipliers are functions of the number of samples taken per month and the TRC variability coefficients (normally kept at default values unless site specific information is available). The most stringent limitation between the acute and chronic long-term averages is converted to an average monthly limit for comparison to the BAT average monthly limit of 0.5 mg/l from 25Pa. Code § 92a.48(b)(2). The more stringent of these average monthly TRC limitations is imposed in the permit. The results of the modeling, included in Attachment D, indicate that WQBELs are not required for TRC at Outfall 001.

Thermal WQBELs for Heated Discharges

Thermal WQBELs are evaluated using a DEP program called "Thermal Discharge Limit Calculation Spreadsheet" created with Microsoft Excel for Windows. The program calculates temperature WLAs through the application of a heat transfer equation, which takes two forms in the program depending on the source of the facility's cooling water. In Case 1, intake

water to a facility is from the receiving stream. In Case 2, intake water is from a source other than the receiving stream (e.g., municipal water supply). The determination of which case applies to a given discharge is determined by the input data which include the receiving stream flow rate (Q₇₋₁₀ or the minimum regulated flow for large rivers), the stream intake flow rate, external source intake flow rates, consumptive flow rates and site-specific ambient stream temperatures. Case 1 limits are generally expressed as heat rejection rates while Case 2 limits are usually expressed as temperatures.

Since the temperature criteria from 25 Pa. Code Chapter 93.7(a) are expressed on monthly and semi-monthly bases for three different aquatic life-uses—cold water fishes, warm water fishes and trout stocking—the program generates monthly and semi-monthly limits for each use. DEP selects the output that corresponds to the aquatic life-use of the receiving stream and consequently which limits apply to the discharge. Temperature WLAs are bounded by an upper limit of 110°F for the safety of sampling personnel and anyone who may come into contact with the heated discharge where it enters the receiving water. If no WLAs below 110°F are calculated, an instantaneous maximum limit of 110°F is recommended by the program.

Discharges from Outfall 001 are classified under Case 1 because water is obtained via an intake structure owned by the permittee on the Monongahela River. The results of the thermal analysis, included in Attachment E, indicate that WQBELs for temperature are not required at Outfall 001. Therefore, because no WLAs below 110°F were calculated, an instantaneous maximum limit of 110°F will be imposed.

Total Maximum Daily Loads

The Monongahela River has a TMDL for PCBs and Chlordane. The TMDL outlines a plan to achieve water quality standards in the water body. The TMDL applies only to discharges of PCBs and chlordane to the Monongahela River and does not provide waste load allocations for either. The TMDL goal is for levels of PCB and chlordane in the water column to be equal to or less than the Commonwealth’s water quality criteria. The production and use of PCB in the United States was banned in July of 1979. In addition, the TMDL acknowledges that there are no longer any known point sources of either pollutant in the watershed and the TMDL is expected to achieve implementation through “natural attenuation”. While it is now illegal to manufacture, distribute, or use PCBs in the United states, these synthetic oils were used in the past. However, this site has not been shown to have PCBs in its discharge and has not been known to use PCBs. Neither chlordane nor PCB’s are used, generated, or stored at the site; nor is there any evidence to suggest that PCBs and chlordane were ever used, generated, or stored onsite in the past. Additionally, because the site is subject to the Steam Electric Generation Effluent Limitation Guidelines, a Part C condition is included in the permit for the exclusion of the discharge of PCB compounds. Based upon these considerations, the Monongahela River TMDL is not applicable to site’s discharges.

Anti-backsliding:

Previous effluent limits and monitoring requirements can be used pursuant to EPA’s anti-backsliding regulation, 40 CFR 122.44(l) and are displayed below in Table 3.

Table 3: Existing Effluent Limitation for Outfall 001

| Parameters | Mass (lb/day) | | Concentration (mg/L) | | | Monitoring Requirements | | |
|-------------------------|-----------------|---------------|----------------------|-----------------|---------------|-------------------------|-----------|-------------|
| | Average Monthly | Daily Maximum | Instant. Minimum | Average Monthly | Daily Maximum | Instant. Maximum | Frequency | Sample Type |
| Flow (MGD) | Report | Report | XXX | XXX | XXX | XXX | 2/Month | estimate |
| Temperature (°F) | XXX | XXX | XXX | XXX | XXX | 110 | 2/Month | I-S |
| Total Residual Chlorine | XXX | XXX | XXX | 0.5 | XXX | 1.0 | 2/Month | Grab |
| Total Suspended Solids | XXX | XXX | XXX | Monitor | Monitor | XXX | 2/Month | Grab |
| Oil and Grease | XXX | XXX | XXX | Monitor | Monitor | XXX | 2/Month | Grab |
| pH (S.U.) | XXX | XXX | 6.0 | XXX | XXX | 9.0 | 2/Month | Grab |

Proposed Effluent Limitations

The proposed effluent limitations and monitoring requirements for Outfall 001 are shown below in Table 4. The limits are the most stringent values from the above limitation analysis.

Table 4: Proposed Effluent Limitation for Outfall 001

| Parameters | Mass (lb/day) | | Concentration (mg/L) | | | | Monitoring Requirements | |
|-------------------------|-----------------|---------------|----------------------|-----------------|---------------|------------------|-------------------------|-------------|
| | Average Monthly | Daily Maximum | Instant. Minimum | Average Monthly | Daily Maximum | Instant. Maximum | Frequency | Sample Type |
| Flow (MGD) | Report | Report | XXX | XXX | XXX | XXX | 2/Month | estimate |
| Temperature (°F) | XXX | XXX | XXX | XXX | XXX | 110 | 2/Month | I-S |
| Total Residual Chlorine | XXX | XXX | XXX | 0.5 | XXX | 1.0 | 2/Month | Grab |
| Total Dissolved Solids | XXX | XXX | XXX | Monitor | Monitor | XXX | 2/Month | Grab |
| Total Suspended Solids | XXX | XXX | XXX | Monitor | Monitor | XXX | 2/Month | Grab |
| Oil and Grease | XXX | XXX | XXX | Monitor | Monitor | XXX | 2/Month | Grab |
| pH (S.U.) | XXX | XXX | 6.0 | XXX | XXX | 9.0 | 2/Month | Grab |
| PFOA (ng/L) | XXX | XXX | XXX | XXX | Monitor | XXX | 1/year | Grab |
| PFOS (ng/L) | XXX | XXX | XXX | XXX | Monitor | XXX | 1/year | Grab |
| PFBS (ng/L) | XXX | XXX | XXX | XXX | Monitor | XXX | 1/year | Grab |
| HFPO-DA (ng/L) | XXX | XXX | XXX | XXX | Monitor | XXX | 1/year | Grab |

Development of Effluent Limitations

| | | | |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------|--------------------------|--------------|
| IMP. | 101 | Design Flow (MGD) | 0.688 |
| Latitude | 39° 52' 01" | Longitude | -79° 55' 49" |
| Wastewater Description: IW Process Effluent with ELG – HRSG Blowdown, blowdown from cooling towers, demineralizer drain, and atmospheric drain tank to cooling tower basin | | | |

Technology-Based Limitations

Regulatory Effluent Standards and Monitoring Requirements

25 PA Code Chapter 92 requires pH requirements to be a minimum of 6.0 and a maximum of 9.0 S.U. for all industrial waste process and non-process discharges.

Flow Reporting requirements is in accordance with the 25 PA Code Chapter 92 regulations.

Federal Effluent Limitation Guidelines (ELGs)

Discharges from IMP 101 consists of Low Volume Waste and Cooling Tower Blowdown and is subject to the steam electric ELG 40 CFR 423. The discharge is considered a new source and is subject to the ELG's New Source Performance Standards (NSPS) effluent limitations in 40 CFR 423.15 (a) (1,2,3 and 10) (1982 NSPS). Applicable effluent limitations are shown in Table 5.

Table 5: Federal Effluent Limitation Guidelines

| Parameters | Concentration (mg/L) | | | |
|-------------------------|----------------------|-----------------|---------------|------------------|
| | Minimum | Average Monthly | Daily Maximum | Instant. Maximum |
| TSS | XXX | 30.0 | 100.0 | XXX |
| Oil and Grease | XXX | 15.0 | 20.0 | XXX |
| Free Available Chlorine | XXX | 0.2 | XXX | 0.5 |
| Total Chromium | XXX | 0.2 | 0.2 | XXX |
| Total Zinc | XXX | 1.0 | 1.0 | XXX |
| pH (S.U.) | 6.0 | XXX | 9.0 | XXX |

In addition to the ELG's numerical limits, other conditions specified are included in Part C. Specifically they require that, "There shall be no discharge of polychlorinated biphenyl compounds" (40 CFR 423.15(a)(2)), "Neither free available nor total residual chlorine may be discharged from any unit for more than two hours in any one day" (40 CFR 423.15 (a)(10)(ii)), and "The 126 priority pollutants (Appendix A) contained in chemicals added for cooling tower maintenance, except chromium and zinc 40 CFR 423.15 (a)(10)(iii)."

Because the site doesn't use any cooling tower maintenance chemicals that contain chromium or zinc, the Department has evaluated the need for these limits in the permit and after evaluation of EPA's Final Rulemaking on the matter, the Department finds merit in the removal of these limits. Volume 47, No. 224 of the Federal Register's Rules and Regulations as published on November 19, 1982 includes the Federal Effluent Limitation Guidelines for chromium and zinc. EPA's proposed rulemaking prohibited "any discharge of cooling tower maintenance chemicals containing the 129 priority pollutants" (defined earlier in the notice); including chromium and zinc. Many commenters indicated that there were (at that time) no acceptable substitutes for the use of chromium-based or zinc-based cooling tower maintenance chemicals. The EPA agreed with this position due in part to site specific conditions, including cooling water intake quality and the use of construction materials (i.e. for cooling water piping) that are susceptible to fouling corrosion. In addition, it was agreed that potential substitutes could be more toxic than the substances they were intended to replace. Therefore, the Federal Register states; "the final BAT, NSPS and pretreatment standards allow for the discharge of chromium and zinc in cooling tower blowdown. The limitations are the same as those adopted in 1974 for BAT and are based upon pH adjustment, chemical precipitation, and sedimentation or filtration to remove precipitated metals".

EPA's original intent was to restrict the discharge of all 129 Priority Toxic Pollutants (including chromium and zinc), a goal that Fayette has achieved. The company does not utilize chromium or zinc additives in its cooling water. Accordingly, total chromium and total zinc effluent limitations have been removed from the Draft Permit. The Department will however maintain a "Monitor and Report" requirement for these pollutants for at least one permit cycle to confirm their absence. In

addition, a Part C Condition has been added to the Draft Permit restricting the use of chromium and zinc chemical additives without first obtaining written approval from the Department.

Water Quality-Based Limitations

Due to the nature of the discharge, water quality limitations are evaluated at Outfall 001.

Anti-backsliding:

Previous effluent limits and monitoring requirements can be used pursuant to EPA's anti-backsliding regulation, 40 CFR 122.44(l) and are displayed below in Table 6. In the 2002 permit, Zinc and Chromium received monitoring frequencies of once per six months because the permittee stated that the facility did not use cooling tower additives that contain chromium or zinc. In the 2007 permit, the sample frequency for zinc was increased to twice per month because there were a few violations of the zinc limitation during the 2002 to 2007 permit term.

Table 6: Existing Effluent Limitation for IMP 101

| Parameters | Mass (lb/day) | | Concentration (mg/L) | | | Monitoring Requirements | | |
|-------------------------|-----------------|---------------|----------------------|-----------------|---------------|-------------------------|-----------|-------------------|
| | Average Monthly | Daily Maximum | Instant. Minimum | Average Monthly | Daily Maximum | Instant. Maximum | Frequency | Sample Type |
| Flow (MGD) | Report | Report | XXX | XXX | XXX | XXX | 2/Month | Measure |
| Total Suspended Solids | XXX | XXX | XXX | 30 | 100 | XXX | 2/Month | Grab |
| Oil and Grease | XXX | XXX | XXX | 15 | 20 | XXX | 2/Month | Grab |
| Free Available Chlorine | XXX | XXX | XXX | 0.2 | XXX | 0.5 | 2/Month | Grab |
| Total Chromium | XXX | XXX | XXX | 0.2 | 0.2 | XXX | 1/6Month | 24-hour composite |
| Total Zinc | XXX | XXX | XXX | 1.0 | 1.0 | XXX | 2/Month | 24-hour composite |
| pH (S.U.) | XXX | XXX | 6.0 | XXX | XXX | 9.0 | 2/Month | Grab |

Proposed Effluent Limitations

The proposed effluent limitations and monitoring requirements for IMP 101 are shown below in Table 7. The limits are the most stringent values from the above limitation analysis. The limitations for zinc and chromium been replace with monitor and report requirements. A part C condition has been added that prevents the use of chemical additives that contain chromium and/or zinc. Additionally, the sample frequency for Zinc will be reduce to 1/6 months because the DMRs have shown consistent non-detect, with a few occasional detections less than 10% of the effluent limitation.

Table 7: Proposed Effluent Limitation for IMP 101

| Parameters | Mass (lb/day) | | Concentration (mg/L) | | | Monitoring Requirements | | |
|-------------------------|-----------------|---------------|----------------------|-----------------|---------------|-------------------------|-----------|-------------------|
| | Average Monthly | Daily Maximum | Instant. Minimum | Average Monthly | Daily Maximum | Instant. Maximum | Frequency | Sample Type |
| Flow (MGD) | Report | Report | XXX | XXX | XXX | XXX | 2/Month | Measure |
| Total Suspended Solids | XXX | XXX | XXX | 30 | 100 | XXX | 2/Month | Grab |
| Oil and Grease | XXX | XXX | XXX | 15 | 20 | XXX | 2/Month | Grab |
| Free Available Chlorine | XXX | XXX | XXX | 0.2 | XXX | 0.5 | 2/Month | Grab |
| Total Chromium | XXX | XXX | XXX | XXX | Report | XXX | 1/6Month | 24-hour composite |
| Total Zinc | XXX | XXX | XXX | XXX | Report | XXX | 1/6Month | 24-hour composite |
| pH (S.U.) | XXX | XXX | 6.0 | XXX | XXX | 9.0 | 2/Month | Grab |

Development of Effluent Limitations

| | | | |
|----------------------------------------------------------------------------------|-------------|--------------------------|--------------|
| IMP. | 201 | Design Flow (MGD) | 0.036 |
| Latitude | 39° 52' 01" | Longitude | -79° 55' 49" |
| Wastewater Description: Non-Process – wastewater from Oil/Water Separator | | | |

Technology-Based Limitations

Regulatory Effluent Standards and Monitoring Requirements

25 PA Code Chapter 92 requires pH requirements to be a minimum of 6.0 and a maximum of 9.0 S.U. for all industrial waste process and non-process discharges.

Flow Reporting requirements is in accordance with the 25 PA Code Chapter 92 regulations.

Federal Effluent Limitation Guidelines (ELGs)

Steam Electric Generation 40 CFR 423

Discharges from IMP 201 consists of potentially oily low volume wastewater and is subject to the steam electric ELG 40 CFR 423. The discharge is considered a new source and is subject to the ELG's New Source Performance Standards (NSPS) effluent limitations in 40 CFR 423.15 (a) (1,2,3) (1982 NSPS). Applicable effluent limitations are shown in Table 8.

Table 8: Federal Effluent Limitation Guidelines

| Parameters | Concentration (mg/L) | | | |
|------------------------|----------------------|-----------------|---------------|------------------|
| | Minimum | Average Monthly | Daily Maximum | Instant. Maximum |
| Total Suspended Solids | XXX | 30 | 100 | XXX |
| Oil and Grease | XXX | 15 | 20 | XXX |
| pH (S.U.) | 6.0 | XXX | 9.0 | XXX |

In addition to the ELG's numerical limits, Part C will also require that, "There shall be no discharge of polychlorinated biphenyl compounds" (40 CFR 423.15(a)(2)).

Water Quality-Based Limitations

Due to the nature of the discharge, water quality limitations are evaluated at Outfall 001.

Anti-backsliding:

Previous effluent limits and monitoring requirements can be used pursuant to EPA's anti-backsliding regulation, 40 CFR 122.44(l) and are displayed below in Table 9.

Table 9: Existing Effluent Limitation for IMP 201

| Parameters | Mass (lb/day) | | Concentration (mg/L) | | | | Monitoring Requirements | |
|------------------------|-----------------|---------------|----------------------|-----------------|---------------|------------------|-------------------------|-------------|
| | Average Monthly | Daily Maximum | Minimum | Average Monthly | Daily Maximum | Instant. Maximum | Frequency | Sample Type |
| Flow (MGD) | Report | Report | XXX | XXX | XXX | XXX | 2/Month | Estimate |
| Total Suspended Solids | XXX | XXX | XXX | 30.0 | 100.0 | XXX | 2/Month | Grab |
| Oil and Grease | XXX | XXX | XXX | 15.0 | 20.0 | XXX | 2/Month | Grab |
| pH (S.U.) | XXX | XXX | 6.0 | XXX | XXX | 9.0 | 2/Month | Grab |

Proposed Effluent Limitations

The proposed effluent limitations and monitoring requirements for IMP 201 are shown below in Table 10. The limits are the most stringent values from the above limitation analysis.

Table 10: Existing Effluent Limitation for IMP 201

| Parameters | Mass (lb/day) | | Concentration (mg/L) | | | | Monitoring Requirements | |
|------------------------|-----------------|---------------|----------------------|-----------------|---------------|------------------|-------------------------|-------------|
| | Average Monthly | Daily Maximum | Minimum | Average Monthly | Daily Maximum | Instant. Maximum | Frequency | Sample Type |
| Flow (MGD) | Report | Report | XXX | XXX | XXX | XXX | 2/Month | Estimate |
| Total Suspended Solids | XXX | XXX | XXX | 30.0 | 100.0 | XXX | 2/Month | Grab |
| Oil and Grease | XXX | XXX | XXX | 15.0 | 20.0 | XXX | 2/Month | Grab |
| pH (S.U.) | XXX | XXX | 6.0 | XXX | XXX | 9.0 | 2/Month | Grab |

Development of Effluent Limitations

Outfall No. 002 Design Flow (MGD) 0
 Latitude 39° 51' 42" Longitude -79° 55' 00"
 Wastewater Description: Stormwater

Technology-Based Limitations

The stormwater discharges from Outfall 002 will be subjected to the monitoring requirements in Appendix H of the PAG-03 General Stormwater Permit as a minimum requirement because the outfall receives stormwater. The SIC code for the site is 4911 and the corresponding appendix that would apply to the facility is Appendix H of the PAG-03, Steam Electric Generating Facilities, and the reporting requirements are in Table 11 below.

Table 11: Appendix H Stormwater Monitoring Requirements – Outfall 002

| Parameter | Max Daily Concentration | Benchmark Values (mg/L) | Measurement Frequency | Sample Type |
|------------------------------|-------------------------|-------------------------|-----------------------|-------------|
| Total Nitrogen * | Report | XXX | 1/6 Months | Calculation |
| Total Phosphorus | Report | XXX | 1/6 Months | Grab |
| pH (S.U.) | Report | 9.0 | 1/6 Months | Grab |
| Total Suspended Solids (TSS) | Report | 100 | 1/6 Months | Grab |
| Oil and Grease | Report | 30 | 1/6 Months | Grab |
| Total Iron | Report | XXX | 1/6 Months | Grab |

*Total Nitrogen is the sum of Total Kjeldahl-N (TKN) plus Nitrite-Nitrate as N (NO₂+NO₃-N), where TKN and NO₂+NO₃-N are measured in the same sample.

Water Quality-Based Limitations

Water quality analyses are typically performed under low-flow (Q&-10) conditions. Stormwater discharges occur at variable rates and frequencies but not however during Q7-10 conditions. Since the discharges from the Stormwater Outfalls are composed entirely of stormwater, a formal water quality analysis cannot be accurately conducted. Accordingly, water quality-based effluent limitations are not proposed.

Anti-Backsliding

The limits in Table 12 below are from the current permit and are based on information that was provided in the previous permit application.

Table 12: Current Monitoring Requirements for Stormwater Outfall 002

| Parameters | Mass (lb/day) | | Concentration (mg/l) | | | | Monitoring Requirements | |
|-------------------------|-----------------|---------------|----------------------|-----------------|---------------|------------------|-------------------------|-------------|
| | Average Monthly | Daily Maximum | Minimum | Average Monthly | Daily Maximum | Instant. Maximum | Frequency | Sample Type |
| Flow (MGD) | Report | Report | XXX | XXX | XXX | XXX | 2/Quarter* | Estimate |
| Total Residual Chlorine | XXX | XXX | XXX | Report | XXX | Report | 2/Quarter* | Grab |

*Two samples will be taken during the same calendar month to calculate a monthly average. Flow will be measured concurrently.

Final Effluent Limitations

The proposed effluent monitoring requirements for Outfall 002 are displayed in Table 13 below, they are the most stringent values from the above effluent limitation development. The flow monitoring requirement from the current permit has been removed from this outfall because flow monitoring is not appropriate for stormwater discharges. The TRC monitoring requirement from the previous permit has been removed because TRC is not a pollutant of concern in the stormwater discharges from Outfall 002. The Draft Permit requires a Corrective Action Plan when there are two consecutive exceedances of the benchmark values, which are also included in the Part C condition. The benchmark values are displayed below in Table 13. These values are not effluent limitations, an exceedance of the benchmark value is not a violation. As described above, if there are two consecutive exceedances of the benchmark value, a corrective action plan must be conducted to evaluate site stormwater controls and BMPs. Benchmark monitoring is a feedback tool, along with routine inspections and visual assessments, for assessing the effectiveness of stormwater controls and BMPs. An exceedance of the benchmark provides permittees with an indication that the facility's controls may not be sufficiently controlling pollutants in stormwater.

Table 13: Proposed Effluent Monitoring Requirements – Outfall 002

| Parameter | Max Daily Concentration | Benchmark Values (mg/L) | Measurement Frequency | Sample Type |
|------------------------------|-------------------------|-------------------------|-----------------------|-------------|
| Total Nitrogen * | Report | XXX | 1/6 Months | Calculation |
| Total Phosphorus | Report | XXX | 1/6 Months | Grab |
| pH (S.U.) | Report | 9.0 | 1/6 Months | Grab |
| Total Suspended Solids (TSS) | Report | 100 | 1/6 Months | Grab |
| Oil and Grease | Report | 30 | 1/6 Months | Grab |
| Total Iron | Report | XXX | 1/6 Months | Grab |

*Total Nitrogen is the sum of Total Kjeldahl-N (TKN) plus Nitrite-Nitrate as N (NO₂+NO₃-N), where TKN and NO₂+NO₃-N are measured in the same sample.

| Tools and References Used to Develop Permit | |
|---------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <input type="checkbox"/> | WQM for Windows Model (see Attachment) |
| <input checked="" type="checkbox"/> | Toxics Management Spreadsheet (see Attachment C) |
| <input checked="" type="checkbox"/> | TRC Model Spreadsheet (see Attachment D) |
| <input type="checkbox"/> | Temperature Model Spreadsheet (see Attachment E) |
| <input type="checkbox"/> | Water Quality Toxics Management Strategy, 361-0100-003, 4/06. |
| <input type="checkbox"/> | Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97. |
| <input type="checkbox"/> | Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98. |
| <input type="checkbox"/> | Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96. |
| <input type="checkbox"/> | Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97. |
| <input type="checkbox"/> | Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97. |
| <input type="checkbox"/> | Pennsylvania CSO Policy, 386-2000-002, 9/08. |
| <input type="checkbox"/> | Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03. |
| <input type="checkbox"/> | Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97. |
| <input type="checkbox"/> | Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97. |
| <input type="checkbox"/> | Implementation Guidance Design Conditions, 386-2000-007, 9/97. |
| <input type="checkbox"/> | Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004. |
| <input type="checkbox"/> | Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997. |
| <input type="checkbox"/> | Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99. |
| <input type="checkbox"/> | Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004. |
| <input type="checkbox"/> | Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97. |
| <input type="checkbox"/> | Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008. |
| <input type="checkbox"/> | Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994. |
| <input type="checkbox"/> | Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09. |
| <input type="checkbox"/> | Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97. |
| <input type="checkbox"/> | Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97. |
| <input type="checkbox"/> | Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99. |
| <input type="checkbox"/> | Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999. |
| <input type="checkbox"/> | Design Stream Flows, 386-2000-003, 9/98. |
| <input type="checkbox"/> | Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98. |
| <input type="checkbox"/> | Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97. |
| <input type="checkbox"/> | Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07. |
| <input type="checkbox"/> | SOP: |
| <input type="checkbox"/> | Other: |

Attachments

Attachment A: NPDES Permit Rating Work Sheet
Attachment B: Outfall 001 StreamStats Report
Attachment C: Outfall 001 Toxics Management Spread Sheet
Attachment D: Outfall 001 TRC Evaluation
Attachment E: Outfall 001 Thermal Discharge Evaluation
Attachment F: Site Flow Diagram
Attachment G: Site Plan

Attachment A:
NPDES Permit Rating Work Sheet

NPDES Permit Rating Work Sheet

- Regular Addition
- Discretionary Addition
- Score change, but no status change
- Deletion

NPDES No.: PA0218863

Facility Name: Fayette Energy Facility

City: German Township, Fayette County

Receiving Water: Monongahela River

Reach Number:

Is this facility a steam electric power plant (SIC=4911) with one or more of the following characteristics?

1. Power output 500 MW or greater (not using a cooling pond/lake)
2. A nuclear power plant
3. Cooling water discharge greater than 25% of the receiving stream's 7Q10 flow rate

YES; score is 600 (stop here) NO (continue)

Is this permit for a municipal separate storm sewer serving a population greater than 100,000?

YES; score is 700 (stop here)

NO (continue)

FACTOR 1: Toxic Pollutant Potential

PCS SIC Code: Primary SIC Code: Other SIC Codes: Industrial Subcategory Code: (Code 000 if no subcategory)

Determine the Toxicity potential from Appendix A. (Be sure to use the TOTAL toxicity potential column and check one)

| Toxicity Group | Code | Points | Toxicity Group | Code | Points | Toxicity Group | Code | Points |
|---------------------------------------------------|------|--------|-----------------------------|------|--------|------------------------------|------|--------|
| <input type="checkbox"/> No process waste streams | 0 | 0 | <input type="checkbox"/> 3. | 3 | 15 | <input type="checkbox"/> 7 | 7 | 35 |
| <input type="checkbox"/> 1. | 1 | 5 | <input type="checkbox"/> 4. | 4 | 20 | <input type="checkbox"/> 8. | 8 | 40 |
| <input type="checkbox"/> 2. | 2 | 10 | <input type="checkbox"/> 5. | 5 | 25 | <input type="checkbox"/> 9. | 9 | 45 |
| | | | <input type="checkbox"/> 6. | 6 | 30 | <input type="checkbox"/> 10. | 10 | 50 |

Code Number Checked:

Total Points Factor 1: 0

FACTOR 2: Flow/Stream Flow Volume (Complete either Section A or Section B; check only one)

Section A - Wastewater Flow Only Considered

| Wastewater type (See Instructions) | Code | Points |
|------------------------------------|------|--------|
| Type I: Flow < 5 MGD | 11 | 0 |
| Flow 5 to 10 MGD | 12 | 10 |
| Flow > 10 to 50 MGD | 13 | 20 |
| Flow > 50 MGD | 14 | 30 |
| Type II: Flow < 1 MGD | 21 | 10 |
| Flow 1 to 5 MGD | 22 | 20 |
| Flow > 5 to 10 MGD | 23 | 30 |
| Flow > 10 MGD | 24 | 50 |
| Type III: Flow < 1 MGD | 31 | 0 |
| Flow 1 to 5 MGD | 32 | 10 |
| Flow > 5 to 10 MGD | 33 | 20 |
| Flow > 10 MGD | 34 | 30 |

Section B - Wastewater and Stream Flow Considered

| Wastewater type (See Instructions) | Percent of Instream Wastewater Concentration at Receiving Stream Low Flow | Code | Points |
|------------------------------------|---------------------------------------------------------------------------|------|--------|
| Type III: | <10% | 41 | 0 |
| | ≥10% to <50% | 42 | 10 |
| | ≥50% | 43 | 20 |
| Type II | <10% | 51 | 0 |
| | ≥10% to <50% | 52 | 20 |
| | ≥50% | 53 | 30 |

Code Checked from Section A or B:

Total Points Factor 2: 0

NPDES Permit Rating Work Sheet

FACTOR 3: Conventional Pollutants
(only when limited by the permit)

NPDES No.: PA0218863

A. Oxygen Demanding Pollutants (check one) BOD COD OTHER:

| Permit Limits (check one) | <input type="checkbox"/> | | Code | Points |
|---------------------------|--------------------------|--|------|--------|
| <100 lbs/day | <input type="checkbox"/> | | 1 | 0 |
| 100 to 1000 lbs/day | <input type="checkbox"/> | | 2 | 5 |
| >1000 to 3000 lbs/day | <input type="checkbox"/> | | 3 | 15 |
| >3000 lbs/day | <input type="checkbox"/> | | 4 | 20 |

Code Checked:
Points Scored: 0

B. Total Suspended Solids (TSS)

| Permit Limits (check one) | <input type="checkbox"/> | | Code | Points |
|---------------------------|--------------------------|--|------|--------|
| <100 lbs/day | <input type="checkbox"/> | | 1 | 0 |
| 100 to 1000 lbs/day | <input type="checkbox"/> | | 2 | 5 |
| >1000 to 5000 lbs/day | <input type="checkbox"/> | | 3 | 15 |
| >5000 lbs/day | <input type="checkbox"/> | | 4 | 20 |

Code Checked:
Points Scored: 0

C. Nitrogen Pollutants (check one)

Ammonia OTHER:

| Permit Limits (check one) | <input type="checkbox"/> | Nitrogen Equivalent | Code | Points |
|---------------------------|--------------------------|---------------------|------|--------|
| <300 lbs/day | <input type="checkbox"/> | | 1 | 0 |
| 300 to 1000 lbs/day | <input type="checkbox"/> | | 2 | 5 |
| >1000 to 3000 lbs/day | <input type="checkbox"/> | | 3 | 15 |
| >3000 lbs/day | <input type="checkbox"/> | | 4 | 20 |

Code Checked:
Points Scored: 0
Total Points Factor 3: 0

FACTOR 4: Public Health Impact

Is there a public drinking water supply located within 50 miles downstream of the effluent discharge (this includes any body of water to which the receiving water is a tributary)? A public drinking water supply may include infiltration galleries, or other methods of conveyance that ultimately get water from the above referenced supply.

- YES (if yes, check toxicity potential number below)
 NO (if no, go to Factor 5)

Determine the human health toxicity potential from Appendix A. Use the same SIC Code and subcategory reference as in Factor 1. (Be sure to use the human health toxicity group column and check one below)

| Toxicity Group | Code | Points | Toxicity Group | Code | Points | Toxicity Group | Code | Points |
|---------------------------------------------------|------|--------|-----------------------------|------|--------|------------------------------|------|--------|
| <input type="checkbox"/> No process waste streams | 0 | 0 | <input type="checkbox"/> 3. | 3 | 0 | <input type="checkbox"/> 7. | 7 | 15 |
| <input type="checkbox"/> 1. | 1 | 0 | <input type="checkbox"/> 4. | 4 | 0 | <input type="checkbox"/> 8. | 8 | 20 |
| <input type="checkbox"/> 2. | 2 | 0 | <input type="checkbox"/> 5. | 5 | 5 | <input type="checkbox"/> 9. | 9 | 25 |
| | | | <input type="checkbox"/> 6. | 6 | 10 | <input type="checkbox"/> 10. | 10 | 30 |

Code Number Checked:
Total Points Factor 4: 0

NPDES Permit Rating Work Sheet

FACTOR 5: Water Quality Factors

NPDES No.: PA0218863

A. Is (or will) one or more of the effluent discharge limits based on water quality factors of the receiving stream (rather than technology-based federal effluent guidelines, or technology-based state effluent guidelines), or has a wasteload allocation been assigned to the discharge?

| | Code | Points |
|------------------------------|------|--------|
| <input type="checkbox"/> YES | 1 | 10 |
| <input type="checkbox"/> NO | 2 | 0 |

B. Is the receiving water in compliance with applicable water quality standards for pollutants that are water quality limited in the permit?

| | Code | Points |
|------------------------------|------|--------|
| <input type="checkbox"/> YES | 1 | 0 |
| <input type="checkbox"/> NO | 2 | 5 |

C. Does the effluent discharged from this facility exhibit the reasonable potential to violate water quality standards due to whole effluent toxicity?

| | Code | Points |
|------------------------------|------|--------|
| <input type="checkbox"/> YES | 1 | 10 |
| <input type="checkbox"/> NO | 2 | 0 |

Code Number Checked: A. B. C.

Total Points Factor 5 A. 0 + B. 0 + C. 0 = 0

FACTOR 6: Proximity to Near Coastal Waters

A. Base Score: Enter flow code here (from Factor 2):

Enter the multiplication factor that corresponds to the flow code: 0.0

Check appropriate facility HPRI Code (from PCS):

| HPRI# | Code | HPRI Score |
|----------------------------|------|------------|
| <input type="checkbox"/> 1 | 1 | 20 |
| <input type="checkbox"/> 2 | 2 | 0 |
| <input type="checkbox"/> 3 | 3 | 30 |
| <input type="checkbox"/> 4 | 4 | 0 |
| <input type="checkbox"/> 5 | 5 | 20 |

| Flow code | Multiplication Factor |
|---------------|-----------------------|
| 11, 31, or 41 | 0.00 |
| 12, 32, or 42 | 0.05 |
| 13, 33, or 43 | 0.10 |
| 14 or 34 | 0.15 |
| 21 or 51 | 0.10 |
| 22 or 52 | 0.30 |
| 23 or 53 | 0.60 |
| 24 | 1.00 |

HPRI Code Checked:

Base Score (HPRI Score) 0 x (Multiplication Factor) 0.0 = 0 (Total Points)

B. Additional Points – NEP Program

For a facility that has an HPRI code of 3, does the facility discharge to one of the estuaries enrolled in the National Estuary Protection (NEP) program (see instructions) or the Chesapeake Bay?

| | Code | Points |
|------------------------------|------|--------|
| <input type="checkbox"/> YES | 1 | 10 |
| <input type="checkbox"/> NO | 2 | 0 |

C. Additional Points – Great Lakes Area of Concern

For a facility that has an HPRI code of 5, does the facility discharge any of the pollutants of concern into one of the Great Lakes' 31 areas of concern (see instructions)?

| | Code | Points |
|------------------------------|------|--------|
| <input type="checkbox"/> YES | 1 | 10 |
| <input type="checkbox"/> NO | 2 | 0 |

Code Number Checked: A. B. C.

Total Points Factor 6 A. 0 + B. 0 + C. 0 = 0

NPDES Permit Rating Work Sheet

Score Summary

NPDES No.: PA0218863

| Factor | Description | Total Points |
|-----------------------------|----------------------------------|--------------|
| 1. | Toxic Pollutant Potential | 0 |
| 2. | Flow/Streamflow Volume | 0 |
| 3. | Conventional Pollutants | 0 |
| 4. | Public Health Impacts | 0 |
| 5. | Water Quality Factors | 0 |
| 6. | Proximity to Near Coastal Waters | 0 |
| TOTAL (Factors 1 through 6) | | 0 |

S1. Is the total score equal to or greater than 80? YES (Facility is a major) NO

S2. If the answer to the above question is no, would you like this facility to be discretionary major?

NO

YES (Add 500 points to the above score and provide reason below:

Reason:

Reason: [Empty text area for providing reasons]

NEW SCORE: 600

OLD SCORE: [Empty text box]

Adam Olesnanik

Permit Reviewer's Name

(412) 442-4254

Phone Number

02/29/2024

Date


Reset Form

Attachment B:

Outfall 001 StreamStats Report

Outfall 001 StreamStats Report

Region ID: PA
 Workspace ID: PA20240229190355096000
 Clicked Point (Latitude, Longitude): 39.86709, -79.93079
 Time: 2024-02-29 14:04:30 -0500



Collapse All

> Basin Characteristics

| Parameter Code | Parameter Description | Value | Unit |
|----------------|--------------------------------------------|---------|--------------|
| CARBON | Percentage of area of carbonate rock | 0 | percent |
| DRNAREA | Area that drains to a point on a stream | 4530 | square miles |
| ELEV | Mean Basin Elevation | 1946 | feet |
| FOREST | Percentage of area covered by forest | 79.7051 | percent |
| PRECIP | Mean Annual Precipitation | 49 | inches |
| URBAN | Percentage of basin with urban development | 1.9011 | percent |

> General Flow Statistics

General Flow Statistics Parameters [Statewide Mean and Base Flow]

| Parameter Code | Parameter Name | Value | Units | Min Limit | Max Limit |
|----------------|---------------------------|---------|--------------|-----------|-----------|
| DRNAREA | Drainage Area | 4530 | square miles | 2.26 | 1720 |
| PRECIP | Mean Annual Precipitation | 49 | inches | 33.1 | 50.4 |
| CARBON | Percent Carbonate | 0 | percent | 0 | 99 |
| FOREST | Percent Forest | 79.7051 | percent | 5.1 | 100 |
| URBAN | Percent Urban | 1.9011 | percent | 0 | 89 |

General Flow Statistics Disclaimers [Statewide Mean and Base Flow]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

General Flow Statistics Flow Report [Statewide Mean and Base Flow]

| Statistic | Value | Unit |
|--------------------------|-------|--------------------|
| Harmonic Mean Streamflow | 4190 | ft ³ /s |

General Flow Statistics Citations

Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.19.4

StreamStats Services Version: 1.2.22

NSS Services Version: 2.2.1

Attachment C:

Outfall 001 Toxics Management Spread Sheet



Discharge Information

Instructions Discharge Stream

Facility: Fayette Energy Facility NPDES Permit No.: PA0218863 Outfall No.: 001
 Evaluation Type: Major Sewage / Industrial Waste Wastewater Description: ELG Wastewater - cooling tower blowdown

| Discharge Characteristics | | | | | | | | |
|---------------------------|------------------|----------|----------------------------|-----|-----|-----|--------------------------|----------------|
| Design Flow (MGD)* | Hardness (mg/l)* | pH (SU)* | Partial Mix Factors (PMFs) | | | | Complete Mix Times (min) | |
| | | | AFC | CFC | THH | CRL | Q ₇₋₁₀ | Q _h |
| 0.67 | 845 | 8.13 | | | | | | |

| Discharge Pollutant | Units | Max Discharge Conc | 0 if left blank | | 0.5 if left blank | | 0 if left blank | | 1 if left blank | | Criteria Mod | Chem Transl |
|---------------------------------|-------|--------------------|-----------------|-------------|-------------------|-----------|-----------------|------------|-----------------|--|--------------|-------------|
| | | | Trib Conc | Stream Conc | Daily CV | Hourly CV | Stream CV | Fate Coeff | FOS | | | |
| Group 1 | | | | | | | | | | | | |
| Total Dissolved Solids (PWS) | mg/L | 1550 | | | | | | | | | | |
| Chloride (PWS) | mg/L | 127 | | | | | | | | | | |
| Bromide | mg/L | < 25 | | | | | | | | | | |
| Sulfate (PWS) | mg/L | 1050 | | | | | | | | | | |
| Fluoride (PWS) | mg/L | 0.65 | | | | | | | | | | |
| Group 2 | | | | | | | | | | | | |
| Total Aluminum | µg/L | 164 | | | | | | | | | | |
| Total Antimony | µg/L | 9.9 | | | | | | | | | | |
| Total Arsenic | µg/L | < 1 | | | | | | | | | | |
| Total Barium | µg/L | 288 | | | | | | | | | | |
| Total Beryllium | µg/L | < 0.3 | | | | | | | | | | |
| Total Boron | µg/L | 215 | | | | | | | | | | |
| Total Cadmium | µg/L | < 1 | | | | | | | | | | |
| Total Chromium (III) | µg/L | < 7 | | | | | | | | | | |
| Hexavalent Chromium | µg/L | < 10 | | | | | | | | | | |
| Total Cobalt | µg/L | 1.6 | | | | | | | | | | |
| Total Copper | µg/L | 7 | | | | | | | | | | |
| Free Cyanide | µg/L | 12 | | | | | | | | | | |
| Total Cyanide | µg/L | | | | | | | | | | | |
| Dissolved Iron | µg/L | 103 | | | | | | | | | | |
| Total Iron | µg/L | 331 | | | | | | | | | | |
| Total Lead | µg/L | < 1 | | | | | | | | | | |
| Total Manganese | µg/L | 84.8 | | | | | | | | | | |
| Total Mercury | µg/L | < 0.2 | | | | | | | | | | |
| Total Nickel | µg/L | 20.6 | | | | | | | | | | |
| Total Phenols (Phenolics) (PWS) | µg/L | < 50 | | | | | | | | | | |
| Total Selenium | µg/L | 2.1 | | | | | | | | | | |
| Total Silver | µg/L | < 1 | | | | | | | | | | |
| Total Thallium | µg/L | 0.3 | | | | | | | | | | |
| Total Zinc | µg/L | 36.7 | | | | | | | | | | |
| Total Molybdenum | µg/L | < 10 | | | | | | | | | | |
| Acrolein | µg/L | < 4 | | | | | | | | | | |
| Acrylamide | µg/L | < 10 | | | | | | | | | | |
| Acrylonitrile | µg/L | < 4 | | | | | | | | | | |
| Benzene | µg/L | < 1 | | | | | | | | | | |
| Bromoform | µg/L | < 1 | | | | | | | | | | |



Stream / Surface Water Information

Fayette Energy Facility, NPDES Permit No. PA0218863, Outfall 001

Instructions Discharge **Stream**

Receiving Surface Water Name: Monongahela River

No. Reaches to Model: 1

- Statewide Criteria
- Great Lakes Criteria
- ORSANCO Criteria

| Location | Stream Code* | RMI* | Elevation (ft)* | DA (mi ²)* | Slope (ft/ft) | PWS Withdrawal (MGD) | Apply Fish Criteria* |
|--------------------|--------------|------|-----------------|------------------------|---------------|----------------------|----------------------|
| Point of Discharge | 037185 | 78.6 | 785 | 4530 | | | Yes |
| End of Reach 1 | 037185 | 77.6 | 784 | 4531 | | | Yes |

Q₇₋₁₀

| Location | RMI | LFY (cfs/mi ²)* | Flow (cfs) | | W/D Ratio | Width (ft) | Depth (ft) | Velocity (fps) | Travel Time (days) | Tributary | | Stream | | Analysis | |
|--------------------|------|-----------------------------|------------|-----------|-----------|------------|------------|----------------|--------------------|-----------|----|-----------|-----|----------|----|
| | | | Stream | Tributary | | | | | | Hardness | pH | Hardness* | pH* | Hardness | pH |
| Point of Discharge | 78.6 | 0.1 | 530 | | | 500 | 10 | | | | | 100 | 7 | | |
| End of Reach 1 | 77.6 | 0.1 | | | | | | | | | | | | | |

Q_n

| Location | RMI | LFY (cfs/mi ²)* | Flow (cfs) | | W/D Ratio | Width (ft) | Depth (ft) | Velocity (fps) | Travel Time (days) | Tributary | | Stream | | Analysis | |
|--------------------|------|-----------------------------|------------|-----------|-----------|------------|------------|----------------|--------------------|-----------|----|----------|----|----------|----|
| | | | Stream | Tributary | | | | | | Hardness | pH | Hardness | pH | Hardness | pH |
| Point of Discharge | 78.6 | | | | | | | | | | | | | | |
| End of Reach 1 | 77.6 | | | | | | | | | | | | | | |



Model Results

Fayette Energy Facility, NPDES Permit No. PA0218863, Outfall 001

Instructions

Results

RETURN TO INPUTS

SAVE AS PDF

PRINT

All

Inputs

Results

Limits

Hydrodynamics

Wasteload Allocations

AFC

OCT (min):

PMF:

Analysis Hardness (mg/l):

Analysis pH:

| Pollutants | Stream Conc (µg/L) | Stream CV | Trib Conc (µg/L) | Fate Coef | WQC (µg/L) | WQ Obj (µg/L) | WLA (µg/L) | Comments |
|---------------------------------|--------------------|-----------|------------------|-----------|------------|---------------|------------|----------------------------------|
| Total Dissolved Solids (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Chloride (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Sulfate (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Fluoride (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Aluminum | 0 | 0 | | 0 | 750 | 750 | 53,786 | |
| Total Antimony | 0 | 0 | | 0 | 1,100 | 1,100 | 78,887 | |
| Total Arsenic | 0 | 0 | | 0 | 340 | 340 | 24,383 | Chem Translator of 1 applied |
| Total Barium | 0 | 0 | | 0 | 21,000 | 21,000 | 1,506,019 | |
| Total Boron | 0 | 0 | | 0 | 8,100 | 8,100 | 580,893 | |
| Total Cadmium | 0 | 0 | | 0 | 2.217 | 2.36 | 169 | Chem Translator of 0.94 applied |
| Total Chromium (III) | 0 | 0 | | 0 | 617.801 | 1,955 | 140,208 | Chem Translator of 0.316 applied |
| Hexavalent Chromium | 0 | 0 | | 0 | 16 | 16.3 | 1,168 | Chem Translator of 0.982 applied |
| Total Cobalt | 0 | 0 | | 0 | 95 | 95.0 | 6,813 | |
| Total Copper | 0 | 0 | | 0 | 14.751 | 15.4 | 1,102 | Chem Translator of 0.96 applied |
| Free Cyanide | 0 | 0 | | 0 | 22 | 22.0 | 1,578 | |
| Dissolved Iron | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Iron | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Lead | 0 | 0 | | 0 | 71.907 | 92.6 | 6,640 | Chem Translator of 0.777 applied |
| Total Manganese | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Mercury | 0 | 0 | | 0 | 1.400 | 1.65 | 118 | Chem Translator of 0.85 applied |
| Total Nickel | 0 | 0 | | 0 | 509.070 | 510 | 36,581 | Chem Translator of 0.998 applied |
| Total Phenols (Phenolics) (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Selenium | 0 | 0 | | 0 | N/A | N/A | N/A | Chem Translator of 0.922 applied |
| Total Silver | 0 | 0 | | 0 | 3.813 | 4.49 | 322 | Chem Translator of 0.85 applied |
| Total Thallium | 0 | 0 | | 0 | 65 | 65.0 | 4,661 | |
| Total Zinc | 0 | 0 | | 0 | 127.416 | 130 | 9,343 | Chem Translator of 0.978 applied |

| | | | | | | | | |
|-----------------------------|---|---|--|---|--------|--------|-----------|--|
| Acrolein | 0 | 0 | | 0 | 3 | 3.0 | 215 | |
| Acrylamide | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Acrylonitrile | 0 | 0 | | 0 | 650 | 650 | 46,615 | |
| Benzene | 0 | 0 | | 0 | 640 | 640 | 45,898 | |
| Bromoform | 0 | 0 | | 0 | 1,800 | 1,800 | 129,087 | |
| Carbon Tetrachloride | 0 | 0 | | 0 | 2,800 | 2,800 | 200,802 | |
| Chlorobenzene | 0 | 0 | | 0 | 1,200 | 1,200 | 86,058 | |
| Chlorodibromomethane | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 2-Chloroethyl Vinyl Ether | 0 | 0 | | 0 | 18,000 | 18,000 | 1,290,873 | |
| Chloroform | 0 | 0 | | 0 | 1,900 | 1,900 | 136,259 | |
| Dichlorobromomethane | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 1,2-Dichloroethane | 0 | 0 | | 0 | 15,000 | 15,000 | 1,075,728 | |
| 1,1-Dichloroethylene | 0 | 0 | | 0 | 7,500 | 7,500 | 537,864 | |
| 1,2-Dichloropropane | 0 | 0 | | 0 | 11,000 | 11,000 | 788,867 | |
| 1,3-Dichloropropylene | 0 | 0 | | 0 | 310 | 310 | 22,232 | |
| Ethylbenzene | 0 | 0 | | 0 | 2,900 | 2,900 | 207,974 | |
| Methyl Bromide | 0 | 0 | | 0 | 550 | 550 | 39,443 | |
| Methyl Chloride | 0 | 0 | | 0 | 28,000 | 28,000 | 2,008,025 | |
| Methylene Chloride | 0 | 0 | | 0 | 12,000 | 12,000 | 860,582 | |
| 1,1,2,2-Tetrachloroethane | 0 | 0 | | 0 | 1,000 | 1,000 | 71,715 | |
| Tetrachloroethylene | 0 | 0 | | 0 | 700 | 700 | 50,201 | |
| Toluene | 0 | 0 | | 0 | 1,700 | 1,700 | 121,916 | |
| 1,2-trans-Dichloroethylene | 0 | 0 | | 0 | 6,800 | 6,800 | 487,663 | |
| 1,1,1-Trichloroethane | 0 | 0 | | 0 | 3,000 | 3,000 | 215,146 | |
| 1,1,2-Trichloroethane | 0 | 0 | | 0 | 3,400 | 3,400 | 243,832 | |
| Trichloroethylene | 0 | 0 | | 0 | 2,300 | 2,300 | 164,945 | |
| Vinyl Chloride | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 2-Chlorophenol | 0 | 0 | | 0 | 560 | 560 | 40,160 | |
| 2,4-Dichlorophenol | 0 | 0 | | 0 | 1,700 | 1,700 | 121,916 | |
| 2,4-Dimethylphenol | 0 | 0 | | 0 | 660 | 660 | 47,332 | |
| 4,6-Dinitro-o-Cresol | 0 | 0 | | 0 | 80 | 80.0 | 5,737 | |
| 2,4-Dinitrophenol | 0 | 0 | | 0 | 660 | 660 | 47,332 | |
| 2-Nitrophenol | 0 | 0 | | 0 | 8,000 | 8,000 | 573,721 | |
| 4-Nitrophenol | 0 | 0 | | 0 | 2,300 | 2,300 | 164,945 | |
| p-Chloro-m-Cresol | 0 | 0 | | 0 | 160 | 160 | 11,474 | |
| Pentachlorophenol | 0 | 0 | | 0 | 8.773 | 8.77 | 629 | |
| Phenol | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 2,4,6-Trichlorophenol | 0 | 0 | | 0 | 460 | 460 | 32,989 | |
| Acenaphthene | 0 | 0 | | 0 | 83 | 83.0 | 5,952 | |
| Anthracene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Benzidine | 0 | 0 | | 0 | 300 | 300 | 21,515 | |
| Benzo(a)Anthracene | 0 | 0 | | 0 | 0.5 | 0.5 | 35.9 | |
| Benzo(a)Pyrene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 3,4-Benzofluoranthene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Benzo(k)Fluoranthene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Bis(2-Chloroethyl)Ether | 0 | 0 | | 0 | 30,000 | 30,000 | 2,151,455 | |
| Bis(2-Chloroisopropyl)Ether | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Bis(2-Ethylhexyl)Phthalate | 0 | 0 | | 0 | 4,500 | 4,500 | 322,718 | |

| | | | | | | | | |
|----------------------------|---|---|--|---|--------|--------|-----------|--|
| 4-Bromophenyl Phenyl Ether | 0 | 0 | | 0 | 270 | 270 | 19,363 | |
| Butyl Benzyl Phthalate | 0 | 0 | | 0 | 140 | 140 | 10,040 | |
| 2-Chloronaphthalene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Chrysene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Dibenzo(a,h)Anthracene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 1,2-Dichlorobenzene | 0 | 0 | | 0 | 820 | 820 | 58,806 | |
| 1,3-Dichlorobenzene | 0 | 0 | | 0 | 350 | 350 | 25,100 | |
| 1,4-Dichlorobenzene | 0 | 0 | | 0 | 730 | 730 | 52,352 | |
| 3,3-Dichlorobenzidine | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Diethyl Phthalate | 0 | 0 | | 0 | 4,000 | 4,000 | 286,861 | |
| Dimethyl Phthalate | 0 | 0 | | 0 | 2,500 | 2,500 | 179,288 | |
| Di-n-Butyl Phthalate | 0 | 0 | | 0 | 110 | 110 | 7,889 | |
| 2,4-Dinitrotoluene | 0 | 0 | | 0 | 1,600 | 1,600 | 114,744 | |
| 2,6-Dinitrotoluene | 0 | 0 | | 0 | 990 | 990 | 70,998 | |
| 1,2-Diphenylhydrazine | 0 | 0 | | 0 | 15 | 15.0 | 1,076 | |
| Fluoranthene | 0 | 0 | | 0 | 200 | 200 | 14,343 | |
| Fluorene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Hexachlorobenzene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Hexachlorobutadiene | 0 | 0 | | 0 | 10 | 10.0 | 717 | |
| Hexachlorocyclopentadiene | 0 | 0 | | 0 | 5 | 5.0 | 359 | |
| Hexachloroethane | 0 | 0 | | 0 | 60 | 60.0 | 4,303 | |
| Indeno(1,2,3-cd)Pyrene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Isophorone | 0 | 0 | | 0 | 10,000 | 10,000 | 717,152 | |
| Naphthalene | 0 | 0 | | 0 | 140 | 140 | 10,040 | |
| Nitrobenzene | 0 | 0 | | 0 | 4,000 | 4,000 | 286,861 | |
| n-Nitrosodimethylamine | 0 | 0 | | 0 | 17,000 | 17,000 | 1,219,158 | |
| n-Nitrosodi-n-Propylamine | 0 | 0 | | 0 | N/A | N/A | N/A | |
| n-Nitrosodiphenylamine | 0 | 0 | | 0 | 300 | 300 | 21,515 | |
| Phenanthrene | 0 | 0 | | 0 | 5 | 5.0 | 359 | |
| Pyrene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 1,2,4-Trichlorobenzene | 0 | 0 | | 0 | 130 | 130 | 9,323 | |

CFC CCT (min): PMF: Analysis Hardness (mg/l): Analysis pH:

| Pollutants | Stream Conc (µg/L) | Stream CV | Trib Conc (µg/L) | Fate Coef | WQC (µg/L) | WQ Obj (µg/L) | WLA (µg/L) | Comments |
|------------------------------|--------------------|-----------|------------------|-----------|------------|---------------|------------|----------------------------------|
| Total Dissolved Solids (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Chloride (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Sulfate (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Fluoride (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Aluminum | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Antimony | 0 | 0 | | 0 | 220 | 220 | 108,004 | |
| Total Arsenic | 0 | 0 | | 0 | 150 | 150 | 73,639 | Chem Translator of 1 applied |
| Total Barium | 0 | 0 | | 0 | 4,100 | 4,100 | 2,012,809 | |
| Total Boron | 0 | 0 | | 0 | 1,600 | 1,600 | 785,487 | |
| Total Cadmium | 0 | 0 | | 0 | 0.249 | 0.27 | 134 | Chem Translator of 0.908 applied |
| Total Chromium (III) | 0 | 0 | | 0 | 75.034 | 87.2 | 42,833 | Chem Translator of 0.86 applied |

| | | | | | | | | |
|---------------------------------|---|---|--|---|---------|-------|-----------|----------------------------------|
| Hexavalent Chromium | 0 | 0 | | 0 | 10 | 10.4 | 5,103 | Chem Translator of 0.962 applied |
| Total Cobalt | 0 | 0 | | 0 | 19 | 19.0 | 9,328 | |
| Total Copper | 0 | 0 | | 0 | 9.072 | 9.45 | 4,639 | Chem Translator of 0.96 applied |
| Free Cyanide | 0 | 0 | | 0 | 5.2 | 5.2 | 2,553 | |
| Dissolved Iron | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Iron | 0 | 0 | | 0 | 1,500 | 1,500 | 768,512 | WQC = 30 day average; PMF = 1 |
| Total Lead | 0 | 0 | | 0 | 2.558 | 3.24 | 1,592 | Chem Translator of 0.789 applied |
| Total Manganese | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Mercury | 0 | 0 | | 0 | 0.770 | 0.91 | 445 | Chem Translator of 0.85 applied |
| Total Nickel | 0 | 0 | | 0 | 52.673 | 52.8 | 25,937 | Chem Translator of 0.997 applied |
| Total Phenols (Phenolics) (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Selenium | 0 | 0 | | 0 | 4.600 | 4.99 | 2,449 | Chem Translator of 0.922 applied |
| Total Silver | 0 | 0 | | 0 | N/A | N/A | N/A | Chem Translator of 1 applied |
| Total Thallium | 0 | 0 | | 0 | 13 | 13.0 | 6,382 | |
| Total Zinc | 0 | 0 | | 0 | 119.656 | 121 | 59,577 | Chem Translator of 0.986 applied |
| Acrolein | 0 | 0 | | 0 | 3 | 3.0 | 1,473 | |
| Acrylamide | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Acrylonitrile | 0 | 0 | | 0 | 130 | 130 | 63,821 | |
| Benzene | 0 | 0 | | 0 | 130 | 130 | 63,821 | |
| Bromoform | 0 | 0 | | 0 | 370 | 370 | 181,644 | |
| Carbon Tetrachloride | 0 | 0 | | 0 | 560 | 560 | 274,920 | |
| Chlorobenzene | 0 | 0 | | 0 | 240 | 240 | 117,823 | |
| Chlorodibromomethane | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 2-Chloroethyl Vinyl Ether | 0 | 0 | | 0 | 3,500 | 3,500 | 1,718,252 | |
| Chloroform | 0 | 0 | | 0 | 390 | 390 | 191,462 | |
| Dichlorobromomethane | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 1,2-Dichloroethane | 0 | 0 | | 0 | 3,100 | 3,100 | 1,521,880 | |
| 1,1-Dichloroethylene | 0 | 0 | | 0 | 1,500 | 1,500 | 736,394 | |
| 1,2-Dichloropropane | 0 | 0 | | 0 | 2,200 | 2,200 | 1,080,044 | |
| 1,3-Dichloropropylene | 0 | 0 | | 0 | 61 | 61.0 | 29,947 | |
| Ethylbenzene | 0 | 0 | | 0 | 580 | 580 | 284,739 | |
| Methyl Bromide | 0 | 0 | | 0 | 110 | 110 | 54,002 | |
| Methyl Chloride | 0 | 0 | | 0 | 5,500 | 5,500 | 2,700,110 | |
| Methylene Chloride | 0 | 0 | | 0 | 2,400 | 2,400 | 1,178,230 | |
| 1,1,2,2-Tetrachloroethane | 0 | 0 | | 0 | 210 | 210 | 103,095 | |
| Tetrachloroethylene | 0 | 0 | | 0 | 140 | 140 | 68,730 | |
| Toluene | 0 | 0 | | 0 | 330 | 330 | 162,007 | |
| 1,2-trans-Dichloroethylene | 0 | 0 | | 0 | 1,400 | 1,400 | 687,301 | |
| 1,1,1-Trichloroethane | 0 | 0 | | 0 | 610 | 610 | 299,467 | |
| 1,1,2-Trichloroethane | 0 | 0 | | 0 | 680 | 680 | 333,832 | |
| Trichloroethylene | 0 | 0 | | 0 | 450 | 450 | 220,918 | |
| Vinyl Chloride | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 2-Chlorophenol | 0 | 0 | | 0 | 110 | 110 | 54,002 | |
| 2,4-Dichlorophenol | 0 | 0 | | 0 | 340 | 340 | 166,916 | |
| 2,4-Dimethylphenol | 0 | 0 | | 0 | 130 | 130 | 63,821 | |

| | | | | | | | |
|-----------------------------|---|---|--|---|-------|-------|-----------|
| 4,6-Dinitro-o-Cresol | 0 | 0 | | 0 | 16 | 16.0 | 7,855 |
| 2,4-Dinitrophenol | 0 | 0 | | 0 | 130 | 130 | 63,821 |
| 2-Nitrophenol | 0 | 0 | | 0 | 1,600 | 1,600 | 785,487 |
| 4-Nitrophenol | 0 | 0 | | 0 | 470 | 470 | 230,737 |
| p-Chloro-m-Cresol | 0 | 0 | | 0 | 500 | 500 | 245,465 |
| Pentachlorophenol | 0 | 0 | | 0 | 6.731 | 6.73 | 3,304 |
| Phenol | 0 | 0 | | 0 | N/A | N/A | N/A |
| 2,4,6-Trichlorophenol | 0 | 0 | | 0 | 91 | 91.0 | 44,675 |
| Acenaphthene | 0 | 0 | | 0 | 17 | 17.0 | 8,346 |
| Anthracene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Benzidine | 0 | 0 | | 0 | 59 | 59.0 | 28,965 |
| Benzo(a)Anthracene | 0 | 0 | | 0 | 0.1 | 0.1 | 49.1 |
| Benzo(a)Pyrene | 0 | 0 | | 0 | N/A | N/A | N/A |
| 3,4-Benzofluoranthene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Benzo(k)Fluoranthene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Bis(2-Chloroethyl)Ether | 0 | 0 | | 0 | 6,000 | 6,000 | 2,945,574 |
| Bis(2-Chloroisopropyl)Ether | 0 | 0 | | 0 | N/A | N/A | N/A |
| Bis(2-Ethylhexyl)Phthalate | 0 | 0 | | 0 | 910 | 910 | 446,745 |
| 4-Bromophenyl Phenyl Ether | 0 | 0 | | 0 | 54 | 54.0 | 26,510 |
| Butyl Benzyl Phthalate | 0 | 0 | | 0 | 35 | 35.0 | 17,183 |
| 2-Chloronaphthalene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Chrysene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Dibenzo(a,h)Anthracene | 0 | 0 | | 0 | N/A | N/A | N/A |
| 1,2-Dichlorobenzene | 0 | 0 | | 0 | 160 | 160 | 78,549 |
| 1,3-Dichlorobenzene | 0 | 0 | | 0 | 69 | 69.0 | 33,874 |
| 1,4-Dichlorobenzene | 0 | 0 | | 0 | 150 | 150 | 73,639 |
| 3,3-Dichlorobenzidine | 0 | 0 | | 0 | N/A | N/A | N/A |
| Diethyl Phthalate | 0 | 0 | | 0 | 800 | 800 | 392,743 |
| Dimethyl Phthalate | 0 | 0 | | 0 | 500 | 500 | 245,465 |
| Di-n-Butyl Phthalate | 0 | 0 | | 0 | 21 | 21.0 | 10,310 |
| 2,4-Dinitrotoluene | 0 | 0 | | 0 | 320 | 320 | 157,097 |
| 2,6-Dinitrotoluene | 0 | 0 | | 0 | 200 | 200 | 98,186 |
| 1,2-Diphenylhydrazine | 0 | 0 | | 0 | 3 | 3.0 | 1,473 |
| Fluoranthene | 0 | 0 | | 0 | 40 | 40.0 | 19,637 |
| Fluorene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Hexachlorobenzene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Hexachlorobutadiene | 0 | 0 | | 0 | 2 | 2.0 | 982 |
| Hexachlorocyclopentadiene | 0 | 0 | | 0 | 1 | 1.0 | 491 |
| Hexachloroethane | 0 | 0 | | 0 | 12 | 12.0 | 5,891 |
| Indeno(1,2,3-cd)Pyrene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Isophorone | 0 | 0 | | 0 | 2,100 | 2,100 | 1,030,951 |
| Naphthalene | 0 | 0 | | 0 | 43 | 43.0 | 21,110 |
| Nitrobenzene | 0 | 0 | | 0 | 810 | 810 | 397,653 |
| n-Nitrosodimethylamine | 0 | 0 | | 0 | 3,400 | 3,400 | 1,669,159 |
| n-Nitrosodi-n-Propylamine | 0 | 0 | | 0 | N/A | N/A | N/A |

| | | | | | | | |
|------------------------|---|---|--|---|-----|------|--------|
| n-Nitrosodiphenylamine | 0 | 0 | | 0 | 59 | 59.0 | 28,985 |
| Phenanthrene | 0 | 0 | | 0 | 1 | 1.0 | 491 |
| Pyrene | 0 | 0 | | 0 | N/A | N/A | N/A |
| 1,2,4-Trichlorobenzene | 0 | 0 | | 0 | 26 | 26.0 | 12,764 |

THH CCT (min): PMF: Analysis Hardness (mg/l): Analysis pH:

| Pollutants | Stream Conc (µg/L) | Stream CV | Trib Conc (µg/L) | Fate Coef | WQC (µg/L) | WQ Obj (µg/L) | WLA (µg/L) | Comments |
|---------------------------------|--------------------|-----------|------------------|-----------|------------|---------------|------------|----------|
| Total Dissolved Solids (PWS) | 0 | 0 | | 0 | 500,000 | 500,000 | N/A | |
| Chloride (PWS) | 0 | 0 | | 0 | 250,000 | 250,000 | N/A | |
| Sulfate (PWS) | 0 | 0 | | 0 | 250,000 | 250,000 | N/A | |
| Fluoride (PWS) | 0 | 0 | | 0 | 2,000 | 2,000 | N/A | |
| Total Aluminum | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Antimony | 0 | 0 | | 0 | 5.6 | 5.6 | 2,749 | |
| Total Arsenic | 0 | 0 | | 0 | 10 | 10.0 | 4,909 | |
| Total Barium | 0 | 0 | | 0 | 2,400 | 2,400 | 1,178,230 | |
| Total Boron | 0 | 0 | | 0 | 3,100 | 3,100 | 1,521,880 | |
| Total Cadmium | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Chromium (III) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Hexavalent Chromium | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Cobalt | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Copper | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Free Cyanide | 0 | 0 | | 0 | 4 | 4.0 | 1,964 | |
| Dissolved Iron | 0 | 0 | | 0 | 300 | 300 | 147,279 | |
| Total Iron | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Lead | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Manganese | 0 | 0 | | 0 | 1,000 | 1,000 | 490,929 | |
| Total Mercury | 0 | 0 | | 0 | 0.050 | 0.05 | 24.5 | |
| Total Nickel | 0 | 0 | | 0 | 610 | 610 | 299,467 | |
| Total Phenols (Phenolics) (PWS) | 0 | 0 | | 0 | 5 | 5.0 | N/A | |
| Total Selenium | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Silver | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Thallium | 0 | 0 | | 0 | 0.24 | 0.24 | 118 | |
| Total Zinc | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Acrolein | 0 | 0 | | 0 | 3 | 3.0 | 1,473 | |
| Acrylamide | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Acrylonitrile | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Benzene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Bromoform | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Carbon Tetrachloride | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Chlorobenzene | 0 | 0 | | 0 | 100 | 100.0 | 49,093 | |
| Chlorodibromomethane | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 2-Chloroethyl Vinyl Ether | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Chloroform | 0 | 0 | | 0 | 5.7 | 5.7 | 2,798 | |

| | | | | | | | |
|-----------------------------|---|---|--|---|--------|--------|-----------|
| Dichlorobromomethane | 0 | 0 | | 0 | N/A | N/A | N/A |
| 1,2-Dichloroethane | 0 | 0 | | 0 | N/A | N/A | N/A |
| 1,1-Dichloroethylene | 0 | 0 | | 0 | 33 | 33.0 | 16,201 |
| 1,2-Dichloropropane | 0 | 0 | | 0 | N/A | N/A | N/A |
| 1,3-Dichloropropylene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Ethylbenzene | 0 | 0 | | 0 | 68 | 68.0 | 33,383 |
| Methyl Bromide | 0 | 0 | | 0 | 100 | 100.0 | 49,093 |
| Methyl Chloride | 0 | 0 | | 0 | N/A | N/A | N/A |
| Methylene Chloride | 0 | 0 | | 0 | N/A | N/A | N/A |
| 1,1,2,2-Tetrachloroethane | 0 | 0 | | 0 | N/A | N/A | N/A |
| Tetrachloroethylene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Toluene | 0 | 0 | | 0 | 57 | 57.0 | 27,983 |
| 1,2-trans-Dichloroethylene | 0 | 0 | | 0 | 100 | 100.0 | 49,093 |
| 1,1,1-Trichloroethane | 0 | 0 | | 0 | 10,000 | 10,000 | 4,909,291 |
| 1,1,2-Trichloroethane | 0 | 0 | | 0 | N/A | N/A | N/A |
| Trichloroethylene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Vinyl Chloride | 0 | 0 | | 0 | N/A | N/A | N/A |
| 2-Chlorophenol | 0 | 0 | | 0 | 30 | 30.0 | 14,728 |
| 2,4-Dichlorophenol | 0 | 0 | | 0 | 10 | 10.0 | 4,909 |
| 2,4-Dimethylphenol | 0 | 0 | | 0 | 100 | 100.0 | 49,093 |
| 4,6-Dinitro-o-Cresol | 0 | 0 | | 0 | 2 | 2.0 | 982 |
| 2,4-Dinitrophenol | 0 | 0 | | 0 | 10 | 10.0 | 4,909 |
| 2-Nitrophenol | 0 | 0 | | 0 | N/A | N/A | N/A |
| 4-Nitrophenol | 0 | 0 | | 0 | N/A | N/A | N/A |
| p-Chloro-m-Cresol | 0 | 0 | | 0 | N/A | N/A | N/A |
| Pentachlorophenol | 0 | 0 | | 0 | N/A | N/A | N/A |
| Phenol | 0 | 0 | | 0 | 4,000 | 4,000 | 1,963,716 |
| 2,4,6-Trichlorophenol | 0 | 0 | | 0 | N/A | N/A | N/A |
| Acenaphthene | 0 | 0 | | 0 | 70 | 70.0 | 34,385 |
| Anthracene | 0 | 0 | | 0 | 300 | 300 | 147,279 |
| Benzidine | 0 | 0 | | 0 | N/A | N/A | N/A |
| Benzo(a)Anthracene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Benzo(a)Pyrene | 0 | 0 | | 0 | N/A | N/A | N/A |
| 3,4-Benzofluoranthene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Benzo(k)Fluoranthene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Bis(2-Chloroethyl)Ether | 0 | 0 | | 0 | N/A | N/A | N/A |
| Bis(2-Chloroisopropyl)Ether | 0 | 0 | | 0 | 200 | 200 | 98,186 |
| Bis(2-Ethylhexyl)Phthalate | 0 | 0 | | 0 | N/A | N/A | N/A |
| 4-Bromophenyl Phenyl Ether | 0 | 0 | | 0 | N/A | N/A | N/A |
| Butyl Benzyl Phthalate | 0 | 0 | | 0 | 0.1 | 0.1 | 49.1 |
| 2-Chloronaphthalene | 0 | 0 | | 0 | 800 | 800 | 392,743 |
| Chrysene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Dibenzo(a,h)Anthracene | 0 | 0 | | 0 | N/A | N/A | N/A |
| 1,2-Dichlorobenzene | 0 | 0 | | 0 | 1,000 | 1,000 | 490,929 |
| 1,3-Dichlorobenzene | 0 | 0 | | 0 | 7 | 7.0 | 3,437 |

| | | | | | | | | |
|---------------------------|---|---|--|---|-------|-------|---------|--|
| 1,4-Dichlorobenzene | 0 | 0 | | 0 | 300 | 300 | 147,279 | |
| 3,3-Dichlorobenzidine | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Diethyl Phthalate | 0 | 0 | | 0 | 600 | 600 | 294,557 | |
| Dimethyl Phthalate | 0 | 0 | | 0 | 2,000 | 2,000 | 981,858 | |
| Di-n-Butyl Phthalate | 0 | 0 | | 0 | 20 | 20.0 | 9,819 | |
| 2,4-Dinitrotoluene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 2,6-Dinitrotoluene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 1,2-Diphenylhydrazine | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Fluoranthene | 0 | 0 | | 0 | 20 | 20.0 | 9,819 | |
| Fluorene | 0 | 0 | | 0 | 50 | 50.0 | 24,546 | |
| Hexachlorobenzene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Hexachlorobutadiene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Hexachlorocyclopentadiene | 0 | 0 | | 0 | 4 | 4.0 | 1,964 | |
| Hexachloroethane | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Indeno(1,2,3-cd)Pyrene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Isophorone | 0 | 0 | | 0 | 34 | 34.0 | 16,692 | |
| Naphthalene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Nitrobenzene | 0 | 0 | | 0 | 10 | 10.0 | 4,909 | |
| n-Nitrosodimethylamine | 0 | 0 | | 0 | N/A | N/A | N/A | |
| n-Nitrosodi-n-Propylamine | 0 | 0 | | 0 | N/A | N/A | N/A | |
| n-Nitrosodiphenylamine | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Phenanthrene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Pyrene | 0 | 0 | | 0 | 20 | 20.0 | 9,819 | |
| 1,2,4-Trichlorobenzene | 0 | 0 | | 0 | 0.07 | 0.07 | 34.4 | |

CRL CCT (min): PMF: Analysis Hardness (mg/l): Analysis pH:

| Pollutants | Stream Conc (µg/L) | Stream CV | Trib Conc (µg/L) | Fate Coef | WQC (µg/L) | WQ Obj (µg/L) | WLA (µg/L) | Comments |
|------------------------------|--------------------|-----------|------------------|-----------|------------|---------------|------------|----------|
| Total Dissolved Solids (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Chloride (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Sulfate (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Fluoride (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Aluminum | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Antimony | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Arsenic | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Barium | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Boron | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Cadmium | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Chromium (III) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Hexavalent Chromium | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Cobalt | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Copper | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Free Cyanide | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Dissolved Iron | 0 | 0 | | 0 | N/A | N/A | N/A | |

| | | | | | | | |
|---------------------------------|---|---|--|---|------|------|--------|
| Total Iron | 0 | 0 | | 0 | N/A | N/A | N/A |
| Total Lead | 0 | 0 | | 0 | N/A | N/A | N/A |
| Total Manganese | 0 | 0 | | 0 | N/A | N/A | N/A |
| Total Mercury | 0 | 0 | | 0 | N/A | N/A | N/A |
| Total Nickel | 0 | 0 | | 0 | N/A | N/A | N/A |
| Total Phenols (Phenolics) (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A |
| Total Selenium | 0 | 0 | | 0 | N/A | N/A | N/A |
| Total Silver | 0 | 0 | | 0 | N/A | N/A | N/A |
| Total Thallium | 0 | 0 | | 0 | N/A | N/A | N/A |
| Total Zinc | 0 | 0 | | 0 | N/A | N/A | N/A |
| Acrolein | 0 | 0 | | 0 | N/A | N/A | N/A |
| Acrylamide | 0 | 0 | | 0 | 0.07 | 0.07 | 121 |
| Acrylonitrile | 0 | 0 | | 0 | 0.06 | 0.06 | 103 |
| Benzene | 0 | 0 | | 0 | 0.58 | 0.58 | 1,000 |
| Bromoform | 0 | 0 | | 0 | 7 | 7.0 | 12,072 |
| Carbon Tetrachloride | 0 | 0 | | 0 | 0.4 | 0.4 | 690 |
| Chlorobenzene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Chlorodibromomethane | 0 | 0 | | 0 | 0.8 | 0.8 | 1,380 |
| 2-Chloroethyl Vinyl Ether | 0 | 0 | | 0 | N/A | N/A | N/A |
| Chloroform | 0 | 0 | | 0 | N/A | N/A | N/A |
| Dichlorobromomethane | 0 | 0 | | 0 | 0.95 | 0.95 | 1,638 |
| 1,2-Dichloroethane | 0 | 0 | | 0 | 9.9 | 9.9 | 17,074 |
| 1,1-Dichloroethylene | 0 | 0 | | 0 | N/A | N/A | N/A |
| 1,2-Dichloropropane | 0 | 0 | | 0 | 0.9 | 0.9 | 1,552 |
| 1,3-Dichloropropylene | 0 | 0 | | 0 | 0.27 | 0.27 | 466 |
| Ethylbenzene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Methyl Bromide | 0 | 0 | | 0 | N/A | N/A | N/A |
| Methyl Chloride | 0 | 0 | | 0 | N/A | N/A | N/A |
| Methylene Chloride | 0 | 0 | | 0 | 20 | 20.0 | 34,492 |
| 1,1,2,2-Tetrachloroethane | 0 | 0 | | 0 | 0.2 | 0.2 | 345 |
| Tetrachloroethylene | 0 | 0 | | 0 | 10 | 10.0 | 17,246 |
| Toluene | 0 | 0 | | 0 | N/A | N/A | N/A |
| 1,2-trans-Dichloroethylene | 0 | 0 | | 0 | N/A | N/A | N/A |
| 1,1,1-Trichloroethane | 0 | 0 | | 0 | N/A | N/A | N/A |
| 1,1,2-Trichloroethane | 0 | 0 | | 0 | 0.55 | 0.55 | 949 |
| Trichloroethylene | 0 | 0 | | 0 | 0.6 | 0.6 | 1,035 |
| Vinyl Chloride | 0 | 0 | | 0 | 0.02 | 0.02 | 34.5 |
| 2-Chlorophenol | 0 | 0 | | 0 | N/A | N/A | N/A |
| 2,4-Dichlorophenol | 0 | 0 | | 0 | N/A | N/A | N/A |
| 2,4-Dimethylphenol | 0 | 0 | | 0 | N/A | N/A | N/A |
| 4,6-Dinitro-o-Cresol | 0 | 0 | | 0 | N/A | N/A | N/A |
| 2,4-Dinitrophenol | 0 | 0 | | 0 | N/A | N/A | N/A |
| 2-Nitrophenol | 0 | 0 | | 0 | N/A | N/A | N/A |
| 4-Nitrophenol | 0 | 0 | | 0 | N/A | N/A | N/A |
| p-Chloro-m-Cresol | 0 | 0 | | 0 | N/A | N/A | N/A |

| | | | | | | | | |
|-----------------------------|---|---|--|---|---------|---------|-------|--|
| Pentachlorophenol | 0 | 0 | | 0 | 0.030 | 0.03 | 51.7 | |
| Phenol | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 2,4,6-Trichlorophenol | 0 | 0 | | 0 | 1.5 | 1.5 | 2,587 | |
| Acenaphthene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Anthracene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Benidine | 0 | 0 | | 0 | 0.0001 | 0.0001 | 0.17 | |
| Benzo(a)Anthracene | 0 | 0 | | 0 | 0.001 | 0.001 | 1.72 | |
| Benzo(a)Pyrene | 0 | 0 | | 0 | 0.0001 | 0.0001 | 0.17 | |
| 3,4-Benzofluoranthene | 0 | 0 | | 0 | 0.001 | 0.001 | 1.72 | |
| Benzo(k)Fluoranthene | 0 | 0 | | 0 | 0.01 | 0.01 | 17.2 | |
| Bis(2-Chloroethyl)Ether | 0 | 0 | | 0 | 0.03 | 0.03 | 51.7 | |
| Bis(2-Chloroisopropyl)Ether | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Bis(2-Ethylhexyl)Phthalate | 0 | 0 | | 0 | 0.32 | 0.32 | 552 | |
| 4-Bromophenyl Phenyl Ether | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Butyl Benzyl Phthalate | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 2-Chloronaphthalene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Chrysene | 0 | 0 | | 0 | 0.12 | 0.12 | 207 | |
| Dibenzo(a,h)Anthracene | 0 | 0 | | 0 | 0.0001 | 0.0001 | 0.17 | |
| 1,2-Dichlorobenzene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 1,3-Dichlorobenzene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 1,4-Dichlorobenzene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 3,3-Dichlorobenzidine | 0 | 0 | | 0 | 0.05 | 0.05 | 88.2 | |
| Diethyl Phthalate | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Dimethyl Phthalate | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Di-n-Butyl Phthalate | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 2,4-Dinitrotoluene | 0 | 0 | | 0 | 0.05 | 0.05 | 88.2 | |
| 2,6-Dinitrotoluene | 0 | 0 | | 0 | 0.05 | 0.05 | 86.2 | |
| 1,2-Diphenylhydrazine | 0 | 0 | | 0 | 0.03 | 0.03 | 51.7 | |
| Fluoranthene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Fluorene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Hexachlorobenzene | 0 | 0 | | 0 | 0.00008 | 0.00008 | 0.14 | |
| Hexachlorobutadiene | 0 | 0 | | 0 | 0.01 | 0.01 | 17.2 | |
| Hexachlorocyclopentadiene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Hexachloroethane | 0 | 0 | | 0 | 0.1 | 0.1 | 172 | |
| Indeno(1,2,3-cd)Pyrene | 0 | 0 | | 0 | 0.001 | 0.001 | 1.72 | |
| Isophorone | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Naphthalene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Nitrobenzene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| n-Nitrosodimethylamine | 0 | 0 | | 0 | 0.0007 | 0.0007 | 1.21 | |
| n-Nitrosodi-n-Propylamine | 0 | 0 | | 0 | 0.005 | 0.005 | 8.62 | |
| n-Nitrosodiphenylamine | 0 | 0 | | 0 | 3.3 | 3.3 | 5,691 | |
| Phenanthrene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Pyrene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 1,2,4-Trichlorobenzene | 0 | 0 | | 0 | N/A | N/A | N/A | |

Recommended WQBELs & Monitoring Requirements

No. Samples/Month: **4**

| Pollutants | Mass Limits | | Concentration Limits | | | | Governing WQBEL | WQBEL Basis | Comments |
|------------|---------------|---------------|----------------------|-----|------|-------|-----------------|-------------|----------|
| | AML (lbs/day) | MDL (lbs/day) | AML | MDL | IMAX | Units | | | |
| | | | | | | | | | |

Other Pollutants without Limits or Monitoring

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., <= Target QL).

| Pollutants | Governing WQBEL | Units | Comments |
|---------------------------------|-----------------|-------|----------------------------|
| Total Dissolved Solids (PWS) | N/A | N/A | PWS Not Applicable |
| Chloride (PWS) | N/A | N/A | PWS Not Applicable |
| Bromide | N/A | N/A | No WQS |
| Sulfate (PWS) | N/A | N/A | PWS Not Applicable |
| Fluoride (PWS) | N/A | N/A | PWS Not Applicable |
| Total Aluminum | 34,475 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Antimony | 2,749 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Arsenic | N/A | N/A | Discharge Conc < TQL |
| Total Barium | 965,297 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Beryllium | N/A | N/A | No WQS |
| Total Boron | 372,329 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Cadmium | 108 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Chromium (III) | 42,833 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Hexavalent Chromium | 749 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Cobalt | 4,367 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Copper | 706 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Free Cyanide | 1,011 | µg/L | Discharge Conc ≤ 25% WQBEL |
| Dissolved Iron | 147,279 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Iron | 768,512 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Lead | 1,592 | µg/L | Discharge Conc < TQL |
| Total Manganese | 490,929 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Mercury | 24.5 | µg/L | Discharge Conc < TQL |
| Total Nickel | 23,447 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Phenols (Phenolics) (PWS) | | µg/L | PWS Not Applicable |
| Total Selenium | 2,449 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Silver | 206 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Thallium | 118 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Zinc | 5,989 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Molybdenum | N/A | N/A | No WQS |
| Acrolein | 138 | µg/L | Discharge Conc ≤ 25% WQBEL |

| | | | |
|----------------------------|-----------|------|----------------------------|
| Acrylamide | 121 | µg/L | Discharge Conc ≤ 25% WQBEL |
| Acrylonitrile | 103 | µg/L | Discharge Conc < TQL |
| Benzene | 1,000 | µg/L | Discharge Conc ≤ 25% WQBEL |
| Bromoform | 12,072 | µg/L | Discharge Conc ≤ 25% WQBEL |
| Carbon Tetrachloride | 690 | µg/L | Discharge Conc ≤ 25% WQBEL |
| Chlorobenzene | 49,093 | µg/L | Discharge Conc ≤ 25% WQBEL |
| Chlorodibromomethane | 1,380 | µg/L | Discharge Conc ≤ 25% WQBEL |
| Chloroethane | N/A | N/A | No WQS |
| 2-Chloroethyl Vinyl Ether | 827,398 | µg/L | Discharge Conc < TQL |
| Chloroform | 2,798 | µg/L | Discharge Conc ≤ 25% WQBEL |
| Dichlorobromomethane | 1,638 | µg/L | Discharge Conc ≤ 25% WQBEL |
| 1,1-Dichloroethane | N/A | N/A | No WQS |
| 1,2-Dichloroethane | 17,074 | µg/L | Discharge Conc ≤ 25% WQBEL |
| 1,1-Dichloroethylene | 16,201 | µg/L | Discharge Conc ≤ 25% WQBEL |
| 1,2-Dichloropropane | 1,552 | µg/L | Discharge Conc ≤ 25% WQBEL |
| 1,3-Dichloropropylene | 466 | µg/L | Discharge Conc ≤ 25% WQBEL |
| 1,4-Dioxane | N/A | N/A | No WQS |
| Ethylbenzene | 33,383 | µg/L | Discharge Conc ≤ 25% WQBEL |
| Methyl Bromide | 25,282 | µg/L | Discharge Conc ≤ 25% WQBEL |
| Methyl Chloride | 1,287,063 | µg/L | Discharge Conc ≤ 25% WQBEL |
| Methylene Chloride | 34,492 | µg/L | Discharge Conc ≤ 25% WQBEL |
| 1,1,2,2-Tetrachloroethane | 345 | µg/L | Discharge Conc ≤ 25% WQBEL |
| Tetrachloroethylene | 17,246 | µg/L | Discharge Conc ≤ 25% WQBEL |
| Toluene | 27,983 | µg/L | Discharge Conc ≤ 25% WQBEL |
| 1,2-trans-Dichloroethylene | 49,093 | µg/L | Discharge Conc ≤ 25% WQBEL |
| 1,1,1-Trichloroethane | 137,900 | µg/L | Discharge Conc ≤ 25% WQBEL |
| 1,1,2-Trichloroethane | 949 | µg/L | Discharge Conc ≤ 25% WQBEL |
| Trichloroethylene | 1,035 | µg/L | Discharge Conc ≤ 25% WQBEL |
| Vinyl Chloride | 34.5 | µg/L | Discharge Conc ≤ 25% WQBEL |
| 2-Chlorophenol | 14,728 | µg/L | Discharge Conc < TQL |
| 2,4-Dichlorophenol | 4,909 | µg/L | Discharge Conc < TQL |
| 2,4-Dimethylphenol | 30,338 | µg/L | Discharge Conc < TQL |
| 4,6-Dinitro-o-Cresol | 982 | µg/L | Discharge Conc < TQL |
| 2,4-Dinitrophenol | 4,909 | µg/L | Discharge Conc < TQL |
| 2-Nitrophenol | 367,732 | µg/L | Discharge Conc < TQL |
| 4-Nitrophenol | 105,723 | µg/L | Discharge Conc < TQL |
| p-Chloro-m-Cresol | 7,355 | µg/L | Discharge Conc < TQL |
| Pentachlorophenol | 51.7 | µg/L | Discharge Conc < TQL |
| Phenol | 1,963,716 | µg/L | Discharge Conc < TQL |
| 2,4,6-Trichlorophenol | 2,587 | µg/L | Discharge Conc < TQL |
| Acenaphthene | 3,815 | µg/L | Discharge Conc < TQL |
| Acenaphthylene | N/A | N/A | No WQS |
| Anthracene | 147,279 | µg/L | Discharge Conc < TQL |
| Benzidine | 0.17 | µg/L | Discharge Conc < TQL |
| Benzo(a)Anthracene | 1.72 | µg/L | Discharge Conc < TQL |

| | | | |
|-----------------------------|---------|------|----------------------------|
| Benzo(a)Pyrene | 0.17 | µg/L | Discharge Conc < TQL |
| 3,4-Benzofluoranthene | 1.72 | µg/L | Discharge Conc < TQL |
| Benzo(ghi)Perylene | N/A | N/A | No WQS |
| Benzo(k)Fluoranthene | 17.2 | µg/L | Discharge Conc < TQL |
| Bis(2-Chloroethoxy)Methane | N/A | N/A | No WQS |
| Bis(2-Chloroethyl)Ether | 51.7 | µg/L | Discharge Conc < TQL |
| Bis(2-Chloroisopropyl)Ether | 98,186 | µg/L | Discharge Conc < TQL |
| Bis(2-Ethylhexyl)Phthalate | 552 | µg/L | Discharge Conc < TQL |
| 4-Bromophenyl Phenyl Ether | 12,411 | µg/L | Discharge Conc < TQL |
| Butyl Benzyl Phthalate | 49.1 | µg/L | Discharge Conc < TQL |
| 2-Chloronaphthalene | 392,743 | µg/L | Discharge Conc < TQL |
| 4-Chlorophenyl Phenyl Ether | N/A | N/A | No WQS |
| Chrysene | 207 | µg/L | Discharge Conc < TQL |
| Dibenzo(a,h)Anthracene | 0.17 | µg/L | Discharge Conc < TQL |
| 1,2-Dichlorobenzene | 37,693 | µg/L | Discharge Conc ≤ 25% WQBEL |
| 1,3-Dichlorobenzene | 3,437 | µg/L | Discharge Conc ≤ 25% WQBEL |
| 1,4-Dichlorobenzene | 33,556 | µg/L | Discharge Conc ≤ 25% WQBEL |
| 3,3-Dichlorobenzidine | 86.2 | µg/L | Discharge Conc < TQL |
| Diethyl Phthalate | 183,866 | µg/L | Discharge Conc < TQL |
| Dimethyl Phthalate | 114,916 | µg/L | Discharge Conc < TQL |
| Di-n-Butyl Phthalate | 5,056 | µg/L | Discharge Conc < TQL |
| 2,4-Dinitrotoluene | 86.2 | µg/L | Discharge Conc < TQL |
| 2,6-Dinitrotoluene | 86.2 | µg/L | Discharge Conc < TQL |
| Di-n-Octyl Phthalate | N/A | N/A | No WQS |
| 1,2-Diphenylhydrazine | 51.7 | µg/L | Discharge Conc < TQL |
| Fluoranthene | 9,193 | µg/L | Discharge Conc < TQL |
| Fluorene | 24,546 | µg/L | Discharge Conc < TQL |
| Hexachlorobenzene | 0.14 | µg/L | Discharge Conc < TQL |
| Hexachlorobutadiene | 17.2 | µg/L | Discharge Conc ≤ 25% WQBEL |
| Hexachlorocyclopentadiene | 230 | µg/L | Discharge Conc < TQL |
| Hexachloroethane | 172 | µg/L | Discharge Conc < TQL |
| Indeno(1,2,3-cd)Pyrene | 1.72 | µg/L | Discharge Conc < TQL |
| Isophorone | 16,692 | µg/L | Discharge Conc < TQL |
| Naphthalene | 6,435 | µg/L | Discharge Conc ≤ 25% WQBEL |
| Nitrobenzene | 4,909 | µg/L | Discharge Conc < TQL |
| n-Nitrosodimethylamine | 1.21 | µg/L | Discharge Conc < TQL |
| n-Nitrosodi-n-Propylamine | 8.62 | µg/L | Discharge Conc < TQL |
| n-Nitrosodiphenylamine | 5,691 | µg/L | Discharge Conc < TQL |
| Phenanthrene | 230 | µg/L | Discharge Conc < TQL |
| Pyrene | 9,819 | µg/L | Discharge Conc < TQL |
| 1,2,4-Trichlorobenzene | 34.4 | µg/L | Discharge Conc ≤ 25% WQBEL |

Attachment D:
Outfall 001 TRC Evaluation

TRC EVALUATION

| 530 | = Q stream (cfs) | 0.5 | = CV Daily | |
|----------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------|--------------------------------------|---------------------|
| 0.67 | = Q discharge (MGD) | 0.5 | = CV Hourly | |
| 4 | = no. samples | 0.25 | = AFC_Partial Mix Factor | |
| 0.3 | = Chlorine Demand of Stream | 0.25 | = CFC_Partial Mix Factor | |
| 0 | = Chlorine Demand of Discharge | 15 | = AFC_Criteria Compliance Time (min) | |
| 0.5 | = BAT/BPJ Value | 720 | = CFC_Criteria Compliance Time (min) | |
| | = %Factor of Safety (FOS) | | =Decay Coefficient (K) | |
| Source | Reference | AFC Calculations | Reference | CFC Calculations |
| TRC | 1.3.2.iii | WLA_afc = 40.798 | 1.3.2.iii | WLA_cfc = 39.768 |
| PENTOXSD TRG | 5.1a | LTAMULT_afc = 0.373 | 5.1c | LTAMULT_cfc = 0.581 |
| PENTOXSD TRG | 5.1b | LTA_afc= 15.202 | 5.1d | LTA_cfc = 23.119 |
| Source | Effluent Limit Calculations | | | |
| PENTOXSD TRG | 5.1f | AML_MULT = 1.720 | | |
| PENTOXSD TRG | 5.1g | AVG_MON_LIMIT (mg/l) = 0.500 | BAT/BPJ | |
| | | INST_MAX_LIMIT (mg/l) = 1.170 | | |
| WLA_afc | $(.019/e^{-k \cdot AFC_tc}) + [(AFC_Yc \cdot Qs \cdot .019 / Qd \cdot e^{-k \cdot AFC_tc}) \dots + Xd + (AFC_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$ | | | |
| LTAMULT_afc | $EXP((0.5 \cdot LN(cvh^2 + 1)) - 2.326 \cdot LN(cvh^2 + 1)^{0.5})$ | | | |
| LTA_afc | wla_afc * LTAMULT_afc | | | |
| WLA_cfc | $(.011/e^{-k \cdot CFC_tc}) + [(CFC_Yc \cdot Qs \cdot .011 / Qd \cdot e^{-k \cdot CFC_tc}) \dots + Xd + (CFC_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$ | | | |
| LTAMULT_cfc | $EXP((0.5 \cdot LN(cvd^2 / no_samples + 1)) - 2.326 \cdot LN(cvd^2 / no_samples + 1)^{0.5})$ | | | |
| LTA_cfc | wla_cfc * LTAMULT_cfc | | | |
| AML_MULT | $EXP(2.326 \cdot LN((cvd^2 / no_samples + 1)^{0.5}) - 0.5 \cdot LN(cvd^2 / no_samples + 1))$ | | | |
| AVG_MON_LIMIT | MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc) * AML_MULT) | | | |
| INST_MAX_LIMIT | 1.5 * ((av_mon_limit / AML_MULT) / LTAMULT_afc) | | | |

Attachment E:

Outfall 001 Thermal Discharge Evaluation

| | | | | | | | |
|------------------------------------------------------------------------------------------------------------------|-----------------------------|-------------------------------|------------------------------|----------------------------|----------------------------------|----------------------------------|------------------------------------|
| Facility: Fayette Energy Facility | | | | | | | |
| Permit Number: PA0218863 | | | | | | | PMF |
| Stream Name: Monongahela River | | | | | | | 1.00 |
| Analyst/Engineer: Adam Olesnanik | | | | | | | |
| Stream Q7-10 (cfs): 530 | | | | | | | |
| | | | | | | | |
| Facility Flows | | | | | Stream Flows | | |
| | Intake (Stream) (MGD) | Intake (External) (MGD) | Consumptive Loss (MGD) | Discharge Flow (MGD) | Upstream Stream Flow (cfs) | Adjusted Stream Flow (cfs) | Downstream Stream Flow (cfs) |
| Jan 1-31 | 8.1 | 0 | 7.127 | 0.973 | 1696.00 | 1683.47 | 1684.97 |
| Feb 1-29 | 8.1 | 0 | 7.127 | 0.973 | 1855.00 | 1842.47 | 1843.97 |
| Mar 1-31 | 8.1 | 0 | 7.127 | 0.973 | 3710.00 | 3697.47 | 3698.97 |
| Apr 1-15 | 8.1 | 0 | 7.127 | 0.973 | 4929.00 | 4916.47 | 4917.97 |
| Apr 16-30 | 8.1 | 0 | 7.127 | 0.973 | 4929.00 | 4916.47 | 4917.97 |
| May 1-15 | 8.1 | 0 | 7.127 | 0.973 | 2703.00 | 2690.47 | 2691.97 |
| May 16-30 | 8.1 | 0 | 7.127 | 0.973 | 2703.00 | 2690.47 | 2691.97 |
| Jun 1-15 | 8.1 | 0 | 7.127 | 0.973 | 1590.00 | 1577.47 | 1578.97 |
| Jun 16-30 | 8.1 | 0 | 7.127 | 0.973 | 1590.00 | 1577.47 | 1578.97 |
| Jul 1-31 | 8.1 | 0 | 7.127 | 0.973 | 901.00 | 888.47 | 889.97 |
| Aug 1-15 | 8.1 | 0 | 7.127 | 0.973 | 742.00 | 729.47 | 730.97 |
| Aug 16-31 | 8.1 | 0 | 7.127 | 0.973 | 742.00 | 729.47 | 730.97 |
| Sep 1-15 | 8.1 | 0 | 7.127 | 0.973 | 583.00 | 570.47 | 571.97 |
| Sep 16-30 | 8.1 | 0 | 7.127 | 0.973 | 583.00 | 570.47 | 571.97 |
| Oct 1-15 | 8.1 | 0 | 7.127 | 0.973 | 636.00 | 623.47 | 624.97 |
| Oct 16-31 | 8.1 | 0 | 7.127 | 0.973 | 636.00 | 623.47 | 624.97 |
| Nov 1-15 | 8.1 | 0 | 7.127 | 0.973 | 848.00 | 835.47 | 836.97 |
| Nov 16-30 | 8.1 | 0 | 7.127 | 0.973 | 848.00 | 835.47 | 836.97 |
| Dec 1-31 | 8.1 | 0 | 7.127 | 0.973 | 1272.00 | 1259.47 | 1260.97 |
| Please forward all comments to Tom Starosta at 717-787-4317, tstarosta@state.pa.us. | | | | | | | |
| Version 2.0 -- 07/01/2005 Reference: Implementation Guidance for Temperature Criteria, DEP-ID: 391-2000-017 | | | | | | | |
| NOTE: The user can only edit fields that are blue. | | | | | | | |
| NOTE: MGD x 1.547 = cfs. | | | | | | | |

**NPDES Permit Fact Sheet
Fayette Energy Facility**


NPDES Permit No. PA0218863

| | | | | | | | | |
|------------------------|--------------------------------|---------------------|---------------------|---------------------|--|--------------------------|--------------------------|--|
| Facility: | Fayette Energy Facility | | | | | | | |
| Permit Number: | PA0218863 | | | | | | | |
| Stream: | Monongahela River | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | WWF Criteria | CWF Criteria | TSF Criteria | 316 Criteria | | Q7-10 Multipliers | Q7-10 Multipliers | |
| | (°F) | (°F) | (°F) | (°F) | | (Used in Analysis) | (Default - Info Only) | |
| Jan 1-31 | 40 | 38 | 40 | 0 | | 3.2 | 3.2 | |
| Feb 1-29 | 40 | 38 | 40 | 0 | | 3.5 | 3.5 | |
| Mar 1-31 | 46 | 42 | 46 | 0 | | 7 | 7 | |
| Apr 1-15 | 52 | 48 | 52 | 0 | | 9.3 | 9.3 | |
| Apr 16-30 | 58 | 52 | 58 | 0 | | 9.3 | 9.3 | |
| May 1-15 | 64 | 54 | 64 | 0 | | 5.1 | 5.1 | |
| May 16-30 | 72 | 58 | 68 | 0 | | 5.1 | 5.1 | |
| Jun 1-15 | 80 | 60 | 70 | 0 | | 3 | 3 | |
| Jun 16-30 | 84 | 64 | 72 | 0 | | 3 | 3 | |
| Jul 1-31 | 87 | 66 | 74 | 0 | | 1.7 | 1.7 | |
| Aug 1-15 | 87 | 66 | 80 | 0 | | 1.4 | 1.4 | |
| Aug 16-31 | 87 | 66 | 87 | 0 | | 1.4 | 1.4 | |
| Sep 1-15 | 84 | 64 | 84 | 0 | | 1.1 | 1.1 | |
| Sep 16-30 | 78 | 60 | 78 | 0 | | 1.1 | 1.1 | |
| Oct 1-15 | 72 | 54 | 72 | 0 | | 1.2 | 1.2 | |
| Oct 16-31 | 66 | 50 | 66 | 0 | | 1.2 | 1.2 | |
| Nov 1-15 | 58 | 46 | 58 | 0 | | 1.6 | 1.6 | |
| Nov 16-30 | 50 | 42 | 50 | 0 | | 1.6 | 1.6 | |
| Dec 1-31 | 42 | 40 | 42 | 0 | | 2.4 | 2.4 | |
| | | | | | | | | |
| | | | | | | | | |
| NOTES: | | | | | | | | |
| WWF= Warm water fishes | | | | | | | | |
| CWF= Cold water fishes | | | | | | | | |
| TSF= Trout stocking | | | | | | | | |

Attachment F:
Site Flow Diagram

FAYETTE ENERGY FACILITY - LINE DRAWING AND WATER BALANCE OF FLOW THROUGH THE FACILITY

Case: Historic Summer Maximum Full Duct Firing with Chiller on; Conditions: 103°F, 22.4% RH



- Notes:
1. All numbers are in GPM unless otherwise noted.
 2. Clarifier chemical feed system used as needed.
 3. "HRSG" means Heat Recovery Steam Generators.
 4. HRSG vent and flash losses based upon frequent startups and shutdowns.

Attachment G:

Site Plan

