

Application Type Renewal
Facility Type Municipal
Major / Minor Minor

NPDES PERMIT FACT SHEET INDIVIDUAL SEWAGE

Application No. PA0221449
APS ID 1061683
Authorization ID 1393103

Applicant and Facility Information

Applicant Name <u>Buffalo Township Municipal Authority</u>	Facility Name <u>Buffalo Township Municipal Authority STP</u>
Applicant Address <u>707 South Pike Road</u> <u>Sarver, PA 16055-9201</u>	Facility Address <u>161 Monroe Road</u> <u>Sarver, PA 16055</u>
Applicant Contact <u>Kristine Donaldson</u>	Facility Contact <u>Kristine Donaldson</u>
Applicant Phone <u>(724) 383-2259 (mabt@zoominternet.net)</u>	Facility Phone <u></u>
Client ID <u>62915</u>	Site ID <u>262419</u>
Ch 94 Load Status <u>Not Overloaded</u>	Municipality <u>Buffalo Township</u>
Connection Status <u>No Limitations</u>	County <u>Butler</u>
Date Application Received <u>April 19, 2022</u>	EPA Waived? <u>Yes</u>
Date Application Accepted <u>May 2, 2022</u>	If No, Reason <u></u>
Purpose of Application <u>Renewal of a NPDES Permit for an existing discharge of treated sewage.</u>	

Summary of Review

This is a publicly operated sewage treatment plant which services parts of Buffalo and Winfield Townships, Butler County. In addition, the facility has, and plans to continue accepting hauled in WTP filter backwash sludge.

No changes to discharge quantity or quality are proposed as part of this permit renewal.

There are currently five open violations listed in EFACTS for this client, all from the Safe Drinking Water Program (12/28/2023). *The permittee will be notified of the open violations in the Draft Permit Cover Letter and given an opportunity to address the violations prior to final permit issuance. CWY 12/29/2023*

Sludge use and disposal description and location(s): Dewatered sludge is hauled to Seneca Landfill for disposal.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		Adam J. Pesek Adam J. Pesek, E.I.T. / Project Manager	December 28, 2023
X		Chad W. Yurisc Chad W. Yurisc, P.E. / Environmental Engineer Manager	12/29/2023

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	0.89
Latitude	40° 42' 19"	Longitude	-79° 41' 38"
Quad Name	Freeport	Quad Code	1708
Wastewater Description: Treated domestic sewage			
Receiving Waters	Buffalo Creek (TSF)	Stream Code	42557
NHD Com ID	123971892	RMI	3.42
Drainage Area	167.65	Yield (cfs/mi ²)	0.04284
Q ₇₋₁₀ Flow (cfs)	7.182	Q ₇₋₁₀ Basis	USGS #03049000 ('77-'11)
Elevation (ft)	778	Slope (ft/ft)	0.00183
Watershed No.	18-F	Chapter 93 Class.	TSF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Impaired		
Cause(s) of Impairment	CAUSE UNKNOWN		
Source(s) of Impairment	SOURCE UNKNOWN		
TMDL Status		Name	
Background/Ambient Data		Data Source	
pH (SU)	8.3		DEP 4/21/09 macroinvertebrate sample taken upstream
Temperature (°C)	20		Default
Hardness (mg/L)	108		7/13/17 upstream sample taken by permittee.
Other:			
Nearest Downstream Public Water Supply Intake	Harrison Twp. Water Authority		
PWS Waters	Allegheny River	Flow at Intake (cfs)	2390
PWS RMI	24.2	Distance from Outfall (mi)	8.0

Changes Since Last Permit Issuance: None

Other Comments:

Treatment Facility Summary				
Treatment Facility Name: Buffalo Township Municipal Authority STP				
WQM Permit No.		Issuance Date		
1096406 A-1		5/16/2012		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary with Ammonia Reduction	Activated Sludge	Ultraviolet	0.89
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.89	1782	Not Overloaded	Aerobic Digestion	Landfill

Changes Since Last Permit Issuance: None

Other Comments: Treatment consists of influent pump station, aeration (4 tanks), settling (2 tanks), UV disinfection, sludge holding / aerobic digestion and sludge press.

Compliance History	
Summary of DMRs:	There have been ten effluent limit excursions since September 2018.
Summary of Inspections:	The last facility inspection was conducted on 8/6/2020. No violations or issues were report in the inspection report. Five are for D.O., four for fecal coliform, and one for TSS.

Other Comments:

Compliance History

DMR Data for Outfall 001 (from November 1, 2022 to October 31, 2023)

Parameter	OCT-23	SEP-23	AUG-23	JUL-23	JUN-23	MAY-23	APR-23	MAR-23	FEB-23	JAN-23	DEC-22	NOV-22
Flow (MGD) Average Monthly	0.502	0.506	0.575	0.554	0.505	0.668	0.681	0.810	0.664	0.695	0.709	0.693
Flow (MGD) Weekly Average	0.502	0.596	0.630	0.598	0.557	0.747	0.773	0.906	0.680	0.784	0.808	0.792
pH (S.U.) Daily Minimum	6.04	6.0	6.03	6.05	6.0	6.18	6.35	6.04	6.26	6.18	6.08	6.07
pH (S.U.) Daily Maximum	7.07	6.47	6.58	6.52	6.4	6.61	6.77	6.81	6.65	6.72	6.62	6.77
DO (mg/L) Daily Minimum	6.06	5.54	5.29	4.93	4.78	4.77	4.5	4.33	4.15	4.13	4.2	4.31
CBOD5 (lbs/day) Average Monthly	< 10	< 10	< 10	< 11	< 12	< 15	15	19	< 16	< 12	< 13	< 9
CBOD5 (lbs/day) Weekly Average	< 10	16	< 11	15	23	19	18	30	14	< 20	17	< 13
CBOD5 (mg/L) Average Monthly	< 2.1	< 2.5	< 2.0	< 2.5	< 2.7	< 2.8	2.7	3.1	< 2.7	< 2.1	< 2.7	< 2.0
CBOD5 (mg/L) Weekly Average	< 2.0	3.5	< 2.0	3.4	5.0	3.3	3.3	3.9	2.5	2.4	4.9	< 2.0
BOD5 (lbs/day) Raw Sewage Influent Average Monthly	589	552	606	480	< 589	669	602	465	768	< 383	560	570
BOD5 (lbs/day) Raw Sewage Influent Daily Maximum	765	624	981	604	849	767	829	549	915	< 598	656	859
BOD5 (mg/L) Raw Sewage Influent Average Monthly	138.1	136	135.1	104	< 135	121.8	108.4	78.3	141.8	< 67.3	118.7	120.2
TSS (lbs/day) Average Monthly	< 34	< 22	< 28	< 28	< 22	< 29	< 33	< 51	< 47	< 36	< 25	< 34
TSS (lbs/day) Raw Sewage Influent Average Monthly	441	430	414	350	728	354	318	358	667	387	496	495

NPDES Permit Fact Sheet
Buffalo Township Municipal Authority STP

NPDES Permit No. PA0221449

TSS (lbs/day) Raw Sewage Influent Daily Maximum	593	641	500	401	1350	453	428	380	903	495	707	978
TSS (lbs/day) Weekly Average	< 25	27	40	43	< 24	38	43	103	61	< 50	< 31	60
TSS (mg/L) Average Monthly	< 6.8	< 5.5	< 5.8	< 6.0	< 5.0	< 5.2	< 6.0	< 8.0	< 8.0	< 6.4	< 5.0	< 7.2
TSS (mg/L) Raw Sewage Influent Average Monthly	103	104	87	76	171	64	58	61	125	70	108	103
TSS (mg/L) Weekly Average	5.0	6.0	7.0	9.0	< 5.0	6.0	8.0	14.0	11.0	8.0	< 5.0	11.0
Fecal Coliform (No./100 ml) Geometric Mean	< 6	< 4	< 10	< 10	< 10	< 10	< 10	< 10	< 10	< 10	< 10	< 10
Fecal Coliform (No./100 ml) Instantaneous Maximum	1	< 10	< 10	< 10	< 10	< 10	< 10	< 10	< 10	< 10	< 10	< 10
UV Intensity (μw/cm²) Minimum	2	2.3	2.5	3.4	3.4	4.1	4	4.4	4	3.8	3.7	3.5
UV Intensity (μw/cm²) Average Monthly	3	2.9	3.0	3.9	4.6	5.8	4.7	5.6	4.6	4.4	4.4	4.3
Total Nitrogen (lbs/day) Annual Average											184	
Total Nitrogen (mg/L) Annual Average											24.87	
Ammonia (lbs/day) Average Monthly	< 0.9	< 0.8	< 1.0	< 0.9	< 0.9	< 1.1	< 8	< 1	< 3	< 0.8	< 2	< 4
Ammonia (mg/L) Average Monthly	< 0.2	< 0.2	< 0.2	< 0.2	< 0.2	< 0.2	< 1.4	< 0.2	< 0.57	< 0.10	< 0.5	< 0.80
Total Phosphorus (lbs/day) Annual Average											12	
Total Phosphorus (mg/L) Annual Average											1.65	
Total Copper (lbs/day) Average Quarterly		< 0.04			< 0.055			0.03			< 0.01	
Total Copper (mg/L) Average Quarterly		< 0.01			< 0.01			0.006			< 0.004	

Development of Effluent Limitations

Outfall No.	001	Design Flow (MGD)	0.89
Latitude	40° 42' 19.00"	Longitude	-79° 41' 38.00"
Wastewater Description: Treated domestic sewage			

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)
E. Coli	Report (No./100 ml)	IMAX	-	92a.61

Comments: The TRC limit is not applicable because UV disinfection is utilized.

Monitoring for E. Coli is placed in the permit in accordance with the Department's SOP entitled "Establishing Effluent Limitations for Individual Sewage Permits."

Water Quality-Based Limitations

The following limitations were determined through water quality modeling (output files attached):

Parameter	Limit (mg/l)	SBC	Model
Ammonia Nitrogen (5/01 – 10/31)	8.5	Average Monthly	Previous WQM or WQAM modeling
Total Copper	0.0242	Average Monthly	TMS Ver 1.4
Total Copper	0.0377	Daily Maximum	TMS Ver 1.4

Comments: A seasonal multiplier of "3" is typically applied for ammonia nitrogen. Current WQM 7.0 modeling (attached) did not produce effluent limits for ammonia that were as stringent as the previous limits. Previous summertime limit will remain due to anti-backsliding provisions. Wintertime period for ammonia nitrogen will receive monitoring instead of limits since the WQBEL limit of 25 mg/l, which is close the raw sewage concentration, can be easily met based on utilization of secondary treatment and historical DMR data.

The Toxics Management also recommended monitoring and reporting requirements for total zinc, which will thus be placed in the permit at a monitoring frequency of 1/quarter.

Best Professional Judgment (BPJ) Limitations

Comments: A dissolved oxygen limit of a minimum of 4.0 mg/l and monitoring for total nitrogen and total phosphorus is being placed in the renewed permit in accordance with the Department's SOP entitled "Establishing Effluent Limitations for Individual Sewage Permits."

Anti-Backsliding

N/A

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0 Daily Min	XXX	9.0 Daily Max	XXX	1/day	Grab
DO	XXX	XXX	4.0 Daily Min	XXX	XXX	XXX	1/day	Grab
CBOD5	185	295	XXX	25.0	40.0	50	1/week	24-Hr Composite
BOD5 Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	24-Hr Composite
TSS Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	24-Hr Composite
TSS	225	335	XXX	30.0	45.0	60	1/week	24-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/week	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/quarter	Grab
UV Intensity (µw/cm²)	XXX	XXX	Report	Report	XXX	XXX	1/day	Measured
Total Nitrogen	Report Annl Avg	XXX	XXX	Report Annl Avg	XXX	XXX	1/year	24-Hr Composite
Ammonia Nov 1 - Apr 30	Report	XXX	XXX	Report	XXX	XXX	1/week	24-Hr Composite

Outfall 001 , Continued (from Permit Effective Date through Permit Expiration Date)

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Ammonia May 1 - Oct 31	63.0	XXX	XXX	8.5	XXX	17	1/week	24-Hr Composite
Total Phosphorus	Report Annl Avg	XXX	XXX	Report Annl Avg	XXX	XXX	1/year	24-Hr Composite
Total Copper (ug/l)	0.18	0.28 Daily Max	XXX	24.2	37.7	60.4	2/month	24-Hr Composite
Total Zinc	Report Avg Qrtly	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	24-Hr Composite

Compliance Sampling Location: Outfall 001 (after disinfection)

Other Comments:

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
18F	42557	BUFFALO CREEK	3.420	778.00	167.65	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary		Stream	
	(cfsm)	(cfs)	(cfs)						Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.043	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	8.30	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Buffalo Twp MA	PA0221449	0.8900	0.0000	0.0000	0.000	20.00	6.30

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	4.00	8.24	0.00	0.00
NH3-N	25.00	0.10	0.00	0.70

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
18F	42557	BUFFALO CREEK	0.001	745.00	171.00	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary		Stream	
	(cfsm)	(cfs)	(cfs)						Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.043	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	8.30	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
18F		42557				BUFFALO CREEK						
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
Q7-10 Flow												
3.420	7.21	0.00	7.21	1.3768	0.00183	.794	51.77	65.17	0.21	1.001	20.00	7.07
Q1-10 Flow												
3.420	4.61	0.00	4.61	1.3768	0.00183	NA	NA	NA	0.17	1.224	20.00	6.92
Q30-10 Flow												
3.420	9.80	0.00	9.80	1.3768	0.00183	NA	NA	NA	0.24	0.863	20.00	7.18

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		

WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>		<u>Stream Code</u>	<u>Stream Name</u>						
18F		42557	BUFFALO CREEK						
NH3-N Acute Allocations									
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction		
3.420	Buffalo Twp MA	17.85	50	17.85	50	0	0		
NH3-N Chronic Allocations									
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction		
3.420	Buffalo Twp MA	1.74	13.42	1.74	13.42	0	0		
Dissolved Oxygen Allocations									
RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
3.42	Buffalo Twp MA	25	25	13.42	13.42	4	4	0	0

WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
18F	42557	BUFFALO CREEK		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
3.420	0.890	20.000	7.073	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
51.768	0.794	65.168	0.209	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
5.69	0.793	2.24	0.700	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
7.563	3.626	Tsivoglou	6	
<u>Reach Travel Time (days)</u>	Subreach Results			
1.001	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
	0.100	5.25	2.08	6.93
	0.200	4.85	1.94	6.56
	0.300	4.48	1.81	6.39
	0.400	4.14	1.69	6.33
	0.500	3.83	1.57	6.36
	0.600	3.53	1.47	6.44
	0.701	3.26	1.37	6.55
	0.801	3.02	1.28	6.68
	0.901	2.79	1.19	6.81
	1.001	2.57	1.11	6.95

WQM 7.0 Effluent Limits

<u>SWP Basin</u>		<u>Stream Code</u>	<u>Stream Name</u>				
18F		42557	BUFFALO CREEK				
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
3.420	Buffalo Twp MA	PA0221449	0.890	CBOD5	25		
				NH3-N	13.42	26.84	
				Dissolved Oxygen			4

Buffalo Township Muni Auth STP

Buffalo Township, Butler County

PA0221449

Discharge pH

Outfall 001

<u>Date</u>	<u>pH min</u>	<u>pH max</u>	<u>10^{-pH min}</u>	<u>10^{-pH max}</u>	<u>& pH max)</u>	<u>-Log (Ave pH)</u>
Jul-21	6.2	6.8	6.31E-07	1.58E-07	3.95E-07	6.4
Aug-21	6.02	6.95	9.55E-07	1.12E-07	5.34E-07	6.3
Sep-21	6.07	6.96	8.51E-07	1.1E-07	4.8E-07	6.3
Jul-22	6.0	6.8	0.000001	1.58E-07	5.79E-07	6.2
Aug-22	6.16	6.75	6.92E-07	1.78E-07	4.35E-07	6.4
Sep-22	6.04	6.71	9.12E-07	1.95E-07	5.53E-07	6.3
Jul-23	6.05	6.52	8.91E-07	3.02E-07	5.97E-07	6.2
Aug-23	6.03	6.58	9.33E-07	2.63E-07	5.98E-07	6.2
Sep-23	6.0	6.47	0.000001	3.39E-07	6.69E-07	6.2
Median:						6.3

12/28/2023

12/28/2023



Toxics Management Spreadsheet
Version 1.4, May 2023

Discharge Information

Instructions Discharge Stream

Facility: Buffalo Township MA STP NPDES Permit No.: PA0221449 Outfall No.: 001

Evaluation Type: Major Sewage / Industrial Waste Wastewater Description: Treated Domestic Sewage

Discharge Characteristics								
Design Flow (MGD)*	Hardness (mg/l)*	pH (SU)*	Partial Mix Factors (PMFs)				Complete Mix Times (min)	
			AFC	CFC	THH	CRL	Q ₇₋₁₀	Q _h
0.89	100	6.3						

Discharge Pollutant	Units	Max Discharge Conc	0 if left blank		0.5 if left blank		0 if left blank			1 if left blank	
			Trib Conc	Stream Conc	Daily CV	Hourly CV	Stream CV	Fate Coeff	FOS	Criteria Mod	Chem Transl
Group 1	Total Dissolved Solids (PWS)	mg/L	518								
	Chloride (PWS)	mg/L	175								
	Bromide	mg/L	< 0.1								
	Sulfate (PWS)	mg/L	36.5								
	Fluoride (PWS)	mg/L									
Group 2	Total Aluminum	µg/L									
	Total Antimony	µg/L									
	Total Arsenic	µg/L									
	Total Barium	µg/L									
	Total Beryllium	µg/L									
	Total Boron	µg/L									
	Total Cadmium	µg/L									
	Total Chromium (III)	µg/L									
	Hexavalent Chromium	µg/L									
	Total Cobalt	µg/L									
	Total Copper	µg/L	19.73		0.5019						
	Free Cyanide	µg/L									
	Total Cyanide	µg/L									
	Dissolved Iron	µg/L									
	Total Iron	µg/L									
	Total Lead	µg/L	< 1								
	Total Manganese	µg/L									
	Total Mercury	µg/L									
	Total Nickel	µg/L									
	Total Phenols (Phenolics) (PWS)	µg/L									
	Total Selenium	µg/L									
	Total Silver	µg/L									
	Total Thallium	µg/L									
	Total Zinc	µg/L	70.5								
	Total Molybdenum	µg/L									
	Acrolein	µg/L	<								
	Acrylamide	µg/L	<								
	Acrylonitrile	µg/L	<								
	Benzene	µg/L	<								
	Bromoform	µg/L	<								

Group 3	Carbon Tetrachloride	µg/L	<																	
	Chlorobenzene	µg/L	<																	
	Chlorodibromomethane	µg/L	<																	
	Chloroethane	µg/L	<																	
	2-Chloroethyl Vinyl Ether	µg/L	<																	
	Chloroform	µg/L	<																	
	Dichlorobromomethane	µg/L	<																	
	1,1-Dichloroethane	µg/L	<																	
	1,2-Dichloroethane	µg/L	<																	
	1,1-Dichloroethylene	µg/L	<																	
	1,2-Dichloropropane	µg/L	<																	
	1,3-Dichloropropylene	µg/L	<																	
	1,4-Dioxane	µg/L	<																	
	Ethylbenzene	µg/L	<																	
	Methyl Bromide	µg/L	<																	
	Methyl Chloride	µg/L	<																	
	Methylene Chloride	µg/L	<																	
	1,1,2,2-Tetrachloroethane	µg/L	<																	
	Tetrachloroethylene	µg/L	<																	
	Toluene	µg/L	<																	
	1,2-trans-Dichloroethylene	µg/L	<																	
Group 4	1,1,1-Trichloroethane	µg/L	<																	
	1,1,2-Trichloroethane	µg/L	<																	
	Trichloroethylene	µg/L	<																	
	Vinyl Chloride	µg/L	<																	
	2-Chlorophenol	µg/L	<																	
	2,4-Dichlorophenol	µg/L	<																	
	2,4-Dimethylphenol	µg/L	<																	
	4,6-Dinitro- <i>o</i> -Cresol	µg/L	<																	
	2,4-Dinitrophenol	µg/L	<																	
	2-Nitrophenol	µg/L	<																	
Group 5	4-Nitrophenol	µg/L	<																	
	<i>p</i> -Chloro- <i>m</i> -Cresol	µg/L	<																	
	Pentachlorophenol	µg/L	<																	
	Phenol	µg/L	<																	
	2,4,6-Trichlorophenol	µg/L	<																	
	Acenaphthene	µg/L	<																	
	Acenaphthylene	µg/L	<																	
	Anthracene	µg/L	<																	
	Benazidine	µg/L	<																	
	Benzo(a)Anthracene	µg/L	<																	
	Benzo(a)Pyrene	µg/L	<																	
	3,4-Benzofluoranthene	µg/L	<																	
	Benzo(ghi)Perylene	µg/L	<																	
	Benzo(k)Fluoranthene	µg/L	<																	
	Bis(2-Chloroethoxy)Methane	µg/L	<																	
	Bis(2-Chloroethyl)Ether	µg/L	<																	
	Bis(2-Chloroisopropyl)Ether	µg/L	<																	
	Bis(2-Ethylhexyl)Phthalate	µg/L	<																	
	4-Bromophenyl Phenyl Ether	µg/L	<																	
	Butyl Benzyl Phthalate	µg/L	<																	
	2-Chloronaphthalene	µg/L	<																	
	4-Chlorophenyl Phenyl Ether	µg/L	<																	
	Chrysene	µg/L	<																	
	Dibenzo(a,h)Anthracene	µg/L	<																	
	1,2-Dichlorobenzene	µg/L	<																	
	1,3-Dichlorobenzene	µg/L	<																	
	1,4-Dichlorobenzene	µg/L	<																	
	3,3-Dichlorobenzidine	µg/L	<																	
	Diethyl Phthalate	µg/L	<																	
	Dimethyl Phthalate	µg/L	<																	
	Di-n-Butyl Phthalate	µg/L	<																	
	2,4-Dinitrotoluene	µg/L	<																	

Page 3



Stream / Surface Water Information

Buffalo Township MA STP, NPDES Permit No. PA0221449, Outfall 001

Instructions Discharge **Stream**

Receiving Surface Water Name: **Buffalo Creek**

No. Reaches to Model: **1**

- ☒ Statewide Criteria
☐ Great Lakes Criteria
☐ ORSANCO Criteria

Location	Stream Code*	RMI*	Elevation (ft)*	DA (mi ²)*	Slope (ft/ft)	PWS Withdrawal (MGD)	Apply Fish Criteria*
Point of Discharge	042557	8	778	167.65			Yes
End of Reach 1	042122	0.001	755	11410		4	Yes

Q₇₋₁₀

Location	RMI	LFY (cfs/mi ²)*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness*	pH*	Hardness	pH
Point of Discharge	8	0.043										108	8.3		
End of Reach 1	0.001	0.043	2390									100	7		

Q_h

Location	RMI	LFY (cfs/mi ²)*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness	pH	Hardness	pH
Point of Discharge	8														
End of Reach 1	0.001														



Toxics Management Spreadsheet
Version 1.4, May 2023

Model Results

Buffalo Township MA STP, NPDES Permit No. PA0221449, Outfall 001

Instructions Results RETURN TO INPUTS SAVE AS PDF PRINT All Inputs Results Limits

☒ Hydrodynamics

Q_{7-10}

RMI	Stream Flow (cfs)	PWS Withdrawal (cfs)	Net Stream Flow (cfs)	Discharge Analysis Flow (cfs)	Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Travel Time (days)	Complete Mix Time (min)
8	7.21		7.21	1.377	0.00054	0.826	55.046	66.638	0.189	2.589	167.121
0.001	2390.00	6.188	2383.812								

Q_h

RMI	Stream Flow (cfs)	PWS Withdrawal (cfs)	Net Stream Flow (cfs)	Discharge Analysis Flow (cfs)	Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Travel Time (days)	Complete Mix Time (min)
8	41.76		41.76	1.377	0.00054	1.681	55.046	32.753	0.466	1.048	76.553
0.001	6663.595	6.188	6657.41								

☒ Wasteload Allocations

☒ AFC

CCT (min): 15

PMF: 0.300

Analysis Hardness (mg/l): 104.89

Analysis pH: 6.70

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Total Copper	0	0		0	14.057	14.6	37.6	Chem Translator of 0.96 applied
Total Lead	0	0		0	68.021	86.8	223	Chem Translator of 0.784 applied
Total Zinc	0	0		0	122.013	125	320	Chem Translator of 0.978 applied

☒ CFC

CCT (min): #####

PMF: 1

Analysis Hardness (mg/l): 106.72

Analysis pH: 7.07

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	

Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Total Copper	0	0		0	9.467	9.86	61.5	Chem Translator of 0.96 applied
Total Lead	0	0		0	2.701	3.46	21.6	Chem Translator of 0.782 applied
Total Zinc	0	0		0	124.829	127	789	Chem Translator of 0.986 applied

☒ **THH** CCT (min): THH PMF: Analysis Hardness (mg/l): Analysis pH: PWS PMF:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	500,000	500,000	#####	WQC applied at RMI 0.001 with a design stream flow of 2390 cfs
Chloride (PWS)	0	0		0	250,000	250,000	#####	WQC applied at RMI 0.001 with a design stream flow of 2390 cfs
Sulfate (PWS)	0	0		0	250,000	250,000	#####	WQC applied at RMI 0.001 with a design stream flow of 2390 cfs
Total Copper	0	0		0	N/A	N/A	N/A	
Total Lead	0	0		0	N/A	N/A	N/A	
Total Zinc	0	0		0	N/A	N/A	N/A	

☒ **CRL** CCT (min): PMF: Analysis Hardness (mg/l): Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Total Copper	0	0		0	N/A	N/A	N/A	
Total Lead	0	0		0	N/A	N/A	N/A	
Total Zinc	0	0		0	N/A	N/A	N/A	

☒ **Recommended WQBELs & Monitoring Requirements**

No. Samples/Month:

Pollutants	Mass Limits		Concentration Limits				Governing WQBEL	WQBEL Basis	Comments
	AML (lbs/day)	MDL (lbs/day)	AML	MDL	IMAX	Units			
Total Copper	0.18	0.28	24.2	37.7	60.4	µg/L	24.2	AFC	Discharge Conc ≥ 50% WQBEL (RP)
Total Zinc	Report	Report	Report	Report	Report	µg/L	205	AFC	Discharge Conc > 10% WQBEL (no RP)

☒ **Other Pollutants without Limits or Monitoring**

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., <= Target QL).

Pollutants	Governing WQBEL	Units	Comments
Total Dissolved Solids (PWS)	868,436	mg/L	Discharge Conc ≤ 10% WQBEL
Chloride (PWS)	434,218	mg/L	Discharge Conc ≤ 10% WQBEL

Bromide	N/A	N/A	No WQS
Sulfate (PWS)	434,218	mg/L	Discharge Conc \leq 10% WQBEL
Total Lead	N/A	N/A	Discharge Conc < TQL