

Application Type Renewal
 Facility Type Municipal
 Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0222984
 APS ID 1124880
 Authorization ID 1504931

Applicant and Facility Information

Applicant Name	<u>Spartansburg Borough Crawford County</u>	Facility Name	<u>Spartansburg Borough STP</u>
Applicant Address	<u>PO Box 222 Spartansburg, PA 16434-0222</u>	Facility Address	<u>Grade Road Spartansburg, PA 16434</u>
Applicant Contact	<u>Teresa Kent</u>	Facility Contact	<u>Teresa Kent</u>
Applicant Phone	<u>(814) 654-7451</u>	Facility Phone	<u>(814) 654-7451</u>
Client ID	<u>66457</u>	Site ID	<u>527232</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Spartansburg Borough</u>
Connection Status	<u>No Limitations</u>	County	<u>Crawford</u>
Date Application Received	<u>October 28, 2024</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u></u>	If No, Reason	<u>--</u>
Purpose of Application	<u>Renewal application for a Minor Sewage Facility</u>		

Summary of Review

On October 28, 2024, the Department received a renewal application for Individual Permit No. PA0222984 which expired on April 20, 2025. The facility serves a population of 277 and has one outfall (Outfall 001) which discharges to the East Branch of Oil Creek (CWF).

Act 14 notifications were submitted and received.

The facility is currently in the eDMR system.

The last inspection took place on July 17, 2025. No violations were noted.

There are no open violations in WMS for the subject Client ID (66457) as of November 14, 2025.

Proposed Changes:

- Addition of E. Coli monitoring

Approve	Deny	Signatures	Date
X		Carlee Wilson Carlee Wilson / Environmental Engineering Trainee	November 20, 2025
X		Adam Olesnanik Adam Olesnanik, P.E. / Environmental Engineer Manager	April 3, 2026

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>.06</u>
Latitude	<u>41° 49' 5.33"</u>	Longitude	<u>-79° 41' 15.76"</u>
Quad Name	<u>Spartansburg</u>	Quad Code	<u>0408</u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>East Branch Oil Creek (CWF)</u>	Stream Code	<u>54496</u>
NHD Com ID	<u>100467633</u>	RMI	<u>11.3300</u>
Drainage Area	<u>13.9</u>	Yield (cfs/mi ²)	<u>0.068</u>
Q ₇₋₁₀ Flow (cfs)	<u>0.952</u>	Q ₇₋₁₀ Basis	<u>USGS-StreamStats</u>
Elevation (ft)	<u>1423</u>	Slope (ft/ft)	<u>-</u>
Watershed No.	<u>16-E</u>	Chapter 93 Class.	<u>CWF</u>
Existing Use	<u>-</u>	Existing Use Qualifier	<u>-</u>
Exceptions to Use	<u>-</u>	Exceptions to Criteria	<u>-</u>
Assessment Status	<u>Attaining Use(s)</u>		
Cause(s) of Impairment	<u>-</u>		
Source(s) of Impairment	<u>-</u>		
TMDL Status	<u>-</u>	Name	<u>-</u>
Background/Ambient Data		Data Source	
pH (SU)	<u>7.0</u>	Default	
Temperature (°F)	<u>68</u>	Default	
Hardness (mg/L)	<u>100</u>	Default	
Other:	<u>-</u>	-	
Nearest Downstream Public Water Supply Intake	<u>Aqua PA - Emlenton</u>		
PWS Waters	<u>Allegheny River</u>	Flow at Intake (cfs)	
PWS RMI	<u>90.0</u>	Distance from Outfall (mi)	<u>66</u>

Changes Since Last Permit Issuance: Q₇₋₁₀ Flow was adjusted using StreamStats data from USGS. Elevation was adjusted using Google Earth.

Other Comments:

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Treatment Facility Summary				
Treatment Facility Name: Spartansburg Borough				
WQM Permit No.		Issuance Date		
2099414 A-1		11/02/2006		
2099414		2/18/2000		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary	Extended Aeration	Chlorine With Dechlorination	0.06
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.06	108	Not Overloaded	Aerobic Digestion	Other WWTP

Changes Since Last Permit Issuance: None

WQM Permit No. 2099414 A-1

The influent is split between two equalization tanks, which are piped to three aeration tanks that operate in series. Flows are then conveyed through the chlorine contact tank, metering manhole, effluent pump station and to the outfall. Dechlorination takes place in the metering manhole.

Compliance History

DMR Data for Outfall 001 (from October 1, 2024, to September 30, 2025)

Parameter	SEP-25	AUG-25	JUL-25	JUN-25	MAY-25	APR-25	MAR-25	FEB-25	JAN-25	DEC-24	NOV-24	OCT-24
Flow (MGD) Average Monthly	0.0169	0.0088	0.0102	0.0193	0.017	0.0171	0.0183	0.0187	0.0160	0.0217	0.0113	0.0097
Flow (MGD) Daily Maximum	0.0697	0.0136	0.0166	0.0459	0.034	0.0268	0.0247	0.0571	0.0257	0.0459	0.0223	0.0150
pH (S.U.) Daily Minimum	6.5	6.6	6.8	6.5	6.7	6.8	6.5	6.6	6.7	6.9	6.9	6.8
pH (S.U.) Daily Maximum	7.3	7.2	7.3	7.2	7.3	7.1	7.1	7.0	7.4	7.7	7.5	7.4
DO (mg/L) Daily Minimum	6.6	6.3	6.3	6.5	6.7	7.0	5.2	7.1	6.8	7.2	6.9	7.1
TRC (mg/L) Average Monthly	0.05	0.04	0.04	0.04	0.06	0.04	0.04	0.05	0.05	0.04	0.05	0.04
TRC (mg/L) Instantaneous Maximum	0.08	0.08	0.09	0.09	0.14	0.06	0.08	0.09	0.09	0.07	0.09	0.09
CBOD5 (lbs/day) Average Monthly	< 0.4	< 0.2	< 0.3	< 0.4	< 0.4	< 0.4	< 0.5	< 0.4	< 0.4	< 0.4	< 0.1	< 0.2
CBOD5 (lbs/day) Weekly Average	< 0.6	< 0.2	< 0.4	< 0.4	< 0.5	< 0.4	0.5	< 0.5	< 0.5	< 0.5	< 0.1	< 0.3
CBOD5 (mg/L) Average Monthly	< 3.0	< 3.0	< 3.0	< 3.0	< 3.0	< 3.0	< 4.0	< 3.0	< 3.0	< 3.0	< 3.0	< 3.0
CBOD5 (mg/L) Weekly Average	< 3.0	< 3.0	< 3.0	< 3.0	< 3.0	< 3.0	5.0	< 3.0	< 3.0	< 3.0	< 3.0	< 3.0
BOD5 (lbs/day) Raw Sewage Influent Average Monthly	27	11	19	23	12	20	18	25	17	23	6	11
BOD5 (lbs/day) Raw Sewage Influent Daily Maximum	46	11	29	24	16	22	18	32	24	26	6	17
BOD5 (mg/L) Raw Sewage Influent Average Monthly	212	177	173	187	122	149	152	188	119	168	145	147
TSS (lbs/day) Average Monthly	< 0.6	< 0.3	< 0.5	0.7	1.0	1.0	0.8	1.0	1	1.0	0.5	< 1.0

**NPDES Permit Fact Sheet
Spartansburg Borough STP**

NPDES Permit No. PA0222984

TSS (lbs/day) Raw Sewage Influent Average Monthly	24	11	24	22	17	24	20	38	16	26	9	16
TSS (lbs/day) Raw Sewage Influent Daily Maximum	44	12	35	32	23	31	22	58	26	31	9	26
TSS (lbs/day) Weekly Average	< 0.9	< 0.3	< 0.7	0.7	1.9	1.2	1.1	1.4	1.7	1.1	0.8	2.1
TSS (mg/L) Average Monthly	< 6.0	< 5.0	< 5.0	6.0	10	8.0	7.0	8.0	12	8.0	12	< 13
TSS (mg/L) Raw Sewage Influent Average Monthly	232	181	226	184	175	179	168	268	99	192	227	199
TSS (mg/L) Weekly Average	7.0	< 5.0	< 5.0	6.0	13	8.0	7.0	9.0	17	9.0	16	21
Fecal Coliform (CFU/100 ml) Geometric Mean	< 1.0	< 1.0	< 1.0	1.0	< 1.0	< 1.0	< 1.0	1.0	< 1.0	< 1.0	3.0	< 1.0
Total Nitrogen (lbs/day) Average Quarterly	< 0.8			2			< 1.0			< 1.0		
Total Nitrogen (mg/L) Average Quarterly	< 4.27			15.075			< 8.37			< 9.87		
Ammonia (lbs/day) Average Quarterly	< 0.06			< 0.04			< 0.05			< 0.04		
Ammonia (mg/L) Average Quarterly	< 0.30			< 0.3			< 0.30			< 0.30		
Total Phosphorus (lbs/day) Average Quarterly	0.2			0.1			0.30			0.2		
Total Phosphorus (mg/L) Average Quarterly	1.19			1.1			1.69			1.6		

Compliance History

Table 1. 5-Year Inspection Summary for Spartansburg Borough STP

Site Name	Inspection Program	Inspection Date	Inspection Type	Inspection Result	Inspector
SPARTANSBURG BORO STP	WPCNP	03/16/2021	Chapter 94 Inspection	No Violations Noted	CARVER, MELISSA
SPARTANSBURG BORO STP	WPCNP	07/03/2025	Chapter 94 Inspection	No Violations Noted	CARVER, MELISSA
SPARTANSBURG BORO STP	WPCNP	03/09/2021	Compliance Evaluation	No Violations Noted	CARVER, MELISSA
SPARTANSBURG BORO STP	WPCNP	05/02/2023	Chapter 94 Inspection	No Violations Noted	CARVER, MELISSA
SPARTANSBURG BORO STP	WPCNP	07/17/2025	Compliance Evaluation	No Violations Noted	CARVER, MELISSA

Development of Effluent Limitations

Outfall No. <u>001</u>	Design Flow (MGD) <u>.06</u>
Latitude <u>41° 49' 6.10"</u>	Longitude <u>-79° 41' 17.30"</u>
Wastewater Description: <u>Sewage Effluent</u>	

1. Technology-Based Limitations

Table 2. Minimum Technology-Based Standards for Individual Sewage Permits

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)
E. Coli	Report	IMAX	-	92a.61
Total Phosphorous	Report	Average Monthly	-	92a.61
Total Nitrogen	Report	Average Monthly	-	92a.61

The above limits are minimum technology-based and BPJ standards for individual sewage permits which are found in the Department's "Establishing Effluent Limitations for Individual Sewage Permits" document (SOP. No. BCW-PMT-033). The limits for pH are technology-based on Chapter 93.7. The limits for Total Suspended Solids, and Fecal Coliforms are technology-based on Chapter 92a.47. Monitoring for E. Coli, Total Nitrogen, and Total Phosphorus are based on Chapter 92a.61.

2. Water Quality-Based Limitations

Table 3. Water-Quality Modeling Results

Parameter	Limit (mg/l)	SBC	Model
CBOD ₅	25	Average Monthly	WQM 7
	50	IMAX	
NH ₃ -N	25	Average Monthly	
	50	IMAX	
DO	4	Daily Minimum	
TRC	0.5	Average Monthly	TRC Spreadsheet
	1.2	IMAX	

The TRC Spreadsheet and WQM 7 models were used to establish or verify WQBELs. The Department's Toxics Management Spreadsheet (TMS) is not used because no other sampling than sewage-related parameters is required with the renewal application. The table above displays the modeling outputs. All the above limits are less stringent or equal to the current permit limits and therefore no new WQBELs are proposed in this renewal (Attachments 5 & 6). Since BPJ limits are recommended by WQM 7 for ammonia-nitrogen, quarterly monitoring can be retained into this renewal.

3. Anti-Backsliding

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0 Daily Min	XXX	9.0 Daily Max	XXX	1/day	Grab
DO	XXX	XXX	4.0 Daily Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.2	1/day	Grab
CBOD5	12.5	20	XXX	25	40	50	2/month	24-Hr Composite
BOD5 Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	2/month	24-Hr Composite
TSS Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	2/month	24-Hr Composite
TSS	15	22.5	XXX	30	45	60	2/month	24-Hr Composite
Fecal Coliform (CFU/100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (CFU/100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Total Nitrogen	Report Avg Qrtly	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	24-Hr Composite
Ammonia	Report Avg Qrtly	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	24-Hr Composite
Total Phosphorus	Report Avg Qrtly	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	24-Hr Composite

Comments: All permit limitations, monitoring requirements, and conditions will be retained into the next permit with the addition of E. Coli monitoring.

Proposed Effluent Limitations and Monitoring Requirements


The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the “NPDES Permit Writer’s Manual” (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0 Daily Min	XXX	9.0 Daily Max	XXX	1/day	Grab
DO	XXX	XXX	4.0 Daily Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.2	1/day	Grab
CBOD5	12.5	20	XXX	25	40	50	2/month	24-Hr Composite
BOD5 Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	2/month	24-Hr Composite
TSS Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	2/month	24-Hr Composite
TSS	15	22.5	XXX	30	45	60	2/month	24-Hr Composite
Fecal Coliform (CFU/100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (CFU/100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Total Nitrogen	Report Avg Qrtly	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	24-Hr Composite
Ammonia	Report Avg Qrtly	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	24-Hr Composite
Total Phosphorus	Report Avg Qrtly	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	24-Hr Composite
E. Coli	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab

Compliance Sampling Location: Outfall 001 – after disinfection

Attachment 1
eMapPA – Receiving Stream Details




Attachment 2
Google Earth – Aerial Site View



Attachment 3
StreamStats Report (Outfall 001)

StreamStats Report

Region ID: PA
 Workspace ID: PA20251114152214103000
 Clicked Point (Latitude, Longitude): 41.81826, -79.68772
 Time: 2025-11-14 10:22:41 -0500



➤ Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 3]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	13.9	square miles	2.33	1720
ELEV	Mean Basin Elevation	1621	feet	898	2700
PRECIP	Mean Annual Precipitation	47	inches	38.7	47.9

Low-Flow Statistics Flow Report [Low Flow Region 3]

PIL: Lower 90% Prediction Interval, PIU: Upper 90% Prediction Interval, ASEp: Average Standard Error of Prediction, SE: Standard Error, PC: Percent Correct, RMSE: Root Mean Squared Error, PseudoR^2: Pseudo R Squared (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	1.87	ft^3/s	43	43
30 Day 2 Year Low Flow	2.71	ft^3/s	38	38
7 Day 10 Year Low Flow	0.952	ft^3/s	54	54
30 Day 10 Year Low Flow	1.28	ft^3/s	49	49
90 Day 10 Year Low Flow	1.83	ft^3/s	41	41

Low-Flow Statistics Citations


[Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p.](#)

Attachment 4
StreamStats Report (Endpoint)

StreamStats Report

Region ID:
Workspace ID:
Clicked Point (Latitude, Longitude):
Time:

PA
PA20251114153421164000
41.81340, -79.68886
2025-11-14 10:34:42 -0500



➤ Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 3]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	14.1	square miles	2.33	1720
ELEV	Mean Basin Elevation	1619	feet	898	2700
PRECIP	Mean Annual Precipitation	47	inches	38.7	47.9

Low-Flow Statistics Flow Report [Low Flow Region 3]

PIL: Lower 90% Prediction Interval, PIU: Upper 90% Prediction Interval, ASEp: Average Standard Error of Prediction, SE: Standard Error, PC: Percent Correct, RMSE: Root Mean Squared Error, PseudoR^2: Pseudo R Squared (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	1.9	ft^3/s	43	43
30 Day 2 Year Low Flow	2.75	ft^3/s	38	38
7 Day 10 Year Low Flow	0.965	ft^3/s	54	54
30 Day 10 Year Low Flow	1.29	ft^3/s	49	49
90 Day 10 Year Low Flow	1.85	ft^3/s	41	41

Low-Flow Statistics Citations

[Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p.](#)

**Attachment 5
WQM Modeling Results**

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
16E	54496	EAST BRANCH OIL CREEK	11.000	1423.00	13.90	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.068	0.00	0.95	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Spartansburg	PA0222984	0.0600	0.0600	0.0600	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	4.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
16E	54496	EAST BRANCH OIL CREEK	10.700	1410.00	14.10	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.068	0.00	0.96	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data							
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00
Parameter Data							
Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)			
CBOD5	25.00	2.00	0.00	1.50			
Dissolved Oxygen	3.00	8.24	0.00	0.00			
NH3-N	25.00	0.00	0.00	0.70			

WQM 7.0 Hydrodynamic Outputs

SWP Basin	Stream Code	Stream Name										
16E	54496	EAST BRANCH OIL CREEK										
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
Q7-10 Flow												
11.000	0.95	0.00	0.95	.0928	0.00821	.524	15.87	30.31	0.13	0.146	20.44	7.00
Q1-10 Flow												
11.000	0.61	0.00	0.61	.0928	0.00821	NA	NA	NA	0.10	0.182	20.66	7.00
Q30-10 Flow												
11.000	1.29	0.00	1.29	.0928	0.00821	NA	NA	NA	0.15	0.124	20.33	7.00

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		

WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
16E	54496	EAST BRANCH OIL CREEK

NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
11.000	Spartansburg	15.87	50	15.87	50	0	0

NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
11.000	Spartansburg	1.85	25	1.85	25	0	0

Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
11.00	Spartansburg	25	25	25	25	4	4	0	0

WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
16E	54496	EAST BRANCH OIL CREEK		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
11.000	0.060	20.444	7.000	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
15.870	0.524	30.311	0.126	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
4.04	0.782	2.22	0.724	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
7.866	9.909	Tsivoglou	6	
<u>Reach Travel Time (days)</u>	Subreach Results			
0.146	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.015	4.00	2.20	7.87
	0.029	3.95	2.17	7.87
	0.044	3.90	2.15	7.87
	0.058	3.86	2.13	7.87
	0.073	3.81	2.11	7.88
	0.087	3.77	2.08	7.88
	0.102	3.73	2.06	7.89
	0.117	3.68	2.04	7.90
	0.131	3.64	2.02	7.91
	0.146	3.60	2.00	7.92

WQM 7.0 Effluent Limits

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>					
16E	54496	EAST BRANCH OIL CREEK					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
11.000	Spartansburg	PA0222984	0.060	CBOD5	25		
				NH3-N	25	50	
				Dissolved Oxygen			4

Attachment 6
TRC Spreadsheet

TRC EVALUATION					
0.952	= Q stream (cfs)		0.5	= CV Daily	
0.06	= Q discharge (MGD)		0.5	= CV Hourly	
30	= no. samples		1	= AFC_Partial Mix Factor	
0.3	= Chlorine Demand of Stream		1	= CFC_Partial Mix Factor	
0	= Chlorine Demand of Discharge		15	= AFC_Criteria Compliance Time (min)	
0.5	= BAT/BPJ Value		720	= CFC_Criteria Compliance Time (min)	
	= % Factor of Safety (FOS)			= Decay Coefficient (K)	
Source	Reference	AFC Calculations		Reference	CFC Calculations
TRC	1.3.2.iii	WLA afc = 3.291		1.3.2.iii	WLA cfc = 3.201
PENTOXSD TRG	5.1a	LTAMULT afc = 0.373		5.1c	LTAMULT cfc = 0.581
PENTOXSD TRG	5.1b	LTA_afc = 1.226		5.1d	LTA_cfc = 1.861
Source	Effluent Limit Calculations				
PENTOXSD TRG	5.1f	AML MULT = 1.231			
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.500		BAT/BPJ	
		INST MAX LIMIT (mg/l) = 1.635			
WLA afc	$(.019/e^{-k \cdot AFC_tc}) + [(AFC_Yc \cdot Qs \cdot .019 / Qd \cdot e^{-k \cdot AFC_tc}) \dots + Xd + (AFC_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$				
LTAMULT afc	$EXP((0.5 \cdot LN(cvh^2 + 1)) - 2.326 \cdot LN(cvh^2 + 1)^{0.5})$				
LTA_afc	wla_afc * LTAMULT_afc				
WLA_cfc	$(.011/e^{-k \cdot CFC_tc}) + [(CFC_Yc \cdot Qs \cdot .011 / Qd \cdot e^{-k \cdot CFC_tc}) \dots + Xd + (CFC_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$				
LTAMULT_cfc	$EXP((0.5 \cdot LN(cvd^2 / no_samples + 1)) - 2.326 \cdot LN(cvd^2 / no_samples + 1)^{0.5})$				
LTA_cfc	wla_cfc * LTAMULT_cfc				
AML MULT	$EXP(2.326 \cdot LN((cvd^2 / no_samples + 1)^{0.5}) - 0.5 \cdot LN(cvd^2 / no_samples + 1))$				
AVG MON LIMIT	MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc) * AML_MULT)				
INST MAX LIMIT	1.5 * ((av_mon_limit / AML_MULT) / LTAMULT_afc)				

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment [redacted])
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [redacted])
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 386-2000-002, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input type="checkbox"/>	SOP: [redacted]
<input type="checkbox"/>	Other: [redacted]