

Southwest Regional Office CLEAN WATER PROGRAM

Application Type
Facility Type
Major / Minor

Minor

NPDES PERMIT FACT SHEET INDIVIDUAL SEWAGE

Application No. PA0253472

APS ID 1055921

Authorization ID 1383663

pplicant Name	Hanover Township Sewer Authority	Facility Name	Bavington STP
pplicant Address	533 Bavington Road	_ Facility Address	533 Bavington Road
	Burgettstown, PA 15021-2734	_	Burgettstown, PA 15021
pplicant Contact	Mr. Greg Call	_ Facility Contact	Patty Garrett
pplicant Phone	(724) 899-5055	Facility Phone	(724) 899-5055
Client ID	160306	Site ID	684366
ch 94 Load Status	Not Overloaded	_ Municipality	Hanover Township
onnection Status	No Limitations	County	Washington
ate Application Rece	eived January 21, 2022	EPA Waived?	Yes
ate Application Acce	epted	If No, Reason	

Summary of Review

The applicant has applied for a renewal of an existing NPDES Permit No. PA, which was previously issued by the Department on July 24, 2017. That permit expired on July 31, 2022.

WQM Permit No. 6307403 authorized the construction of the plant to treat an annual average design flow of 0.18 MGD. The existing treatment process consists of screening/grit removal, two SBR tanks, and UV disinfection. The design organic capacity is 396 lbs/day.

The receiving stream, Raccoon Creek, is currently classified as a WWF and is located in State Watershed No. 20-D.

The applicant has complied with Act 14 Notifications and no comments were received. The application states that the STP receives no IW wastewater contributions and does not receive hauled-in wastes.

Sludge use and disposal description and location(s): Sludge from the Bavington STP is hauled to the New Castle SA WWTP for processing.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request

Approve	Deny	Signatures	Date
Х		hill C Mitebell	
		William C. Mitchell, E.I.T. / Environmental Engineering Specialist	August 23, 2022
Х		Christopher Kriley, P.E. / Program Manager	August 23, 2022

Summary of Review
or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the <i>Pennsylvania Bulletin</i> at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Discharge, Receiving Waters and Water Supply Information	mation	
Outfall No. 001	Design Flow (MGD)	.18
Latitude _40° 25' 24.00"	Longitude	-80° 22' 08.00"
Quad Name Clinton	Quad Code	
Wastewater Description: Sewage Effluent		
Receiving Waters Raccoon Creek (WWF)	Stream Code	33564
NHD Com ID 99688434	RMI	33.7
Drainage Area 44.30	Yield (cfs/mi²)	0.020
Q ₇₋₁₀ Flow (cfs)0.866	Q ₇₋₁₀ Basis	USGS StreamStats
Elevation (ft) 920.00	Slope (ft/ft)	0.00322
Watershed No. 20-D	Chapter 93 Class.	WWF
Existing Use	Existing Use Qualifier	
Exceptions to Use NONE	Exceptions to Criteria	NONE
Assessment Status Impaired		
Cause(s) of Impairment METALS, PH		
Source(s) of Impairment ACID MINE DRAINAGE		
TMDL Status Final	Name Raccoon Cre	eek Watershed
Background/Ambient Data	Data Source	
pH (SU)		
Temperature (°F)		
Hardness (mg/L)		
Other:		
Nearest Downstream Public Water Supply Intake	Midland Borough Municipal A	
PWS Waters Ohio River	_ Flow at Intake (cfs)	5,880
PWS RMI	Distance from Outfall (mi)	39.68

Changes Since Last Permit Issuance: None

Other Comments: The discharge is to Raccoon Creek, which has a Final TMDL and is impaired by metals & pH. This sewage discharge is not expected to contribute to the stream impairment for which abandoned mine drainage is source of such impairment. No WLAs have been developed for this sewage discharge and they are not expected to contribute to the stream impairment for these pollutants. Application data states that maximum concentration values for total aluminum, total iron, and total manganese is 0.017 mg/L, 0.06 mg/L, and 0.006 mg/L, which is below their criteria based concentration values. These pollutants were analyzed using the TMS and no WQBELs or monitoring requirements for these pollutants will be placed on this facility at this time.

Treatment Facility Summary

Treatment Facility Name: Bavington STP

WQM Permit No.	Issuance Date
6307403	12/17/2008

Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary with Ammonia Reduction	SBRs	Ultraviolet	0.025 (2020)

Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal	
				Hauled to New	
0.18	396	Not Overloaded	Sludge Holding Tank	Castle SA WWTP	

Changes Since Last Permit Issuance: None

Other Comments: N/A

Compliance History

Operaions Compliance Check Summary Report

Facility: Bavington STP

NPDES Permit No.: PA0253472

Compliance Review Period: 3/2017 – 3/2022

Inspection Summary:

INSP ID	INSPECTED DATE	INSP TYPE	AGENCY	INSPECTION RESULT DESC
<u>3212665</u>	06/30/2021	Compliance Evaluation	PA Dept of Environmental Protection	No Violations Noted

Violation Summary:

No violations

Open Violations by Client ID:

No open violations for client 160306

Enforcement Summary:

No enforcements

DMR Violation Summary:

No DMR exceedances

Compliance Status: In compliance

Completed by: John Murphy

Completed date: 3/21/2022

Compliance History

DMR Data for Outfall 001 (from July 1, 2021 to June 30, 2022)

Parameter	JUN-22	MAY-22	APR-22	MAR-22	FEB-22	JAN-22	DEC-21	NOV-21	OCT-21	SEP-21	AUG-21	JUL-21
Flow (MGD)												
Average Monthly	0.0232	0.0277	0.023	0.0231	0.0269	0.0216	0.0188	0.0267	0.03	0.0368	0.0363	0.0176
Flow (MGD)												
Daily Maximum	0.03	0.1114	0.0525	0.0305	0.087	0.049	0.037	0.0374	0.0463	0.0833	0.0806	0.0435
pH (S.U.)												
Minimum	7.54	7.34	7.42	7.42	7.32	7.45	7.46	7.44	7.35	7.45	7.4	7.53
pH (S.U.)												
Maximum	7.76	7.76	7.67	7.61	7.78	7.65	7.69	7.72	7.75	7.72	7.76	7.83
DO (mg/L)												
Minimum	7.65	7.87	7.42	8.78	8.28	9.87	7.57	7.97	7.67	7.53	6.65	6.38
CBOD5 (lbs/day)												
Average Monthly	< 0.7	< 0.5	< 0.7	< 0.6	< 0.4	< 0.5	< 0.5	< 0.6	< 0.7	< 0.9	< 0.9	< 0.3
CBOD5 (lbs/day)												
Weekly Average	1.1	< 0.6	< 1.0	< 0.8	< 0.7	< 0.7	0.6	< 0.7	< 0.9	< 1.2	< 1.0	< 0.4
CBOD5 (mg/L)												
Average Monthly	< 4.0	< 3.0	< 3.0	< 3.0	< 3.0	< 3.0	< 3.0	< 3.0	< 3.0	< 3.0	< 3.0	< 3.0
CBOD5 (mg/L)												
Weekly Average	5.0	< 3.0	< 3.0	< 3.0	< 3.0	< 3.0	4.0	< 3.0	< 3.0	< 3.0	< 3.0	< 3.0
BOD5 (lbs/day)												
Raw Sewage Influent												
 Average												
Monthly	15	19	38	17	16	< 16	19	13	15	25	30	< 12.0
BOD5 (lbs/day)												
Raw Sewage Influent												
 br/> Daily Maximum	23	28	61	21	22	28	38	17	22	44	48	19
BOD5 (mg/L)												
Raw Sewage Influent												
 Average		4000			4.40	44=0	440.00	4.0			40=0	4400
Monthly	93.9	122.6	200.9	93.5	119	< 115.9	116.29	49	60.6	78.8	105.6	< 118.3
TSS (lbs/day)	0.5	0.0	0.7	0.0	0.0	0.5	0.7		0.0	0.0	4.0	0.7
Average Monthly	< 0.5	< 0.6	< 0.7	< 0.6	0.6	< 0.5	0.7	< 1.1	< 0.9	< 0.9	< 1.0	< 0.7
TSS (lbs/day)												
Raw Sewage Influent												
 Average	40	40	20	40	40	40	25	40	40	00	0.4	40
Monthly	19	18	20	19	12	13	25	10	10	26	24	10

NPDES Permit Fact Sheet Bavington STP

NPDES Permit No. PA0253472

TSS (lbs/day)												
Raw Sewage Influent												
 br/> Daily Maximum	24	38	39	33	19	31	51	16	17	49	50	18
TSS (lbs/day)												
Weekly Average	0.6	1.0	< 1.0	0.8	1.2	< 0.7	1.3	2.1	1.2	1.5	1.0	1.2
TSS (mg/L)												
Average Monthly	< 3.0	< 4.0	< 3.0	< 3.0	4.0	< 3.0	5.0	< 6.0	< 4.0	< 3.0	< 3.0	< 6.0
TSS (mg/L)												
Raw Sewage Influent												
 Average												
Monthly	111	104	92	105	100	99	150	49	38	83	84	95
TSS (mg/L)		0.0	4.0	4.0	5 0	0.0	0.0	40.0	5 0	4.0	0.0	44.0
Weekly Average	3.0	6.0	4.0	4.0	5.0	< 3.0	9.0	10.0	5.0	4.0	3.0	11.0
Fecal Coliform												
(No./100 ml)		. 4.0	.4.0	. 0. 0		0.0	. 0. 0	. 0. 0		. 0. 0		.4.0
Geometric Mean Fecal Coliform	< 2.0	< 4.0	< 1.0	< 2.0	< 2.0	2.0	< 2.0	< 2.0	< 2.0	< 2.0	< 2.0	< 1.0
(No./100 ml)												
Instantaneous												
Maximum	4.0	< 1.0	1.0	6.0	6.0	22	6.0	16.0	19	8.0	9.0	1.0
UV Transmittance (%)	4.0	V 1.0	1.0	0.0	0.0	22	0.0	10.0	13	0.0	3.0	1.0
Average Monthly	4.9	5.1	3.8	4.6	4.1	4.5	4.2	5.3	5.9	8.1	4.7	5.4
Total Nitrogen (mg/L)		_		_		-				-		-
Daily Maximum							20.3					
Ammonia (mg/L)												
Average Monthly	0.1	0.1	0.1	0.18	0.15	< 0.16	0.19	0.17	0.22	0.2	0.3	0.2
Ammonia (mg/L)												
Weekly Average	< 1.0	< 1.0	0.15	0.23	0.17	0.24	0.22	0.19	0.37	< 1.0	< 1.0	< 1.0
Total Phosphorus												
(mg/L)												
Daily Maximum							3.27					

Development of Effluent Limitations						
Outfall No.	001		Design Flow (MGD)	0.18		
Latitude	40° 25' 24.00)"	Longitude	-80° 22' 08.00"		
Wastewater Description: Sewage Effluent		-				

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
CBOD5	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
Solids	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform				
(5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform				
(5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform				
(10/1 - 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform				
(10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: The above Technology-Based Limitations are imposed for CBOD5 (Nov 1 – April 30), TSS, pH, and Fecal Coliform.

Water Quality-Based Limitations

A "Reasonable Potential Analysis" (TMS Version 1.3) was conducted.

The following limitations were determined through water quality modeling for the facility (Attachment # 2, 3, and 4):

Parameter	Limit (mg/l)	SBC	Model
CBOD5			
May 1 – Oct 31	20.0	Average Monthly	WQM 7.0 Version 1.1
Ammonia-Nitrogen		·	
Nov 1 - Apr 30	20.7	Average Monthly	WQM 7.0 Version 1.1
Ammonia-Nitrogen			
May 1 - Oct 31	6.9	Average Monthly	WQM 7.0 Version 1.1

Comments: DMR data above confirms that the applicant should not have any trouble complying with the revised CBOD5 and ammonia-nitrogen limits, which are based upon updated StreamStats data and WQM 7.0 Version 1.1 model.

The TMS recommended monitoring for total copper and total zinc because the discharge concentration is greater than 10% of the WQBEL.

Best Professional Judgment (BPJ) Limitations

Comments: A Dissolved Oxygen minimum limitation of 4.0 mg/L will be implemented based on the standard in 25 PA Code Chapter 93 and best professional judgment.

Anti-Backsliding

Section 402(o) of the Clean Water Act (CWA), enacted in the Water Quality Act of 1987, establishes anti-backsliding rules governing two situations. The first situation occurs when a permittee seeks to revise a Technology-Based effluent limitation based on BPJ to reflect a subsequently promulgated effluent guideline which is less stringent. The second situation addressed by Section 402(o) arises when a permittee seeks relaxation of an effluent limitation which is based upon a State treatment standard of water quality standard.

Previous limits can be used pursuant to EPA's anti-backsliding regulation 40 CFR 122.44 (I) Reissued permits. (1) Except as provided in paragraph (I)(2) of this section when a permit is renewed or reissued. Interim effluent limitations, standards or conditions must be at least as stringent as the final effluent limitations, standards, or conditions in the previous permit (unless the circumstances on which the previous permit was based have materially and substantially changed since the time the permit was issued and would constitute cause for permit modification or revocation and reissuance under §122.62). (2) In the case of effluent limitations established on the basis of Section 402(a)(1)(B) of the CWA, a permit may not be renewed, reissued, or modified on the basis of effluent guidelines promulgated under section 304(b) subsequent to the original issuance of such permit, to contain effluent limitations which are less stringent than the comparable effluent limitations in the previous permit.

The facility is not seeking to revise the previously permitted effluent limits.

Additional Considerations

Ultraviolet (UV) disinfection is used, and therefore, Total Residual Chlorine (TRC) limits are not applicable. Routine monitoring of UV Transmittance will be at the same monitoring frequency that is used for TRC.

For pH, Dissolved Oxygen (DO) and UV Transmittance, a monitoring frequency of 1/day has been imposed. In general, less frequent monitoring may be established only when the permittee demonstrates that there will be no discharge on days where monitoring is not required.

Sewage discharges will include monitoring, at a minimum, for *E. Coli*, in new and reissued permits, with a monitoring frequency of 1/quarter for facilities with a design flows >=0.05 and < 1.0 MGD per Chapter 92.a.61.

Nutrient monitoring is required to establish the nutrient load from the wastewater treatment facility and the impacts that load may have on the quality of the receiving stream(s). A 1/quarter monitoring requirement for Total N & Total P has been added to the permit per Chapter 92.a.61.

Mass loading limits are applicable for publicly owned treatment works (POTWs). Current policy requires average monthly mass loading limits be established for CBOD $_5$, TSS, and NH $_3$ -N and average weekly mass loading limits be established for CBOD $_5$ and TSS. Average monthly mass loading limits (lbs/day) are based on the formula: design flow (MGD) x concentration limit (mg/L) x conversion factor (8.34).

For POTWs with design flows greater than 2,000 GPD influent BOD₅ and TSS monitoring must be established in the permit, and the monitoring should be consistent with the same frequency and sample type as is used for other effluent parameters.

Monitoring frequency for the proposed effluent limits are based upon Table 6-3, Self-Monitoring Requirements for Sewage Dischargers, from the Departments Technical Guidance for the Development and Specification of Effluent Limitations and Other Permit Conditions in NPDES Permits (362-0400-001).

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

			Effluent Lir	mitations			Monitoring Re	quirements
Parameter	Mass Units	(lbs/day) (1)		Concentrati	ons (mg/L)		Minimum ⁽²⁾	Required
Farameter	Average Monthly	Weekly Average	Instantaneous Minimum	Average Monthly	Weekly Average	Instant. Maximum	Measurement Frequency	Sample Type
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	1/week	Metered
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	4.0	XXX	XXX	XXX	1/day	Grab
CBOD5 Nov 1 - Apr 30	37.0	57.0	XXX	25.0	38.0	50	1/week	8-Hr Composite
CBOD5 May 1 - Oct 31	30.0	45.0	XXX	20.0	30.0	40	1/week	8-Hr Composite
BOD5 Raw Sewage Influent	Report	XXX	XXX	Report	XXX	XXX	1/week	8-Hr Composite
TSS	45.0	65.0	XXX	30.0	45.0	60	1/week	8-Hr Composite
TSS Raw Sewage Influent	Report	XXX	XXX	Report	XXX	XXX	1/week	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/week	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/quarter	Grab
UV Transmittance (%)	XXX	XXX	Report	XXX	XXX	XXX	1/day	Measured
Total Nitrogen	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	8-Hr Composite
Ammonia-Nitrogen Nov 1 - Apr 30	31.0	XXX	XXX	20.7	XXX	41.4	1/week	8-Hr Composite

Outfall 001, Continued (from Permit Effective Date through Permit Expiration Date)

			Effluent Lin	nitations			Monitoring Re	quirements
Parameter	Mass Units	(lbs/day) (1)		Concentrati	ions (mg/L)		Minimum ⁽²⁾	Required
Farameter	Average Monthly	Weekly Average	Instantaneous Minimum	Average Monthly	Weekly Average	Instant. Maximum	Measurement Frequency	Sample Type
Ammonia-Nitrogen								8-Hr
May 1 - Oct 31	10.3	XXX	XXX	6.9	XXX	13.9	1/week	Composite
					Report			8-Hr
Total Phosphorus	XXX	XXX	XXX	XXX	Daily Max	XXX	1/year	Composite
		Report			Report			24-Hr
Total Copper	Report	Daily Max	XXX	Report	Daily Max	XXX	1/week	Composite
		Report		-	Report			24-Hr
Total Zinc	Report	Daily Max	XXX	Report	Daily Max	XXX	1/week	Composite

Compliance Sampling Location: Outfall 001

Other Comments: N/A

Attachment #1 - USGS StreamStats Report


StreamStats Report

Region ID: PA

Workspace ID: PA20220318185013528000

Clicked Point (Latitude, Longitude): 40.42490, -80.36900

2022-03-18 14:50:33 -0400 Time:



Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	44.3	square miles
ELEV	Mean Basin Elevation	1162	feet

	ics Parameters [Low				
Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	44.3	square miles	2.26	1400

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
ELEV	Mean Basin Elevation	1162	feet	1050	2580

Low-Flow Statistics Flow Report [Low Flow Region 4]

PII: Prediction Interval-Lower, Plu: Prediction Interval-Upper, ASEp: Average Standard Error of Prediction, SE: Standard Error (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	2.05	ft^3/s	43	43
30 Day 2 Year Low Flow	3.31	ft^3/s	38	38
7 Day 10 Year Low Flow	0.866	ft^3/s	66	66
30 Day 10 Year Low Flow	1.39	ft^3/s	54	54
90 Day 10 Year Low Flow	2.35	ft^3/s	41	41

Low-Flow Statistics Citations

Stuckey, M.H.,2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (http://pubs.usgs.gov/sir/2006/5130/)

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.7.0

StreamStats Services Version: 1.2.22

NSS Services Version: 2.1.2

Attachment #2 - WQM 7.0 Version 1.1 - Warmer Period

Input Data WQM 7.0

	SWP Basin	Strea Cod		Stre	eam Name		RMI		vation (ft)	Drainage Area (sq mi)		Wit	WS hdrawal mgd)	Apply FC
	20D	335	64 RACC	OON CRI	EEK		33.70	00	920.00	44.	30 0.0	00000	0.00	✓
					St	ream Dat	a							
Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Ten	Tributary	Н	Stre Temp	am pH	
Cond.	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C	;)		(°C)		
Q7-10 Q1-10 Q30-10	0.020	0.00 0.00 0.00	0.00 0.00 0.00	0.000 0.000 0.000	0.000 0.000 0.000	0.0	0.00	0.0	00 2	5.00	7.00	0.00	0.00	
					Di	scharge l	Data							
			Name	Per	mit Number	Disc	Permitte Disc Flow (mgd)	Dis Flo	c Res	erve 7	Disc 「emp (°C)	Disc pH		
		Bavin	gton STP	PA	0253472	0.180	0.000	0.0	0000	0.000	20.00	7.00		
					Pa	arameter l	Data							
			ı	^o aramete	r Name	C	onc C	rib conc ng/L)	Stream Conc (mg/L)	Fate Coef (1/days)				
	_		CBOD5				25.00	2.00	0.00					
			Dissolved	Oxygen			4.00	8.24	0.00					
			NH3-N				18.00	0.00	0.00	0.60)			

Input Data WQM 7.0

	SWP Basin			Stre	eam Name		RMI		vation (ft)	Drainage Area (sq mi)	Slop (ft/f	Witho	VS drawal igd)	Appl FC
	20D	335	564 RACC	OON CR	EEK		32.70	00	903.00	61.1	0.00	0000	0.00	✓
					St	ream Dat	ta							
Design	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tem	Tributary np pl	Н	Strea Temp	m pH	
Cond.	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C	()		(°C)		
Q7-10 Q1-10 Q30-10	0.020	0.00 0.00 0.00	0.00	0.000 0.000 0.000	0.000	0.0	0.00	0.0	0 2	5.00	7.00	0.00	0.00	
					Di	scharge	Data						7	
			Name	Per	mit Numbe	Disc	Permitte Disc Flow (mgd)	Dis Flo	c Res w Fa	erve T	Disc emp (°C)	Disc pH		
						0.000	0.000	0.0	000	0.000	25.00	7.00		
					Pa	arameter	Data							
			ı	Paramete	r Name			Trib Conc	Stream Conc	Fate Coef				
						(n	ng/L) (r	mg/L)	(mg/L)	(1/days)				
			CBOD5				25.00	2.00	0.00	1.50				
			Dissolved	Oxygen			3.00	8.24	0.00	0.00				
			NH3-N				25.00	0.00	0.00	0.70				
													_	

WQM 7.0 Hydrodynamic Outputs

	SW	P Basin	Strea	m Code				Stream	<u>Name</u>			
		20D	3	3564			RA	CCOON	CREEK			
RMI	Stream Flow	PWS With	Net Stream	-	Reach Slope	Depth	Width	W/D Ratio	Velocity	Trav	Analysis Temp	Analysis pH
	(cfs)	(cfs)	Flow (cfs)	Flow (cfs)	(ft/ft)	(ft)	(ft)		(fps)	Time (days)	(°C)	
Q7-1	0 Flow											
33.700	0.87	0.00	0.87	.2785	0.00322	.57	21.16	37.11	0.09	0.644	23.78	7.00
Q1-1	0 Flow											
33.700	0.55	0.00	0.55	.2785	0.00322	NA	NA	NA	0.08	0.770	23.33	7.00
Q30-	10 Flow	,										
33.700	1.18	0.00	1.18	.2785	0.00322	NA	NA	NA	0.11	0.563	24.04	7.00

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	~
WLA Method	EMPR	Use Inputted W/D Ratio	~
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	~
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	
D.O. Saturation	90.00%	Use Balanced Technology	~
D.O. Goal	5		

Monday, March 21, 2022 Version 1.1 Page 1 of 1

WQM 7.0 Wasteload Allocations

SWP Basin	Stream Code	Stream Name
20D	33564	RACCOON CREEK

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
33.70	0 Bavington STP	12.72	36	12.72	36	0	0
H3-N (Chronic Allocati	ons					
H3-N (Chronic Allocati	ons Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction

Dissolved Oxygen Allocations

		CBC			3-N	Dissolved	d Oxygen	Cettoral	Percent
RMI	Discharge Name	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	muluple	Daseillie	Muluple	Reach	Reduction
33.70 E	Bavington STP	20.01	20.01	6.99	6.99	4	4	0	0

WQM 7.0 D.O.Simulation

SWP Basin St	ream Code			Stream Name	
20D	33564		R	ACCOON CREEK	
<u>RMI</u> 33.700	Total Discharge 0.180)) Ana	ysis Temperature (7.000
Reach Width (ft) 21.157 Reach CBOD5 (mg/L)	<u>Reach De</u> r 0.570 <u>Reach Kc (</u>)	R	Reach WDRatio 37.105 each NH3-N (mg/L)	Reach Velocity (fps) 0.095 Reach Kn (1/days)
6.38 <u>Reach DO (mg/L)</u> 7.211	0.802 Reach Kr (1 2.903	2 1/days)		1.70 Kr Equation Tsivoglou	0.803 Reach DO Goal (mg/L) 5
Reach Travel Time (days) 0.644	TravTime (days)	Subreach CBOD5 (mg/L)	Results NH3-N (mg/L)	D.O. (mg/L)	
	0.064	6.00	1.61	6.56	
	0.129 0.193 0.258	5.65 5.31 4.99	1.53 1.46 1.38	6.08 5.72 5.46	
	0.322 0.386	4.70 4.42	1.31 1.25	5.29 5.19	
	0.451 0.515	4.15 3.90	1.18 1.12	5.14 5.14	
	0.580 0.644	3.67 3.45	1.07 1.01	5.17 5.22	

WQM 7.0 Effluent Limits

		n Code					
	20D 33	564		RACCOON CRE	:EK		
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
33.700	Bavington STP	PA0253472	0.180	CBOD5	20.01		
				NH3-N	6.99	13.98	
				Dissolved Oxygen			4

Attachment # 3 - WQM 7.0 Version 1.1 - Colder Period

Input Data WQM 7.0

	SWP Basir			Stre	eam Name		RMI		vation (ft)	Drainao Area (sq m	í	Slope (ft/ft)	PW Withd (mg	rawal	Apply FC
	20D	33	564 RACC	OON CRI	EEK		33.70	00	920.00	44	4.30 0.	.00000		0.00	✓
					St	ream Dat	ta								
Design	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tem	Tributar np	<u>v</u> pH	Tem	Strean np	n pH	
Cond.	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C	;)		
Q7-10 Q1-10 Q30-10	0.039	0.00 0.00 0.00	0.00	0.000 0.000 0.000	0.000 0.000 0.000	0.0	0.00	0.0	0	5.00	7.00		0.00	0.00	
					Di	scharge]	
			Name	Per	mit Number	Disc	Permitte Disc Flow (mgd)	Disc Flo	c Res w Fa	erve	Disc Temp (°C)		sc H		
		Bavir	ngton STP	PA	0253472	0.180	0.000	0.0	000	0.000	15.0	00	7.00		
					Pa	arameter	Data								
			ı	Paramete	r Name			Frib Sonc	Stream Conc	Fate Coef					
				aramoto	radino	(n	ng/L) (n	ng/L)	(mg/L)	(1/days	s)				
			CBOD5				25.00	2.00	0.00	1.5	50				
			Dissolved	Oxygen			4.00	12.51	0.00	0.0	00				
			NH3-N				20.70	0.00	0.00	0.6	60				

Input Data WQM 7.0

	SWP Basir			Stre	eam Name		RMI		ation ft)	Drainag Area (sq mi		lope ft/ft)	PW Withda (mg	rawal	Apply FC
	20D	33	564 RACC	OON CRI	EEK		32.70	00	903.00	61	.10 0.	00000		0.00	✓
					St	ream Dat	a								
Design	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tem	Tributan p	<u>/</u> pH	Tem	Stream p	<u>p</u> H	
Cond.	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)		
Q7-10 Q1-10 Q30-10	0.039	0.00 0.00 0.00	0.00	0.000 0.000 0.000	0.000 0.000 0.000	0.0	0.00	0.00) !	5.00	7.00	(0.00	0.00	
					D	scharge	Data								
			Name	Per	mit Numbe	Disc	Permitte Disc Flow (mgd)	Disc Flow	Res V Fa	erve ctor	Disc Temp (°C)	Di p	sc H		
						0.000	0.000	0.00	000 (0.000	25.0	0	7.00		
					Pa	arameter	Data								
			ı	Paramete	r Name				Stream Conc	Fate Coef					
				aramete	i Name	(m	ng/L) (n	ng/L)	(mg/L)	(1/days)				
			CBOD5				25.00	2.00	0.00	1.5	0				
			Dissolved	Oxygen			3.00	8.24	0.00	0.0	0				
			NH3-N				25.00	0.00	0.00	0.7	0				

WQM 7.0 Hydrodynamic Outputs

		<u>P Basin</u> 20D		<u>m Code</u> 3564				Stream CCOON	<u>Name</u> I CREEK			
RMI	Stream Flow	PWS With	Net Stream		Reach Slope	Depth	Width	W/D Ratio	Velocity	Trav	Analysis Temp	Analysis pH
	(cfs)	(cfs)	Flow (cfs)	Flow (cfs)	(ft/ft)	(ft)	(ft)		(fps)	Time (days)	(°C)	
	0 Flow											
33.700	1.73	0.00	1.73	.2785	0.00322	.611	25.31	41.43	0.13	0.470	6.38	7.00
Q1-1	0 Flow											
33.700	1.11	0.00	1.11	.2785	0.00322	NA	NA	NA	0.11	0.578	7.01	7.00
Q30-	10 Flow	,										
33.700	2.36	0.00	2.36	.2785	0.00322	NA	NA	NA	0.15	0.404	6.06	7.00

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	~
WLA Method	EMPR	Use Inputted W/D Ratio	✓
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	~
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	
D.O. Saturation	90.00%	Use Balanced Technology	~
D.O. Goal	5		

Wonday, March 21, 2022 Version 1.1 Page 1 of 1

WQM 7.0 Wasteload Allocations

	SWP Basin Str	eam Code		St	ream Name		
	20D	33564		RAC	COON CREEK	<	
NH3-N	Acute Allocatio	ns					
RMI	Discharge Name	Baseline e Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
33.70	0 Bavington STP	24.1	41.4	24.1	41.4	0	0
NH3-N (Chronic Allocat	ions					
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction

Dissolved Oxygen Allocations

33.700 Bavington STP

		CBC			3-N	Dissolved	d Oxygen	Critical	Percent
RMI	Discharge Name	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Mulupie	Dascillic	Mulupie	Reach	Reduction
33.70	Bavington STP	25	25	20.7	20.7	4	4	0	0

4.36

20.7

0

0

20.7

4.36

WQM 7.0 D.O.Simulation

SWP Basin St	ream Code 33564		R	Stream Name ACCOON CRE	-	
RMI 33.700 Reach Width (ft) 25.306 Reach CBOD5 (mg/L) 5.19 Reach DO (mg/L) 11.331 Reach Travel Time (days) 0.470	Total Discharge 0.180 Reach De 0.61 Reach Kc (0.930 Reach Kr (3.970 TravTime (days)	0 pth (ft) 1 1/days) 6 1/days)	<u>R</u>	lysis Temperatu 6.385 Reach WDRat 41.433 leach NH3-N (m 2.87 Kr Equation Tsivoglou D.O. (mg/L)	io ng/L)	Analysis pH 7.000 Reach Velocity (fps) 0.130 Reach Kn (1/days) 0.210 Reach DO Goal (mg/L) 5
	0.047 0.094 0.141 0.188 0.235 0.282 0.329 0.376 0.423 0.470	5.06 4.95 4.83 4.72 4.61 4.50 4.40 4.30 4.20 4.10	2.84 2.81 2.78 2.76 2.73 2.70 2.68 2.65 2.62 2.60	11.06 11.04 10.99 10.95 10.92 10.90 10.88 10.88 10.88		

WQM 7.0 Effluent Limits

		<u>ım Code</u> 3564	Stream Name RACCOON CREEK						
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)		
33.700	Bavington STP	PA0253472	0.180	CBOD5	25				
				NH3-N	20.7	41.4			
				Dissolved Oxygen			4		

Attachment # 4 - TMS Version 1.3



Toxics Management Spreadsheet Version 1.3, March 2021

Discharge Information

Instructions	Disch	arge	Stream				
Facility:	Bavingt	on STF	•		NPDES Permit No.:	PA0253472	Outfall No.: 001
Evaluation T	ype:	Major	Sewage / Ind	lustrial Waste	Wastewater Descrip	tion: Sewage Effluen	t - Minor 0.18 MGD

Discharge Characteristics											
Design Flow	Hardnoce (mg/l)*	ьЦ (CII)*	Partial Mix Factors (PMFs)				Complete Mix Times (min)				
(MGD)*	Hardness (mg/l)*	pH (SU)*	AFC CFC THH CRL Q ₇₋₁₀ Q _h								
0.18	214.5	7	1 1								

					0 if lef	t blank	0.5 if le	ft blank	() if left blan	k	1 if lef	t blank
	Discharge Pollutant	Units	Ma	x Discharge Conc	Trib Conc	Stream Conc	Daily CV	Hourly CV	Strea m CV	Fate Coeff	FOS	Criteri a Mod	Chem Transi
	Total Dissolved Solids (PWS)	mg/L		554									
7	Chloride (PWS)	mg/L		80.3									
	Bromide	mg/L	٧	0.1									
5	Sulfate (PWS)	mg/L		133									
	Fluoride (PWS)	mg/L											
	Total Aluminum	μg/L		17									
	Total Antimony	μg/L											
	Total Arsenic	μg/L											
	Total Barium	μg/L											
	Total Beryllium	μg/L											
	Total Boron	μg/L											
	Total Cadmium	μg/L											
	Total Chromium (III)	μg/L											
	Hexavalent Chromium	μg/L											
	Total Cobalt	μg/L											
	Total Copper	μg/L		22.7									
2	Free Cyanide	μg/L											
l ğ	Total Cyanide	μg/L											
Group	Dissolved Iron	μg/L											
	Total Iron	μg/L		60									
	Total Lead	μg/L		0.07									
	Total Manganese	μg/L		6									
	Total Mercury	μg/L											
	Total Nickel	μg/L											
	Total Phenols (Phenolics) (PWS)	μg/L											
	Total Selenium	μg/L											
	Total Silver	μg/L											
	Total Thallium	μg/L											
	Total Zinc	μg/L		48									
	Total Molybdenum	μg/L											
	Acrolein	μg/L	<										
	Acrylamide	μg/L	<										
	Acrylonitrile	μg/L	~										
	Benzene	μg/L	<										
	Bromoform	μg/L	<										

1	0 1 7 11 11							
	Carbon Tetrachloride	μg/L	<					
	Chlorobenzene	μg/L						
	Chlorodibromomethane	μg/L	<					
	Chloroethane	μg/L	<					
	2-Chloroethyl Vinyl Ether	μg/L	<					
	Chloroform	μg/L	<					
	Dichlorobromomethane	μg/L	<					
	1,1-Dichloroethane	μg/L	<					
က	1,2-Dichloroethane	μg/L	<					
<u>~</u>	1,1-Dichloroethylene	μg/L	<					
Group	1,2-Dichloropropane	μg/L	<					
ō	1,3-Dichloropropylene	μg/L	<					
	1,4-Dioxane	μg/L	<					
	Ethylbenzene	μg/L	<					
	Methyl Bromide	μg/L	<					
	Methyl Chloride	μg/L	<					
	Methylene Chloride		<					
		μg/L	<					
	1,1,2,2-Tetrachloroethane	μg/L	_					
	Tetrachloroethylene	μg/L	<					
	Toluene	μg/L	<					
	1,2-trans-Dichloroethylene	μg/L	<					
	1,1,1-Trichloroethane	μg/L	<					
	1,1,2-Trichloroethane	μg/L	<					
	Trichloroethylene	μg/L	<					
	Vinyl Chloride	μg/L	<					
	2-Chlorophenol	μg/L	<					
	2,4-Dichlorophenol	μg/L	<					
	2,4-Dimethylphenol	μg/L	<					
	4,6-Dinitro-o-Cresol	μg/L	<					
4	2,4-Dinitrophenol	μg/L	<					
Group 4	2-Nitrophenol	μg/L	<					
18	4-Nitrophenol	μg/L	<					
	p-Chloro-m-Cresol	μg/L	<					
	Pentachlorophenol	μg/L	<					
	Phenol	μg/L	<					
	2,4,6-Trichlorophenol	μg/L	<					
\vdash	Acenaphthene	μg/L	<					
	Acenaphthylene	μg/L	<					
	Anthracene	μg/L	<					
	Benzidine	μg/L	<					
	Benzo(a)Anthracene		<					
		μg/L	_					
	Benzo(a)Pyrene 3.4-Benzofluoranthene	μg/L	<					
	-,	μg/L	<					
	Benzo(ghi)Perylene	μg/L	<					
	Benzo(k)Fluoranthene	μg/L	<					
	Bis(2-Chloroethoxy)Methane	μg/L	<					
	Bis(2-Chloroethyl)Ether	μg/L	<					
	Bis(2-Chloroisopropyl)Ether	μg/L	<					
	Bis(2-Ethylhexyl)Phthalate	μg/L	<					
	4-Bromophenyl Phenyl Ether	μg/L	<					
	Butyl Benzyl Phthalate	μg/L	<					
	2-Chloronaphthalene	μg/L	<					
	4-Chlorophenyl Phenyl Ether	μg/L	<					
	Chrysene	μg/L	<					
	Dibenzo(a,h)Anthrancene	μg/L	<					
	1,2-Dichlorobenzene	μg/L	<					
	1,3-Dichlorobenzene	μg/L	<					
	1,4-Dichlorobenzene	μg/L	<					
p 5	3,3-Dichlorobenzidine	μg/L	<					
Group	Diethyl Phthalate	μg/L	<					
ō	Dimethyl Phthalate	μg/L	<					
	Di-n-Butyl Phthalate	μg/L	<					
	2,4-Dinitrotoluene		<					
1	Z,4-Diffilifololuerie	μg/L	<					

	0.0.00			1					
	2,6-Dinitrotoluene	μg/L	<						
	Di-n-Octyl Phthalate	μg/L	<						
	1,2-Diphenylhydrazine	μg/L	<						
	Fluoranthene	μg/L	<						
	Fluorene	μg/L	<						
	Hexachlorobenzene	μg/L	<						
	Hexachlorobutadiene	μg/L	<						
	Hexachlorocyclopentadiene	μg/L	<						
	Hexachloroethane	μg/L	<						
	Indeno(1,2,3-cd)Pyrene	μg/L	<						
	Isophorone	μg/L	<						
	Naphthalene	μg/L	<						
	Nitrobenzene	μg/L	<						
	n-Nitrosodimethylamine		<						
		μg/L	_						
	n-Nitrosodi-n-Propylamine	μg/L	<						
	n-Nitrosodiphenylamine	μg/L	<						
	Phenanthrene	μg/L	<						
	Pyrene	μg/L	<						
	1,2,4-Trichlorobenzene	μg/L	<						
	Aldrin	μg/L	<						
	alpha-BHC	μg/L	<						
	beta-BHC	μg/L	<						
	gamma-BHC	μg/L	<						
	delta BHC	μg/L	<						
	Chlordane	μg/L	<						
	4,4-DDT	μg/L	<						
	4,4-DDE	μg/L	<						
	4,4-DDD	μg/L	<						
	Dieldrin		_						
		μg/L	<						
	alpha-Endosulfan	μg/L	<						
	beta-Endosulfan	μg/L	<						
	Endosulfan Sulfate	μg/L	<						
5	Endrin	μg/L	<						
	Endrin Aldehyde	μg/L	<						
	Heptachlor	μg/L	<						
	Heptachlor Epoxide	μg/L	<						
	PCB-1016	µg/L	<						
	PCB-1221	μg/L	<						
	PCB-1232	μg/L	<						
	PCB-1242	μg/L	<						
	PCB-1248	μg/L	<						
	PCB-1254	μg/L	<						
	PCB-1260	μg/L	<						
	PCBs, Total	μg/L	<						
	Toxaphene	μg/L	<						
	2,3,7,8-TCDD	ng/L	<						
	Gross Alpha	pCi/L							
	Total Beta	pCi/L	<						
	Radium 226/228	pCi/L	<						
	Total Strontium	µg/L	<						
ō	Total Uranium		<						
		μg/L	_						
	Osmotic Pressure	mOs/kg							
					P				



Toxics Management Spreadsheet Version 1.3, March 2021

Stream / Surface Water Information

Bavington STP, NPDES Permit No. PA0253472, Outfall 001

Receiving Surface W	/ater Name:	Raccoon	Creek				No. Rea	aches to M	lodel:	1	_	tewide Criteri			
Location	Stream Co	de* RN	Elevat	I DΔ /mi	²)* SI	lope (ft/ft)		Withdrawa MGD)	Apply Crite		-	SANCO Crite			
Point of Discharge	033564	33	.7 920	44.3	(0.00322			Ye	S					
End of Reach 1	033564	32	.7 903	61.1	(0.00322			Ye	S					
Q ₇₋₁₀ Location	RMI	LFY (cfs/mi ²)*	Flow	(cfs)	W/D Ratio		Depth (ft)	Velocit y (fps)	Time	Tribut Hardness	ary pH	Strea	m pH*	Analys Hardness	sis pH
Point of Discharge	33.7	0.01955		,		21.16	0.57	0.09	(days)			100	7		
End of Reach 1	32.7	0.01955													
Q _h			-			-		-		-				+	
Location	RMI	LFY	Flow	(cfs)	W/D	Width	Depth	Velocit	Time	Tribut	ary	Strea	m	Analys	sis
LUCATION	KIVII	(cfs/mi ²)	Stream	Tributary	Ratio	(ft)	(ft)	y (fps)	Time (days)	Hardness	pН	Hardness	pН	Hardness	pН
Point of Discharge	33.7								.11718 31						
End of Reach 1	32.7														



Toxics Management Spreadsheet Version 1.3, March 2021

Model Results

Bavington STP, NPDES Permit No. PA0253472, Outfall 001

Instructions Results	RETURN	TO INPU	тѕ) (SAVE AS	PDF)	PRINT	·) • /	All () Inputs	○ Results	○ Limits		
☐ Hydrodynamics												
- Western Allered												
✓ Wasteload Allocations												
☑ AFC CC												
Pollutants	Conc	Stream	Trib Conc	Fate	WQC	WQ Obj	WLA (µg/L)		Cor	mments		
	(ug/L)	CV	(µg/L)	Coef	(µg/L)	(µg/L)				Time to		
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A					
Chloride (PWS)	0	0		0	N/A	N/A	N/A					
Sulfate (PWS)	0	0		0	N/A	N/A	N/A					
Total Aluminum	0	0		0	750	750	3,083					
Total Copper	0	0		0	16.941	17.6	72.5		Chem Transla	tor of 0.96 applied		
Total Iron	0	0		0	N/A	N/A	N/A					
Total Lead	0	0		0	84.305	112	459		Chem Translat	or of 0.755 applied		
Total Manganese	0	0		0	N/A	N/A	N/A					
Total Zinc	0	0		0	144.306	148	606		Chem Translat	or of 0.978 applied		
✓ CFC CC	T (min): 14	.390	PMF:	1	Ana	alysis Hardne	ess (mg/l):	127.86	Analysis pH:	7.00		
Pollutants	Conc	Stream	Trib Conc	Fate	WQC	WQ Obj	WLA (µg/L)		Cor	mments		
1 olidiants	(ug/L)	CV	(µg/L)	Coef	(µg/L)	(µg/L)	VEX (pg/E)		001	inicito		
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A					
Chloride (PWS)	0	0		0	N/A	N/A	N/A					
Sulfate (PWS)	0	0		0	N/A	N/A	N/A					
Total Aluminum	0	0		0	N/A	N/A	N/A					
Total Copper	0	0		0	11.048	11.5	47.3		Chem Transla	tor of 0.96 applied		
Total Iron	0	0		0	1,500	1,500	6,165	١	WQC = 30 day	average; PMF = 1		
Total Lead	0	0		0	3.285	4.35	17.9	(Chem Translat	or of 0.755 applied		
Total Manganese	0	0		0	N/A	N/A	N/A			••		
Total Zinc	0	0		0	145.486	148	606		Chem Translat	or of 0.986 applied		
☑ THH CC	T (min): 14	.390	PMF:	1	Ana	lysis Hardne	ess (mg/l):	N/A	Analysis pH:	N/A		

NPDES Permit Fact Sheet Bavington STP

Pollutants	Conc	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	500,000	500,000	N/A	
Chloride (PWS)	0	0		0	250,000	250,000	N/A	
Sulfate (PWS)	0	0		0	250,000	250,000	N/A	
Total Aluminum	0	0		0	N/A	N/A	N/A	
Total Copper	0	0		0	N/A	N/A	N/A	
Total Iron	0	0		0	N/A	N/A	N/A	
Total Lead	0	0		0	N/A	N/A	N/A	
Total Manganese	0	0		0	1,000	1,000	4,110	
Total Zinc	0	0		0	N/A	N/A	N/A	

 ✓ CRL
 CCT (min):
 7.112
 PMF:
 1
 Analysis Hardness (mg/l):
 N/A
 Analysis pH:
 N/A

Pollutants	Conc	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Total Aluminum	0	0		0	N/A	N/A	N/A	
Total Copper	0	0		0	N/A	N/A	N/A	
Total Iron	0	0		0	N/A	N/A	N/A	
Total Lead	0	0		0	N/A	N/A	N/A	
Total Manganese	0	0		0	N/A	N/A	N/A	
Total Zinc	0	0		0	N/A	N/A	N/A	

☑ Recommended WQBELs & Monitoring Requirements

No. Samples/Month: 4

	Mass	Limits		Concentra	ition Limits				
Pollutants	AML (lbs/day)	MDL (lbs/day)	AML	MDL	IMAX	Units	Governing WQBEL	WQBEL Basis	Comments
Total Copper	Report	Report	Report	Report	Report	μg/L	46.5	AFC	Discharge Conc > 10% WQBEL (no RP)
Total Zinc	Deport	Deport	Deport	Deport	Deport	ua/l	390	AEC	Discharge Conc > 10% MOREL (no DD)

✓ Other Pollutants without Limits or Monitoring

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., <= Target QL).

Pollutants	Governing WQBEL	Units	Comments
Total Dissolved Solids (PWS)	N/A	N/A	PWS Not Applicable
Chloride (PWS)	N/A	N/A	PWS Not Applicable

Model Results 7/5/2022 Page 6

NPDES Permit Fact Sheet Bavington STP

Bromide	N/A	N/A	No WQS
Sulfate (PWS)	N/A	N/A	PWS Not Applicable
Total Aluminum	1,976	μg/L	Discharge Conc ≤ 10% WQBEL
Total Iron	6,165	μg/L	Discharge Conc ≤ 10% WQBEL
Total Lead	17.9	μg/L	Discharge Conc ≤ 10% WQBEL
Total Manganese	4,110	μg/L	Discharge Conc ≤ 10% WQBEL

Model Results 7/5/2022 Page 7