

Northwest Regional Office CLEAN WATER PROGRAM

Application Type

Wastewater Type

Facility Type

Renewal

Sewage

SRSTP

NPDES PERMIT FACT SHEET INDIVIDUAL SFTF/SRSTP

 Application No.
 PA0263753

 APS ID
 1037492

 Authorization ID
 1352535

Applicant Name	Cheryl & Lee Arnold	Facility Name	Cheryl & Lee Arnold SRSTP
Applicant Address	8105 Edinboro Road	Facility Address	8105 Edinboro Road
	Erie, PA 16509-4468		Erie, PA 16509-4468
Applicant Contact	Cheryl Arnold	Facility Contact	
Applicant Phone	None provided	Facility Phone	
Applicant E Mail	None provided	Facility E Mail	
Client ID	362599	Site ID	738297
Municipality	Summit Township	County	Erie
SIC Code	8800	SIC Code	4952
SIC Description	Private Households	SIC Description	Trans. & Utilities - Sewerage Systems
Application Received	March 26, 2021	WQM Required	Yes – transfer proposed
Application Accepted	June 3, 2021	WQM App. No.	WQG018784 T-1

Summary of Review

No violations are reported

The stream names have been changed to use published names

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		William #. Mentzer William H. Mentzer, P.E.	
		Environmental Engineering Specialist	September 15, 2021
X		Justin C. Dickey Justin C. Dickey, P.E. Environmental Engineer Manager	September 20, 2021

Discharge and Stream Data – 2 - Receiving Waters and PWS

charge, Receiving	y Wate	s and Water Supply Information	on		
Outfall No. 001			Design Flow (MGD)	0.0004	
Latitude	42º 1	58.70"	Longitude	-80° 6' 48.90"	
Latitude	42º 1	52.43"	Longitude	-80° 7' 4.42"	
Quad Name	Erie S	South	Quad Code	0205	
Nastewater:	treated single residence domestic wa				
Receiving Waters	Unna	med Tributary to Walnut Creek	Stream Code	unknown	
NHD Com ID	13420	05239	RMI	0.16	
Drainage Area	0.01 ((9.14 acres)	Yield (cfs/mi ²)		
Q ₇₋₁₀ Flow (cfs)	0		Q ₇₋₁₀ Basis	Dry stream 0.03931 HQ-CWF, MF none	
Elevation (ft)	1120.	63	Slope (ft/ft)		
Watershed No.	15-A		Chapter 93 Class.		
Existing Use	state	wide	Existing Use Qualifier		
Exceptions to Use	none		Exceptions to Criteria	none	
Comments Assessment Status		Impaired			
Cause(s) of Impairn	nent	Other Habitat Alterations, Silta	ition Water/Flow Variability		
Source(s) of Impair		Urban Runoff/Storm Sewers, I			
TMDL Status			Name		
Background/Ambient Data pH (SU)			ata Source		
DH (SU)					
Temperature (°F)					
Temperature (°F) Hardness (mg/L)					
Temperature (°F) Hardness (mg/L) Other:	m Publi	c Water Supply Intake <u>M</u>	III Creek Water Authority		
Temperature (°F) Hardness (mg/L) Other: Nearest Downstrea	m Publi .ake Er		ill Creek Water Authority Flow at Intake (cfs)	NA	

Changes Since Last Permit Issuance: none

Other Comments: none

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

	Effluent Limitations				Monitoring Requirements			
Parameter	Mass Units	Mass Units (lbs/day) (1)		Concentrations (mg/L)			Minimum ⁽²⁾	Required
	Average Monthly	Average Weekly	Minimum	Annual Average	Maximum	Instant. Maximum	Measurement Frequency	Sample Type
Flow (GPD)	Report Annl Avg	XXX	XXX	XXX	XXX	XXX	1/year	Estimate
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/month	Grab
BOD5	XXX	XXX	XXX	10.0	XXX	20.0	1/year	Grab
TSS	XXX	XXX	XXX	10.0	XXX	20.0	1/year	Grab
Fecal Coliform (No./100 ml)	XXX	XXX	XXX	200	XXX	XXX	1/year	Grab

Compliance Sampling Location: Outfall 001 after disinfection

Other Comments: UV radiation disinfection requirements are stated on the annual Maintenance Report (AMR)

1/month pH monitoring is being proposed per Regional policy for systems located in special protection watersheds (HQ or EV). JCD 9/20/2021