

Northwest Regional Office CLEAN WATER PROGRAM

Application Type

Facility Type

Major / Minor

Minor

NPDES PERMIT FACT SHEET INDIVIDUAL SEWAGE

Application No. PA0263851

APS ID 1068637

Authorization ID 1405263

Applicant Name	Keating	g Township	Facility Name	Keating Township Cyclone STP
Applicant Address	7160 R	oute 46	Facility Address	83 Peach Drive
	Smethp	ort, PA 16749-4700	<u></u>	Cyclone, PA 16726
Applicant Contact		IcClain, Chairman utwp@gmail.com)	Facility Contact	Amy Sipes, Stiffler, McGraw and Associates, Inc. (asipes@stiffler-mcgraw.com)
Applicant Phone	(814) 887-9921		Facility Phone	(814) 696-6280
Client ID	63228		Site ID	746168
Ch 94 Load Status	Not Ove	erloaded	Municipality	Keating Township
Connection Status	No Limi	tations	County	McKean
Date Application Rec	eived	August 1, 2022	EPA Waived?	Yes
Date Application Acc	epted	August 4, 2022	If No, Reason	-

Summary of Review

Act 14 - Proof of Notification was submitted and received.

A Part II Water Quality Management permit is not required at this time.

The applicant should be able to meet the limits of this permit, which will protect the uses of the receiving stream.

I. OTHER REQUIREMENTS:

SPECIAL CONDITIONS:

Solids Management

- A. Stormwater into Sewers
- 3. Right of Way
- C. Solids Handling
- D. Effluent Chlorine Optimization and Minimization
- E. Little or No Assimilative Capacity or Dilution

There are no open violations in efacts associated with the subject Client ID (63228) as of 11/29/2023. CWY 12/15/2023

Approve	Deny	Signatures	Date	
V		Stephen A. McCauley	11/20/2022	
^		Stephen A. McCauley, E.I.T. / Environmental Engineering Specialist	11/29/2023	
V		Chad W. Yurisic	12/15/2023	
Х		Chad W. Yurisic, P.E. / Environmental Engineer Manager		

Discharge, Receiving	Waters and Water Supply Inform	nation				
0.46.11.11		B : 5: 416-1				
Outfall No. 001		Design Flow (MGD)	0.085			
Latitude 41° 49	9' 06"	Longitude	-78° 35' 07"			
Quad Name		Quad Code				
Wastewater Descrip	otion: Sewage Effluent					
Desciving Weters	Kingua Craak	Chromo Codo	50500			
Receiving Waters	Kinzua Creek	Stream Code	56522			
NHD Com ID	112372123	RMI	34.0			
Drainage Area	0.738	Yield (cfs/mi²)	0.08			
Q ₇₋₁₀ Flow (cfs)	0.059	Q ₇₋₁₀ Basis	calculated			
Elevation (ft)	2100		0.00631			
Watershed No.	16-B		CWF			
Existing Use	_ -					
	<u>-</u>	Exceptions to Criteria				
Assessment Status	Impaired*					
Cause(s) of Impairm						
Source(s) of Impairn		age, Natural Sources, Source Unknown				
TMDL Status	Scheduled for 2019	Name				
Background/Ambien	nt Data	Data Source				
pH (SU)	<u>-</u>	-				
Temperature (°F)	<u>-</u> .					
Hardness (mg/L)	<u>-</u>					
Other:	<u>-</u>	-				
Nearest Downstream	m Public Water Supply Intake	Aqua Pennsylvania, Inc Em	lenton			
PWS Waters A	Allegheny River	Flow at Intake (cfs) 1,376				
PWS RMI 90	0.0	Distance from Outfall (mi)	147			

Sludge use and disposal description and location(s): All sludge is disposed of at an approved landfill.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the Pennsylvania Bulletin in accordance with 25 Pa. Code § 92a.82. Upon publication in the Pennsylvania Bulletin, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the Pennsylvania Bulletin at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

^{*} The aquatic life in the Kinzua Creek is impaired by metals due to Abandoned Mine Drainage (AMD) and siltation. The Kinzua Creek is listed on the PA 303(d) list for metals, but a TMDL has not been developed for it yet. This discharge consists of treated non-municipal sewage only. However, since the stream is impaired for AMD metals, per the SOP, monitoring for Total Aluminum, Total Iron, and Total Manganese will be added with this renewal.

NPDES Permit Fact Sheet Keating Township Cyclone STP

Narrative: This Fact Sheet details the determination of draft NPDES permit limits for an existing discharge of 0.085 MGD of treated sewage from a municipal STP in Keating Township, McKean County.

Treatment permitted under WQM Permit 4212401 consists of the following: A manually cleaned bar screen with bypass, an aerated 23,590 gallon surge tank with duplex grinder pumps, a 42,885 gallon anoxic tank, dual 24,770 gallon aeration tanks, dual 9,788 gallon hopper style clarifiers, and ultraviolet (UV) light disinfection. Sludge is digested in a 15,260 gallon aerobic tank and dried using two 2,232 square foot open access reed sludge drying beds.

1. Streamflow:

Potato Creek at Smethport, PA (USGS Gage No. 03009680):

Q₇₋₁₀: <u>13.4</u> cfs (USGS StreamStats)

Drainage Area: 160 sq. mi. (USGS StreamStats)

Yieldrate: <u>0.08</u> cfsm (Calculated)

Kinzua Creek at Outfall 001:

Yieldrate: <u>0.08</u> cfsm (Calculated above)

Drainage Area: <u>0.738</u> sq. mi. (USGS StreamStats)

% of stream allocated: 100% Basis: No nearby discharges

 Q_{7-10} : 0.059 cfs (Calculated)

2. Wasteflow:

Maximum discharge: 0.085 MGD = 0.131 cfs

Runoff flow period: 24 hours Basis: Runoff flow for municipal STPs

The calculated stream flow (Q7-10) is less than 3 times the permitted discharge flow. In accordance with the SOP, since this is an existing discharge, the treatment requirements in document number 391-2000-014, titled, "Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers", dated April 12, 2008, were not evaluated for this facility.

Flow will be required to be monitored as authorized under Chapter 92a.61, and as recommended in the SOP.

3. Parameters:

The following parameters were evaluated: pH, Total Suspended Solids, Fecal Coliform, E. Coli, Total Phosphorus, Total Nitrogen, NH₃-N, CBOD₅, Dissolved Oxygen, and Disinfection.

a. <u>pH</u>

Between 6.0 and 9.0 at all times

Basis: Application of Chapter 93.7 technology-based limits.

The measurement frequency was increased from 5/week to 1/day as recommended in the SOP, based on Table 6-3 in the "Technical Guidance for the Development and Specification of Effluent Limitations" (362-0400-001).

b. Total Suspended Solids

Limits are 30.0 mg/l as a monthly average and 60.0 as an instantaneous maximum.

Basis: Application of Chapter 92a47 technology-based limits.

c. Fecal Coliform

05/01 - 09/30: <u>200/100ml</u> (monthly average geometric mean)

1,000/100ml (instantaneous maximum)

10/01 - 04/30: 2,000/100ml (monthly average geometric mean)

10,000/100ml (instantaneous maximum)

Basis: Application of Chapter 92a47 technology-based limits

d. E. Coli

Monitoring was added for E. Coli at a frequency of 1/quarter.

Basis: Application of Chapter 92a.61 as recommended by the SOP for flows greater than 0.05 MGD

and less than 1.0 MGD.

e. <u>Phosphorus</u>

Chapter 96.5 does not apply. However, the previous monitoring for Total Phosphorus will be retained in accordance with the SOP, based on Chapter 92a.61.

f. <u>Total Nitrogen</u>

The previous monitoring for Total Nitrogen will be retained in accordance with the SOP, based on Chapter 92a.61.

g. <u>Ammonia-Nitrogen (NH₃-N)</u>

Median discharge pH to be used: 7.6 Standard Units (S.U.)

Basis: eDMR data from previous 12 months

Discharge temperature: 25°C (default value used in the absence of data)

Median stream pH to be used: 7.0 Standard Units (S.U.)

Basis: <u>default value used in the absence of data</u>

Stream Temperature: <u>20°C</u> (default value used for CWF modeling)

Background NH₃-N concentration: <u>0.0</u> mg/l

Basis: <u>Default value</u>

Calculated NH₃-N Summer limits: 2.1 mg/l (monthly average)

4.2 mg/l (instantaneous maximum)

Calculated NH₃-N Winter limits: 6.3 mg/l (monthly average)

<u>12.6</u> mg/l (instantaneous maximum)

Result: WQ modeling resulted in the summer NH3-N limits above (see Attachment 1). The winter limits

<u>previous permit.</u> Based on eDMR data, the more restrictive limits are attainable so they will be added with this renewal without a compliance schedule.

	added with this renewal w	ithout a	compliance schedule.
h.	CBOD ₅		
	Median discharge pH to be used:	<u>7.6</u>	Standard Units (S.U.)
		В	asis: eDMR data from previous 12 months
	Discharge temperature:	<u>25°C</u>	(default value used in the absence of data)
	Median stream pH to be used:	<u>7.0</u>	Standard Units (S.U.)
		В	asis: default value used in the absence of data
	Stream Temperature:	<u>20°C</u>	(default value used for CWF modeling)
	Background CBOD ₅ concentration:	<u>2.0</u>	mg/l
		В	asis: <u>Default value</u>
	Calculated CBOD ₅ limits:	<u>25.0</u>	mg/l (monthly average)
		<u>50.0</u>	mg/l (instantaneous maximum)
	Result: WQ modeling resulted in the same as in the previous		lated CBOD5 limits above (see Attachment 1). These limits are t and will be retained.
i.	Influent Total Suspended Solids and	BOD ₅	
	Monitoring for these two parameters under Chapter 92a.61.	will be re	tained as recommended in the SOP for POTWs, as authorized
j.	Dissolved Oxygen (DO)		
	SOP based on Chapter 93.7, under t	he autho DES Peri	s recommended by the WQ Model (see Attachment 1) and the prity of Chapter 92a.61. This minimum replaces the previous 4.0 mit. Based on the eDMR data, the new minimum is achievable,
	·		rom 5/week to 1/day as recommended in the SOP, based on Development and Specification of Effluent Limitations"
k.	<u>Disinfection</u>		
	☑ Ultraviolet (UV) light monitoring)	
	☐ Total Residual Chlorine (TRC)	limits:	mg/l (monthly average)
		_	mg/l (instantaneous maximum)

Basis: Monitoring for UV Intensity (µw/cm²) will be retained with this renewal.

The measurement frequency was increased from 5/week to 1/day as recommended in the SOP, based on Table 6-3 in the "Technical Guidance for the Development and Specification of Effluent Limitations" (362-0400-001).

4. Reasonable Potential Analysis for Receiving Stream:

A Reasonable Potential Analysis was performed in accordance with State practices for Outfall 001 using the Department's Toxics Management Spreadsheet (see Attachment 2).

Result: The discharge concentrations for the following parameters were found to be greater than 10% of the calculated WQBELs:

Parameter	Discharge Conc. (μg/l)	WQBEL (µg/l)	%WQBEL
Total Aluminum	120	750	>10%
Total Copper	11.2	13.5	>50%
Total Iron	858	2,175	>10%
Total Lead	0.7	4.61	>10%
Total Zinc	87	120	>50%

Per the SOP, since the maximum discharge concentrations for Total Copper and Total Zinc were greater than 50% of the calculated WQBEL, new limits were added.

Also per the SOP, since the maximum discharge concentrations for Total Aluminum, Total Iron, and Total Lead were greater than 10% of the calculated WQBELs, 1/quarter monitoring will be set with the NPDES Permit renewal.

5. Reasonable Potential for Downstream Public Water Supply (PWS):

The Department's Toxics Management Spreadsheet does not calculate limits for parameters that are based on PWS criteria (TDS, Chloride, Bromide, and Sulfate). However, since no sample data was provided, mass-balance calculations were not performed.

Nearest Downstream potable water supply (PWS): Aqua Pennsylvania, Inc. - Emlenton

Distance downstream from the point of discharge: 147.0 miles (approximate)

Result: No limits are necessary as significant dilution is available

6. Flow Information:

The Keating Township Cyclone STP receives flow from the Villages of Ormsby, Cyclone, Gifford, and Aiken in the Keating Township in McKean County. All the sewers are separate sewers.

7. Anti-Backsliding:

A WQBEL for Total Iron was set in the previous permit. Based on the most recent sampling results for Total Iron, the previous limit is no longer required. Monitoring for Total Iron will replace the previous limits based on 40 CFR §122.44(I)(i)(B)(1).

All other permit limits in this renewal are the same or more restrictive than the previous NPDES Permit.

8. Attachment List:

Attachment 1 - WQ Modeling Printouts

Attachment 2 - Toxics Management Spreadsheet

(The Attachments above can be found at the end of this document)

Compliance History

DMR Data for Outfall 001 (from October 1, 2022 to September 30, 2023)

Parameter	SEP-23	AUG-23	JUL-23	JUN-23	MAY-23	APR-23	MAR-23	FEB-23	JAN-23	DEC-22	NOV-22	OCT-22
Flow (MGD)												
Average Monthly	0.0216	0.02271	0.02235	0.02189	0.02210	0.02180	0.02256	0.02138	0.02332	0.02405	0.02329	0.02217
Flow (MGD)												
Daily Maximum	0.0224	0.02416	0.02407	0.03063	0.02706	0.02940	0.02926	0.02849	0.02855	0.03331	0.03468	0.02794
pH (S.U.)												
Instantaneous Minimum	7.3	7.2	7.43	7.52	7.55	7.54	7.47	7.53	7.36	7.31	7.28	7.32
pH (S.U.)												
Instantaneous Maximum	7.91	7.6	8.4	7.94	8.03	8.33	7.92	7.92	7.89	7.72	7.90	7.87
DO (mg/L)												
Instantaneous Minimum	5.13	6.4	6.04	6.82	9.53	8.33	9.9	6.32	7.41	9.07	9.25	6.81
CBOD5 (lbs/day)												
Average Monthly	0.8	0.9	0.6	< 0.7	1.1	1.7	1.6	2.9	0.9	1.2	0.6	0.7
CBOD5 (lbs/day)												
Weekly Average	1.0	1.0	0.9	0.9	1.7	2.7	2.1	7.6	1.1	2.2	0.7	1.1
CBOD5 (mg/L)												
Average Monthly	4.45	4.4	3.7	< 4.0	6.4	10.0	8.3	15.1	4.3	6.4	3.1	3.8
CBOD5 (mg/L)												
Weekly Average	7.15	5.37	6.1	5.0	10.0	15.0	10.0	38.0	5.0	11.0	4.0	5.0
BOD5 (lbs/day)												
Influent Average Monthly	< 26.0	49.0	24.0	22	27	40	40	31	37	33	34	20
BOD5 (mg/L)												
Influent Average Monthly	< 144.0	232.8	142.0	129	154	237	208	172	48	169	177	107
TSS (lbs/day)												
Average Monthly	< 0.8	2.0	0.7	1.2	2.5	1.9	2.1	1.7	1.4	2.2	0.9	1.6
TSS (lbs/day)												
Influent Average Monthly	20.0	40.0	27.0	42	27	32	29	37	19	23	25	23
TSS (lbs/day)												
Weekly Average	1.0	3.0	0.9	1.4	5.5	3.4	3.6	2.8	1.6	3.4	1.2	3.9
TSS (mg/L)												
Average Monthly	< 4.4	8.5	4.3	7	15	11	11	10.0	7	11.0	5.0	9.0
TSS (mg/L)												
Influent Average Monthly	111.0	191.0	155.0	254	33	192	151	208	31	123	130	122
TSS (mg/L)												
Weekly Average	7.5	13.0	5.0	8	34	22	19	17.0	8	16.0	6.0	22.0
Fecal Coliform (No./100 ml)												
Geometric Mean	7.0	18.0	27.0	86	415	21	< 1	9	4	2	6	8
Fecal Coliform (No./100 ml)												
Instantaneous Maximum	8.5	25.6	34.1	93.2	2419.6	88	1	13.2	8.5	3.1	16	20.1

NPDES Permit Fact Sheet Keating Township Cyclone STP

UV Intensity (µw/cm²) Average Monthly	71.0	75.0	174.0	73	44	38	50	46	52	69	74	79
UV Intensity (µw/cm²)	7 1.0	70.0	17 1.0	70		- 00	- 00	10	- 02	- 00	, , ,	70
Instantaneous Maximum	120.0	90.0	174.0	137	144	42	76	75	95	98	99	125
Total Nitrogen (lbs/day)												
Average Quarterly	9.0			0.803			2.73			5.866		
Total Nitrogen (mg/L)												
Average Quarterly	39.19			4.47			13.8			33.385		
Ammonia (lbs/day)												
Average Monthly	< 0.02	< 0.02	< 0.2	< 0.3	< 0.03	0.1	0.07	< 0.03	< 0.02	< 0.04	< 0.02	< 0.02
Ammonia (mg/L)												
Average Monthly	< 0.1	< 0.1	< 0.1	< 2.3	< 0.2	0.6	0.4	< 0.2	< 0.10	< 0.2	< 0.10	< 0.10
Total Phosphorus (lbs/day)												
Average Quarterly	0.5			0.2552			0.3809			0.421		
Total Phosphorus (mg/L)												
Average Quarterly	2.7			1.42			1.92			2.40		
Total Iron (lbs/day)												
Average Monthly	< 0.04	0.06	0.05	0.1	0.06	0.06	0.08	0.09	0.04	0.05	0.04	< 0.04
Total Iron (mg/L)												
Average Monthly	< 0.2	0.364	0.275	0.857	0.31	0.343	0.422	0.478	0.224	0.252	0.226	< 0.219
Total Iron (mg/L)												
Instantaneous Maximum	< 0.2	0.377	0.325	0.858	0.346	0.444	0.602	0.575	0.238	0.263	0.249	0.238

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

		Monitoring Re	quirements					
Doromotor	Mass Units	(lbs/day) (1)		Concentrat	ions (mg/L)		Minimum (2)	Required
Parameter	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum	Measurement Frequency	Sample Type
		Report						
Flow (MGD)	Report	Daily Max	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0 Daily Min	XXX	9.0 Daily Max	XXX	1/day	Grab
DO	XXX	XXX	5.0 Daily Min	XXX	XXX	XXX	1/day	Grab
CBOD5	17.7	26.5	XXX	25.0	37.5	50	1/week	24-Hr Composite
BOD5 Raw Sewage Influent	Report	XXX	XXX	Report	XXX	XXX	1/week	24-Hr Composite
TSS	21.2	31.9	XXX	30.0	45.0	60	1/week	24-Hr Composite
TSS Raw Sewage Influent	Report	XXX	XXX	Report	XXX	XXX	1/week	24-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/quarter	Grab
UV Intensity (μw/cm²)	XXX	XXX	XXX	Report	XXX	Report	1/day	Grab
Total Nitrogen	XXX	Report Daily Max	XXX	Report Daily Max	XXX	XXX	1/quarter	Grab
Ammonia Nov 1 - Apr 30	4.4	XXX	XXX	6.3	XXX	12.6	2/month	24-Hr Composite
Ammonia May 1 - Oct 31	1.4	XXX	XXX	2.1	XXX	4.2	2/month	24-Hr Composite

Outfall 001, Continued (from Permit Effective Date through Permit Expiration Date)

		Effluent Limitations								
Parameter	Mass Units	(lbs/day) ⁽¹⁾		Concentrat	Minimum ⁽²⁾	Required				
rarameter	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum	Measurement Frequency	Sample Type		
Total Phosphorus	XXX	Report Daily Max	XXX	Report Daily Max	XXX	XXX	1/quarter	Grab		
Total Aluminum (ug/L)	XXX	Report Daily Max	XXX	Report Daily Max	XXX	XXX	1/quarter	Grab		
Total Copper (ug/L)	0.0095	XXX	XXX	13.5	XXX	33.7	2/month	24-Hr Composite		
Total Iron (ug/L)	XXX	Report Daily Max	XXX	Report Daily Max	XXX	XXX	1/quarter	Grab		
Total Lead (ug/L)	XXX	Report Daily Max	XXX	Report Daily Max	XXX	XXX	1/quarter	Grab		
Total Manganese	XXX	Report Daily Max	XXX	Report Daily Max	XXX	XXX	1/quarter	Grab		
Total Zinc (ug/L)	0.085	XXX	XXX	120.0	XXX	300	2/month	24-Hr Composite		

Compliance Sampling Location: at Outfall 001, after Ultraviolet (UV) light disinfection.

Flow is monitor only based on Chapter 92a.61. The limits for pH and Dissolved Oxygen are technology-based on Chapter 93.7. The limits for CBOD₅, Total Suspended Solids, and Fecal Coliforms are technology-based on Chapter 92a.47. Monitoring for influent BOD₅ and influent TSS is based on Chapter 92a.61. Monitoring for E. Coli, UV Intensity, Total Nitrogen, Total Phosphorus, Total Aluminum, Total Iron, Total Manganese, and Total Iron is based on Chapter 92a.61. The limits for Ammonia-Nitrogen are water quality-based on Chapter 93.7. The limits for Total Copper and Total Zinc are water quality-based on Chapter 16.

Attachment 1

WQM 7.0 Effluent Limits

		eam Code		Stream Nam			
	16B	56522		KINZUA CREE	≣K		
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
34.000	Cyclone STP	PA0263851	0.085	CBOD5	25		*
				NH3-N	2.18	4.36	
				Dissolved Oxygen			5

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	✓
WLA Method	EMPR	Use Inputted W/D Ratio	
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	✓
D.O. Saturation	90.00%	Use Balanced Technology	✓
D.O. Goal	6		

WQM 7.0 D.O.Simulation

SWP Basin St	ream Code			Stream Name	
16B	56522			KINZUA CREEK	
<u>RMI</u>	Total Discharge	Flow (mgd	<u>) Ana</u>	lysis Temperature (°C)	Analysis pH
34.000	0.08	5		23.448	7.315
Reach Width (ft)	Reach Dep	oth (ft)		Reach WDRatio	Reach Velocity (fps)
5.374	0.392	2		13.703	0.090
Reach CBOD5 (mg/L)	Reach Kc (<u>1/days)</u>	<u>R</u>	each NH3-N (mg/L)	Reach Kn (1/days)
17.86	1.338			1.50	0.913
Reach DO (mg/L)	Reach Kr (Kr Equation	Reach DO Goal (mg/L)
6.007	26.60	5		Owens	6
Reach Travel Time (days)		Subreach	Poculte		
1.216	TravTime	CBOD5	NH3-N	D.O.	
	(days)	(mg/L)	(mg/L)	(mg/L)	
	0.122	14.76	1.35	6.97	
	0.243	12.20	1.20	7.26	
	0.365	10.08	1.08	7.48	
	0.486	8.33	0.96	7.67	
	0.608	6.89	0.86	7.74	
	0.729	5.69	0.77	7.74	
	0.851	4.71	0.69	7.74	
	0.973	3.89	0.62	7.74	
	1.094	3.21	0.55	7.74	
	1.216	2.66	0.50	7.74	

Input Data WQM 7.0

					iiip.	ut Date	A 88 CK.	VI 7.0						
	SWP Basin			Str	eam Name		RM		evation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	Witho	VS drawal gd)	App FC
	16B	565	522 KINZU	JA CREE	K		34.0	00	2100.00	0.74	0.000	00	0.00	V
					St	ream Dat	a							
Design	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	n Ten	<u>Tributary</u> np pH	Т	<u>Strear</u> emp	<u>m</u> pH	
Cond.	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C	;)		(°C)		
Q7-10 Q1-10 Q30-10	0.080	0.00 0.00 0.00	0.00 0.00 0.00	0.000 0.000 0.000	0.000	0.0	0.00	0.0	00 2	0.00 7	.00	0.00	0.00	
					Di	scharge I	Data						1	
			Name	Pe	rmit Number	Existing Disc r Flow (mgd)	Permit Disc Flow (mgc	Dis	sc Res	serve Te ictor	sc mp C)	Disc pH		
		Cyclo	ne STP	PA	0263851	0.0850	0.00	00 0.0	0000	0.000	25.00	7.60		
					Pa	arameter I	Data							
				Paramete	r Name			Trib Conc	Stream Conc	Fate Coef				
				i di dillioto	i iiuiiio	(m	ıg/L) (mg/L)	(mg/L)	(1/days)				
			CBOD5			:	25.00	2.00	0.00	1.50				
	Dissolved Oxygen						4.00	8.24	0.00	0.00				
			NH3-N			1	25.00	0.00	0.00	0.70				

Input Data WQM 7.0

								and in the s						
	SWP Basin			Stre	eam Name		RMI		evation (ft)	Drainage Area (sq mi)	Slop (ft/ft	With	WS drawal ngd)	Appl FC
	16B	56	522 KINZU	JA CREEI	K		32.20	00	2040.00	3.5	9 0.000	000	0.00	✓
					St	ream Dat	a							
Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth		<u>Tributary</u> np pH	1 1	<u>Strea</u> Temp	<u>m</u> pH	
Conu.	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)		
Q7-10 Q1-10 Q30-10	0.080	0.00 0.00 0.00	0.00 0.00 0.00	0.000 0.000 0.000	0.000	0.0	0.00	0.0	00 2	0.00 7	1.00	0.00	0.00	
					Di	scharge I	Data						Ī	
			Name	Per	rmit Number	Disc	Permitte Disc Flow (mgd)	Dis Flo	sc Res	erve Te	isc mp 'C)	Disc pH		
		-				0.0000	0.000	0.0	0000	0.000	25.00	7.00	-	
					Pa	arameter l	Data							
				Paramete	r Name			Γrib ≎onc	Stream Conc	Fate Coef				
	_					(m	g/L) (n	ng/L)	(mg/L)	(1/days)				
			CBOD5			:	25.00	2.00	0.00	1.50				
			Dissolved	Oxygen			3.00	8.24	0.00	0.00				
			NH3-N				25.00	0.00	0.00	0.70				
													-	

WQM 7.0 Wasteload Allocations

SWP Basin	Stream Code	Stream Name
16B	56522	KINZUA CREEK

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
34.00	0 Cyclone STP	7.97	10.26	7.97	10.26	0	0
	Ol						
H3-N (Chronic Allocati		Deseline	Multiple	Maritima	Critical	Davaant
H3-N (Chronic Allocati	ONS Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction

Dissolved Oxygen Allocations

		CBC	<u>DD5</u>	<u>NH</u>	<u>3-N</u>	Dissolved	d Oxygen	Critical	Percent
RMI	Discharge Name	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Reach	Reduction
34.00	Cyclone STP	25	25	2.18	2.18	5	5	0	0

WQM 7.0 Hydrodynamic Outputs

	<u>sw</u>	P Basin	Strea	m Code				<u>Stream</u>	<u>Name</u>			
		16B	5	6522			K	INZUA (CREEK			
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
Q7-1	0 Flow											
34.000	0.06	0.00	0.06	.1315	0.00631	.392	5.37	13.7	0.09	1.216	23.45	7.32
Q1-1	0 Flow											
34.000	0.04	0.00	0.04	.1315	0.00631	NA	NA	NA	0.08	1.299	23.88	7.38
Q30-	10 Flow	ı										
34.000	0.08	0.00	0.08	.1315	0.00631	NA	NA	NA	0.10	1.146	23.10	7.27

Attachment 2



Toxics Management Spreadsheet Version 1.4, May 2023

Discharge Information

Instructions	Disch	arge Stream				
Facility:	Keating	Township Cyclon	e STP	NPDES Permit No.:	PA0263851	Outfall No.: 001
Evaluation T	ype:	<mark>Major Sewage / In</mark>	dustrial Waste	Wastewater Descrip	tion: POTW sewage d	i <mark>scharge</mark>

			Discharge	Characteris	tics			
Design Flow	Hardness (mg/l)*	pH (SU)*	F	Partial Mix Fa	actors (PMF:	s)	Complete Mix	x Times (min)
(MGD)*	Hardness (mg/l)*	рн (50)	AFC	CFC	THH	CRL	Q ₇₋₁₀	Q _h
0.085	100	7.6						

					0 if lef	t blank	0.5 if le	eft blank	0	if left blan	k	1 if left	t blank
	Discharge Pollutant	Units	Max	x Discharge Conc	Trib Conc	Stream Conc	Daily CV	Hourly CV	Strea m CV	Fate Coeff	FOS	Criteri a Mod	Chem Transl
	Total Dissolved Solids (PWS)	mg/L											
12	Chloride (PWS)	mg/L											
ΙĦ	Bromide	mg/L											
Group	Sulfate (PWS)	mg/L											
-	Fluoride (PWS)	mg/L	,										
	Total Aluminum	μg/L		120									
	Total Antimony	μg/L											
	Total Arsenic	μg/L											
1	Total Barium	μg/L											
	Total Beryllium	μg/L											
	Total Boron	μg/L											
	Total Cadmium	μg/L											
	Total Chromium (III)	μg/L											
	Hexavalent Chromium	μg/L	0										
	Total Cobalt	μg/L											
	Total Copper	μg/L		11.2									
Group 2	Free Cyanide	μg/L											
۱ã	Total Cyanide	μg/L											
Ö	Dissolved Iron	μg/L											
	Total Iron	μg/L		858									
	Total Lead	μg/L		0.7									
	Total Manganese	μg/L		60									
	Total Mercury	μg/L											
	Total Nickel	μg/L											
	Total Phenols (Phenolics) (PWS)	μg/L											
	Total Selenium	μg/L											
	Total Silver	μg/L											
	Total Thallium	μg/L											
	Total Zinc	μg/L		87									
	Total Molybdenum	μg/L											
	Acrolein	μg/L	٧										
1	Acrylamide	μg/L	<										
1	Acrylonitrile	μg/L	٧										
1	Benzene	μg/L	<										
	Bromoform	μg/L	<										

1	Carbon Tetrachloride	μg/L	<				
	Chlorobenzene	μg/L					
	Chlorodibromomethane	μg/L	<				
	Chloroethane		/				
	2-Chloroethyl Vinyl Ether	μg/L	/ /				
		μg/L	<				
	Chloroform	μg/L					
	Dichlorobromomethane	μg/L	<	<u> </u>			
	1,1-Dichloroethane	μg/L	<				
60	1,2-Dichloroethane	μg/L	<				
Group	1,1-Dichloroethylene	μg/L	<				
1%	1,2-Dichloropropane	μg/L	<				
١٩	1,3-Dichloropropylene	μg/L	<				
	1,4-Dioxane	μg/L	٧				
	Ethylbenzene	μg/L	<				
	Methyl Bromide	μg/L	٧				
	Methyl Chloride	μg/L	<				
	Methylene Chloride	μg/L	<				
	1,1,2,2-Tetrachloroethane	μg/L	<				
	Tetrachloroethylene	μg/L	<				
	Toluene	μg/L	<				
	1,2-trans-Dichloroethylene	μg/L	<	+ +			
1	1,1,1-Trichloroethane	μg/L	/				
1	1,1,2-Trichloroethane		< <				
1	300 2	μg/L	1000				
1	Trichloroethylene	μg/L	<				
\vdash	Vinyl Chloride	μg/L	<				
	2-Chlorophenol	μg/L	<				
	2,4-Dichlorophenol	μg/L	<				
	2,4-Dimethylphenol	μg/L	<				
	4,6-Dinitro-o-Cresol	μg/L	<				
4	2,4-Dinitrophenol	μg/L	٧				
Group	2-Nitrophenol	μg/L	<				
้อั	4-Nitrophenol	μg/L	<				
	p-Chloro-m-Cresol	μg/L	<				
	Pentachlorophenol	μg/L	<				
	Phenol	μg/L	<				
	2,4,6-Trichlorophenol	μg/L	<				
	Acenaphthene	μg/L	<				
	Acenaphthylene	μg/L	<				
	Anthracene	μg/L	<	1 1			
	Benzidine	μg/L	<				
	Benzo(a) Anthracene	μg/L	<	+ +	<u> </u>		
	to a second						
1	Benzo(a)Pyrene	μg/L	<				
	3,4-Benzofluoranthene	μg/L					
1	Benzo(ghi)Perylene	μg/L	<				
1	Benzo(k)Fluoranthene	μg/L	<				
1	Bis(2-Chloroethoxy)Methane	μg/L	<				
l	Bis(2-Chloroethyl)Ether	μg/L	<				
l	Bis(2-Chloroisopropyl)Ether	μg/L	<				
1	Bis(2-Ethylhexyl)Phthalate	μg/L	<				
1	4-Bromophenyl Phenyl Ether	μg/L	٧				
1	Butyl Benzyl Phthalate	μg/L	٧				
1	2-Chloronaphthalene	μg/L	٧				
I	4-Chlorophenyl Phenyl Ether	μg/L	<				
1	Chrysene	μg/L	<				
I	Dibenzo(a,h)Anthrancene	μg/L	<				
1	1,2-Dichlorobenzene	μg/L	<				
1	1,3-Dichlorobenzene	μg/L	<				
l	1,4-Dichlorobenzene	μg/L	<				
p 5	3,3-Dichlorobenzidine	μg/L	<				
Group	Diethyl Phthalate	μg/L	\ <				
ပြ	Dimethyl Phthalate	μg/L	/				
1	Di-n-Butyl Phthalate		\ \				
1		μg/L	<				
	2,4-Dinitrotoluene	μg/L	<				


	2 C Di-itt-l		١.					
	2,6-Dinitrotoluene	μg/L	<					
	Di-n-Octyl Phthalate	μg/L	<					
	1,2-Diphenylhydrazine	μg/L	-					
	Fluoranthene	μg/L	<					
	Fluorene	μg/L	<				-	
	Hexachlorobenzene	μg/L	<					
	Hexachlorobutadiene	μg/L	<					
	Hexachlorocyclopentadiene	μg/L	<					
	Hexachloroethane	μg/L	<					
	Indeno(1,2,3-cd)Pyrene	μg/L	<					
	Isophorone	μg/L	<					
	Naphthalene	μg/L	<					
	Nitrobenzene	μg/L	<					
	n-Nitrosodimethylamine	μg/L	<					
	n-Nitrosodi-n-Propylamine	μg/L	<					
	n-Nitrosodiphenylamine	μg/L	<					
	Phenanthrene	μg/L	<					
	Pyrene	μg/L	٧					
	1,2,4-Trichlorobenzene	μg/L	<					
	Aldrin	μg/L	<					
	alpha-BHC	μg/L	<					
	beta-BHC	μg/L	<					
	gamma-BHC	μg/L	<					
	delta BHC	μg/L	<					
	Chlordane	μg/L	<					
	4,4-DDT	μg/L	<					
	4,4-DDE	µg/L	<					
	4,4-DDD	µg/L	<					
	Dieldrin	µg/L	<					
	alpha-Endosulfan	μg/L	<		_			
	beta-Endosulfan	μg/L	<					
,	Endosulfan Sulfate	µg/L	<					
dnois	Endrin	μg/L	<					
2	Endrin Aldehyde	µg/L	<					
,	Heptachlor	µg/L	<					
			<		-			
	Heptachlor Epoxide PCB-1016	μg/L	<		_			
	PCB-1016 PCB-1221	μg/L	<					
		μg/L						
	PCB-1232	μg/L	<					
	PCB-1242	μg/L	<					
	PCB-1248	μg/L	<				-	
	PCB-1254	μg/L	<					
	PCB-1260	μg/L	<					
	PCBs, Total	μg/L	<					
	Toxaphene	μg/L	<					
	2,3,7,8-TCDD	ng/L	<					
	Gross Alpha	pCi/L						
	Total Beta	pCi/L	<					
doolo	Radium 226/228	pCi/L	<					
2	Total Strontium	μg/L	<					
,	Total Uranium	μg/L	<					
	Osmotic Pressure	mOs/kg						
				8				



Toxics Management Spreadsheet Version 1.4, May 2023

Stream / Surface Water Information

Keating Township Cyclone STP, NPDES Permit No. PA0263851, Outfall 001





Toxics Management Spreadsheet Version 1.4, May 2023

Model Results

Keating Township Cyclone STP, NPDES Permit No. PA0263851, Outfall 001

nstruction	ns Results	RETU	JRN TO INPUTS	S	AVE AS PDI	• (PRINT	• All	◯ Inputs	O Results	O Limits	
☑ Hydro	dynamics											
7-10												
RMI	Stream Flow (cfs)	PWS Withdrawal (cfs)	Net Stream Flow (cfs)		je Analysis v (cfs)	Slope (ft/ft)	Depth (ft)	Width (f	t) W/D Ratio	Velocity (fps)	Time	Complete Mix Time (min)
34	0.06		0.06	0.	131	0.006	0.392	5.374	13.703	0.09	1.216	0.195
32.2	0.29		0.287	1								
) _h												
RMI	Stream Flow (cfs)	PWS Withdrawal (cfs)	Net Stream Flow (cfs)		je Analysis v (cfs)	Slope (ft/ft)	Depth (ft)	Width (f	t) W/D Ratio	Velocity (fps)	Time (days)	Complete Mix Time (min)
34	0.63		0.63	0.	131	0.006	0.72	5.374	7.46	0.196	0.561	0.557
32.2	2.497	-	2.50									
☑ Al	FC	CCT (min):	0.195	PMF:	1	(00.00000000000000000000000000000000000	s Hardness	(mg/l):	100	Analysis pH:	7.32	
	Pollutants	Cond	CV	rib Conc (µg/L)	Coef (μg/L)	(Pg/L)	LA (µg/L)		C	omments	
3.	Total Aluminu	000 000	0		3.1100	750	750	1,088				
	Total Coppe Total Iron	r 0	0			3.439 N/A	14.0 N/A	20.3 N/A		Chem Trans	ator of 0.96 a	applied
	Total Lead	0	0			4.581	81.6	118		Chem Transl	ator of 0.791	applied
1	otal Mangane	10000	0			N/A	N/A	N/A				
	Total Zinc	0	0		0 1	17.180	120	174		Chem Transla	ator of 0.978	applied
☑ CI	FC	CCT (min):	0.195	PMF:	1	Analysi	s Hardness	(mg/l):	100	Analysis pH:	7.32	
	Pollutants	Cond	CV Stream	rib Conc (µg/L)	Coef (μg/L)	(µg/L)	LA (µg/L)		C	omments	
	Total Aluminu		0			N/A	N/A	N/A				
	Total Coppe	r 0	0		0	3 956	9.33	13.5	· · · · · · · · · · · · · · · · · · ·	Chem Trans	ator of 0.96 a	applied

Model Results 11/29/2023 Page 5

MF = 1	WQC = 30 day average; PMF = 1	2,175	1,500	1,500	0	0	0	Total Iron
applied	Chem Translator of 0.791 applied	4.61	3.18	2.517	0	0	0	Total Lead
		N/A	N/A	N/A	0	0	0	Total Manganese
applied	Chem Translator of 0.986 applied	174	120	118.139	0	0	0	Total Zinc
3	Chem Translator of 0.986 a	174	120	118.139	0	0	0	Total Zinc

☑ THH CCT (min): 0.195 PMF: 1 Analysis Hardness (mg/l): N/A Analysis pH: N/A

Pollutants	Conc	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Aluminum	0	0		0	N/A	N/A	N/A	
Total Copper	0	0		0	N/A	N/A	N/A	
Total Iron	0	0		0	N/A	N/A	N/A	
Total Lead	0	0		0	N/A	N/A	N/A	
Total Manganese	0	0		0	1,000	1,000	1,450	
Total Zinc	Ω	0		Ω	N/A	N/A	N/A	

 ☑ CRL
 CCT (min):
 0.557
 PMF:
 1
 Analysis Hardness (mg/l):
 N/A
 Analysis pH:
 N/A

Pollutants	Conc	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Aluminum	0	0		0	N/A	N/A	N/A	
Total Copper	0	0		0	N/A	N/A	N/A	
Total Iron	0	0		0	N/A	N/A	N/A	
Total Lead	0	0		0	N/A	N/A	N/A	
Total Manganese	0	0		0	N/A	N/A	N/A	
Total Zinc	0	0		0	N/A	N/A	N/A	

☑ Recommended WQBELs & Monitoring Requirements

No. Samples/Month:

ontn: 4

	Mass	Limits		Concentra	tion Limits		l,		
Pollutants	AML (lbs/day)	MDL (lbs/day)	AML	MDL	IMAX	Units	Governing WQBEL	WQBEL Basis	Comments
Total Aluminum	Report	Report	Report	Report	Report	μg/L	750	AFC	Discharge Conc > 10% WQBEL (no RP)
Total Copper	0.01	0.014	13.5	20.3	20.3	μg/L	13.5	CFC	Discharge Conc ≥ 50% WQBEL (RP)
Total Iron	Report	Report	Report	Report	Report	μg/L	2,175	CFC	Discharge Conc > 10% WQBEL (no RP)
Total Lead	Report	Report	Report	Report	Report	μg/L	4.61	CFC	Discharge Conc > 10% WQBEL (no RP)
Total Zinc	0.085	0.12	120	174	174	μg/L	120	AFC	Discharge Conc ≥ 50% WQBEL (RP)

☑ Other Pollutants without Limits or Monitoring

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., <= Target QL).

Model Results 11/29/2023 Page 6

Pollutants	Governing WQBEL	Units	Comments
Total Manganese	1,450	µg/L	Discharge Conc ≤ 10% WQBEL