

Application Type Renewal
Facility Type Industrial
Major / Minor Major

**NPDES PERMIT FACT SHEET
INDIVIDUAL INDUSTRIAL WASTE (IW)
AND IW STORMWATER**

Application No. PA0265951
APS ID 848854
Authorization ID 1294755

Applicant and Facility Information

| | | | |
|---------------------------|--|------------------|--|
| Applicant Name | <u>Old Dominion Electric Cooperative</u> | Facility Name | <u>Wildcat Point Generation Facility</u> |
| Applicant Address | <u>4201 Dominion Boulevard</u> <u>Glen Allen, VA 23060-6149</u> | Facility Address | <u>546 S. Railroad Lane</u> <u>Peach Bottom, PA 17563</u> |
| Applicant Contact | <u>Dale Beam</u> | Facility Contact | <u>Brian Heinbaugh</u> |
| Applicant Phone | <u>(804) 747-0592</u> | Facility Phone | <u>(410) 658-1229</u> |
| Client ID | <u>313854</u> | Site ID | <u>785318</u> |
| SIC Code | <u>4911</u> | Municipality | <u>Fulton Township</u> |
| SIC Description | <u>Trans. & Utilities - Electric Services</u> | County | <u>Lancaster</u> |
| Date Application Received | <u>October 31, 2019</u> | EPA Waived? | <u>No</u> |
| Date Application Accepted | <u>November 6, 2019</u> | If No, Reason | <u>Major Facility</u> |
| Purpose of Application | <u>NPDES Renewal.</u> | | |

Summary of Review

Old Dominion Electric Cooperative has applied to the Pennsylvania Department of Environmental Protection (DEP) for reissuance of its National Pollutant Discharge Elimination System (NPDES) permit. The existing permit was issued on April 9, 2015 and became effective on May 1, 2015, authorizing discharge of treated industrial wastewater from the new facility. An amendment for the NPDES permit was issued on December 6, 2016. The existing permit expiration date was April 30, 2020, and the permit has been administratively extended since that time.

Per the previous fact sheet, this permit is for ODEC's Wildcat Point Generation Facility (WPGF) industrial wastewater discharge. The facility is a 1,000 megawatt combined-cycle, natural gas-fueled electric generation facility located in Cecil County, Maryland. WPGF is adjacent to the existing Rock Springs Generation Facility as a separate entity, but share an existing water tank and the existing 500-kilovolt switchyard. WPGF consists of two natural gas-fired combustion turbines and a steam turbine in a two-on-one combined cycle configuration. Approximately two-thirds of the 1,000 MW capacity is generated directly by the combustion turbines turning electrical generators. The remaining capacity is generated by the conversion of waste heat in the combustion turbine exhaust into steam that powers a steam-driven electrical generator. The steam is converted to boiler feed water in a condenser. The condenser is cooled by a closed-cycle system that transfers the heat from the condenser to the atmosphere through the evaporation of water in cooling towers. An intake supply pipeline transports cooling and process water for facility operation from the Conowingo Pond portion of the Susquehanna River to the WPGF site in Maryland. At the maximum design intake rate, 93% of the water withdrawn is sent to the cooling towers of WPGF. Approximately 3% of the intake water is used for inlet air conditioning and 3% is used by WPGF for steam-cycle makeup and other service water uses.

Wastewater is discharged to the Conowingo Pond through Outfall 001. The sources of wastewater consist of boiler blowdown, cycle makeup treatment, evaporative coolers, clarified raw water, and services water uses. No stormwater outfalls exist at this site in the Pennsylvania portion. An approval was gained from the Susquehanna River Basin Commission (SRBC) on March

| Approve | Deny | Signatures | Date |
|---------|------|---|------------------|
| X | | Benjamin R. Lockwood Benjamin R. Lockwood / Environmental Engineering Specialist | January 21, 2022 |
| X | | Maria D. Bebenek for Daniel W. Martin, P.E. / Environmental Engineer Manager | February 1, 2022 |
| X | | Maria D. Bebenek Maria D. Bebenek, P.E. / Program Manager | February 1, 2022 |

Summary of Review

5, 2014 which allows WPGF to withdraw and return 8.7 and 0.8 mgd, respectively, for a total maximum consumptive use of 7.9 mgd. The previous NPDES permit application listed a maximum daily discharge rate of 0.857 mgd. About 90% of the water withdrawn is evaporated, and the other 10% is returned to the pond (under the target concentration ratio of 10).

The intake screens are connected to an onshore pump house by two approximately 900 ft. long, 30 in. wide diameter pipes. 800 ft. of the pipes will be under the pond. The pump house is located south of the existing Chester Water Authority pump house. Regulations under Section 316(b) of the Clean Water Act apply to the intake structure. The intake and discharge structures are located a distance of 630 ft. and 940 ft., respectively, from the CWA intake. Conowingo Pond is a 14 mile portion of the Susquehanna River, bounded upstream by the Holtwood Dam and impounded downstream by the Conowingo Dam. The pond is the source and receiver of water for Peach Bottom Atomic Power Station (PBAPS), Muddy Run Pumped Storage Facility (MRPSF), and York Energy Center (YEC). The Conowingo Pond is also the drinking water supply for Chester Water Authority (CWA) and the City of Baltimore. The treatment units that are part of this facility include a raw water clarifier and filter press, two-pass reverse osmosis treatment – cooling tower makeup, a mixed-bed demineralizer system, condensate polisher – HRSG/stream turbine cycle, dichlorination – cooling tower blowdown, and an oil/water separator – water from building floor drains. The water withdrawn is clarified, chlorinated, treated with an anti-scaling agent, and then used in the cooling towers. About 90% of the water is evaporated in this process. The blowdown from the cooling towers will be chemically dechlorinated.

Changes in this renewal: Monitoring for Hexachlorobutadiene and 1,2,4 – Trichlorobenzene was added to the permit. 316(b) monitoring requirement was removed from Part C of the permit. Monitoring for TSS, TDS, Oil and Grease, Total Chromium, Total Zinc at Outfall 001 have been reduced from 1/week to 1/month. For Outfalls 101 and 102, monitoring for TSS and Oil and Grease have been reduced from 1/week to 1/month.

Supplemental information for this facility is provided at the end of this fact sheet.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

| Discharge, Receiving Waters and Water Supply Information | | | |
|--|-----------------------------|------------------------------|-------------------------------------|
| Outfall No. | 001 | Design Flow (MGD) | .857 |
| Latitude | 39° 44' 35" | Longitude | 76° 13' 41" |
| Quad Name | Conowingo Dam | Quad Code | 2136 |
| Wastewater Description: Boiler blowdown, Noncontact Cooling Water (NCCW), IMP 101, IMP 102 | | | |
| Receiving Waters | Susquehanna River (WWF, MF) | Stream Code | 6685 |
| NHD Com ID | 57473383 | RMI | 1.7 |
| Drainage Area | 27,000 mi ² | Yield (cfs/mi ²) | 0.13 |
| Q ₇₋₁₀ Flow (cfs) | 3,500 | Q ₇₋₁₀ Basis | Dam Release Rate Data / StreamStats |
| Elevation (ft) | 106.1 | Slope (ft/ft) | |
| Watershed No. | 7-K | Chapter 93 Class. | WWF, MF |
| Existing Use | N/A | Existing Use Qualifier | N/A |
| Exceptions to Use | N/A | Exceptions to Criteria | N/A |
| Assessment Status | Impaired | | |
| Cause(s) of Impairment | Polychlorinated Biphenyls | | |
| Source(s) of Impairment | Source Unknown | | |
| TMDL Status | N/A | Name | N/A |
| Nearest Downstream Public Water Supply Intake | Chester Water Authority | | |
| PWS Waters | Susquehanna River | Flow at Intake (cfs) | |
| PWS RMI | 1.69 | Distance from Outfall (ft) | 940 |

Changes Since Last Permit Issuance: None

Other Comments: This facility discharges to the Conowingo Pond portion of the Susquehanna River. As was done during the previous permit review, despite the abnormal flow process of this portion of the Susquehanna, a Q₇₋₁₀ was developed for modeling purposes for this permit. Per StreamStats, a Q₇₋₁₀ value of 3,620 cfs was determined at the point of discharge, with a drainage area of 27,000 mi². Additionally, according to SRBC's 2006 Conowingo Pond Management Plan, the release rates from the Conowingo and Holtwood dams reach a minimum of 3,500 cfs during the low flow months of July-November. The stream flow of 3,500 cfs will therefore be used in the modeling, as it is the more conservative of the two values. This is consistent with the past permit evaluation.

| Compliance History | |
|--------------------------------|---|
| Summary of DMRs: | A summary of the past 12-month DMR effluent data is presented on the next page of this fact sheet. |
| Summary of Inspections: | <p>8/20/2018: A routine inspection was conducted. Samples collected at the Susquehanna Pump Station were tested and within permit limits. It was recommended to ODEC to gather and record free chlorine results from the cooling tower after blowdown to ensure the blowdown water will have free chlorine results within permit limits before reaching Outfall 001. No other issues were noted.</p> <p>9/17/2019: A routine inspection was conducted. Samples collected at the Susquehanna Pump Station were tested and within permit limits. No other issues were noted.</p> <p>7/15/2020: An administrative inspection was conducted. It was noted that the facility was operating normally, and all units were online and operable. There were not any issues noted in the report.</p> <p>8/3/2021: A routine inspection was conducted. Samples collected at the Susquehanna Pump Station were tested and within permit limits. No other issues were noted.</p> |

Other Comments: There are currently no open violations associated with the permittee or the facility.

Compliance History

DMR Data for Outfall 001 (from November 1, 2020 to October 31, 2021)

| Parameter | OCT-21 | SEP-21 | AUG-21 | JUL-21 | JUN-21 | MAY-21 | APR-21 | MAR-21 | FEB-21 | JAN-21 | DEC-20 | NOV-20 |
|---|--------------|--------------|--------------|--------------|--------------|--------------|--------------|---------------|--------------|--------------|--------------|--------------|
| Flow (MGD) Average Monthly | 0.28729 4 | 0.30409 6 | 0.34126 | 0.36517 9 | 0.23659 9 | 0.03391 3 | 0.18320 7 | 0.10716 5 | 0.17174 2 | 0.04523 6 | 0.07379 7 | 0.22061 3 |
| Flow (MGD) Daily Maximum | 0.65580 8 | 0.77011 2 | 0.64249 6 | 0.76992 | 0.73373 2 | 0.46224 | 0.57488 | 0.34854 4 | 0.46566 4 | 0.26688 | 0.56233 6 | 0.72275 2 |
| pH (S.U.) Minimum | 7.0 | 6.9 | 7.0 | 7.0 | 7.0 | 7.2 | 7.0 | 6.8 | 6.4 | 7.0 | 7.1 | 6.99 |
| pH (S.U.) Instantaneous Maximum | 7.6 | 7.4 | 7.5 | 7.7 | 7.7 | 7.8 | 7.8 | 7.6 | 7.6 | 7.3 | 7.7 | 7.8 |
| Free Available Chlorine (mg/L) Daily Maximum | < 0.02 | < 0.02 | < 0.02 | < 0.02 | < 0.02 | 0.02 | < 0.02 | 0.11 | 0.02 | < 0.02 | < 0.02 | 0.02 |
| Free Available Chlorine (mg/L) Instantaneous Maximum | < 0.02 | < 0.02 | < 0.02 | < 0.02 | < 0.02 | 0.02 | < 0.02 | 0.20 | 0.02 | < 0.02 | < 0.02 | 0.02 |
| Temperature (°F) Average Monthly | 73 | 78 | 82 | 82 | 76 | 70 | 68 | 64 | 63 | 62 | 64 | 72 |
| Temperature (°F) Daily Maximum | 80 | 84 | 87 | 87 | 85 | 73 | 73.4 | 70 | 70.9 | 63 | 67.2 | 80.8 |
| TSS (mg/L) Average Monthly | 16 | 17 | 19 | 10 | 13 | 10 | < 7 | < 6 | < 5 | 11 | < 8 | < 5 |
| TSS (mg/L) Daily Maximum | 35 | 50 | 50 | 13 | 30 | 10 | 11 | 9 | < 5 | 19 | 10 | 5 |
| Total Dissolved Solids (mg/L) Effluent Net Average Monthly | 102.51 | -758.24 | -86.82 | -457.48 | -292.56 | NULL5.0 6 | 202.13 | NULL66. 94 | FF | 62.5 | 249.6 | -86.17 |
| Total Dissolved Solids (mg/L) Effluent Net Daily Maximum | 1127.92 | 799.06 | 386.1 | 1466.69 | 1249.82 | 1088.29 | 1202.53 | 440.08 | FF | 62.5 | 1153.33 | 664.99 |
| Oil and Grease (mg/L) Average Monthly | < 4 | < 4 | < 4.0 | < 4 | < 4 | < 4 | < 4 | < 4 | < 4 | < 4 | < 5 | < 4 |
| Oil and Grease (mg/L) Daily Maximum | < 4.3 | < 4.3 | < 4.3 | < 4.6 | < 4.6 | < 4.3 | < 4.5 | < 4.5 | < 4.2 | < 4.5 | 5.8 | < 4.5 |

NPDES Permit Fact Sheet
Wildcat Pt Gen Facility

NPDES Permit No. PA0265951

| | | | | | | | | | | | | |
|---|----------|----------|----------|---------------|----------|----------|----------|--------------|----------|--------------|----------------|----------|
| Oil and Grease (mg/L) Instantaneous Maximum | < 4.3 | < 4.3 | < 4.3 | < 4.6 | < 4.6 | < 4.3 | < 4.5 | < 4.5 | < 4.2 | < 4.5 | 5.8 | < 4.5 |
| Total Nitrogen (mg/L) Effluent Net Average Monthly | 5.06 | -0.09 | -3.97 | -9.52 | 3.7 | 5.48 | NULL.89 | NULL6.6 7 | FF | -6.64 | 0.33 | -9.23 |
| Total Nitrogen (lbs) Effluent Net Total Monthly | 803.22 | -9.77 | -253.67 | -821.05 | 352.11 | 84.54 | -89.95 | -743.67 | FF | -92.01 | 13.72 | -290.18 |
| Total Nitrogen (lbs) Other Annual Effluent Net Total Annual | | | | | | | | | | | NULL78 8.39 | |
| Total Phosphorus (mg/L) Effluent Net Average Monthly | -0.58 | -0.3 | NULL.06 | NULL.42 | -0.58 | -0.28 | NULL.25 | -0.92 | FF | -0.98 | -0.51 | NULL.44 |
| Total Phosphorus (lbs) Effluent Net Total Monthly | -91.95 | -31.21 | -68.05 | NULL22. 32 | -54.94 | -4.39 | -62.71 | -41.03 | FF | NULL3.6 3 | -21.37 | -45.40 |
| Total Phosphorus (lbs) Other Annual Effluent Net Total Annual | | | | | | | | | | | -437.32 | |
| Total Aluminum (mg/L) Daily Maximum | 1.6 | 1.9 | 0.9 | 0.35 | 1.1 | 0.41 | 0.18 | 0.16 | 0.13 | 0.22 | 0.63 | 0.53 |
| Total Aluminum (mg/L) Intake Daily Maximum | 0.40 | 0.33 | < 0.05 | 0.092 | 0.13 | 0.26 | 0.078 | 0.13 | E | 0.350 | 0.099 | 0.040 |
| Total Chromium (mg/L) Daily Maximum | < 0.0025 | 0.029 | < 0.013 | < 0.013 | < 0.0025 | < 0.0025 | 0.0011 | < 0.001 | < 0.001 | < 0.001 | < 0.001 | 0.0011 |
| Sulfate (mg/L) Daily Maximum | 703 | 677 | 759 | 1020 | 779 | 509 | 613 | 812 | 726 | 729 | 669 | 984 |
| Total Zinc (mg/L) Daily Maximum | < 0.01 | 0.012 | 0.058 | < 0.05 | < 0.01 | < 0.01 | 0.0044 | 0.0054 | 0.0045 | 0.0043 | 0.0082 | 0.0041 |
| Haloacetic Acids (mg/L) Daily Maximum | < 0.0471 | < 0.1753 | < 0.0274 | < 0.0544 | < 0.1753 | < 0.0148 | < 0.0576 | < 0.0798 | < 0.2367 | < 0.1495 | < 0.0607 | < 0.0532 |
| Monobromoacetic acid (mg/L) Daily Maximum | < 0.001 | < 0.001 | < 0.001 | < 0.001 | < 0.001 | < 0.001 | < 0.001 | < 0.001 | < 0.001 | < 0.001 | < 0.001 | < 0.001 |
| Monochloroacetic acid (mg/L) Daily Maximum | < 0.002 | 0.0025 | 0.0022 | 0.0022 | 0.0021 | < 0.002 | < 0.002 | < 0.002 | < 0.002 | < 0.002 | 0.0023 | < 0.002 |

NPDES Permit Fact Sheet
Wildcat Pt Gen Facility

NPDES Permit No. PA0265951

| | | | | | | | | | | | | |
|--|----------|----------|----------|----------|----------|-----------|----------|----------|----------|----------|----------|----------|
| Dibromoacetic acid (mg/L) Daily Maximum | < 0.001 | < 0.001 | < 0.001 | < 0.001 | < 0.001 | < 0.001 | < 0.001 | < 0.001 | < 0.001 | < 0.001 | < 0.001 | < 0.001 |
| Dichloroacetic acid (mg/L) Daily Maximum | 0.0112 | 0.0158 | 0.0135 | 0.012 | 0.0142 | 0.0047 | 0.0082 | 0.008 | 0.0287 | 0.0115 | 0.0131 | 0.0073 |
| Trichloroacetic acid (mg/L) Daily Maximum | 0.0319 | 0.155 | 0.0097 | 0.0382 | 0.157 | 0.0061 | 0.0454 | 0.0678 | 0.204 | 0.134 | 0.0433 | 0.0419 |
| Bromoform (mg/L) Daily Maximum | < 0.0005 | < 0.0005 | < 0.0005 | < 0.0005 | < 0.0005 | < 0.0005 | < 0.0005 | < 0.0005 | < 0.0005 | < 0.0005 | < 0.0005 | < 0.0005 |
| Chloride (mg/L) Daily Maximum | 460 | 402 | 440 | 503 | 503 | 319 | 387 | 437 | 363 | 326.0 | 269 | 410 |
| Bromide (mg/L) Daily Maximum | < 0.2 | < 0.05 | 0.0296 | 0.0381 | 0.0326 | < 0.05 | 0.0397 | 0.0759 | < 0.05 | < 0.05 | < 0.05 | < 0.05 |
| Dibromochloromethane (mg/L) Daily Maximum | < 0.0005 | < 0.0005 | < 0.0005 | < 0.0005 | < 0.0005 | < 0.0005 | < 0.0005 | < 0.0005 | < 0.0005 | < 0.0005 | < 0.0005 | < 0.0005 |
| Dichlorobromomethane (mg/L) Daily Maximum | < 0.0005 | < 0.0005 | < 0.0005 | < 0.0005 | < 0.0005 | < 0.0005 | < 0.0005 | < 0.0005 | < 0.0005 | < 0.0005 | < 0.0005 | < 0.0005 |
| Chloroform (mg/L) Daily Maximum | 0.0085 | 0.0097 | 0.0102 | 0.0045 | 0.0028 | 0.00087 | 0.0016 | 0.0011 | 0.0025 | 0.0016 | 0.0027 | 0.0032 |
| Trihalomethanes (mg/L) Daily Maximum | < 0.01 | < 0.0112 | < 0.0117 | < 0.006 | < 0.0043 | < 0.00237 | < 0.0031 | < 0.0026 | < 0.004 | < 0.0031 | < 0.0042 | < 0.0047 |

DMR Data for Outfall 102 (from November 1, 2020 to October 31, 2021)

| Parameter | OCT-21 | SEP-21 | AUG-21 | JUL-21 | JUN-21 | MAY-21 | APR-21 | MAR-21 | FEB-21 | JAN-21 | DEC-20 | NOV-20 |
|--|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|
| Flow (MGD) Average Monthly | 0.28666 | 0.30059 3 | 0.36129 | 0.41665 8 | 0.22550 3 | 0.12676 9 | 0.18743 6 | 0.14820 4 | 0.17305 6 | 0.11822 1 | 0.12262 3 | 0.16875 5 |
| Flow (MGD) Daily Maximum | 0.46189 3 | 0.67183 3 | 0.72963 8 | 0.72246 | 0.46555 4 | 0.43887 | 0.53879 3 | 0.27955 | 0.27378 7 | 0.22794 1 | 0.25509 4 | 0.65393 9 |
| TSS (mg/L) Average Monthly | < 5 | < 11 | < 6 | < 8 | < 7 | < 7 | < 7 | < 6 | < 5 | < 5 | < 5 | < 5 |
| TSS (mg/L) Daily Maximum | < 5 | 16 | 10 | 15 | 15 | 12 | 12 | 8 | < 5 | 5 | < 5 | < 5 |
| Oil and Grease (mg/L) Average Monthly | < 4 | < 4 | < 4 | < 4 | < 4 | < 5 | < 4 | < 4 | < 4 | < 4 | < 4 | < 4 |
| Oil and Grease (mg/L) Daily Maximum | < 4.4 | < 4.4 | < 4.2 | < 4.2 | < 4.5 | 7.7 | < 4.2 | < 4.2 | < 4.2 | < 4.3 | 5.1 | < 4.4 |

| | | | | | | | | | | | | |
|---|-------|-------|-------|-------|-------|-----|-------|-------|-------|-------|-----|-------|
| Oil and Grease (mg/L) Instantaneous Maximum | < 4.4 | < 4.4 | < 4.2 | < 4.2 | < 4.5 | 7.7 | < 4.2 | < 4.2 | < 4.2 | < 4.3 | 5.1 | < 4.4 |
|---|-------|-------|-------|-------|-------|-----|-------|-------|-------|-------|-----|-------|

Existing Effluent Limitations and Monitoring Requirements

The tables below summarize the effluent limits and monitoring requirements implemented in the existing NPDES permit.

Outfall 001

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|--|-------------------------------------|------------------|-----------------------|--------------------|------------------|---------------------|--|----------------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Total Monthly | Daily Maximum | Minimum | Average Monthly | Daily Maximum | Instant. Maximum | | |
| Flow (MGD) | Report Avg Mo | Report | XXX | XXX | XXX | XXX | Continuous | Measured |
| pH (S.U.) | XXX | XXX | 6.0 | XXX | XXX | 9.0 | 1/day | Grab |
| Free Available Chlorine | XXX | XXX | XXX | XXX | 0.2 | 0.5 | 1/day | Grab |
| Temperature (°F) | XXX | XXX | XXX | Report | 110 | XXX | Continuous | I-S |
| TSS | XXX | XXX | XXX | 30 | 60 | 75 | 1/week | 24-Hr Composite |
| Total Dissolved Solids Effluent Net | XXX | XXX | XXX | Report | Report | XXX | 1/week | 24-Hr Composite |
| Oil and Grease | XXX | XXX | XXX | 15 | 20 | 30 | 1/week | Grab |
| Total Chromium | XXX | XXX | XXX | XXX | 0.2 | XXX | 1/week | 24-Hr Composite |
| Total Zinc | XXX | XXX | XXX | XXX | 1.0 | XXX | 1/week | 24-Hr Composite |
| Total Aluminum | XXX | XXX | XXX | XXX | Report | XXX | 1/month | 24-Hr Composite |
| Total Aluminum Intake | XXX | XXX | XXX | XXX | Report | XXX | 1/month | 24-Hr Composite |
| Sulfate | XXX | XXX | XXX | XXX | Report | XXX | 1/month | 24-Hr Composite |
| Chloride | XXX | XXX | XXX | XXX | Report | XXX | 1/month | 24-Hr Composite |
| Bromide | XXX | XXX | XXX | XXX | Report | XXX | 1/month | 24-Hr Composite |
| Trihalomethanes | XXX | XXX | XXX | XXX | Report | XXX | 1/month | 24-Hr Composite |

Outfall 001 , Continued (from Permit Effective Date through Permit Expiration Date)

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|----------------------------------|-------------------------------------|------------------------|-----------------------|--------------------|------------------|---------------------|--|----------------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Total Monthly | Daily Maximum | Minimum | Average Monthly | Daily Maximum | Instant. Maximum | | |
| Dibromochloro-methane | XXX | XXX | XXX | XXX | Report | XXX | 1/month | 24-Hr Composite |
| Dichlorobromo-methane | XXX | XXX | XXX | XXX | Report | XXX | 1/month | 24-Hr Composite |
| Chloroform | XXX | XXX | XXX | XXX | Report | XXX | 1/month | 24-Hr Composite |
| Bromoform | XXX | XXX | XXX | XXX | Report | XXX | 1/month | 24-Hr Composite |
| Haloacetic Acids | XXX | XXX | XXX | XXX | Report | XXX | 1/month | 24-Hr Composite |
| Monobromoacetic acid | XXX | XXX | XXX | XXX | Report | XXX | 1/month | 24-Hr Composite |
| Monochloroacetic acid | XXX | XXX | XXX | XXX | Report | XXX | 1/month | 24-Hr Composite |
| Dibromoacetic acid | XXX | XXX | XXX | XXX | Report | XXX | 1/month | 24-Hr Composite |
| Dichloroacetic acid | XXX | XXX | XXX | XXX | Report | XXX | 1/month | 24-Hr Composite |
| Trichloroacetic acid | XXX | XXX | XXX | XXX | Report | XXX | 1/month | 24-Hr Composite |
| Total Nitrogen Effluent Net | Report | XXX | XXX | Report | XXX | XXX | 1/month | 24-Hr Composite |
| Total Nitrogen Effluent Net | XXX | Report Total Annual | XXX | XXX | XXX | XXX | 1/month | Calculation |
| Total Phosphorus Effluent Net | Report | XXX | XXX | Report | XXX | XXX | 1/month | 24-Hr Composite |
| Total Phosphorus Effluent Net | XXX | Report Total Annual | XXX | XXX | XXX | XXX | 1/month | Calculation |

Compliance Sampling Location: At discharge from facility for all parameters except temperature; temperature monitoring shall be performed at Outfall 001

Outfall 101

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|----------------|-------------------------------------|------------------|-----------------------|--------------------|------------------|---------------------|--|----------------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Average Monthly | Daily Maximum | Minimum | Average Monthly | Daily Maximum | Instant. Maximum | | |
| Flow (MGD) | Report | Report | XXX | XXX | XXX | XXX | Continuous | Measured |
| TSS | XXX | XXX | XXX | 30 | 100 | XXX | 1/week | Grab |
| Oil and Grease | XXX | XXX | XXX | 15 | 20 | 30 | 1/week | Grab |

Compliance Sampling Location: Cooling tower discharge line

Outfall 102

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|----------------|-------------------------------------|------------------|-----------------------|--------------------|------------------|---------------------|--|----------------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Average Monthly | Daily Maximum | Minimum | Average Monthly | Daily Maximum | Instant. Maximum | | |
| Flow (MGD) | Report | Report | XXX | XXX | XXX | XXX | Continuous | Measured |
| TSS | XXX | XXX | XXX | 30 | 100 | XXX | 1/week | Grab |
| Oil and Grease | XXX | XXX | XXX | 15 | 20 | 30 | 1/week | Grab |

Compliance Sampling Location: Internal monitoring point located at the point of combined discharge for all building wastewater sumps prior to its internal discharge to the cooling tower basin

Development of Effluent Limitations

| | | | |
|---|-------------|--------------------------|------------|
| Outfall No. | 001 | Design Flow (MGD) | .857 |
| Latitude | 39° 44' 35" | Longitude | 76° 13' 4" |
| Wastewater Description: Boiler blowdown, Noncontact Cooling Water (NCCW), IMP 101, IMP 102 | | | |

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

| Parameter | Limit (mg/l) | SBC | Federal Regulation | State Regulation |
|-------------------------|----------------------|-----------------|--------------------|------------------|
| pH | 6.0 – 9.0 S.U. | Min – Max | 423.15(b)(1) | 95.2(1) |
| Total Suspended Solids | 30 | Average Monthly | 423.15(b)(3) | |
| Total Suspended Solids | 100 | Daily Maximum | 423.15(b)(3) | |
| Oil and Grease | 15 | Average Monthly | 423.15(b)(3) | 95.2(2)(ii) |
| Oil and Grease | 20 | Daily Maximum | 423.15(b)(3) | |
| Oil and Grease | 30 | IMAX | | 95.2(2)(ii) |
| Free Available Chlorine | 0.2 | Average | 423.15(b)(10)(i) | |
| Free Available Chlorine | 0.5 | Maximum | 423.15(b)(10)(i) | |
| Total Chromium | 0.2 | Average Monthly | 423.15(b)(10)(i) | |
| Total Chromium | 0.2 | Daily Maximum | 423.15(b)(10)(i) | |
| Total Zinc | 1.0 | Average Monthly | 423.15(b)(10)(i) | |
| Total Zinc | 1.0 | Daily Maximum | 423.15(b)(10)(i) | |
| 126 Priority Pollutants | No detectable amount | | 423.15(b)(10)(i) | |

Effluent Limitations Guidelines

This facility is regulated by an Effluent Limitation Guideline (ELG) from the Code of Federal Regulations 40 CFR Part 423 Steam Electric Power Generating Point Source Category. Limits have been applied in the permit based on Part 423.15 – New Source Performance Standards (NSPS).

pH

PA Code Part 95.2(1) and 40 CFR Part 423.15(b) requires effluent pH limits of 6.0 to 9.0 standard units (S.U.) at all times in effluent. The permit will continue to require pH limit of 6.0 to 9.0 S.U.

Polychlorinated Biphenyls (PCBs)

The ELG Part 423.15(b)(2) states “There shall be no discharge of polychlorinated biphenyl compounds such as those commonly used for transformer fluid.” This statement will be included in the Part C conditions of the NPDES permit, which is consistent with the existing permit.

Total Suspended Solids

The ELG Part 423.15(b)(3) requires limits for TSS in low volume waste sources. The requirement is an average monthly limit of 30 mg/l, and a daily maximum limit of 100 mg/l. Multipliers of 2.0 and 2.5 will be used for the daily maximum and instantaneous maximum (IMAX) in accordance with DEP’s Guidance 362-0400-001. This results in a daily maximum limit of 60 mg/l, and an IMAX limit of 75 mg/l. These limits will be included, which is consistent with the existing permit. ODEC has requested a reduction in monitoring frequency from 1/week to 1/month for this parameter, as they have experienced no reoccurring issues related to compliance with any pollutant limits. Therefore, the frequency has been reduced to 1/month.

Oil and Grease

The ELG Part 423.15(b)(3) requires limits for oil and grease in low volume waste sources. The requirement is an average monthly limit of 15 mg/l, and a daily maximum limit of 20 mg/l. Additionally, 25 Pa Code § 95.2(2)(ii) requires an IMAX limit of 30 mg/l for oil and grease. These limits will be included, which is consistent with the existing permit limits. ODEC has requested a reduction in monitoring frequency from 1/week to 1/month for this parameter, as they have experienced no reoccurring issues related to compliance with any pollutant limits. Therefore, the frequency has been reduced to 1/month.

Free Available Chlorine

The ELG Part 423.15(b)(10)(i) requires limits for free available chlorine in cooling tower blowdown. The requirement is a concentration of 0.2 mg/l as an average concentration, and a concentration of 0.5 mg/l as a maximum concentration. DEP's Guidance Document No.362-2183-004 "Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry" states that the average FAC limit from the ELG should be included in the permit as a maximum daily, and the maximum limit should be included as an IMAX. This is consistent with the existing limits, which will remain in the permit. Additionally, the Guidance 362-2183-004 and ELG Part 423 requires the following language to be included in Part C of the NPDES permit:

"The term maximum daily concentration as it relates to chlorine discharge means the average analyses made over a single period of chlorine release which does not exceed two hours."

"The term 'free available chlorine' shall mean the value obtained using the amperometric titration method for free available chlorine described in "Standard methods for the Examination of Water and Wastewater," page 112 (13th edition)."

"Neither free available chlorine nor total residual chlorine may be discharged from any unit for more than two hours in any one day and not more than one unit in any plant may discharge free available or total residual chlorine at any one time unless the utility can demonstrate to the Regional Administrator or state, if the state has NPDES permit issuing authority, that the units in a particular location cannot operate at or below this level of chlorination."

This additional language will be included in Part C of the NPDES permit, which is consistent with the existing permit.

Total Chromium/Total Zinc

The ELG Part 423.15(b)(10)(i) requires limits for Total Chromium and Total Zinc. The requirement for Total Chromium is an average monthly limit of 0.2 mg/l and a maximum daily limit of 0.2 mg/l. The requirement for Total Zinc is an average monthly limit of 1.0 mg/l and a maximum daily limit of 1.0 mg/l. A maximum daily limit of 0.2 mg/l for Total Chromium and 1.0 mg/l for Total Zinc will remain, which is consistent with the existing permit. ODEC has requested a reduction in monitoring frequency from 1/week to 1/month for these parameters, as they have experienced no reoccurring issues related to compliance with any pollutant limits. Therefore, the frequency has been reduced to 1/month.

Priority Pollutants

The ELG Part 423.15(b)(10)(i) requires that any of the 126 Priority Pollutants contained in chemicals added for cooling tower maintenance should not be detectable, except for Total Zinc and total Chromium. In accordance with DEP's Guidance No. 362-2183-004, it is not always necessary to require monitoring for priority pollutants, and can be handled with a narrative condition instead. Since the chemical additives used at the facility do not contain any of the Priority Pollutants, a narrative condition was included in Part C of the permit. This is consistent with the existing permit. The Part C condition states

"Cooling tower blowdown discharges shall contain no detectable amounts of the 126 Priority Pollutants listed in 40 CFR Part 423, Appendix A, with the exception of Total Chromium and Total Zinc."

Total Dissolved Solids (TDS)

Total Dissolved Solids and its major constituents including Bromide, Chloride, and Sulfate have become statewide pollutants of concern and threats to DEP's mission to prevent violations of water quality standards. The requirement to monitor these pollutants must be considered under the criteria specified in 25 Pa. Code § 95.10 and the following January 23, 2014 DEP Central Office Directive:

For point source discharges and upon issuance or reissuance of an individual NPDES permit:

- Where the concentration of TDS in the discharge exceeds 1,000 mg/L, or the net TDS load from a discharge exceeds 20,000 lbs/day, and the discharge flow exceeds 0.1 MGD, Part A of the permit should include monitor and report for TDS, sulfate, chloride, and bromide. Discharges of 0.1 MGD or less should monitor and report for TDS, sulfate, chloride, and bromide if the concentration of TDS in the discharge exceeds 5,000 mg/L.
- Where the concentration of bromide in a discharge exceeds 1 mg/L and the discharge flow exceeds 0.1 MGD, Part A of the permit should include monitor and report for bromide. Discharges of 0.1 MGD or less should monitor and report for bromide if the concentration of bromide in the discharge exceeds 10 mg/L.

- Where the concentration of 1,4-dioxane (CAS 123-91-1) in a discharge exceeds 10 µg/l and the discharge flow exceeds 0.1 mgd, Part A of the permit should include monitor and report for 1,4-dioxane. Discharges of 0.1 mgd or less should monitor and report for 1,4-dioxane if the concentration of 1,4-dioxane in the discharge exceeds 100 µg/l.

ODEC reported a maximum effluent concentration of 2,840 mg/l for TDS. Based upon the data provided in the application, monitoring of TDS, Bromide, Chloride, and Sulfate will be required. These monitoring requirements were included in the existing permit, and will remain in the renewal. ODEC has requested a reduction in monitoring frequency from 1/week to 1/month for this parameter, as they have experienced no reoccurring issues related to compliance with any pollutant limits. Therefore, the frequency has been reduced to 1/month.

Toxics

Effluent sample results for toxic pollutants reported on the renewal application were entered into DEP's Toxics Management Spreadsheet Version 1.0 to develop appropriate permit requirements for toxic pollutants of concern. The Toxics Management Spreadsheet combines the functions of PENTOXSD and DEP's Toxics Screening Analysis. Based on effluent sample results reported on the application, the Toxics Management Spreadsheet recommended a limit for Hexachlorobutadiene, and monitoring for 1,2,4-Trichlorobenzene. A discharge hardness of 1080 mg/l and a pH of 8.2 were used in the Spreadsheet, taken from the application.

The TMS output provided specific partial mix factors for each criteria. These partial mix factors were multiplied by 2, to account for the fact that mixing occurs on two sides of the plume. The width and depth of the river at the point of discharge were stated in the previous permit application to be approximately 6,500 ft. and 14 ft., respectively. Additionally, elevations were provided in the previous application for the outfall location and at the PA/MD border. These values were all used in the TMS, and are consistent with how modeling was performed for the existing permit.

Stream pH and hardness inputs for the spreadsheet were based on data acquired from the National Water Quality Monitoring Council website. Data was analyzed from the Water Quality Network (WQN) Station ID 201 on the Susquehanna River from 2010 to 2020. A 90th percentile analysis was performed on the data and resulted in a Stream pH of 8.4 and a Stream Hardness of 270 mg/l.

This data was analyzed based on the guidelines found in DEP's Water Quality Toxics Management Strategy (Document No. 361-0100-003) and DEP's SOP No. BPNPSM-PMT-033. Spreadsheet results are attached to this fact sheet. The Toxics Management Spreadsheet uses the following logic:

- a. Establish average monthly and IMAX limits in the draft permit where the maximum reported concentration exceeds 50% of the WQBEL.
- b. For non-conservative pollutants, establish monitoring requirements where the maximum reported concentration is between 25% - 50% of the WQBEL.
- c. For conservative pollutants, establish monitoring requirements where the maximum reported concentration is between 10%-50% of the WQBEL.

Since the reported maximum concentration for Hexachlorobutadiene was greater than 50% of its WQBEL, the TMS produced an effluent limit. However, the maximum concentration reported in the application for Hexachlorobutadiene was based on a non-detect result of <3.1 µg/l. This was also true of 1,2,4-Trichlorobenzene; the maximum reported concentration was based on a non-detect results of <3.1 µg/l. Therefore, these parameters will be included in the permit as monitoring requirements with a sample frequency of 1/6 months. These parameters should be sampled at the Target Quantitation Limit of 0.5 µg/l to determine if they are parameters of concern. These parameters will be re-evaluated again during the next permit cycle to determine if they will remain, or can be removed from the permit. Total Aluminum monitoring was required in the existing permit, and will remain in the renewal. Due to concerns from Chester Water Authority during the previous application review regarding the potential concentrations of pollutants at the facility, monitoring requirements were added to the permit for trihalomethanes and haloacetic acids. These monitoring requirements will remain in the renewal permit.

Chemical Additives

The term chemical additive means a chemical product introduced into a waste stream that is used for cleaning, disinfecting, or maintenance and which may be detected in effluent discharged to waters of the Commonwealth. Generally, the term "chemical additive" excludes chemicals used for neutralization of waste streams, the production of goods, and treatment of wastewater. The following chemical additives will be used at the facility, and will replace the chemical additives currently used. These chemicals were not identified on the previous permit application.

| Chemical Additive | Purpose | Maximum Usage (lb/day) | Usage Frequency |
|-------------------|-----------------------|------------------------|-----------------|
| 4864 | Deposit Control Agent | 70.8 | Daily |
| 6105 | Oxygen Scavenger | 11371.7 | Intermittently |
| RA9051 | Antiscalant | 7.266 | Daily |
| FoamBloc 10 | Antifoam | 77.74 | Daily |
| 5015 | Neutralizing Amine | 5.6 | Intermittently |
| 4072 | Corrosion Inhibitor | 2.8 | 1/Quarter |

These chemicals are included on DEP's Approved List of Chemical Additives. No limits or monitoring requirements will be necessary for these chemicals. The permittee will be required to provide the usage rates of all chemical additives used at the site on a monthly basis, and will report these results on DEP's Chemical Additives Usage Form. The permit will include Part C conditions for chemical additive usage and reporting requirements.

Temperature Limitations

A reasonable potential (RP) analysis was performed for temperature which is the main pollutant of concern for the NCCW. Effluent limitations for temperature were calculated using DEP's Temperature Spreadsheet Model which uses DEP's Guidance No. 391-2000-017 for Temperature Criteria. In the Temperature Spreadsheet, per the previous fact sheet, a Q_{7-10} multiplier of 1.0 was used for each more in the spreadsheet. This was done to be conservative due to the nature of the low flows in the Conowingo Pond. The stream Q_{7-10} of 77 cfs used in the previous fact sheet was used in the Temperature Spreadsheet to account for the partial mixing of the discharge plume. The effluent limitations were analyzed using the Case 2 Thermal Worksheet for WWF streams. The worksheet recommended permit limits of 110°F for all months. The existing permit limit for Temperature of 110°F is consistent with this analysis, and will remain in the permit. A printout of the worksheet is attached.

Chesapeake Bay Total Maximum Daily Load (TMDL)

DEP developed a strategy to comply with the EPA and Chesapeake Bay Foundation requirements by reducing point source loadings of Total Nitrogen (TN) and Total Phosphorus (TP). This strategy can be located in the Pennsylvania Chesapeake Watershed Implementation Plan (WIP), dated January 11, 2011. Subsequently, an update to the WIP was published as the Phase 2 WIP. As part of the Phase 2 WIP, a Phase 2 Watershed Implementation Plan Wastewater Supplement (Phase 2 Supplement) was developed, providing an update on TMDL implementation for point sources and DEP's current implementation strategy for wastewater. The Phase 2 Supplement was most recently revised on September 6, 2017. A new update to the WIP was published as the Phase 3 WIP in August 2019. As part of the Phase 3 WIP, a *Phase 3 Watershed Implementation Plan Wastewater Supplement* (Phase 3 Supplement) was developed, and was most recently revised on December 17, 2019, and is the basis for the development of any Chesapeake Bay related permit parameters. Industrial discharges have been prioritized by Central Office based on their delivered TN and TP loadings to the Bay. Significant industrial wastewater dischargers are facilities that discharge more than 75 lbs/day of TN or 25 lbs/day of TP on an average annual basis and the rest are classified as non-significant dischargers. This facility is classified as a non-significant discharger. From the Phase 3 Supplement, for non-significant IW facilities, "monitoring and reporting of TN and TP will be required throughout the permit term in renewed or amended permits anytime the facility has the potential to introduce a net TN or TP increase to the load contained within the intake water used in processing. In general, facilities that discharge groundwater and cooling water with no addition of chemicals containing N or P do not require monitoring."

As the majority of this facility's discharge is boiler blowdown and NCCW, there should not be any significant net TN or TP contributions to the Susquehanna. Therefore, the permit will not include Cap Loads for TN or TP, which is consistent with the existing permit. The permit will continue to require a 1/month monitoring requirement for TN or TP to monitor the net nutrients being discharged.

316(b) Cooling Water Intake Structures

This facility withdraws 8.7 mgd of intake water from the Susquehanna River. Due to the use of a cooling water intake structure (CWISs), this facility must meet the requirements of Section 316(b) of the Clean Water Act (CWA). Section 316(b) requires that the location, design, construction, and capacity of CWISs reflect the best technology available (BTA) for minimizing adverse environmental impacts. This facility falls under Phase I Section 316(b) for new facilities, under 40 CFR Part 125, Subpart I. In the previous application, a 316(b) demonstration report was submitted to demonstrate compliance with the Track I application requirements in 40 CFR Part 125.86. It was concluded in the report that the impingement mortality rate of the intake is expected to be essentially zero with an overall negligible impact on the fish community.

Per the application, the facility has closed-cycle cooling, and the intake structure consists of six passive, submerged wedge-wire screens with a 2 mm. slot width. The interior of each screen is equipped with a flow modifier to produce an even through-screen velocity across the entire screen surface. The screens are made of a copper-nickel alloy to resist biofouling, particularly colonization of zebra and quagga mussels. Additionally, the actual through-screen velocity is substantially less than 0.5 ft/s. During the previous application review, the DEP permit engineer and biologist determine this facility will meet both impingement mortality and entrainment standards with the proposed design, and is considered to demonstrate BTA. On February 3, 2020, ODEC requested the removal of the monitoring requirement in the renewal permit, as two years of monitoring had been completed. In consultation with DEP's biologist, this monitoring requirement has been removed from Part C of the permit. DEP may request additional sampling in future permits. The remaining Part C language included in the existing permit for CWISs will remain

Additional Considerations

Stormwater

No stormwater outfalls exist for this facility in Pennsylvania; therefore, no additional monitoring or reporting is needed.

Flow Monitoring

Flow monitoring is recommended by DEP's technical guidance and is also required by 25 PA Code §§ 92a.61. It will be included, which is consistent with the existing permit.

Anti-Degradation

The effluent limits for this discharge have been developed to ensure that existing instream water uses and the level of water quality necessary to protect the existing uses are maintained and protected. No High Quality Waters are impacted by this discharge. No Exceptional Value Waters are impacted by this discharge.

303(d) Listed Streams

The discharge is located on a stream segment that is designated on the 303(d) list as impaired. There is a fish consumption impairment for polychlorinated biphenyls and pH due to an unknown source. The permit has a condition that states there shall be no discharge of polychlorinated biphenyl compounds such as those commonly used for transformer fluid, and contains a limit for pH.

Class A Wild Trout Fisheries

No Class A Wild Trout Fisheries are impacted by this discharge.

Development of Effluent Limitations

| | | | |
|--|--|--------------------------|--|
| Outfall No. | 101, 102 | Design Flow (MGD) | 0.025 (Outfall 101) 0.296 (Outfall 102) |
| Latitude | 39° 43' 16" (Outfall 101) 39° 43' 13" (Outfall 102) | Longitude | 76° 9' 34" (Outfall 101) 76° 9' 41" (Outfall 102) |
| Wastewater Description: Outfall 101: Internal low-volume waste discharge from oil/water separator effluent monitoring sumps, including stormwater from secondary containments for the generator step-up (GSU) units (transformers), auxiliary transformers, emergency diesel generator, and equipment fueling tank. Outfall 102: Internal low-volume discharge from building wastewaters and sumps and non-process wastewater (drum blowdown) | | | |

Limitations

A major permit amendment was issued by DEP on December 6, 2016 to add two internal monitoring points (IMPs) to the permit for Outfall 101 and 102. This was done to account for low volume waste sources required by 40 CFR Part 423. Outfall 101 is located at the point of combined discharge from the oil/water separator effluent monitoring sumps prior to its internal discharge to the cooling tower discharge line. Outfall 102 is located at the point of combined discharge for all building wastewater sumps prior to its internal discharge to the cooling tower basin.

From the permit application regarding Outfall 101, the wastewater sources described above normally passes through an oil/water separator before being pumped to two sumps located within the Raw Water Building. From these sumps, the water is pumped to the Raw Water Building sump and then to the head of the clarifier to be recirculated back into the system. During normal operations there are no discharges through IMP 101; however, during an outage when the clarifier is out of service, wastewater may be discharged through IMP 101 to Outfall 001. These discharges are very small, typically 20,000 gallons over a period of less than one hour, and may occur two time in a 24-hour period.

Regarding Outfall 102, during normal operations effluent from the locations described above is collected in the various building sumps and is pumped to the Cooling Tower basin. As it is pumped to the Cooling Tower basin, it passes through IMP 102.

As described above, the ELG Part 423.15(b)(3) requires limits for TSS and Oil and Grease in low volume waste sources. The requirement for TSS is an average monthly limit of 30 mg/l, and a daily maximum limit of 100 mg/l. The requirement for Oil and Grease is an average monthly limit of 15 mg/l, and a daily maximum limit of 20 mg/l. Additionally, 25 Pa Code Part 95.2(2)(ii) requires an IMAX limit of 30 mg/l for oil and grease. These limits will be included, which is consistent with the existing permit limits. These are the only limits required for these Outfalls, as they only receive the low volume waste sources, and TSS and Oil and Grease are the only relevant parameters for these discharges based on the ELG. ODEC has requested a reduction in monitoring frequency from 1/week to 1/month for these parameters, as they have experienced no reoccurring issues related to compliance with any pollutant limits. Therefore, the frequency has been reduced to 1/month.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|--|-------------------------------------|------------------|-----------------------|--------------------|------------------|---------------------|--|----------------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Total Monthly | Daily Maximum | Minimum | Average Monthly | Daily Maximum | Instant. Maximum | | |
| Flow (MGD) | Report Avg Mo | Report | XXX | XXX | XXX | XXX | Continuous | Measured |
| Temperature (°F) | XXX | XXX | XXX | Report | 110 | XXX | Continuous | I-S |
| pH (S.U.) | XXX | XXX | 6.0 Inst Min | XXX | XXX | 9.0 | 1/day | Grab |
| Free Available Chlorine | XXX | XXX | XXX | XXX | 0.2 | 0.5 | 1/day | Grab |
| TSS | XXX | XXX | XXX | 30 | 60 | 75 | 1/month | 24-Hr Composite |
| Total Dissolved Solids Effluent Net | XXX | XXX | XXX | Report | Report | XXX | 1/month | 24-Hr Composite |
| Oil and Grease | XXX | XXX | XXX | 15 | 20 | 30 | 1/month | Grab |
| Total Chromium | XXX | XXX | XXX | XXX | 0.2 | XXX | 1/month | 24-Hr Composite |
| Total Zinc | XXX | XXX | XXX | XXX | 1.0 | XXX | 1/month | 24-Hr Composite |
| Total Aluminum | XXX | XXX | XXX | XXX | Report | XXX | 1/month | 24-Hr Composite |
| Sulfate | XXX | XXX | XXX | XXX | Report | XXX | 1/month | 24-Hr Composite |
| Chloride | XXX | XXX | XXX | XXX | Report | XXX | 1/month | 24-Hr Composite |
| Bromide | XXX | XXX | XXX | XXX | Report | XXX | 1/month | 24-Hr Composite |
| Trihalomethanes | XXX | XXX | XXX | XXX | Report | XXX | 1/month | 24-Hr Composite |
| Dibromochloro-methane | XXX | XXX | XXX | XXX | Report | XXX | 1/month | 24-Hr Composite |

Outfall 001 , Continued (from Permit Effective Date through Permit Expiration Date)

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|----------------------------------|-------------------------------------|------------------------|-----------------------|--------------------|------------------|---------------------|--|----------------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Total Monthly | Daily Maximum | Minimum | Average Monthly | Daily Maximum | Instant. Maximum | | |
| Dichlorobromo-methane | XXX | XXX | XXX | XXX | Report | XXX | 1/month | 24-Hr Composite |
| Chloroform | XXX | XXX | XXX | XXX | Report | XXX | 1/month | 24-Hr Composite |
| Bromoform | XXX | XXX | XXX | XXX | Report | XXX | 1/month | 24-Hr Composite |
| Haloacetic Acids | XXX | XXX | XXX | XXX | Report | XXX | 1/month | 24-Hr Composite |
| Monobromoacetic acid | XXX | XXX | XXX | XXX | Report | XXX | 1/month | 24-Hr Composite |
| Monochloroacetic acid | XXX | XXX | XXX | XXX | Report | XXX | 1/month | 24-Hr Composite |
| Dibromoacetic acid | XXX | XXX | XXX | XXX | Report | XXX | 1/month | 24-Hr Composite |
| Dichloroacetic acid | XXX | XXX | XXX | XXX | Report | XXX | 1/month | 24-Hr Composite |
| Trichloroacetic acid | XXX | XXX | XXX | XXX | Report | XXX | 1/month | 24-Hr Composite |
| Hexachlorobutadiene | XXX | XXX | XXX | XXX | Report | XXX | 1/6 months | 24-Hr Composite |
| 1,2,4-Trichlorobenzene | XXX | XXX | XXX | XXX | Report | XXX | 1/6 months | 24-Hr Composite |
| Total Nitrogen Effluent Net | Report | XXX | XXX | Report | XXX | XXX | 1/month | 24-Hr Composite |
| Total Nitrogen Effluent Net | XXX | Report Total Annual | XXX | XXX | XXX | XXX | 1/month | Calculation |
| Total Phosphorus Effluent Net | Report | XXX | XXX | Report | XXX | XXX | 1/month | 24-Hr Composite |
| Total Phosphorus Effluent Net | XXX | Report Total Annual | XXX | XXX | XXX | XXX | 1/month | Calculation |

Compliance Sampling Location: At discharge from facility for all parameters except temperature; temperature monitoring shall be performed at Outfall 001

Other Comments: None

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 101, Effective Period: Permit Effective Date through Permit Expiration Date.

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|----------------|-------------------------------------|------------------|-----------------------|--------------------|------------------|---------------------|--|----------------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Average Monthly | Daily Maximum | Minimum | Average Monthly | Daily Maximum | Instant. Maximum | | |
| Flow (MGD) | Report | Report | XXX | XXX | XXX | XXX | Continuous | Measured |
| TSS | XXX | XXX | XXX | 30 | 100 | XXX | 1/month | Grab |
| Oil and Grease | XXX | XXX | XXX | 15 | 20 | 30 | 1/month | Grab |

Compliance Sampling Location: Cooling tower discharge line

Other Comments: None

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 102, Effective Period: Permit Effective Date through Permit Expiration Date.


| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|----------------|-------------------------------------|------------------|-----------------------|--------------------|------------------|---------------------|--|----------------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Average Monthly | Daily Maximum | Minimum | Average Monthly | Daily Maximum | Instant. Maximum | | |
| Flow (MGD) | Report | Report | XXX | XXX | XXX | XXX | Continuous | Measured |
| TSS | XXX | XXX | XXX | 30 | 100 | XXX | 1/month | Grab |
| Oil and Grease | XXX | XXX | XXX | 15 | 20 | 30 | 1/month | Grab |

Compliance Sampling Location: Internal monitoring point located at the point of combined discharge for all building wastewater sumps prior to its internal discharge to the cooling tower basin

Other Comments: None

| Tools and References Used to Develop Permit | |
|---|--|
| <input type="checkbox"/> | WQM for Windows Model (see Attachment) |
| <input checked="" type="checkbox"/> | Toxics Management Spreadsheet (see Attachment) |
| <input type="checkbox"/> | TRC Model Spreadsheet (see Attachment) |
| <input checked="" type="checkbox"/> | Temperature Model Spreadsheet (see Attachment) |
| <input checked="" type="checkbox"/> | Water Quality Toxics Management Strategy, 361-0100-003, 4/06. |
| <input checked="" type="checkbox"/> | Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97. |
| <input type="checkbox"/> | Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98. |
| <input type="checkbox"/> | Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96. |
| <input type="checkbox"/> | Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97. |
| <input checked="" type="checkbox"/> | Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97. |
| <input type="checkbox"/> | Pennsylvania CSO Policy, 385-2000-011, 9/08. |
| <input type="checkbox"/> | Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03. |
| <input type="checkbox"/> | Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97. |
| <input checked="" type="checkbox"/> | Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97. |
| <input type="checkbox"/> | Implementation Guidance Design Conditions, 391-2000-006, 9/97. |
| <input type="checkbox"/> | Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004. |
| <input type="checkbox"/> | Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997. |
| <input type="checkbox"/> | Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99. |
| <input checked="" type="checkbox"/> | Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004. |
| <input type="checkbox"/> | Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97. |
| <input type="checkbox"/> | Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008. |
| <input checked="" type="checkbox"/> | Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994. |
| <input checked="" type="checkbox"/> | Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09. |
| <input type="checkbox"/> | Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97. |
| <input type="checkbox"/> | Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97. |
| <input type="checkbox"/> | Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99. |
| <input type="checkbox"/> | Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999. |
| <input type="checkbox"/> | Design Stream Flows, 391-2000-023, 9/98. |
| <input type="checkbox"/> | Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98. |
| <input type="checkbox"/> | Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97. |
| <input checked="" type="checkbox"/> | Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07. |
| <input type="checkbox"/> | SOP: No. BPNPSM-PMT-001, No. BCW-PMT-032 |
| <input type="checkbox"/> | Other: |

DEP Map



NPDES Permit Fact Sheet
Wildcat Pt Gen Facility

NPDES Permit No. PA0265951

[illegible]

NPDES Permit Fact Sheet
Wildcat Pt Gen Facility

NPDES Permit No. PA0265951

[illegible]

NPDES Permit Fact Sheet Wildcat Pt Gen Facility

NPDES Permit No. PA0265951

[illegible]

Report

×

Enter a report title and/or comments here that will display on the printed report. Use the print button below.

Enter report title:

Old Dominion Electric Cooperative PA0265951 Outfall 001

Enter comments:

Some comments here

Old Dominion Electric Cooperative PA0265951 Outfall 001

Region ID:
Workspace ID:
Clicked Point (Latitude, Longitude):
Time:

PA
PA20220118163849566000
39.73815, -76.23765
2022-01-18 11:39:21 -0500



| Basin Characteristics | | | |
|-----------------------|--|---------|-----------------------|
| Parameter Code | Parameter Description | Value | Unit |
| DRNAREA | Area that drains to a point on a stream | 27000 | square miles |
| BSLOPD | Mean basin slope measured in degrees | 8.0219 | degrees |
| ROCKDEP | Depth to rock | 4.5 | feet |
| URBAN | Percentage of basin with urban development | 3.0283 | percent |
| PRECIP | Mean Annual Precipitation | 40 | inches |
| STRDEN | Stream Density -- total length of streams divided by drainage area | 1.75 | miles per square mile |
| CARBON | Percentage of area of carbonate rock | 7.91 | percent |
| ELEV | Mean Basin Elevation | 1300 | feet |
| GLACIATED | Percentage of basin area that was historically covered by glaciers | 43.768 | percent |
| FOREST | Percentage of area covered by forest | 66.3501 | percent |

| Low-Flow Statistics Parameters [7.3 Percent (1970 square miles) Low Flow Region 1] | | | | | |
|--|---------------------------|--------|-----------------------|-----------|-----------|
| Parameter Code | Parameter Name | Value | Units | Min Limit | Max Limit |
| DRNAREA | Drainage Area | 27000 | square miles | 4.78 | 1150 |
| BSLOPD | Mean Basin Slope degrees | 8.0219 | degrees | 1.7 | 6.4 |
| ROCKDEP | Depth to Rock | 4.5 | feet | 4.13 | 5.21 |
| URBAN | Percent Urban | 3.0283 | percent | 0 | 89 |
| Low-Flow Statistics Parameters [41.0 Percent (11100 square miles) Low Flow Region 2] | | | | | |
| Parameter Code | Parameter Name | Value | Units | Min Limit | Max Limit |
| DRNAREA | Drainage Area | 27000 | square miles | 4.93 | 1280 |
| PRECIP | Mean Annual Precipitation | 40 | inches | 35 | 50.4 |
| STRDEN | Stream Density | 1.75 | miles per square mile | 0.51 | 3.1 |
| ROCKDEP | Depth to Rock | 4.5 | feet | 3.32 | 5.65 |
| CARBON | Percent Carbonate | 7.91 | percent | 0 | 99 |
| Low-Flow Statistics Parameters [6.0 Percent (1610 square miles) Low Flow Region 3] | | | | | |
| Parameter Code | Parameter Name | Value | Units | Min Limit | Max Limit |
| DRNAREA | Drainage Area | 27000 | square miles | 2.33 | 1720 |
| ELEV | Mean Basin Elevation | 1300 | feet | 898 | 2700 |
| PRECIP | Mean Annual Precipitation | 40 | inches | 38.7 | 47.9 |
| Low-Flow Statistics Parameters [45.5 Percent (12300 square miles) Low Flow Region 5] | | | | | |
| Parameter Code | Parameter Name | Value | Units | Min Limit | Max Limit |
| DRNAREA | Drainage Area | 27000 | square miles | 4.84 | 982 |
| PRECIP | Mean Annual Precipitation | 40 | inches | 33.1 | 47.1 |

| | | | | | |
|---|-----------------------|--------------|---------|--------------------|-----|
| GLACIATED | Percent of Glaciation | 43.768 | percent | 0 | 100 |
| FOREST | Percent Forest | 66.3501 | percent | 41 | 100 |
| Low-Flow Statistics Disclaimers [7.3 Percent (1970 square miles) Low Flow Region 1] | | | | | |
| One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors | | | | | |
| Low-Flow Statistics Flow Report [7.3 Percent (1970 square miles) Low Flow Region 1] | | | | | |
| Statistic | | Value | | Unit | |
| 7 Day 2 Year Low Flow | | 9510 | | ft ³ /s | |
| 30 Day 2 Year Low Flow | | 10600 | | ft ³ /s | |
| 7 Day 10 Year Low Flow | | 7410 | | ft ³ /s | |
| 30 Day 10 Year Low Flow | | 7820 | | ft ³ /s | |
| 90 Day 10 Year Low Flow | | 8400 | | ft ³ /s | |
| Low-Flow Statistics Disclaimers [41.0 Percent (11100 square miles) Low Flow Region 2] | | | | | |
| One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors | | | | | |
| Low-Flow Statistics Flow Report [41.0 Percent (11100 square miles) Low Flow Region 2] | | | | | |
| Statistic | | Value | | Unit | |
| 7 Day 2 Year Low Flow | | 6360 | | ft ³ /s | |
| 30 Day 2 Year Low Flow | | 7480 | | ft ³ /s | |
| 7 Day 10 Year Low Flow | | 4780 | | ft ³ /s | |
| 30 Day 10 Year Low Flow | | 5620 | | ft ³ /s | |
| 90 Day 10 Year Low Flow | | 6930 | | ft ³ /s | |
| Low-Flow Statistics Disclaimers [6.0 Percent (1610 square miles) Low Flow Region 3] | | | | | |
| One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors | | | | | |
| Low-Flow Statistics Flow Report [6.0 Percent (1610 square miles) Low Flow Region 3] | | | | | |
| Statistic | | Value | | Unit | |
| 7 Day 2 Year Low Flow | | 2460 | | ft ³ /s | |
| 30 Day 2 Year Low Flow | | 3050 | | ft ³ /s | |
| 7 Day 10 Year Low Flow | | 1490 | | ft ³ /s | |
| 30 Day 10 Year Low Flow | | 1850 | | ft ³ /s | |
| 90 Day 10 Year Low Flow | | 2540 | | ft ³ /s | |
| Low-Flow Statistics Disclaimers [45.5 Percent (12300 square miles) Low Flow Region 5] | | | | | |
| One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors | | | | | |
| Low-Flow Statistics Flow Report [45.5 Percent (12300 square miles) Low Flow Region 5] | | | | | |

| 30 Day 10 Year Low Flow | 1850 | ft ³ /s |
|---|-------|--------------------|
| 90 Day 10 Year Low Flow | 2540 | ft ³ /s |
| Low-Flow Statistics Disclaimers: (45.5 Percent (12300 square miles) Low Flow Region 5) | | |
| One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors. | | |
| Low-Flow Statistics Flow Report (45.5 Percent (12300 square miles) Low Flow Region 5) | | |
| Statistic | Value | Unit |
| 7 Day 2 Year Low Flow | 3540 | ft ³ /s |
| 30 Day 2 Year Low Flow | 4480 | ft ³ /s |
| 7 Day 10 Year Low Flow | 2250 | ft ³ /s |
| 30 Day 10 Year Low Flow | 2980 | ft ³ /s |
| 90 Day 10 Year Low Flow | 3850 | ft ³ /s |
| Low-Flow Statistics Flow Report (Area-Averaged) | | |
| Statistic | Value | Unit |
| 7 Day 2 Year Low Flow | 5060 | ft ³ /s |
| 30 Day 2 Year Low Flow | 6060 | ft ³ /s |
| 7 Day 10 Year Low Flow | 3620 | ft ³ /s |
| 30 Day 10 Year Low Flow | 4340 | ft ³ /s |
| 90 Day 10 Year Low Flow | 5360 | ft ³ /s |
| Low-Flow Statistics Citations | | |
| Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. | | |

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.6.2

StreamStats Services Version: 1.2.22

NBS Services Version: 2.1.2



Discharge Information

Instructions Discharge Stream

Facility: **Wildcat Point Generation Facility** NPDES Permit No.: **PA0265951** Outfall No.: **001**

Evaluation Type: **Major Sewage / Industrial Waste** Wastewater Description: **Boiler blowdown, NCCW, IMP 101, IMP 102**

| Discharge Characteristics | | | | | | | |
|---------------------------|------------------|----------|----------------------------|-------|-------|-------|----------------------------------|
| Design Flow (MGD)* | Hardness (mg/l)* | pH (SU)* | Partial Mix Factors (PMFs) | | | | Complete Mix Times (min) |
| | | | AFC | CFC | THH | CRL | Q ₇₋₁₀ Q _h |
| 0.857 | 1080 | 8.2 | 0.006 | 0.038 | 0.038 | 0.052 | |

| Discharge Pollutant | Units | Max Discharge Conc | 0 if left blank | | 0.5 if left blank | | 0 if left blank | | | 1 if left blank | |
|---------------------|---------------------------------|--------------------|-----------------|-------------|-------------------|-----------|-----------------|------------|-----|-----------------|-------------|
| | | | Trib Conc | Stream Conc | Daily CV | Hourly CV | Stream CV | Fate Coeff | FOS | Criteria Mod | Chem Transl |
| Group 1 | Total Dissolved Solids (PWS) | mg/L | 2840 | | | | | | | | |
| | Chloride (PWS) | mg/L | 458 | | | | | | | | |
| | Bromide | mg/L | 10.9 | | | | | | | | |
| | Sulfate (PWS) | mg/L | 949 | | | | | | | | |
| | Fluoride (PWS) | mg/L | 0.36 | | | | | | | | |
| Group 2 | Total Aluminum | µg/L | 740 | | | | | | | | |
| | Total Antimony | µg/L | 1.7 | | | | | | | | |
| | Total Arsenic | µg/L | 4.3 | | | | | | | | |
| | Total Barium | µg/L | 250 | | | | | | | | |
| | Total Beryllium | µg/L | < 0.5 | | | | | | | | |
| | Total Boron | µg/L | 230 | | | | | | | | |
| | Total Cadmium | µg/L | < 0.2 | | | | | | | | |
| | Total Chromium (III) | µg/L | 3 | | | | | | | | |
| | Hexavalent Chromium | µg/L | 0.59 | | | | | | | | |
| | Total Cobalt | µg/L | < 2.5 | | | | | | | | |
| | Total Copper | µg/L | 12 | | | | | | | | |
| | Free Cyanide | µg/L | | | | | | | | | |
| | Total Cyanide | µg/L | 6.8 | | | | | | | | |
| | Dissolved Iron | µg/L | < 60 | | | | | | | | |
| | Total Iron | µg/L | 130 | | | | | | | | |
| | Total Lead | µg/L | < 1 | | | | | | | | |
| | Total Manganese | µg/L | 83 | | | | | | | | |
| | Total Mercury | µg/L | 0.0018 | | | | | | | | |
| | Total Nickel | µg/L | 7.5 | | | | | | | | |
| | Total Phenols (Phenolics) (PWS) | µg/L | < 5 | | | | | | | | |
| | Total Selenium | µg/L | 2.7 | | | | | | | | |
| | Total Silver | µg/L | < 0.5 | | | | | | | | |
| | Total Thallium | µg/L | < 0.5 | | | | | | | | |
| | Total Zinc | µg/L | 12 | | | | | | | | |
| | Total Molybdenum | µg/L | | | | | | | | | |
| | Acrolein | µg/L | < 2.5 | | | | | | | | |
| | Acrylamide | µg/L | < | | | | | | | | |
| | Acrylonitrile | µg/L | < 5 | | | | | | | | |
| | Benzene | µg/L | < 0.5 | | | | | | | | |
| | Bromoform | µg/L | < 1 | | | | | | | | |

[illegible]

| | | | | | | | | | | | | | | | | | | | | |
|--------------------|---------------------------|--------|------|-----|----|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|
| | 2,6-Dinitrotoluene | µg/L | < | 3.1 | | | | | | | | | | | | | | | | |
| | Di-n-Octyl Phthalate | µg/L | < | 3.1 | | | | | | | | | | | | | | | | |
| | 1,2-Diphenylhydrazine | µg/L | < | 3.1 | | | | | | | | | | | | | | | | |
| | Fluoranthene | µg/L | < | 1.6 | | | | | | | | | | | | | | | | |
| | Fluorene | µg/L | < | 1.6 | | | | | | | | | | | | | | | | |
| | Hexachlorobenzene | µg/L | < | 3.1 | | | | | | | | | | | | | | | | |
| | Hexachlorobutadiene | µg/L | < | 3.1 | | | | | | | | | | | | | | | | |
| | Hexachlorocyclopentadiene | µg/L | < | 3.1 | | | | | | | | | | | | | | | | |
| | Hexachloroethane | µg/L | < | 3.1 | | | | | | | | | | | | | | | | |
| | Indeno(1,2,3-cd)Pyrene | µg/L | < | 1.6 | | | | | | | | | | | | | | | | |
| | Isophorone | µg/L | < | 3.1 | | | | | | | | | | | | | | | | |
| | Naphthalene | µg/L | < | 1.6 | | | | | | | | | | | | | | | | |
| | Nitrobenzene | µg/L | < | 3.1 | | | | | | | | | | | | | | | | |
| | n-Nitrosodimethylamine | µg/L | < | 3.1 | | | | | | | | | | | | | | | | |
| | n-Nitrosodi-n-Propylamine | µg/L | < | 3.1 | | | | | | | | | | | | | | | | |
| | n-Nitrosodiphenylamine | µg/L | < | 3.1 | | | | | | | | | | | | | | | | |
| | Phenanthrene | µg/L | < | 1.6 | | | | | | | | | | | | | | | | |
| | Pyrene | µg/L | < | 1.6 | | | | | | | | | | | | | | | | |
| | 1,2,4-Trichlorobenzene | µg/L | < | 3.1 | | | | | | | | | | | | | | | | |
| | Group 6 | Aldrin | µg/L | < | | | | | | | | | | | | | | | | |
| alpha-BHC | | µg/L | < | | | | | | | | | | | | | | | | | |
| beta-BHC | | µg/L | < | | | | | | | | | | | | | | | | | |
| gamma-BHC | | µg/L | < | | | | | | | | | | | | | | | | | |
| delta BHC | | µg/L | < | | | | | | | | | | | | | | | | | |
| Chlordane | | µg/L | < | | | | | | | | | | | | | | | | | |
| 4,4-DDT | | µg/L | < | | | | | | | | | | | | | | | | | |
| 4,4-DDE | | µg/L | < | | | | | | | | | | | | | | | | | |
| 4,4-DDD | | µg/L | < | | | | | | | | | | | | | | | | | |
| Dieldrin | | µg/L | < | | | | | | | | | | | | | | | | | |
| alpha-Endosulfan | | µg/L | < | | | | | | | | | | | | | | | | | |
| beta-Endosulfan | | µg/L | < | | | | | | | | | | | | | | | | | |
| Endosulfan Sulfate | | µg/L | < | | | | | | | | | | | | | | | | | |
| Endrin | | µg/L | < | | | | | | | | | | | | | | | | | |
| Endrin Aldehyde | | µg/L | < | | | | | | | | | | | | | | | | | |
| Heptachlor | | µg/L | < | | | | | | | | | | | | | | | | | |
| Heptachlor Epoxide | | µg/L | < | | | | | | | | | | | | | | | | | |
| PCB-1016 | | µg/L | < | | | | | | | | | | | | | | | | | |
| PCB-1221 | | µg/L | < | | | | | | | | | | | | | | | | | |
| PCB-1232 | | µg/L | < | | | | | | | | | | | | | | | | | |
| PCB-1242 | µg/L | < | | | | | | | | | | | | | | | | | | |
| PCB-1248 | µg/L | < | | | | | | | | | | | | | | | | | | |
| PCB-1254 | µg/L | < | | | | | | | | | | | | | | | | | | |
| PCB-1260 | µg/L | < | | | | | | | | | | | | | | | | | | |
| PCBs, Total | µg/L | < | | | | | | | | | | | | | | | | | | |
| Toxaphene | µg/L | < | | | | | | | | | | | | | | | | | | |
| Group 7 | 2,3,7,8-TCDD | ng/L | < | | | | | | | | | | | | | | | | | |
| | Gross Alpha | pCi/L | | | | | | | | | | | | | | | | | | |
| | Total Beta | pCi/L | < | | | | | | | | | | | | | | | | | |
| | Radium 226/228 | pCi/L | < | | | | | | | | | | | | | | | | | |
| | Total Strontium | µg/L | < | | | | | | | | | | | | | | | | | |
| | Total Uranium | µg/L | < | | | | | | | | | | | | | | | | | |
| | Osmotic Pressure | mOs/kg | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | |
| | | | | | </ | | | | | | | | | | | | | | | |



Stream / Surface Water Information

Wildcat Point Generation Facility, NPDES Permit No. PA0265951, Outfall 001

Instructions Discharge **Stream**

Receiving Surface Water Name: **Susquehanna River**

No. Reaches to Model: **1**

- ☒ Statewide Criteria
☐ Great Lakes Criteria
☐ ORSANCO Criteria

| Location | Stream Code* | RMI* | Elevation (ft)* | DA (mi ²)* | Slope (ft/ft) | PWS Withdrawal (MGD) | Apply Fish Criteria* |
|--------------------|--------------|--------|-----------------|------------------------|---------------|----------------------|----------------------|
| Point of Discharge | 006685 | 1.7 | 109.2 | 27000 | | | Yes |
| End of Reach 1 | 006685 | 0.0001 | 108.3 | 27001 | | | Yes |

Q₇₋₁₀

| Location | RMI | LFY (cfs/mi ²)* | Flow (cfs) | | W/D Ratio | Width (ft) | Depth (ft) | Velocity (fps) | Travel Time (days) | Tributary | | Stream | | Analysis | |
|--------------------|--------|-----------------------------|------------|-----------|-----------|------------|------------|----------------|--------------------|-----------|----|-----------|-------|----------|----|
| | | | Stream | Tributary | | | | | | Hardness | pH | Hardness* | pH* | Hardness | pH |
| Point of Discharge | 1.7 | 0.13 | | | | 6500 | 14 | | | | | 128 | 8.376 | | |
| End of Reach 1 | 0.0001 | 0.13 | | | | 6500 | 14 | | | | | 128 | 8.376 | | |

Q_h

| Location | RMI | LFY (cfs/mi ²)* | Flow (cfs) | | W/D Ratio | Width (ft) | Depth (ft) | Velocity (fps) | Travel Time (days) | Tributary | | Stream | | Analysis | |
|--------------------|--------|-----------------------------|------------|-----------|-----------|------------|------------|----------------|--------------------|-----------|----|----------|----|----------|----|
| | | | Stream | Tributary | | | | | | Hardness | pH | Hardness | pH | Hardness | pH |
| Point of Discharge | 1.7 | | | | | | | | | | | | | | |
| End of Reach 1 | 0.0001 | | | | | | | | | | | | | | |



Model Results

Wildcat Point Generation Facility, NPDES Permit No. PA0265951, Outfall 001

[Instructions](#)
[Results](#)
[RETURN TO INPUTS](#)
[SAVE AS PDF](#)
[PRINT](#)
☒ All
 ☐ Inputs
 ☐ Results
 ☐ Limits

☐ Hydrodynamics

☒ Wasteload Allocations

☒ AFC

CCT (min): 15

PMF: 0.006

Analysis Hardness (mg/l): 184.38

Analysis pH: 8.36

| Pollutants | Stream Conc (µg/L) | Stream CV | Trib Conc (µg/L) | Fate Coef | WQC (µg/L) | WQ Obj (µg/L) | WLA (µg/L) | Comments |
|---------------------------------|--------------------|-----------|------------------|-----------|------------|---------------|------------|----------------------------------|
| Total Dissolved Solids (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Chloride (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Sulfate (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Fluoride (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Aluminum | 0 | 0 | | 0 | 750 | 750 | 12,664 | |
| Total Antimony | 0 | 0 | | 0 | 1,100 | 1,100 | 18,574 | |
| Total Arsenic | 0 | 0 | | 0 | 340 | 340 | 5,741 | Chem Translator of 1 applied |
| Total Barium | 0 | 0 | | 0 | 21,000 | 21,000 | 354,585 | |
| Total Boron | 0 | 0 | | 0 | 8,100 | 8,100 | 136,769 | |
| Total Cadmium | 0 | 0 | | 0 | 3,649 | 3,97 | 67.1 | Chem Translator of 0.918 applied |
| Total Chromium (III) | 0 | 0 | | 0 | 940,409 | 2,976 | 50,249 | Chem Translator of 0.316 applied |
| Hexavalent Chromium | 0 | 0 | | 0 | 16 | 16.3 | 275 | Chem Translator of 0.982 applied |
| Total Cobalt | 0 | 0 | | 0 | 95 | 95.0 | 1,604 | |
| Total Copper | 0 | 0 | | 0 | 23,918 | 24.9 | 421 | Chem Translator of 0.96 applied |
| Dissolved Iron | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Iron | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Lead | 0 | 0 | | 0 | 124,862 | 178 | 3,004 | Chem Translator of 0.702 applied |
| Total Manganese | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Mercury | 0 | 0 | | 0 | 1,400 | 1.65 | 27.8 | Chem Translator of 0.85 applied |
| Total Nickel | 0 | 0 | | 0 | 785,708 | 787 | 13,293 | Chem Translator of 0.998 applied |
| Total Phenols (Phenolics) (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Selenium | 0 | 0 | | 0 | N/A | N/A | N/A | Chem Translator of 0.922 applied |
| Total Silver | 0 | 0 | | 0 | 9,214 | 10.8 | 183 | Chem Translator of 0.85 applied |
| Total Thallium | 0 | 0 | | 0 | 65 | 65.0 | 1,098 | |
| Total Zinc | 0 | 0 | | 0 | 196,787 | 201 | 3,398 | Chem Translator of 0.978 applied |
| Acrolein | 0 | 0 | | 0 | 3 | 3.0 | 50.7 | |

| | | | | | | | |
|-----------------------------|---|---|--|---|--------|--------|---------|
| Acrylonitrile | 0 | 0 | | 0 | 650 | 650 | 10,975 |
| Benzene | 0 | 0 | | 0 | 640 | 640 | 10,806 |
| Bromoform | 0 | 0 | | 0 | 1,800 | 1,800 | 30,393 |
| Carbon Tetrachloride | 0 | 0 | | 0 | 2,800 | 2,800 | 47,278 |
| Chlorobenzene | 0 | 0 | | 0 | 1,200 | 1,200 | 20,262 |
| Chlorodibromomethane | 0 | 0 | | 0 | N/A | N/A | N/A |
| 2-Chloroethyl Vinyl Ether | 0 | 0 | | 0 | 18,000 | 18,000 | 303,930 |
| Chloroform | 0 | 0 | | 0 | 1,900 | 1,900 | 32,082 |
| Dichlorobromomethane | 0 | 0 | | 0 | N/A | N/A | N/A |
| 1,2-Dichloroethane | 0 | 0 | | 0 | 15,000 | 15,000 | 253,275 |
| 1,1-Dichloroethylene | 0 | 0 | | 0 | 7,500 | 7,500 | 126,638 |
| 1,2-Dichloropropane | 0 | 0 | | 0 | 11,000 | 11,000 | 185,735 |
| 1,3-Dichloropropylene | 0 | 0 | | 0 | 310 | 310 | 5,234 |
| Ethylbenzene | 0 | 0 | | 0 | 2,900 | 2,900 | 48,967 |
| Methyl Bromide | 0 | 0 | | 0 | 550 | 550 | 9,287 |
| Methyl Chloride | 0 | 0 | | 0 | 28,000 | 28,000 | 472,780 |
| Methylene Chloride | 0 | 0 | | 0 | 12,000 | 12,000 | 202,620 |
| 1,1,2,2-Tetrachloroethane | 0 | 0 | | 0 | 1,000 | 1,000 | 16,885 |
| Tetrachloroethylene | 0 | 0 | | 0 | 700 | 700 | 11,820 |
| Toluene | 0 | 0 | | 0 | 1,700 | 1,700 | 28,705 |
| 1,2-trans-Dichloroethylene | 0 | 0 | | 0 | 6,800 | 6,800 | 114,818 |
| 1,1,1-Trichloroethane | 0 | 0 | | 0 | 3,000 | 3,000 | 50,655 |
| 1,1,2-Trichloroethane | 0 | 0 | | 0 | 3,400 | 3,400 | 57,409 |
| Trichloroethylene | 0 | 0 | | 0 | 2,300 | 2,300 | 38,836 |
| Vinyl Chloride | 0 | 0 | | 0 | N/A | N/A | N/A |
| 2-Chlorophenol | 0 | 0 | | 0 | 560 | 560 | 9,456 |
| 2,4-Dichlorophenol | 0 | 0 | | 0 | 1,700 | 1,700 | 28,705 |
| 2,4-Dimethylphenol | 0 | 0 | | 0 | 660 | 660 | 11,144 |
| 4,6-Dinitro-o-Cresol | 0 | 0 | | 0 | 80 | 80.0 | 1,351 |
| 2,4-Dinitrophenol | 0 | 0 | | 0 | 660 | 660 | 11,144 |
| 2-Nitrophenol | 0 | 0 | | 0 | 8,000 | 8,000 | 135,080 |
| 4-Nitrophenol | 0 | 0 | | 0 | 2,300 | 2,300 | 38,836 |
| p-Chloro-m-Cresol | 0 | 0 | | 0 | 160 | 160 | 2,702 |
| Pentachlorophenol | 0 | 0 | | 0 | 34.335 | 34.3 | 580 |
| Phenol | 0 | 0 | | 0 | N/A | N/A | N/A |
| 2,4,6-Trichlorophenol | 0 | 0 | | 0 | 460 | 460 | 7,767 |
| Acenaphthene | 0 | 0 | | 0 | 83 | 83.0 | 1,401 |
| Anthracene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Benzidine | 0 | 0 | | 0 | 300 | 300 | 5,066 |
| Benzo(a)Anthracene | 0 | 0 | | 0 | 0.5 | 0.5 | 8.44 |
| Benzo(a)Pyrene | 0 | 0 | | 0 | N/A | N/A | N/A |
| 3,4-Benzofluoranthene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Benzo(k)Fluoranthene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Bis(2-Chloroethyl)Ether | 0 | 0 | | 0 | 30,000 | 30,000 | 506,550 |
| Bis(2-Chloroisopropyl)Ether | 0 | 0 | | 0 | N/A | N/A | N/A |
| Bis(2-Ethylhexyl)Phthalate | 0 | 0 | | 0 | 4,500 | 4,500 | 75,983 |
| 4-Bromophenyl Phenyl Ether | 0 | 0 | | 0 | 270 | 270 | 4,559 |
| Butyl Benzyl Phthalate | 0 | 0 | | 0 | 140 | 140 | 2,364 |

| | | | | | | | | |
|---------------------------|---|---|--|---|--------|--------|---------|--|
| 2-Chloronaphthalene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Chrysene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Dibenzo(a,h)Anthracene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 1,2-Dichlorobenzene | 0 | 0 | | 0 | 820 | 820 | 13,846 | |
| 1,3-Dichlorobenzene | 0 | 0 | | 0 | 350 | 350 | 5,910 | |
| 1,4-Dichlorobenzene | 0 | 0 | | 0 | 730 | 730 | 12,326 | |
| 3,3-Dichlorobenzidine | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Diethyl Phthalate | 0 | 0 | | 0 | 4,000 | 4,000 | 67,540 | |
| Dimethyl Phthalate | 0 | 0 | | 0 | 2,500 | 2,500 | 42,213 | |
| Di-n-Butyl Phthalate | 0 | 0 | | 0 | 110 | 110 | 1,857 | |
| 2,4-Dinitrotoluene | 0 | 0 | | 0 | 1,600 | 1,600 | 27,016 | |
| 2,6-Dinitrotoluene | 0 | 0 | | 0 | 990 | 990 | 16,716 | |
| 1,2-Diphenylhydrazine | 0 | 0 | | 0 | 15 | 15.0 | 253 | |
| Fluoranthene | 0 | 0 | | 0 | 200 | 200 | 3,377 | |
| Fluorene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Hexachlorobenzene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Hexachlorobutadiene | 0 | 0 | | 0 | 10 | 10.0 | 169 | |
| Hexachlorocyclopentadiene | 0 | 0 | | 0 | 5 | 5.0 | 84.4 | |
| Hexachloroethane | 0 | 0 | | 0 | 60 | 60.0 | 1,013 | |
| Indeno(1,2,3-cd)Pyrene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Isophorone | 0 | 0 | | 0 | 10,000 | 10,000 | 168,850 | |
| Naphthalene | 0 | 0 | | 0 | 140 | 140 | 2,364 | |
| Nitrobenzene | 0 | 0 | | 0 | 4,000 | 4,000 | 67,540 | |
| n-Nitrosodimethylamine | 0 | 0 | | 0 | 17,000 | 17,000 | 287,045 | |
| n-Nitrosodi-n-Propylamine | 0 | 0 | | 0 | N/A | N/A | N/A | |
| n-Nitrosodiphenylamine | 0 | 0 | | 0 | 300 | 300 | 5,066 | |
| Phenanthrene | 0 | 0 | | 0 | 5 | 5.0 | 84.4 | |
| Pyrene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 1,2,4-Trichlorobenzene | 0 | 0 | | 0 | 130 | 130 | 2,195 | |

☒ **CFC** CCT (min): PMF: Analysis Hardness (mg/l): Analysis pH:

| Pollutants | Stream Conc (µg/L) | Stream CV | Trib Conc (µg/L) | Fate Coef | WQC (µg/L) | WQ Obj (µg/L) | WLA (µg/L) | Comments |
|------------------------------|--------------------|-----------|------------------|-----------|------------|---------------|------------|----------------------------------|
| Total Dissolved Solids (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Chloride (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Sulfate (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Fluoride (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Aluminum | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Antimony | 0 | 0 | | 0 | 220 | 220 | 22,353 | |
| Total Arsenic | 0 | 0 | | 0 | 150 | 150 | 15,241 | Chem Translator of 1 applied |
| Total Barium | 0 | 0 | | 0 | 4,100 | 4,100 | 416,581 | |
| Total Boron | 0 | 0 | | 0 | 1,600 | 1,600 | 162,568 | |
| Total Cadmium | 0 | 0 | | 0 | 0.307 | 0.34 | 34.8 | Chem Translator of 0.896 applied |
| Total Chromium (III) | 0 | 0 | | 0 | 96.125 | 112 | 11,357 | Chem Translator of 0.86 applied |
| Hexavalent Chromium | 0 | 0 | | 0 | 10 | 10.4 | 1,056 | Chem Translator of 0.962 applied |
| Total Cobalt | 0 | 0 | | 0 | 19 | 19.0 | 1,930 | |

| | | | | | | | | |
|---------------------------------|---|---|--|---|---------|-------|-----------|----------------------------------|
| Total Copper | 0 | 0 | | 0 | 11.747 | 12.2 | 1,243 | Chem Translator of 0.96 applied |
| Dissolved Iron | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Iron | 0 | 0 | | 0 | 1,500 | 1,500 | 3,972,750 | WQC = 30 day average; PMF = 1 |
| Total Lead | 0 | 0 | | 0 | 3.550 | 4.77 | 484 | Chem Translator of 0.745 applied |
| Total Manganese | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Mercury | 0 | 0 | | 0 | 0.770 | 0.91 | 92.0 | Chem Translator of 0.85 applied |
| Total Nickel | 0 | 0 | | 0 | 68.032 | 68.2 | 6,933 | Chem Translator of 0.997 applied |
| Total Phenols (Phenolics) (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Selenium | 0 | 0 | | 0 | 4.600 | 4.99 | 507 | Chem Translator of 0.922 applied |
| Total Silver | 0 | 0 | | 0 | N/A | N/A | N/A | Chem Translator of 1 applied |
| Total Thallium | 0 | 0 | | 0 | 13 | 13.0 | 1,321 | |
| Total Zinc | 0 | 0 | | 0 | 154.607 | 157 | 15,932 | Chem Translator of 0.986 applied |
| Acrolein | 0 | 0 | | 0 | 3 | 3.0 | 305 | |
| Acrylonitrile | 0 | 0 | | 0 | 130 | 130 | 13,209 | |
| Benzene | 0 | 0 | | 0 | 130 | 130 | 13,209 | |
| Bromoform | 0 | 0 | | 0 | 370 | 370 | 37,594 | |
| Carbon Tetrachloride | 0 | 0 | | 0 | 560 | 560 | 56,899 | |
| Chlorobenzene | 0 | 0 | | 0 | 240 | 240 | 24,385 | |
| Chlorodibromomethane | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 2-Chloroethyl Vinyl Ether | 0 | 0 | | 0 | 3,500 | 3,500 | 355,618 | |
| Chloroform | 0 | 0 | | 0 | 390 | 390 | 39,626 | |
| Dichlorobromomethane | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 1,2-Dichloroethane | 0 | 0 | | 0 | 3,100 | 3,100 | 314,976 | |
| 1,1-Dichloroethylene | 0 | 0 | | 0 | 1,500 | 1,500 | 152,408 | |
| 1,2-Dichloropropane | 0 | 0 | | 0 | 2,200 | 2,200 | 223,531 | |
| 1,3-Dichloropropylene | 0 | 0 | | 0 | 61 | 61.0 | 6,198 | |
| Ethylbenzene | 0 | 0 | | 0 | 580 | 580 | 58,931 | |
| Methyl Bromide | 0 | 0 | | 0 | 110 | 110 | 11,177 | |
| Methyl Chloride | 0 | 0 | | 0 | 5,500 | 5,500 | 558,828 | |
| Methylene Chloride | 0 | 0 | | 0 | 2,400 | 2,400 | 243,852 | |
| 1,1,2,2-Tetrachloroethane | 0 | 0 | | 0 | 210 | 210 | 21,337 | |
| Tetrachloroethylene | 0 | 0 | | 0 | 140 | 140 | 14,225 | |
| Toluene | 0 | 0 | | 0 | 330 | 330 | 33,530 | |
| 1,2-trans-Dichloroethylene | 0 | 0 | | 0 | 1,400 | 1,400 | 142,247 | |
| 1,1,1-Trichloroethane | 0 | 0 | | 0 | 610 | 610 | 61,979 | |
| 1,1,2-Trichloroethane | 0 | 0 | | 0 | 680 | 680 | 69,091 | |
| Trichloroethylene | 0 | 0 | | 0 | 450 | 450 | 45,722 | |
| Vinyl Chloride | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 2-Chlorophenol | 0 | 0 | | 0 | 110 | 110 | 11,177 | |
| 2,4-Dichlorophenol | 0 | 0 | | 0 | 340 | 340 | 34,546 | |
| 2,4-Dimethylphenol | 0 | 0 | | 0 | 130 | 130 | 13,209 | |
| 4,6-Dinitro-o-Cresol | 0 | 0 | | 0 | 16 | 16.0 | 1,626 | |
| 2,4-Dinitrophenol | 0 | 0 | | 0 | 130 | 130 | 13,209 | |
| 2-Nitrophenol | 0 | 0 | | 0 | 1,600 | 1,600 | 162,568 | |
| 4-Nitrophenol | 0 | 0 | | 0 | 470 | 470 | 47,754 | |

| | | | | | | | |
|-----------------------------|---|---|--|---|--------|-------|---------|
| p-Chloro-m-Cresol | 0 | 0 | | 0 | 500 | 500 | 50,803 |
| Pentachlorophenol | 0 | 0 | | 0 | 26,342 | 26.3 | 2,676 |
| Phenol | 0 | 0 | | 0 | N/A | N/A | N/A |
| 2,4,6-Trichlorophenol | 0 | 0 | | 0 | 91 | 91.0 | 9,246 |
| Acenaphthene | 0 | 0 | | 0 | 17 | 17.0 | 1,727 |
| Anthracene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Benzidine | 0 | 0 | | 0 | 59 | 59.0 | 5,995 |
| Benzo(a)Anthracene | 0 | 0 | | 0 | 0.1 | 0.1 | 10.2 |
| Benzo(a)Pyrene | 0 | 0 | | 0 | N/A | N/A | N/A |
| 3,4-Benzofluoranthene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Benzo(k)Fluoranthene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Bis(2-Chloroethyl)Ether | 0 | 0 | | 0 | 6,000 | 6,000 | 609,630 |
| Bis(2-Chloroisopropyl)Ether | 0 | 0 | | 0 | N/A | N/A | N/A |
| Bis(2-Ethylhexyl)Phthalate | 0 | 0 | | 0 | 910 | 910 | 92,461 |
| 4-Bromophenyl Phenyl Ether | 0 | 0 | | 0 | 54 | 54.0 | 5,487 |
| Butyl Benzyl Phthalate | 0 | 0 | | 0 | 35 | 35.0 | 3,556 |
| 2-Chloronaphthalene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Chrysene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Dibenzo(a,h)Anthracene | 0 | 0 | | 0 | N/A | N/A | N/A |
| 1,2-Dichlorobenzene | 0 | 0 | | 0 | 160 | 160 | 16,257 |
| 1,3-Dichlorobenzene | 0 | 0 | | 0 | 69 | 69.0 | 7,011 |
| 1,4-Dichlorobenzene | 0 | 0 | | 0 | 150 | 150 | 15,241 |
| 3,3-Dichlorobenzidine | 0 | 0 | | 0 | N/A | N/A | N/A |
| Diethyl Phthalate | 0 | 0 | | 0 | 800 | 800 | 81,284 |
| Dimethyl Phthalate | 0 | 0 | | 0 | 500 | 500 | 50,803 |
| Di-n-Butyl Phthalate | 0 | 0 | | 0 | 21 | 21.0 | 2,134 |
| 2,4-Dinitrotoluene | 0 | 0 | | 0 | 320 | 320 | 32,514 |
| 2,6-Dinitrotoluene | 0 | 0 | | 0 | 200 | 200 | 20,321 |
| 1,2-Diphenylhydrazine | 0 | 0 | | 0 | 3 | 3.0 | 305 |
| Fluoranthene | 0 | 0 | | 0 | 40 | 40.0 | 4,064 |
| Fluorene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Hexachlorobenzene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Hexachlorobutadiene | 0 | 0 | | 0 | 2 | 2.0 | 203 |
| Hexachlorocyclopentadiene | 0 | 0 | | 0 | 1 | 1.0 | 102 |
| Hexachloroethane | 0 | 0 | | 0 | 12 | 12.0 | 1,219 |
| Indeno(1,2,3-cd)Pyrene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Isophorone | 0 | 0 | | 0 | 2,100 | 2,100 | 213,371 |
| Naphthalene | 0 | 0 | | 0 | 43 | 43.0 | 4,369 |
| Nitrobenzene | 0 | 0 | | 0 | 810 | 810 | 82,300 |
| n-Nitrosodimethylamine | 0 | 0 | | 0 | 3,400 | 3,400 | 345,457 |
| n-Nitrosodi-n-Propylamine | 0 | 0 | | 0 | N/A | N/A | N/A |
| n-Nitrosodiphenylamine | 0 | 0 | | 0 | 59 | 59.0 | 5,995 |
| Phenanthrene | 0 | 0 | | 0 | 1 | 1.0 | 102 |
| Pyrene | 0 | 0 | | 0 | N/A | N/A | N/A |
| 1,2,4-Trichlorobenzene | 0 | 0 | | 0 | 26 | 26.0 | 2,642 |

☒ **THH** CCT (min): PMF: Analysis Hardness (mg/l): Analysis pH:

| Pollutants | Stream Conc (µg/L) | Stream CV | Trib Conc (µg/L) | Fate Coef | WQC (µg/L) | WQ Obj (µg/L) | WLA (µg/L) | Comments |
|---------------------------------|--------------------|-----------|------------------|-----------|------------|---------------|------------|----------|
| Total Dissolved Solids (PWS) | 0 | 0 | | 0 | 500,000 | 500,000 | N/A | |
| Chloride (PWS) | 0 | 0 | | 0 | 250,000 | 250,000 | N/A | |
| Sulfate (PWS) | 0 | 0 | | 0 | 250,000 | 250,000 | N/A | |
| Fluoride (PWS) | 0 | 0 | | 0 | 2,000 | 2,000 | N/A | |
| Total Aluminum | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Antimony | 0 | 0 | | 0 | 5.6 | 5.6 | 569 | |
| Total Arsenic | 0 | 0 | | 0 | 10 | 10.0 | 1,016 | |
| Total Barium | 0 | 0 | | 0 | 2,400 | 2,400 | 243,852 | |
| Total Boron | 0 | 0 | | 0 | 3,100 | 3,100 | 314,976 | |
| Total Cadmium | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Chromium (III) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Hexavalent Chromium | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Cobalt | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Copper | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Dissolved Iron | 0 | 0 | | 0 | 300 | 300 | 30,482 | |
| Total Iron | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Lead | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Manganese | 0 | 0 | | 0 | 1,000 | 1,000 | 101,605 | |
| Total Mercury | 0 | 0 | | 0 | 0.050 | 0.05 | 5.08 | |
| Total Nickel | 0 | 0 | | 0 | 610 | 610 | 61,979 | |
| Total Phenols (Phenolics) (PWS) | 0 | 0 | | 0 | 5 | 5.0 | N/A | |
| Total Selenium | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Silver | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Thallium | 0 | 0 | | 0 | 0.24 | 0.24 | 24.4 | |
| Total Zinc | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Acrolein | 0 | 0 | | 0 | 3 | 3.0 | 305 | |
| Acrylonitrile | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Benzene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Bromoform | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Carbon Tetrachloride | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Chlorobenzene | 0 | 0 | | 0 | 100 | 100.0 | 10,161 | |
| Chlorodibromomethane | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 2-Chloroethyl Vinyl Ether | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Chloroform | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Dichlorobromomethane | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 1,2-Dichloroethane | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 1,1-Dichloroethylene | 0 | 0 | | 0 | 33 | 33.0 | 3,353 | |
| 1,2-Dichloropropane | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 1,3-Dichloropropylene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Ethylbenzene | 0 | 0 | | 0 | 68 | 68.0 | 6,909 | |

| | | | | | | | |
|-----------------------------|---|---|--|---|--------|--------|-----------|
| Methyl Bromide | 0 | 0 | | 0 | 100 | 100.0 | 10,161 |
| Methyl Chloride | 0 | 0 | | 0 | N/A | N/A | N/A |
| Methylene Chloride | 0 | 0 | | 0 | N/A | N/A | N/A |
| 1,1,2,2-Tetrachloroethane | 0 | 0 | | 0 | N/A | N/A | N/A |
| Tetrachloroethylene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Toluene | 0 | 0 | | 0 | 57 | 57.0 | 5,791 |
| 1,2-trans-Dichloroethylene | 0 | 0 | | 0 | 100 | 100.0 | 10,161 |
| 1,1,1-Trichloroethane | 0 | 0 | | 0 | 10,000 | 10,000 | 1,016,050 |
| 1,1,2-Trichloroethane | 0 | 0 | | 0 | N/A | N/A | N/A |
| Trichloroethylene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Vinyl Chloride | 0 | 0 | | 0 | N/A | N/A | N/A |
| 2-Chlorophenol | 0 | 0 | | 0 | 30 | 30.0 | 3,048 |
| 2,4-Dichlorophenol | 0 | 0 | | 0 | 10 | 10.0 | 1,016 |
| 2,4-Dimethylphenol | 0 | 0 | | 0 | 100 | 100.0 | 10,161 |
| 4,6-Dinitro-o-Cresol | 0 | 0 | | 0 | 2 | 2.0 | 203 |
| 2,4-Dinitrophenol | 0 | 0 | | 0 | 10 | 10.0 | 1,016 |
| 2-Nitrophenol | 0 | 0 | | 0 | N/A | N/A | N/A |
| 4-Nitrophenol | 0 | 0 | | 0 | N/A | N/A | N/A |
| p-Chloro-m-Cresol | 0 | 0 | | 0 | N/A | N/A | N/A |
| Pentachlorophenol | 0 | 0 | | 0 | N/A | N/A | N/A |
| Phenol | 0 | 0 | | 0 | 4,000 | 4,000 | 406,420 |
| 2,4,6-Trichlorophenol | 0 | 0 | | 0 | N/A | N/A | N/A |
| Acenaphthene | 0 | 0 | | 0 | 70 | 70.0 | 7,112 |
| Anthracene | 0 | 0 | | 0 | 300 | 300 | 30,482 |
| Benidine | 0 | 0 | | 0 | N/A | N/A | N/A |
| Benzo(a)Anthracene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Benzo(a)Pyrene | 0 | 0 | | 0 | N/A | N/A | N/A |
| 3,4-Benzofluoranthene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Benzo(k)Fluoranthene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Bis(2-Chloroethyl)Ether | 0 | 0 | | 0 | N/A | N/A | N/A |
| Bis(2-Chloroisopropyl)Ether | 0 | 0 | | 0 | 200 | 200 | 20,321 |
| Bis(2-Ethylhexyl)Phthalate | 0 | 0 | | 0 | N/A | N/A | N/A |
| 4-Bromophenyl Phenyl Ether | 0 | 0 | | 0 | N/A | N/A | N/A |
| Butyl Benzyl Phthalate | 0 | 0 | | 0 | 0.1 | 0.1 | 10.2 |
| 2-Chloronaphthalene | 0 | 0 | | 0 | 800 | 800 | 81,284 |
| Chrysene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Dibenzo(a,h)Anthracene | 0 | 0 | | 0 | N/A | N/A | N/A |
| 1,2-Dichlorobenzene | 0 | 0 | | 0 | 1,000 | 1,000 | 101,605 |
| 1,3-Dichlorobenzene | 0 | 0 | | 0 | 7 | 7.0 | 711 |
| 1,4-Dichlorobenzene | 0 | 0 | | 0 | 300 | 300 | 30,482 |
| 3,3-Dichlorobenzidine | 0 | 0 | | 0 | N/A | N/A | N/A |
| Diethyl Phthalate | 0 | 0 | | 0 | 600 | 600 | 60,963 |
| Dimethyl Phthalate | 0 | 0 | | 0 | 2,000 | 2,000 | 203,210 |
| Di-n-Butyl Phthalate | 0 | 0 | | 0 | 20 | 20.0 | 2,032 |
| 2,4-Dinitrotoluene | 0 | 0 | | 0 | N/A | N/A | N/A |

| | | | | | | | |
|---------------------------|---|---|--|---|------|------|-------|
| 2,6-Dinitrotoluene | 0 | 0 | | 0 | N/A | N/A | N/A |
| 1,2-Diphenylhydrazine | 0 | 0 | | 0 | N/A | N/A | N/A |
| Fluoranthene | 0 | 0 | | 0 | 20 | 20.0 | 2,032 |
| Fluorene | 0 | 0 | | 0 | 50 | 50.0 | 5,080 |
| Hexachlorobenzene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Hexachlorobutadiene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Hexachlorocyclopentadiene | 0 | 0 | | 0 | 4 | 4.0 | 406 |
| Hexachloroethane | 0 | 0 | | 0 | N/A | N/A | N/A |
| Indeno(1,2,3-cd)Pyrene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Isophorone | 0 | 0 | | 0 | 34 | 34.0 | 3,455 |
| Naphthalene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Nitrobenzene | 0 | 0 | | 0 | 10 | 10.0 | 1,016 |
| n-Nitrosodimethylamine | 0 | 0 | | 0 | N/A | N/A | N/A |
| n-Nitrosodi-n-Propylamine | 0 | 0 | | 0 | N/A | N/A | N/A |
| n-Nitrosodiphenylamine | 0 | 0 | | 0 | N/A | N/A | N/A |
| Phenanthrene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Pyrene | 0 | 0 | | 0 | 20 | 20.0 | 2,032 |
| 1,2,4-Trichlorobenzene | 0 | 0 | | 0 | 0.07 | 0.07 | 7.11 |

☒ **CRL** CCT (min): PMF: Analysis Hardness (mg/l): Analysis pH:

| Pollutants | Stream Conc (µg/L) | Stream CV | Trib Conc (µg/L) | Fate Coef | WQC (µg/L) | WQ Obj (µg/L) | WLA (µg/L) | Comments |
|---------------------------------|--------------------|-----------|------------------|-----------|------------|---------------|------------|----------|
| Total Dissolved Solids (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Chloride (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Sulfate (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Fluoride (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Aluminum | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Antimony | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Arsenic | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Barium | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Boron | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Cadmium | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Chromium (III) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Hexavalent Chromium | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Cobalt | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Copper | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Dissolved Iron | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Iron | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Lead | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Manganese | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Mercury | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Nickel | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Phenols (Phenolics) (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Selenium | 0 | 0 | | 0 | N/A | N/A | N/A | |

| | | | | | | | |
|----------------------------|---|---|--|---|--------|--------|-------|
| Total Silver | 0 | 0 | | 0 | N/A | N/A | N/A |
| Total Thallium | 0 | 0 | | 0 | N/A | N/A | N/A |
| Total Zinc | 0 | 0 | | 0 | N/A | N/A | N/A |
| Acrolein | 0 | 0 | | 0 | N/A | N/A | N/A |
| Acrylonitrile | 0 | 0 | | 0 | 0.06 | 0.06 | 22.0 |
| Benzene | 0 | 0 | | 0 | 0.58 | 0.58 | 213 |
| Bromoform | 0 | 0 | | 0 | 7 | 7.0 | 2,567 |
| Carbon Tetrachloride | 0 | 0 | | 0 | 0.4 | 0.4 | 147 |
| Chlorobenzene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Chlorodibromomethane | 0 | 0 | | 0 | 0.8 | 0.8 | 293 |
| 2-Chloroethyl Vinyl Ether | 0 | 0 | | 0 | N/A | N/A | N/A |
| Chloroform | 0 | 0 | | 0 | 5.7 | 5.7 | 2,090 |
| Dichlorobromomethane | 0 | 0 | | 0 | 0.95 | 0.95 | 348 |
| 1,2-Dichloroethane | 0 | 0 | | 0 | 9.9 | 9.9 | 3,630 |
| 1,1-Dichloroethylene | 0 | 0 | | 0 | N/A | N/A | N/A |
| 1,2-Dichloropropane | 0 | 0 | | 0 | 0.9 | 0.9 | 330 |
| 1,3-Dichloropropylene | 0 | 0 | | 0 | 0.27 | 0.27 | 99.0 |
| Ethylbenzene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Methyl Bromide | 0 | 0 | | 0 | N/A | N/A | N/A |
| Methyl Chloride | 0 | 0 | | 0 | N/A | N/A | N/A |
| Methylene Chloride | 0 | 0 | | 0 | 20 | 20.0 | 7,334 |
| 1,1,2,2-Tetrachloroethane | 0 | 0 | | 0 | 0.2 | 0.2 | 73.3 |
| Tetrachloroethylene | 0 | 0 | | 0 | 10 | 10.0 | 3,667 |
| Toluene | 0 | 0 | | 0 | N/A | N/A | N/A |
| 1,2-trans-Dichloroethylene | 0 | 0 | | 0 | N/A | N/A | N/A |
| 1,1,1-Trichloroethane | 0 | 0 | | 0 | N/A | N/A | N/A |
| 1,1,2-Trichloroethane | 0 | 0 | | 0 | 0.55 | 0.55 | 202 |
| Trichloroethylene | 0 | 0 | | 0 | 0.6 | 0.6 | 220 |
| Vinyl Chloride | 0 | 0 | | 0 | 0.02 | 0.02 | 7.33 |
| 2-Chlorophenol | 0 | 0 | | 0 | N/A | N/A | N/A |
| 2,4-Dichlorophenol | 0 | 0 | | 0 | N/A | N/A | N/A |
| 2,4-Dimethylphenol | 0 | 0 | | 0 | N/A | N/A | N/A |
| 4,6-Dinitro-o-Cresol | 0 | 0 | | 0 | N/A | N/A | N/A |
| 2,4-Dinitrophenol | 0 | 0 | | 0 | N/A | N/A | N/A |
| 2-Nitrophenol | 0 | 0 | | 0 | N/A | N/A | N/A |
| 4-Nitrophenol | 0 | 0 | | 0 | N/A | N/A | N/A |
| p-Chloro-m-Cresol | 0 | 0 | | 0 | N/A | N/A | N/A |
| Pentachlorophenol | 0 | 0 | | 0 | 0.030 | 0.03 | 11.0 |
| Phenol | 0 | 0 | | 0 | N/A | N/A | N/A |
| 2,4,6-Trichlorophenol | 0 | 0 | | 0 | 1.5 | 1.5 | 550 |
| Acenaphthene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Anthracene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Benzdine | 0 | 0 | | 0 | 0.0001 | 0.0001 | 0.037 |
| Benzo(a)Anthracene | 0 | 0 | | 0 | 0.001 | 0.001 | 0.37 |
| Benzo(a)Pyrene | 0 | 0 | | 0 | 0.0001 | 0.0001 | 0.037 |

| | | | | | | | |
|-----------------------------|---|---|--|---|---------|---------|-------|
| 3,4-Benzofluoranthene | 0 | 0 | | 0 | 0.001 | 0.001 | 0.37 |
| Benzo(k)Fluoranthene | 0 | 0 | | 0 | 0.01 | 0.01 | 3.67 |
| Bis(2-Chloroethyl)Ether | 0 | 0 | | 0 | 0.03 | 0.03 | 11.0 |
| Bis(2-Chloroisopropyl)Ether | 0 | 0 | | 0 | N/A | N/A | N/A |
| Bis(2-Ethylhexyl)Phthalate | 0 | 0 | | 0 | 0.32 | 0.32 | 117 |
| 4-Bromophenyl Phenyl Ether | 0 | 0 | | 0 | N/A | N/A | N/A |
| Butyl Benzyl Phthalate | 0 | 0 | | 0 | N/A | N/A | N/A |
| 2-Chloronaphthalene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Chrysene | 0 | 0 | | 0 | 0.12 | 0.12 | 44.0 |
| Dibenzo(a,h)Anthracene | 0 | 0 | | 0 | 0.0001 | 0.0001 | 0.037 |
| 1,2-Dichlorobenzene | 0 | 0 | | 0 | N/A | N/A | N/A |
| 1,3-Dichlorobenzene | 0 | 0 | | 0 | N/A | N/A | N/A |
| 1,4-Dichlorobenzene | 0 | 0 | | 0 | N/A | N/A | N/A |
| 3,3-Dichlorobenzidine | 0 | 0 | | 0 | 0.05 | 0.05 | 18.3 |
| Diethyl Phthalate | 0 | 0 | | 0 | N/A | N/A | N/A |
| Dimethyl Phthalate | 0 | 0 | | 0 | N/A | N/A | N/A |
| Di-n-Butyl Phthalate | 0 | 0 | | 0 | N/A | N/A | N/A |
| 2,4-Dinitrotoluene | 0 | 0 | | 0 | 0.05 | 0.05 | 18.3 |
| 2,6-Dinitrotoluene | 0 | 0 | | 0 | 0.05 | 0.05 | 18.3 |
| 1,2-Diphenylhydrazine | 0 | 0 | | 0 | 0.03 | 0.03 | 11.0 |
| Fluoranthene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Fluorene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Hexachlorobenzene | 0 | 0 | | 0 | 0.00008 | 0.00008 | 0.029 |
| Hexachlorobutadiene | 0 | 0 | | 0 | 0.01 | 0.01 | 3.67 |
| Hexachlorocyclopentadiene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Hexachloroethane | 0 | 0 | | 0 | 0.1 | 0.1 | 36.7 |
| Indeno(1,2,3-cd)Pyrene | 0 | 0 | | 0 | 0.001 | 0.001 | 0.37 |
| Isophorone | 0 | 0 | | 0 | N/A | N/A | N/A |
| Naphthalene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Nitrobenzene | 0 | 0 | | 0 | N/A | N/A | N/A |
| n-Nitrosodimethylamine | 0 | 0 | | 0 | 0.0007 | 0.0007 | 0.26 |
| n-Nitrosodi-n-Propylamine | 0 | 0 | | 0 | 0.005 | 0.005 | 1.83 |
| n-Nitrosodiphenylamine | 0 | 0 | | 0 | 3.3 | 3.3 | 1,210 |
| Phenanthrene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Pyrene | 0 | 0 | | 0 | N/A | N/A | N/A |
| 1,2,4-Trichlorobenzene | 0 | 0 | | 0 | N/A | N/A | N/A |

☒ Recommended WQBELs & Monitoring Requirements

No. Samples/Month: 4

| Pollutants | Mass Limits | | Concentration Limits | | | | Governing WQBEL | WQBEL Basis | Comments |
|---------------------|---------------|---------------|----------------------|------|------|-------|-----------------|-------------|---------------------------------|
| | AML (lbs/day) | MDL (lbs/day) | AML | MDL | IMAX | Units | | | |
| Hexachlorobutadiene | 0.026 | 0.041 | 3.67 | 5.72 | 9.17 | µg/L | 3.67 | CRL | Discharge Conc ≥ 50% WQBEL (RP) |

| | | | | | | | | | |
|------------------------|--------|--------|--------|--------|--------|------|------|-----|------------------------------------|
| 1,2,4-Trichlorobenzene | Report | Report | Report | Report | Report | µg/L | 7.11 | THH | Discharge Conc > 25% WQBEL (no RP) |
| | | | | | | | | | |

☒ **Other Pollutants without Limits or Monitoring**

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., <= Target QL).

| Pollutants | Governing WQBEL | Units | Comments |
|---------------------------------|-----------------|-------|----------------------------|
| Total Dissolved Solids (PWS) | N/A | N/A | PWS Not Applicable |
| Chloride (PWS) | N/A | N/A | PWS Not Applicable |
| Bromide | N/A | N/A | No WQS |
| Sulfate (PWS) | N/A | N/A | PWS Not Applicable |
| Fluoride (PWS) | N/A | N/A | PWS Not Applicable |
| Total Aluminum | 8,117 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Antimony | 569 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Arsenic | 1,016 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Barium | 227,275 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Beryllium | N/A | N/A | No WQS |
| Total Boron | 87,663 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Cadmium | 34.8 | µg/L | Discharge Conc < TQL |
| Total Chromium (III) | 11,357 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Hexavalent Chromium | 176 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Cobalt | 1,028 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Copper | 270 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Cyanide | N/A | N/A | No WQS |
| Dissolved Iron | 30,482 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Iron | 3,972,750 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Lead | 484 | µg/L | Discharge Conc < TQL |
| Total Manganese | 101,605 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Mercury | 5.08 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Nickel | 6,933 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Phenols (Phenolics) (PWS) | | µg/L | Discharge Conc < TQL |
| Total Selenium | 507 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Silver | 117 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Thallium | 24.4 | µg/L | Discharge Conc < TQL |
| Total Zinc | 2,178 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Acrolein | 32.5 | µg/L | Discharge Conc ≤ 25% WQBEL |
| Acrylonitrile | 22.0 | µg/L | Discharge Conc < TQL |
| Benzene | 213 | µg/L | Discharge Conc < TQL |
| Bromoform | 2,567 | µg/L | Discharge Conc ≤ 25% WQBEL |
| Carbon Tetrachloride | 147 | µg/L | Discharge Conc ≤ 25% WQBEL |
| Chlorobenzene | 10,161 | µg/L | Discharge Conc < TQL |
| Chlorodibromomethane | 293 | µg/L | Discharge Conc < TQL |
| Chloroethane | N/A | N/A | No WQS |

| | | | |
|-----------------------------|---------|------|----------------------------|
| 2-Chloroethyl Vinyl Ether | 194,807 | µg/L | Discharge Conc < TQL |
| Chloroform | 2,090 | µg/L | Discharge Conc ≤ 25% WQBEL |
| Dichlorobromomethane | 348 | µg/L | Discharge Conc ≤ 25% WQBEL |
| 1,1-Dichloroethane | N/A | N/A | No WQS |
| 1,2-Dichloroethane | 3,630 | µg/L | Discharge Conc < TQL |
| 1,1-Dichloroethylene | 3,353 | µg/L | Discharge Conc < TQL |
| 1,2-Dichloropropane | 330 | µg/L | Discharge Conc < TQL |
| 1,3-Dichloropropylene | 99.0 | µg/L | Discharge Conc ≤ 25% WQBEL |
| 1,4-Dioxane | N/A | N/A | No WQS |
| Ethylbenzene | 6,909 | µg/L | Discharge Conc < TQL |
| Methyl Bromide | 5,952 | µg/L | Discharge Conc ≤ 25% WQBEL |
| Methyl Chloride | 303,033 | µg/L | Discharge Conc ≤ 25% WQBEL |
| Methylene Chloride | 7,334 | µg/L | Discharge Conc ≤ 25% WQBEL |
| 1,1,2,2-Tetrachloroethane | 73.3 | µg/L | Discharge Conc < TQL |
| Tetrachloroethylene | 3,667 | µg/L | Discharge Conc < TQL |
| Toluene | 5,791 | µg/L | Discharge Conc < TQL |
| 1,2-trans-Dichloroethylene | 10,161 | µg/L | Discharge Conc < TQL |
| 1,1,1-Trichloroethane | 32,468 | µg/L | Discharge Conc < TQL |
| 1,1,2-Trichloroethane | 202 | µg/L | Discharge Conc < TQL |
| Trichloroethylene | 220 | µg/L | Discharge Conc < TQL |
| Vinyl Chloride | 7.33 | µg/L | Discharge Conc < TQL |
| 2-Chlorophenol | 3,048 | µg/L | Discharge Conc < TQL |
| 2,4-Dichlorophenol | 1,016 | µg/L | Discharge Conc < TQL |
| 2,4-Dimethylphenol | 7,143 | µg/L | Discharge Conc < TQL |
| 4,6-Dinitro-o-Cresol | 203 | µg/L | Discharge Conc < TQL |
| 2,4-Dinitrophenol | 1,016 | µg/L | Discharge Conc < TQL |
| 2-Nitrophenol | 86,581 | µg/L | Discharge Conc < TQL |
| 4-Nitrophenol | 24,892 | µg/L | Discharge Conc < TQL |
| p-Chloro-m-Cresol | 1,732 | µg/L | Discharge Conc < TQL |
| Pentachlorophenol | 11.0 | µg/L | Discharge Conc < TQL |
| Phenol | 406,420 | µg/L | Discharge Conc < TQL |
| 2,4,6-Trichlorophenol | 550 | µg/L | Discharge Conc < TQL |
| Acenaphthene | 898 | µg/L | Discharge Conc < TQL |
| Acenaphthylene | N/A | N/A | No WQS |
| Anthracene | 30,482 | µg/L | Discharge Conc < TQL |
| Benidine | 0.037 | µg/L | Discharge Conc < TQL |
| Benzo(a)Anthracene | 0.37 | µg/L | Discharge Conc < TQL |
| Benzo(a)Pyrene | 0.037 | µg/L | Discharge Conc < TQL |
| 3,4-Benzofluoranthene | 0.37 | µg/L | Discharge Conc < TQL |
| Benzo(ghi)Perylene | N/A | N/A | No WQS |
| Benzo(k)Fluoranthene | 3.67 | µg/L | Discharge Conc < TQL |
| Bis(2-Chloroethoxy)Methane | N/A | N/A | No WQS |
| Bis(2-Chloroethyl)Ether | 11.0 | µg/L | Discharge Conc < TQL |
| Bis(2-Chloroisopropyl)Ether | 20,321 | µg/L | Discharge Conc < TQL |
| Bis(2-Ethylhexyl)Phthalate | 117 | µg/L | Discharge Conc < TQL |

| | | | |
|-----------------------------|--------|------|----------------------------|
| 4-Bromophenyl Phenyl Ether | 2,922 | µg/L | Discharge Conc < TQL |
| Butyl Benzyl Phthalate | 10.2 | µg/L | Discharge Conc < TQL |
| 2-Chloronaphthalene | 81,284 | µg/L | Discharge Conc < TQL |
| 4-Chlorophenyl Phenyl Ether | N/A | N/A | No WQS |
| Chrysene | 44.0 | µg/L | Discharge Conc < TQL |
| Dibenzo(a,h)Anthracene | 0.037 | µg/L | Discharge Conc < TQL |
| 1,2-Dichlorobenzene | 8,875 | µg/L | Discharge Conc ≤ 25% WQBEL |
| 1,3-Dichlorobenzene | 711 | µg/L | Discharge Conc ≤ 25% WQBEL |
| 1,4-Dichlorobenzene | 7,901 | µg/L | Discharge Conc ≤ 25% WQBEL |
| 3,3-Dichlorobenzidine | 18.3 | µg/L | Discharge Conc < TQL |
| Diethyl Phthalate | 43,290 | µg/L | Discharge Conc < TQL |
| Dimethyl Phthalate | 27,057 | µg/L | Discharge Conc < TQL |
| Di-n-Butyl Phthalate | 1,190 | µg/L | Discharge Conc < TQL |
| 2,4-Dinitrotoluene | 18.3 | µg/L | Discharge Conc < TQL |
| 2,6-Dinitrotoluene | 18.3 | µg/L | Discharge Conc < TQL |
| Di-n-Octyl Phthalate | N/A | N/A | No WQS |
| 1,2-Diphenylhydrazine | 11.0 | µg/L | Discharge Conc < TQL |
| Fluoranthene | 2,032 | µg/L | Discharge Conc < TQL |
| Fluorene | 5,080 | µg/L | Discharge Conc < TQL |
| Hexachlorobenzene | 0.029 | µg/L | Discharge Conc < TQL |
| Hexachlorocyclopentadiene | 54.1 | µg/L | Discharge Conc < TQL |
| Hexachloroethane | 36.7 | µg/L | Discharge Conc < TQL |
| Indeno(1,2,3-cd)Pyrene | 0.37 | µg/L | Discharge Conc < TQL |
| Isophorone | 3,455 | µg/L | Discharge Conc < TQL |
| Naphthalene | 1,515 | µg/L | Discharge Conc ≤ 25% WQBEL |
| Nitrobenzene | 1,016 | µg/L | Discharge Conc < TQL |
| n-Nitrosodimethylamine | 0.26 | µg/L | Discharge Conc < TQL |
| n-Nitrosodi-n-Propylamine | 1.83 | µg/L | Discharge Conc < TQL |
| n-Nitrosodiphenylamine | 1,210 | µg/L | Discharge Conc < TQL |
| Phenanthrene | 54.1 | µg/L | Discharge Conc < TQL |
| Pyrene | 2,032 | µg/L | Discharge Conc < TQL |
| | | | |
| | | | |