

Application Type Renewal  
Wastewater Type Sewage  
Facility Type SRSTP

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SFTF/SRSTP**

Application No. PA0265977  
APS ID 854551  
Authorization ID 1533604

**Applicant, Facility and Project Information**

Applicant Name	<u>Richard R Stone</u>	Facility Name	<u>Stone Res</u>
Applicant Address	<u>5260 Pinchtown Road</u> <u>Dover, PA 17315-4024</u>	Facility Address	<u>5260 Pinchtown Road</u> <u>Dover, PA 17315-4024</u>
Applicant Contact	<u>Richard Stone</u>	Facility Contact	<u>Richard Stone</u>
Applicant Phone	<u>(717) 880-2101</u>	Facility Phone	<u>(717) 880-2101</u>
Client ID	<u>315220</u>	Site ID	<u>787352</u>
SIC Code	<u>4952</u>	Municipality	<u>Dover Township</u>
SIC Description	<u>Trans. &amp; Utilities - Sewerage Systems</u>	County	<u>York</u>
Date Application Received	<u>July 8, 2025</u>	WQM Required	<u>Issued</u>
Date Application Accepted	<u>July 11, 2025</u>	WQM App. No.	<u>6714402</u>
Project Description	<u>NPDES Renewal submitted for an SRSTP for an existing residence.</u>		

**Summary of Review**

Richard Stone has submitted an application for a renewal permit for their existing Single Residence Small Flow Treatment Facility located in York County. DEP received the NPDES permit applications on July 8, 2025 from the applicant. The Department has reviewed the application in order to ensure that the facility does not receive or discharge a flow greater than 400 GPD or exceed the specified limits of CBOD5, Total Suspended Solids, and Fecal Coliform prescribed in the permit. As per 25 Pa. Code § 92a.53, all applicable effluent limits and standards are considered in development of the permit. The limits noted in the permit suggest that any applicable water quality standards will not be violated.

The limits discussed in the permit are based on several factors that were determined by the Standard Operating Procedure for Small Flow Treatment Facilities (SOP No. BCW-PMT-003).

The TSS and Ammonia-Nitrogen limits were prescribed based on The Department's Water Quality Antidegradation Implementation Guidance ID No. 391-0300-002

The Fecal Coliform limits listed in the permit were required by the Bureau of Clean Water, as stated in Chapter 92.2c.b(2) and 93.7.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is

Approve	Deny	Signatures	Date
X		<i>Jared Lescavage</i> Jared Lescavage / Project Manager	April 14, 2026
x		<i>Scott M Arwood</i> Scott M. Arwood, P.E. / Environmental Engineer Manager	04/15/2026

**Summary of Review**

significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Discharge and Stream Data – 2 - Receiving Waters and PWS

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>.0004</u>
Latitude	<u>39° 58' 4.99"</u>	Longitude	<u>-76° 54' 30.19"</u>
Quad Name	<u></u>	Quad Code	<u></u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Unnamed Tributary to Conewago Creek (WWF, MF)</u>	Stream Code	<u>8751</u>
NHD Com ID	<u>57469323</u>	RMI	<u>0.5600</u>
Drainage Area	<u>0.04 ft<sup>2</sup></u>	Yield (cfs/mi <sup>2</sup> )	<u></u>
Q <sub>7-10</sub> Flow (cfs)	<u>0.000191</u>	Q <sub>7-10</sub> Basis	<u>StreamStats</u>
Elevation (ft)	<u></u>	Slope (ft/ft)	<u></u>
Watershed No.	<u>7-F</u>	Chapter 93 Class.	<u>WWF, MF</u>
Existing Use	<u></u>	Existing Use Qualifier	<u></u>
Exceptions to Use	<u></u>	Exceptions to Criteria	<u></u>
Assessment Status	<u>Impaired</u>		
Cause(s) of Impairment	<u>FLOW REGIME MODIFICATION</u>		
Source(s) of Impairment	<u>IMPACTS FROM HYDROSTRUCTURE FLOW REGULATION/MODIFICATION</u>		
TMDL Status	<u></u>	Name	<u></u>
Background/Ambient Data		Data Source	
pH (SU)	<u></u>		<u></u>
Temperature (°F)	<u></u>		<u></u>
Hardness (mg/L)	<u></u>		<u></u>
Other:	<u></u>		<u></u>
Nearest Downstream Public Water Supply Intake	<u>Wrightsville Borough Municipal Authority</u>		
PWS Waters	<u>Susquehanna River</u>	Flow at Intake (cfs)	<u></u>
PWS RMI	<u>43</u>	Distance from Outfall (mi)	<u>45</u>

Changes Since Last Permit Issuance: None

Other Comments: None

Compliance History	
Summary of DMRs:	N/A
Summary of Inspections:	Last inspection was previously done on July 24, 2024 by DEP. No violations were noted. The treatment plant was well maintained and proper records were kept.

Other Comments: **None**

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Annual Average	Maximum	Instant. Maximum		
Flow (MGD)	Report Annl Avg	XXX	XXX	XXX	XXX	XXX	1/year	Estimate
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/year	Grab
CBOD5	XXX	XXX	XXX	10.0	XXX	20	1/year	Grab
TSS	XXX	XXX	XXX	10.0	XXX	20	1/year	Grab
Fecal Coliform (No./100 ml)	XXX	XXX	XXX	200	XXX	XXX	1/year	Grab

Compliance Sampling Location: Outfall 001

Other Comments: None