

Southcentral Regional Office CLEAN WATER PROGRAM

NPDES:PA026

7228 WQM:6720403

Application Type New Wastewater Type Sewage

SRSTP

Facility Type

NPDES PERMIT FACT SHEET **INDIVIDUAL SFTF/SRSTP**

Application No.

APS ID

1021052

Authorization ID 1322977

Applicant Name	Benja	amin Shipley	Facility Name	Shipley Residence
Applicant Address	208 (Calvary Church Road	Facility Address	208 Calvary Church Road
	Wrigh	ntsville, PA 17368-9518		Wrightsville, PA 17368-9518
Applicant Contact	Benja	amin Shipley	Facility Contact	Benjamin Shipley
Applicant Phone	(717)	659-7816	Facility Phone	(717) 659-7816
Client ID	3577	77	Site ID	844343
SIC Code	8811		Municipality	Lower Windsor Township
SIC Description	Servi	ces - Private Households	County	York
Date Application Rece	eived	August 5, 2020	WQM Required	
Date Application Acce	epted	September 15, 2020	WQM App. No.	6720403

Approve	Deny	Signatures	Date
х		Nicholas Hong, P.E. / Environmental Engineer Nick Hong (via electronic signature)	March 15, 2021
		Daniel W. Martin, P.E. / Environmental Engineer Manager	
		Maria Bebenek, P.E./ Environmental Program Manager	

Summary of Review

The application submitted by the applicant requests a new NPDES and WQM permit for the Shipley Residence located at 208 Calvary Church Road, Wrightsville, PA 17368 in York County, municipality of Lower Windsor Township. The application for renewal was received by DEP Southcentral Regional Office (SCRO) on August 5, 2020. The corresponding WQM permit number for this NPDES is 6720403

The purpose of this Fact Sheet is to present the basis of information used for establishing the proposed NPDES permit effluent limitations. The Fact Sheet includes a description of the facility, a description of the facility's receiving waters, and a description of the facility's receiving waters attainment/non-attainment assessment status. Section 5 provides the justification for the proposed NPDES effluent limits derived from technology based effluent limits (TBEL), water quality based effluent limits (WQBEL), total maximum daily loading (TMDL), antidegradation, anti-backsliding, and/or whole effluent toxicity (WET). A brief summary of the outlined descriptions has been included in the Summary of Review section.

The subject facility is a 0.0004 MGD treatment facility. The NPDES application has been processed as a Small Flow Sewage Facility due to the type of sewage and the design flow rate for the facility. The applicant disclosed the Act 14 requirement to York County Board of Commissioners and Lower Windsor Township and the notice was received by the parties on March 4, 2020 and March 11, 2020. A planning approval letter was issued by DEP on February 20, 2020.

Utilizing the DEP's web-based Emap-PA information system, the receiving waters has been determined to be Cabin Creek. The sequence of receiving streams that Cabin Creek discharges into are the Susquehanna River which eventually drains into the Chesapeake Bay. Due to the low flow rate generated by the facility, the subject site is not subject to the Chesapeake Bay implementation requirements. The receiving water has protected water usage for warm water fishes (WWF) and migratory fishes (MF). No Class A Wild Trout fisheries are impacted by this discharge. The absence of high quality and/or exceptional value surface waters removes the need for an additional evaluation of anti-degradation requirements.

The Cabin Creek is a Category 2 stream listed in the 2020 Integrated List of All Waters (formerly 303d Listed Streams). This stream is an attaining stream that supports aquatic life. The receiving waters is not subject to a total maximum daily load (TMDL) plan to improve water quality in the subject facility's watershed.

Sludge use and disposal description and location(s): Since this is a new NPDES and WQM, this is not applicable at this time.

The proposed permit will expire five (5) years from the effective date.

Based on the review in this report, it is recommended that the permit be drafted. DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Any additional information or public review of documents associated with the discharge or facility may be available at PA DEP Southcentral Regional Office (SCRO), 909 Elmerton Avenue, Harrisburg, PA 17110. To make an appointment for file review, contact the SCRO File Review Coordinator at 717.705.4700.

1.0 Applicant

1.1 General Information

This fact sheet summarizes PA Department of Environmental Protection's review for the NPDES renewal for the following subject facility.

Facility Name: Shipley Residence

NPDES Permit # PA0267228

Physical Address: 208 Calvary Church Road

Wrightsville, PA 17368

Mailing Address: 208 Calvary Church Road

Wrightsville, PA 17368

Contact: Benjamin Shipley

Homeowner

bshipley@shipleyenergy.com

Consultant: Zane Williams, PE, SEO

McKeon & Williams Eng.

717-781-9565

zwilliamsseo@yahoo.com

1.2 Permit History

The existing treatment was usage of a holding tank. This NPDES shall permit the facility to discharge the sewage to surface waters.

2.0 Treatment Facility Summary

2.1.1 Site location

The physical address for the facility is 208 Calvary Church Road, Wrightsville, PA 17368. A topographical and an aerial photograph of the facility are depicted as Figure 1 and Figure 2.

Figure 1: Topographical map of the subject facility





Figure 2: Aerial Photograph of the subject facility



2.2 Description of Wastewater Treatment Process

The subject facility is a 0.0004 MGD (400 GPD) design flow facility. The subject facility treats wastewater using a Premier Tech Ecoflo EC7-500-P-P-Pack coco filter with uv disinfection prior to discharge through the outfall. An effluent filter is to be included on the outlet of the septic tank which is housed in the PACK unit vessel.

The treatment process is summarized in the table.

	Tr	eatment Facility Summar	у	
Treatment Facility Na	me: SFTF Shipley Benjam	in Residence		
WQM Permit No.	Issuance Date			
6720403	TBD			
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Tertiary	ECOFLOW Coco Filter	Ultraviolet	0.0004
Hydraulic Capacity	Organic Capacity			Biosolids
(MGD)	(lbs/day)	Load Status	Biosolids Treatment	Use/Disposal
0.0004		Not Overloaded		

2.3 Facility Outfall Information

The facility has the following outfall information for wastewater.

Outfall No.	001	Design Flow (MGD)	.0004
Latitude	39° 58' 13.00"	Longitude	-76° 29' 45.00"
Wastewater D	escription: Sewage Effluent		

3.0 Receiving Waters and Water Supply Information Detail Summary

3.1 Receiving Waters

The receiving waters has been determined to be Cabin Creek. The sequence of receiving streams that Cabin Creek discharges into are the Susquehanna River which eventually drains into the Chesapeake Bay.

3.2 Public Water Supply (PWS) Intake

The closest PWS to the subject facility is York Water Company (PWS ID #7670100) located approximately 1 mile downstream of the subject facility on the Susquehanna River. Based upon the distance and the flow rate of the facility, the PWS should not be impacted.

3.3 Class A Wild Trout Streams

Class A Wild Trout Streams are waters that support a population of naturally produced trout of sufficient size and abundance to support long-term and rewarding sport fishery. DEP classifies these waters as high-quality coldwater fisheries.

The information obtained from EMAP suggests that no Class A Wild Trout Fishery will be impacted by this discharge.

3.4 2020 Integrated List of All Waters (303d Listed Streams):

Section 303(d) of the Clean Water Act requires States to list all impaired surface waters not supporting uses even after appropriate and required water pollution control technologies have been applied. The 303(d) list includes the reason for impairment which may

be one or more point sources (i.e. industrial or sewage discharges) or non-point sources (i.e. abandoned mine lands or agricultural runoff and the pollutant causing the impairment such as metals, pH, mercury or siltation).

States or the U.S. Environmental Protection Agency (EPA) must determine the conditions that would return the water to a condition that meets water quality standards. As a follow-up to listing, the state or EPA must develop a Total Maximum Daily Load (TMDL) for each waterbody on the list. A TMDL identifies allowable pollutant loads to a waterbody from both point and non-point sources that will prevent a violation of water quality standards. A TMDL also includes a margin of safety to ensure protection of the water.

The water quality status of Pennsylvania's waters uses a five-part categorization (lists) of waters per their attainment use status. The categories represent varying levels of attainment, ranging from Category 1, where all designated water uses are met to Category 5 where impairment by pollutants requires a TMDL for water quality protection.

The receiving waters is listed in the 2020 Pennsylvania Integrated Water Quality Monitoring and Assessment Report as a Category 2 waterbody. The surface waters is an attaining stream that supports aquatic life. The designated use has been classified as protected waters for warm water fishes (WWF) and migratory fishes (MF).

3.5 Low Flow Stream Conditions

Water quality modeling estimates are based upon conservative data inputs. The data are typically estimated using either a stream gauge or through USGS web based StreamStats program. The NPDES effluent limits are based upon the combined flows from both the stream and the facility discharge.

A conservative approach to estimate the impact of the facility discharge using values which minimize the total combined volume of the stream and the facility discharge. The volumetric flow rate for the stream is based upon the seven-day, 10-year low flow (Q710) which is the lowest estimated flow rate of the stream during a 7 consecutive day period that occurs once in 10 -year time period. The facility discharge is based upon a known design capacity of the subject facility.

The low flow yield and the Q710 for the subject facility was estimated using StreamStats.

The estimated low flow yield is 0.26 ft³/s/mi² and the Q710 is 3.84 ft³/s

Summary of Di	scharge.	, Receiving Waters and V	Vater Supply Information	
Outfall No. 00	1		_ Design Flow (MGD)	.0004
Latitude 39° 58' 11.77"		Longitude	-76º 29' 43.79"	
Quad Name			Quad Code	
Wastewater Des	cription:	Sewage Effluent		
Receiving Waters	s Cabi	n Creek (WWF, MF)	Stream Code	7848
NHD Com ID		7095	RMI	0.2
Drainage Area	14.3		Yield (cfs/mi²)	0.26
Q ₇₋₁₀ Flow (cfs)	3.84		Q ₇₋₁₀ Basis	StreamStats
Elevation (ft)	238		Slope (ft/ft)	
Watershed No.	7-I		Chapter 93 Class.	WWF, MF
Existing Use	Sam	e a Chapter 93 Class	Existing Use Qualifier	
Exceptions to Us	е		Exceptions to Criteria	
Assessment Stat	us	Attaining Use(s) suppor	ts aquatic life	
Cause(s) of Impa	irment	Not appl.		
Source(s) of Impa	airment	Not appl.		
TMDL Status		Not appl.	Name	
Background/Amb	sient Data	<u>.</u>	Data Source	
pH (SU)	nont bate	Not appl.	Data Gource	
Temperature (°F)	١	Not appl.		
Hardness (mg/L)	•	Not appl.		
Other:				
Nearest Downstr	eam Pub	lic Water Supply Intake	York Water Company	
PWS Waters	Susque	ehanna River	Flow at Intake (cfs)	
PWS RMI	37		Distance from Outfall (mi)	1

4.0: Overview of Presiding Water Quality Standards

4.1 General

There are at least six (6) different policies which determines the effluent performance limits for the NPDES permit. The policies are technology based effluent limits (TBEL), water quality based effluent limits (WQBEL), antidegradation, total maximum daily loading (TMDL), anti-backsliding, and whole effluent toxicity (WET) The effluent performance limitations enforced are the selected permit limits that is most protective to the designated use of the receiving waters. An overview of each of the policies that are applicable to the subject facility has been presented in Section 6.

4.2.1 Technology-Based Limitations

TBEL treatment requirements under section 301(b) of the Act represent the minimum level of control that must be imposed in a permit issued under section 402 of the Act (40 CFR 125.3).

Small flow treatment facilities are confined to permit limitations promulgated by the Small Flow Treatment Facilities Manual (Document # 36-0300-002) and the SOP- New and Reissuance Small Flow Treatment Facility Individual NPDES Permit Application (Revised May 17, 2019).

Parameter	Avg Mo	IMAX	Sample Type	Frequency: SRSTPs
Flow (GPD)	Report	XXX	Estimate	1/year
BOD5 (mg/l)	10	20	Grab	1/year
TSS (mg/l)	10	20	Grab	1/year
Fecal Coliform (No/100 ml)	200 Ge Me		Grab	1/year

4.3 Water Quality-Based Limitations

The facility is not subject to water quality based effluent limits.

4.3.1 Water Quality Modeling 7.0

The facility is not subject to WQM.

4.3.2 Toxics Modeling

The facility is not subject to toxics modeling.

4.3.3 Whole Effluent Toxicity (WET)

The facility is not subject to WET.

4.4 Total Maximum Daily Loading (TMDL)

4.4.1 TMDL

The goal of the Clean Water Act (CWA), which governs water pollution, is to ensure that all of the Nation's waters are clean and healthy enough to support aquatic life and recreation. To achieve this goal, the CWA created programs designed to regulate and reduce the amount of pollution entering United States waters. Section 303(d) of the CWA requires states to assess their waterbodies to identify those not meeting water quality standards. If a waterbody is not meeting standards, it is listed as impaired and reported to the U.S. Environmental Protection Agency. The state then develops a plan to clean up the impaired waterbody. This plan includes the development of a Total Maximum Daily Load (TMDL) for the pollutant(s) that were found to be the cause of

the water quality violations. A Total Maximum Daily Load (TMDL) calculates the maximum amount of a specific pollutant that a waterbody can receive and still meet water quality standards.

Pennsylvania has committed to restoring all impaired waters by developing TMDLs and TMDL alternatives for all impaired waterbodies. The TMDL serves as the starting point or planning tool for restoring water quality.

4.4.1.1 Local TMDL

The subject facility does not discharge into a local TMDL.

4.4.1.2 Chesapeake Bay TMDL Requirement

The Chesapeake Bay Watershed is a large ecosystem that encompasses approximately 64,000 square miles in Maryland, Delaware, Virginia, West Virginia, Pennsylvania, New York and the District of Columbia. An ecosystem is composed of interrelated parts that interact with each other to form a whole. All of the plants and animals in an ecosystem depend on each other in some way. Every living thing needs a healthy ecosystem to survive. Human activities affect the Chesapeake Bay ecosystem by adding pollution, using resources and changing the character of the land.

Most of the Chesapeake Bay and many of its tidal tributaries have been listed as impaired under Section 303(d) of the federal Water Pollution Control Act ("Clean Water Act"), 33 U.S.C. § 1313(d). While the Chesapeake Bay is outside the boundaries of Pennsylvania, more than half of the State lies within the watershed. Two major rivers in Pennsylvania are part of the Chesapeake Bay Watershed. They are (a) the Susquehanna River and (b) the Potomac River. These two rivers total 40 percent of the entire Chesapeake Bay watershed.

The overall management approach needed for reducing nitrogen, phosphorus and sediment are provided in the Bay TMDL document and the Phase I, II, and III WIPs which is described in the Bay TMDL document and Executive Order 13508.

The Bay TMDL is a comprehensive pollution reduction effort in the Chesapeake Bay watershed identifying the necessary pollution reductions of nitrogen, phosphorus and sediment across the seven Bay watershed jurisdictions of Delaware, Maryland, New York, Pennsylvania, Virginia, West Virginia and the District of Columbia to meet applicable water quality standards in the Bay and its tidal waters.

The Watershed Implementation Plans (WIPs) provides objectives for how the jurisdictions in partnership with federal and local governments will achieve the Bay TMDL's nutrient and sediment allocations.

Phase 3 WIP provides an update on Chesapeake Bay TMDL implementation activities for point sources and DEP's current implementation strategy for wastewater. The latest revision of the supplement was December 17, 2019.

The Chesapeake Bay TMDL (Appendix Q) categorizes point sources into four sectors:

- Sector A- significant sewage dischargers;
- Sector B- significant industrial waste (IW) dischargers:
- Sector C- non-significant dischargers (both sewage and IW facilities); and
- Sector D- combined sewer overflows (CSOs).

All sectors contain a listing of individual facilities with NPDES permits that were believed to be discharging at the time the TMDL was published (2010). All sectors with the exception of the non-significant dischargers have individual wasteload allocations (WLAs) for TN and TP assigned to specific facilities. Non-significant dischargers have a bulk or aggregate allocation for TN and TP based on the facilities in that sector that were believed to be discharging at that time and their estimated nutrient loads.

Based upon the supplement the subject facility has been categorized as a Sector C discharger. The supplement defines Sector C as a non-significant discharger that includes sewage facilities (Phase 4 facilities: ≥ 0.2 MGD and < 0.4 MGD and Phase 5 facilities: > 0.002 MGD and < 0.2 MGD), small flow/single residence sewage treatment facilities (≤ 0.002 MGD), and non-significant IW facilities, all of which may be covered by statewide General Permits or may have individual NPDES permits.

At this time, there are approximately 850 Phase 4 and 5 sewage facilities, approximately 715 small flow sewage treatment facilities covered by a statewide General Permit, and approximately 300 non-significant IW facilities.

Due to the low flow rate generated by this facility, this facility is not subject to Sector C monitoring requirements.

4.5 Anti-Degradation Requirement

Chapter 93.4a of the PA regulations requires that surface water of the Commonwealth of Pennsylvania may not be degraded below levels that protect the existing uses. The regulations specifically state that *Existing instream water uses and the level of water quality necessary to protect the existing uses shall be maintained and protected*. Antidegradation requirements are implemented through DEP's guidance manual entitled Water Quality Antidegradation Implementation Guidance (Document #391-0300-02).

The policy requires DEP to protect the existing uses of all surface waters and the existing quality of High Quality (HQ) and Exceptional Value (EV) Waters. Existing uses are protected when DEP makes a final decision on any permit or approval for an activity that may affect a protected use. Existing uses are protected based upon DEP's evaluation of the best available information (which satisfies DEP protocols and Quality Assurance/Quality Control (QA/QC) procedures) that indicates the protected use of the waterbody.

For a new, additional, or increased point source discharge to an HQ or EV water, the person proposing the discharge is required to utilize a nondischarge alternative that is cost-effective and environmentally sound when compared with the cost of the proposed discharge. If a nondischarge alternative is not cost-effective and environmentally sound, the person must use the best available combination of treatment, pollution prevention, and wastewater reuse technologies and assure that any discharge is nondegrading. In the case of HQ waters, DEP may find that after satisfaction of intergovernmental coordination and public participation requirements lower water quality is necessary to accommodate important economic or social development in the area in which the waters are located. In addition, DEP will assure that cost-effective and reasonable best management practices for nonpoint source control in HQ and EV waters are achieved.

The subject facility's discharge will be to a non-special protection waters and the permit conditions are imposed to protect existing instream water quality and uses. Neither HQ waters or EV waters is impacted by this discharge.

4.6 Anti-Backsliding

Anti-backsliding is a federal regulation which prohibits a permit from being renewed, reissued, or modified containing effluent limitations which are less stringent than the comparable effluent limitations in the previous permit (40 CFR 122.I.1 and 40 CFR 122.I.2).

Since this is a new facility, anti-backsliding does not apply. However, future renewals may be subject to anti-backsliding.

5.0 NPDES Parameter Details

The basis for the proposed sampling and their monitoring frequency that will appear in the permit for each individual parameter are itemized in this Section. The final limits are the more stringent of technology based effluent treatment (TBEL) requirements, water quality based (WQBEL) limits, TMDL, antidegradation, anti-degradation, or WET.

The reader will find in this section:

- a) a justification of recommended permit monitoring requirements and limitations for each parameter in the proposed NPDES permit;
- b) a summary of the proposed NPDES effluent limits.

5.1 Recommended Monitoring Requirements and Effluent Limitations

A summary of the recommended monitoring requirements and effluent limitations are itemized in the tables. The table is categorized by Conventional Pollutants and Disinfection.

5.1.1 Conventional Pollutants and Disinfection

	Summary of Proposed NPDES Parameter Details for Conventional Pollutants and Disinfection						
	Shipley Residence, PA0267228						
Parameter	Permit Limitation		Recommendation				
Parameter	Required by ¹ :		Recommendation				
		Monitoring:	The monitoring frequency shall be 1x/yr as a grab sample (SOP)				
BOD	TBEL	Effluent Limit:	Effluent limits shall not exceed 10 mg/l as an average monthly (SOP)				
		Rationale:	The monitoring frequency and the effluent limits assigned by the SOP.				
		Monitoring:	The monitoring frequency shall be 1x/yr as a grab sample (SOP).				
TSS	TBEL	Effluent Limit:	Effluent limits shall not exceed 10 mg/l as an average monthly (SOP)				
		Rationale:	The monitoring frequency and the effluent limits assigned by the SOP.				
Fecal		Monitoring:	The monitoring frequency shall be 1x/yr as a grab sample (SOP).				
Coliform	TBEL	Effluent Limit:	Effluent limits shall not exceed 200 MPN as a geometric mean (SOP).				
Comorni		Rationale:	The monitoring frequency and the effluent limits assigned by the SOP.				
Notes:							
1 The NPDES	permit was limited by	v (a) anti-Back	sliding. (b) Anti-Degradation. (c) SOP. (d) TBEL. (e) TMDL. (f) WQBEL. or (g) WET				

5.3.1 Summary of Proposed NPDES Effluent Limits

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

The proposed NPDES effluent limitations are summarized in the table below.

PART A - EFFLUENT LIMIT	ATIONS, MONITORING, RECORDKEEPING AND REPORTING REQUIREMENTS
I. A. For Outfall 001	, Latitude39° 58' 13.00", Longitude76° 29' 45.00", River Mile Index0.2, Stream Code7848
Receiving Waters:	Cabin Creek (WWF, MF)
Type of Effluent:	Sewage Effluent

^{1.} The permittee is authorized to discharge during the period from Permit Effective Date through Permit Expiration Date.

Based on the anticipated wastewater characteristics and flows described in the permit application and its supporting documents and/or amendments, the following effluent limitations and monitoring requirements apply (see also Additional Requirements and Footnotes).

		Effluent Limitations					Monitoring Requirements	
Parameter	Mass Units	(lbs/day) (1)		Concentrat	ions (mg/L)		Minimum (2)	Required
Parameter	Average Monthly	Average Weekly	Minimum	Annual Average	Maximum	Instant. Maximum	Measurement Frequency	Sample Type
Flow (MGD)	Report Annl Avg	XXX	XXX	XXX	XXX	XXX	1/year	Estimate
BOD5	XXX	XXX	XXX	10.0	XXX	20.0	1/year	Grab
TSS	XXX	XXX	XXX	10.0	XXX	20.0	1/year	Grab
Fecal Coliform (No /100 ml)	xxx	XXX	XXX	200	XXX	XXX	1/vear	Grab

Samples taken in compliance with the monitoring requirements specified above shall be taken at the following location(s):

at Outfall 001

² Monitoring frequency based on flow rate of 0.0004 MGD.

³ SOP, New and Reissuance Small Flow Treatment Facility Individual NPDES Permit Applications, Revised January 13, 2015

⁴ Water Quality Antidegradation Implementaton Guidance (Document # 391-0300-002)

⁵ Phase 2 Watershed Implementation Plan Wastewater Supplement, Revised September 6, 2017

6.3.2 Summary of Proposed Permit Part C Conditions

The subject facility has the following Part C conditions.

• SFTF Maintenance

		Tools and References Used to Develop Permit
	1	
	<u> </u> 1	WQM for Windows Model (see Attachment)
	<u> </u> 1	Toxics Management Spreadsheet (see Attachment)
	<u> </u>	TRC Model Spreadsheet (see Attachment)
	<u> </u>	Temperature Model Spreadsheet (see Attachment)
	<u> </u>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
	<u> </u>	Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97.
	<u> </u>	Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98.
	<u> </u>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96.
		Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97.
]	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97.
		Pennsylvania CSO Policy, 385-2000-011, 9/08.
		Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
]	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97.
		Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97.
		Implementation Guidance Design Conditions, 391-2000-006, 9/97.
]	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004.
]	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997.
]	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99.
]	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004.
		Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97.
]	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008.
]	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994.
		Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09.
		Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97.
		Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97.
]	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99.
]	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999.
		Design Stream Flows, 391-2000-023, 9/98.
]	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98.
		Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97.
		Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
\boxtimes]	SOP: New and Reissuance Small Flow Treatment Facility Individual NPDES permit Applications, rev 5/17/2019
		Other:

StreamStats Page 2 of 4

StreamStats Report

Region ID: PA

Workspace ID: PA20210312133138794000

Clicked Point (Latitude, Longitude): 39.96995, -76.49542

Time: 2021-03-12 08:31:57 -0500



Shipley Residence PA0267228 Modeling Point #1 March 2021

	7607)		
Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	14.3	square miles
BSLOPD	Mean basin slope measured in degrees	6.9265	degrees
ROCKDEP	Depth to rock	5.1	feet

StreamStats Page 3 of 4

Parameter Code	Parameter Description	Value	Unit
URBAN	Percentage of basin with urban development	1.509	percent

	LOW-Flow Statistics Farameters[Low Flow Region 1]					
	Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
	DRNAREA	Drainage Area	14.3	square miles	4.78	1150
	BSLOPD	Mean Basin Slope degrees	6.9265	degrees	1.7	6.4
	ROCKDEP	Depth to Rock	5.1	feet	4.13	5.21
	URBAN	Percent Urban	1.509	percent	0	89

Low-Flow Statistics Disclaimers(Low Flow Region 1)

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors

Low-Flow Statistics Flow Report(Low Flow Region 1)

Statistic	Value	Unit
7 Day 2 Year Low Flow	6.56	ft^3/s
30 Day 2 Year Low Flow	7.43	ft^3/s
7 Day 10 Year Low Flow	3.84	ft^3/s
30 Day 10 Year Low Flow	4.38	ft^3/s
90 Day 10 Year Low Flow	5.29	ft^3/s

Low-Flow Statistics Citations

Stuckey, M.H.,2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (http://pubs.usgs.gov/sir/2006/5130/)

StreamStats Page 4 of 4

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS).

Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.4.0