

Northwest Regional Office CLEAN WATER PROGRAM

Application Type

Wastewater Type

Facility Type

Renewal

Sewage

SRSTP

NPDES PERMIT FACT SHEET INDIVIDUAL SFTF/SRSTP

Application No. PA0271438

APS ID 1080073

Authorization ID 1425459

Applicant Name	Aubree Hendrickson & Ryan East	Facility Name	Aubree Hendrickson & Ryan East SRSTP	
Applicant Address	563 Talcott Road	Facility Address	563 Talcott Road	
	Waterford, PA 16441-9108	<u> </u>	Waterford, PA 16441	
Applicant Contact	Ryan East	Facility Contact		
Applicant Phone	(814) 779-5187	Facility Phone		
Applicant Email	ryeast96@gmail.com	<u></u>		
Client ID	363426	Site ID	828393	
SIC Code	8800	Municipality	Waterford Township	
SIC Description	Private Households	County	_ Erie	
Date Application Received February 1, 2023		WQM Required	Issued	
Date Application Accepted February 8, 2023		WQM App. No.	2518408	

Summary of Review

Renewal Permit for a SRSTP consists of: A Norweco Singulair Model 960-500 Aerobic Unit, a Norweco Bio Film Reactor, an ultraviolet (UV) disinfection unit, and an effluent pump.

Act 14 - Proof of Notification was submitted and received.

SPECTIAL CONDITIONS: NONE

The EPA waiver is in effect.

There are NO open violations in WMS for the subject Client ID (363426) as of February 8, 2023 5/1/2023 CWY

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
Х		Aeshah Shameseldin Aeshah Shameseldin / Civil Engineer Trainee	February 8, 2023
Х		Chad W. Yurisic Chad W. Yurisic, P.E. / Environmental Program Manager	5/1/2023

Discharge and Stream Data – 2 - Receiving Waters and PWS

Discharge, Receiving Waters and Water Supply Information					
Outfall No. 001	Design Flow (MGD)	.0004			
Latitude41° 58' 25.78"	Longitude	-80° 0' 20.62"			
Quad Name Cambridge Springs	Quad Code	41080H1			
Wastewater Description: Sewage Effluent					
Unnamed Tributary to LeBoeuf					
Receiving Waters Creek (TSF)	Stream Code				
NHD Com ID 127344941	RMI				
Drainage Area	Yield (cfs/mi²)				
Q ₇₋₁₀ Flow (cfs) 0	Q ₇₋₁₀ Basis	Dry Ditch			
Elevation (ft) 1410	Slope (ft/ft)				
Watershed No. 16-A	Chapter 93 Class.	TSF			
Existing Use	Existing Use Qualifier				
Exceptions to Use	Exceptions to Criteria				
Assessment Status Attaining Use(s)					
Cause(s) of Impairment					
Source(s) of Impairment					
TMDL Status	Name				
Background/Ambient Data	Data Source				
pH (SU)	Default				
Temperature (°F)	Default				
Hardness (mg/L)	Default				
Other:					
Nearest Downstream Public Water Supply Intake	Cambridge Springs Borough				
PWS Waters French Creek	Flow at Intake (cfs)	51.45			
PWS RMI 48.35	Distance from Outfall (mi)				

Changes Since Last Permit Issuance: None.

Other Comments: AMRs have been submitted.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.


Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

	Effluent Limitations				Monitoring Requirements			
Parameter	Mass Units (lbs/day) (1)		Concentrations (mg/L)			Minimum (2)	Required	
r ai ainetei	Average Monthly	Average Weekly	Minimum	Annual Average	Maximum	Instant. Maximum	Measurement Frequency	Sample Type
Flow (GPD)	Report Annl Avg	XXX	XXX	XXX	XXX	XXX	1/year	Estimate
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	Upon Request	Grab
BOD5	XXX	XXX	XXX	10.0	XXX	20	1/year	Grab
TSS	XXX	XXX	XXX	10.0	XXX	20	1/year	Grab
Fecal Coliform (No./100 ml)	XXX	XXX	XXX	200	XXX	XXX	1/year	Grab

Compliance Sampling Location: Outfall 001, after Disinfection.

Other Comments: Flow is monitor only based on Chapter 92a.61. The limits for BOD5, Total Suspended Solids are BPJ-based on the Department's "Small Flow Treatment Facilities Manual." Fecal Coliform are technology-based on Chapter 92a.47. The limits for pH are technology-based on Chapter 93.7.

Outfall Location - eMap with Aerial Imagery



Drainage Area Location – StreamStats with Aerial Imagery

StreamStats Report

Region ID: PA

Workspace ID: PA20230418184613662000

 Clicked Point (Latitude, Longitude):
 41.97381, -80.00574

 Time:
 2023-04-18 14:46:40 -0400



Collapse All ■

 ▶ Basin Characteristics

 Parameter Code
 Parameter Description
 Value
 Unit

 DRNAREA
 Area that drains to a point on a stream
 0.0000772
 square miles