

Northwest Regional Office CLEAN WATER PROGRAM

Application Type New Wastewater Type Sewage Facility Type **SRSTP**

NPDES PERMIT FACT SHEET INDIVIDUAL SFTF/SRSTP

PA0272485 Application No. APS ID 998935 1283049

Authorization ID

| Applicant Name | oplicant Name Edward Turose | | Edward Turose SRSTP | | |
|-------------------------|-----------------------------|------------------|--|--|--|
| Applicant Address | 253 Oregon Road | Facility Address | 253 Oregon Road | | |
| | Volant, PA 16156 | | Volant, PA 16156 | | |
| Applicant Contact | Edward Turose | Facility Contact | Edward Turose (724) 301-1127 836653 Springfield Township | | |
| Applicant Phone | (724) 301-1127 | Facility Phone | | | |
| Client ID | 351671 | Site ID | | | |
| SIC Code | 8800 | Municipality | | | |
| SIC Description | Private Households | County | Mercer County | | |
| Date Application Receiv | ved August 2, 2019 | WQM Required | Yes | | |
| Date Application Accep | ted August 7, 2019 | WQM App. No. | 4319410 will be issued concurrently | | |

Summary of Review

Act 14 - Proof of Notification was submitted and received.

The applicant should be able to meet the limits of this permit, which will protect the uses of the receiving stream.

- I. OTHER REQUIREMENTS:
 - A. AMRs
 - B. DMRs
 - C. Depth of Septage and Scum Measurement
 - D. Septic Tank Pumping
 - E. Effluent Chlorine Optimization and Minimization
- F. Stormwater into sewers
- G. Right of way
- H. Solids handling
- Public Sewerage Availability

SPECIAL CONDITIONS: None.

Proposed treatment will consist of: (WQM Permit no. 4319410)

A Norweco Singulair Model 960 aerobic treatment tank and a Norweco Bio-Film Reactor with a

tablet chlorinator and a 500 gallon chlorine contact tank.

There are no open violations in efacts for Client ID 351671 as of 9/23/2019.

| Approve | Deny | Signatures | Date |
|---------|------|--|------|
| Х | | Stephen A. McCauley, E.I.T. / Environmental Engineering Specialist | |
| Х | | Justin C. Dickey, P.E. / Environmental Engineer Manager | |

| Discharge, Receiving Waters and Water Supply Infor | rmation | | |
|---|----------------------------|-------------------|--|
| Outfall No. 001 | Design Flow (MGD) | 0.0004 | |
| Latitude 41° 07' 59.52" | Longitude | -80° 08' 53.16" | |
| Quad Name | Quad Code | - | |
| Wastewater Description: Sewage Effluent | | | |
| Unnamed Tributary to Receiving Waters the Black Run (CWF) | Stream Code | N/A | |
| NHD Com ID 126220695 | RMI | N/A | |
| Drainage Area | Yield (cfs/mi²) | | |
| Q ₇₋₁₀ Flow (cfs) | Q ₇₋₁₀ Basis | | |
| Elevation (ft) | Slope (ft/ft) | | |
| Watershed No. 20-C | Chapter 93 Class. | Cold Water Fishes | |
| Existing Use | Eviating Has Qualifier | | |
| Exceptions to Use | Exceptions to Criteria | | |
| Assessment Status Impaired | | | |
| Cause(s) of Impairment Cause Unknown | | | |
| Source(s) of Impairment Cause Unknown | | | |
| TMDL Status - | Name | | |
| Background/Ambient Data pH (SU) Temperature (°F) Hardness (mg/L) Other: | - | | |
| | | | |
| Nearest Downstream Public Water Supply Intake | - | | |
| PWS Waters | Flow at Intake (cfs) | <u>-</u> | |
| PWS RMI | Distance from Outfall (mi) | - | |
| | | | |

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the Pennsylvania Bulletin in accordance with 25 Pa. Code § 92a.82. Upon publication in the Pennsylvania Bulletin, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the Pennsylvania Bulletin at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

This SFTF was designed where applicable in accordance with the SFTF Manual, but it does not qualify for the PAG-04 General Permit due to the use of a Norweco Singulair Model 960 aerobic treatment tank and a Bio-Film Reactor.

No modeling was performed for this NPDES Permit as the Norweco Singulair Model 960 is capable of meeting CBOD5 averages of 6 mg/l and TSS averages of 10 mg/l, which are less than the inputs of the WQ model.

Planning was approved on July 2, 2019.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

| Parameter | Effluent Limitations | | | | | Monitoring Requirements | | |
|-----------------------------|--------------------------|-------------------|-----------------------|-------------------|---------|-------------------------|------------------------|----------------|
| | Mass Units (lbs/day) (1) | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ | Required |
| | Average Monthly | Average Weekly | Minimum | Annual Average | Maximum | Instant. Maximum | | Sample Type |
| Flow (MGD) | Report Annl Avg | XXX | XXX | XXX | XXX | XXX | 1/year | Estimate |
| pH (S.U.) | XXX | XXX | 6.0 Inst Min | XXX | XXX | 9.0 | Upon Request | Grab |
| TRC | XXX | XXX | XXX | Report Avg Mo | XXX | Report | 1/month | Grab |
| BOD5 | XXX | XXX | XXX | 10.0 | XXX | 20.0 | 1/year | Grab |
| TSS | XXX | XXX | XXX | 10.0 | XXX | 20.0 | 1/year | Grab |
| Fecal Coliform (No./100 ml) | XXX | XXX | XXX | 200 | XXX | XXX | 1/year | Grab |

Compliance Sampling Location: Outfall 001, after disinfection.

Flow and TRC are monitor only based on Chapter 92a.61. The limits for pH are technology-based on Chapter 93.7. The limits for BOD5, Total Suspended Solids, and Fecal Coliforms are technology-based on Chapter 92a.47.