

 Application Type
 New

 Wastewater Type
 Sewage

 Facility Type
 SRSTP

NPDES PERMIT FACT SHEET INDIVIDUAL SFTF/SRSTP

 Application No.
 PA0287920

 APS ID
 1006739

 Authorization ID
 1297178

Applicant, Facility and Project Information

Applicant Name	Terrance & Winifred Gardner	Facility Name	Terrance & Winifred Gardner SRSTP		
Applicant Address	5973 Kuhl Road	Facility Address	5973 Kuhl Road		
	Erie, PA 16510		Erie, PA 16510		
Applicant Contact	Terrance Gardner	Facility Contact	Terrance Gardner		
Applicant Phone	(814) 899-0860	Facility Phone	(814) 899-0860		
Client ID	353858	Site ID	838034		
SIC Code	8800	Municipality	Harborcreek Township		
SIC Description	Private Households	County	Erie		
Date Application Received October 31, 2019		WQM Required	Yes- pending		
Date Application Accepted		WQM App. No.	2519419		
Project Description Single Residence Sewage T		atment Plant.			

Summary of Review

The project involves the installation of a new single residence sewage treatment plant to replace an existing malfunctioning onlot system.

Act 537 Planning was approved on September 25, 2019.

Proposed treatment will consist of: A Norweco Singulair Green 960 treatment tank, a Norweco Hydro-Kinetic Bio-Film Reactor, and a Norweco AT1500 UV disinfection system.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date	
		Emily C. M. Voorhees / Civil Engineer		
		Justin C. Dickey, P.E. / Environmental Engineer Manager		

Γ

Discharge, Receiving Waters and Water Supply Information						
Outfall No. 001	Design Flow (MGD)	.0004				
Latitude42° 6' 9.00"	Longitude	<u>-79° 57' 51.10"</u>				
Quad Name	Quad Code					
Wastewater Description: Sewage Effluent						
Unnamed Tributary of Fourmile Receiving Waters Creek (WWF, MF)		62395				
NHD Com ID 123923439 D 00004	RMI	0.4600				
Drainage Area 0.0394 sq. mi.		0.1				
Q ₇₋₁₀ Flow (cfs) 0.0394		Default				
Elevation (ft)	Slope (ft/ft)	- Warm Water Fishes,				
Watershed No. 15A	Chapter 93 Class.	Migratory Fishes				
Existing Use	Existing Use Qualifier					
Exceptions to Use	Exceptions to Criteria	-				
Assessment Status Attaining Use(s)						
Source(s) of Impairment						
TMDL Status	Name					
Background/Ambient Data pH (SU)	Data Source					
Nearest Downstream Public Water Supply Intake		undary				
PWS Waters Lake Erie	_ Flow at Intake (cfs)	<u> </u>				
PWS RMI	Distance from Outfall (mi)					

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations				Monitoring Requirements			
	Mass Units (Ibs/day) ⁽¹⁾		Concentrations (mg/L)			Minimum ⁽²⁾	Required	
	Average Monthly	Average Weekly	Minimum	Annual Average	Maximum	Instant. Maximum		Sample Type
Flow (GPD)	Report Annl Avg	xxx	xxx	xxx	xxx	XXX	1/year	Estimate
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	Upon Request	Grab
BOD5	ххх	XXX	xxx	10.0	xxx	20	1/year	Grab
TSS	ххх	XXX	xxx	10.0	xxx	20	1/year	Grab
Fecal Coliform (No./100 ml)	ххх	XXX	xxx	200	xxx	ххх	1/year	Grab

Compliance Sampling Location: Outfall 001, after the UV disinfection.

Other Comments: Flow is monitor only based on Chapter 92a.61. The limits for BOD5, Total Suspended Solids, and Fecal Coliforms are technology- based on Chapter 92a.47.