

# Northwest Regional Office CLEAN WATER PROGRAM

Application Type
Wastewater Type
Facility Type

New
Sewage
SRSTP

# NPDES PERMIT FACT SHEET INDIVIDUAL SFTF/SRSTP

Application No. PA0288250

APS ID 1013145

Authorization ID 1308622

Applicant Name	Daniel & Deborah Gruver	Facility Name	Daniel & Deborah Gruver SRSTP		
Applicant Address	5007 North Main Street	Facility Address	8081 Grubb Road		
	McKean, PA 16426		McKean, PA 16426		
Applicant Contact	Daniel Gruver	Facility Contact	Daniel Gruver (814) 476-7914 840696		
Applicant Phone	(814) 476-7914	Facility Phone Site ID			
Client ID	355676				
SIC Code	8800	Municipality	McKean Township		
SIC Description	Private Households	County	Erie		
Date Application Recei	ved March 10, 2020	WQM Required	yes		
Date Application Accep	oted March 12, 2020	WQM App. No.	2520407		

#### **Summary of Review**

The project involves the installation of a new 400-gallon per day single residence sewage treatment plant to replace an existing malfunctioning on-lot system for a 3-bedroom home.

Act 14 – Proof of notification was submitted and received.

The applicant should be able to meet the limits of this permit, which will protect the uses of the receiving stream.

- I. OTHER REQUIRMENTS
  - A. AMRs
  - B. DMRs
  - C. Depth of Septage and Scum Management
  - D. Septic Tank Pumping
  - E. Chlorine Optimization

- F. Stormwater into Sewers
- G. Right of Way
- H. Solids Handling
- I. Public Sewerage Availability

SPECIAL CONDITIONS: None

Proposed treatment will consist of (WQM Permit No. 4220401): A 1000-gallon dual compartment concrete septic tank, a Premier Tech EC7-500-C-P Coco Filter Unit (with an integrated pump and UV disinfection), where the treated effluent will discharge into a roadside ditch on owners property to Elk Creek (WWF, MF).

There are no open violations in WMS for the subject client ID (354869) as of 3/16/2020.

Approve	Deny	Signatures	Date
Х		Jon F. Bucha Jonathan F. Bucha / Civil Engineer Trainee	4/6/2020
Х		Justin C. Dickey Justin C. Dickey, P.E. / Environmental Engineer Manager	4/9/2020

Discharge, Receiving Waters and Water Supply Information					
Outfall No. 001	Design Flow (MGD)0005				
Latitude 42° 1' 21.6"	Longitude80° 8' 41.3"				
Quad Name Swanville	Quad Code <u>42080A2</u>				
Wastewater Description: Sewage Effluent					
Unnamed Tributary (62586) to					
Receiving Waters Creek (WWF-MF)					
NHD Com ID					
Drainage Area					
Q <sub>7-10</sub> Flow (cfs)					
Elevation (ft)	Slope (ft/ft) Warm Water Fish –				
Watershed No. 15-X	Chapter 02 Class Migrating Fish				
Existing Use -					
Eventions to Lies	Evantians to Critoria				
•					
O					
• • • • • • • • • • • • • • • • • • • •					
TMDL Status	Name				
Background/Ambient Data	Data Source				
pH (SU)	-				
Temperature (°F)					
Hardness (mg/L)	<u>-</u>				
Other: -	<u>-</u>				
Nearest Downstream Public Water Supply Intake	-				
PWS Waters -	Flow at Intake (cfs)				
PWS RMI -	Distance from Outfall (mi)				
	Distance from Outrali (ml)				

Changes Since Last Permit Issuance: N/A

Other Comments: This SRSTP is capable of meeting effluent limits. There are no public water supplies downstream, as Elk Creek flows into Lake Erie.

#### **Public Participation**

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

### **Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

## Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

	Effluent Limitations				Monitoring Requirements			
Parameter	Mass Units (lbs/day) (1)		Concentrations (mg/L)			Minimum <sup>(2)</sup>	Required	
	Average Monthly	Average Weekly	Minimum	Annual Average	Maximum	Instant. Maximum	Measurement Frequency	Sample Type
Flow (GPD)	Report Annl Avg	XXX	XXX	XXX	XXX	XXX	1/year	Estimate
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	Upon Request	Grab
BOD5	XXX	XXX	XXX	10.0	XXX	20	1/year	Grab
TSS	XXX	XXX	XXX	10.0	XXX	20	1/year	Grab
Fecal Coliform (No./100 ml)	XXX	XXX	XXX	200	XXX	XXX	1/year	Grab

Compliance Sampling Location: Outfall 001, after disinfection

Other Comments: Flow is monitor only based on Chapter 92a.61. The limits for BOD5, Total Suspended Solids, and Fecal Coliform are technology-based on Chapter 92a.47. The limits for pH are technology-based on Chapter 93.7 and the monitoring frequency has been established as "upon request" due to CWF stream designation.