

### Northwest Regional Office CLEAN WATER PROGRAM

Application Type

Wastewater Type

Facility Type

New

Sewage

SRSTP

# NPDES PERMIT FACT SHEET INDIVIDUAL SFTF/SRSTP

 Application No.
 PA0291323

 APS ID
 1072232

 Authorization ID
 1411814

| Applicant Name                            | Ashle               | ey Farrell         | Facility Name    | Ashley Farrell SRSTP |  |
|---|---------------------|--------------------|------------------|----------------------|--|
| Applicant Address                         | 5702 Lunger Road    |                    | Facility Address | 5702 Lunger Road     |  |
|   | Erie, PA 16510-4841 |                    |                  | Erie, PA 16510-4841  |  |
| Applicant Contact                         | Ashley Farrell      |                    | Facility Contact |                      |  |
| Applicant Phone                           | (814)               | 572-1072           | Facility Phone   |                      |  |
| Client ID                                 | 3726                | 37                 | Site ID          | 856493               |  |
| SIC Code                                  | 8800                |                    | Municipality     | Harborcreek Township |  |
| SIC Description                           | Private Households  |                    | County           | _Erie                |  |
| Date Application Received                 |                     | September 26, 2022 | WQM Required     | Yes                  |  |
| Date Application Accepted October 5, 2022 |                     | October 5, 2022    | WQM App. No.     | 2522434              |  |

#### **Summary of Review**

This is a new discharge for an existing 4-bedroom home to a repair of an existing malfunctioning on-lot system.

Act 14 - Proof of Notification was submitted and received.

Proposed treatment will consist of (WQM Permit No. 2522434): A Premier Tech EC7-500-P-P PACK Coco Filter unit with integrated DiUV ultraviolet (UV) disinfection unit preinstalled.

The EPA Waiver is in effect.

There are no open violations in WMS for the subject Client ID (372637) as of 11/30/2022.

#### **Public Participation**

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

| Approve | Deny | Signatures  | Date              |
|---------|------|---|-------------------|
| Х       |      | Jordan A. Frey, E.I.T.<br>Jordan A. Frey, E.I.T. / Project Manager              | November 30, 2022 |
| Х       |      | Adam J. Pesek (Lead Reviewer) for<br>Vacant / Environmental Engineering Manager | December 2, 2022  |

| Outfall No. 001                          |          |                            | Design Flow (MGD)       | 0.0005          |  |  |
|--|----------|----------------------------|-------------------------|-----------------|--|--|
| Latitude 42° 6' 28.88"                   |          |                            | Longitude               | -79° 56' 40.94" |  |  |
| Quad Name Hammett                        |          |                            | Quad Code               | 42079A8         |  |  |
| Wastewater Descri                        | otion:   | Sewage Effluent            |                         |                 |  |  |
|  |          | ned Tributary to Sixmile   |                         |                 |  |  |
| Receiving Waters                         | Creek    | (CWF, MF)                  | Stream Code             | 62357<br>0.1600 |  |  |
| NHD Com ID                               | 12392    | 3482                       | RMI                     |                 |  |  |
| Drainage Area                            | 0.23     |                            | Yield (cfs/mi²)         | 0.1             |  |  |
| Q <sub>7-10</sub> Flow (cfs)             | 0.02     |                            | Q <sub>7-10</sub> Basis | Default         |  |  |
| Elevation (ft)                           | 1343     |                            | Slope (ft/ft)           |                 |  |  |
| Watershed No.                            | 15-A     |                            | Chapter 93 Class.       | CWF, MF         |  |  |
| Existing Use                             |          |                            | Existing Use Qualifier  | -               |  |  |
| Exceptions to Use                        |          |                            | Exceptions to Criteria  |                 |  |  |
| Assessment Status                        | -        | Attaining Use(s)           |                         |                 |  |  |
| Cause(s) of Impairr                      | nent     |                            |                         |                 |  |  |
| Source(s) of Impair                      | ment     |                            |                         |                 |  |  |
| TMDL Status                              |          | Name                       |                         |                 |  |  |
| Background/Ambient Data                  |          | Data Source                |                         |                 |  |  |
| pH (SU)                                  |          | 7.0                        | Default                 |                 |  |  |
| Temperature (°F) 20                      |          | Default                    |                         |                 |  |  |
| Hardness (mg/L) 100                      |          | Default                    |                         |                 |  |  |
| Other:                                   |          |                            |                         |                 |  |  |
| Nearest Downstrea                        | m Public | : Water Supply Intake      | Erie Water Works        |                 |  |  |
| PWS Waters Lake Erie (Chestnut and West) |          |                            | Flow at Intake (cfs)    | N/A             |  |  |
| PWS RMI N/A                              |          | Distance from Outfall (mi) |                         |                 |  |  |

Changes Since Last Permit Issuance: N/A – This is a proposed discharge (Planning was approved on September 14, 2022).

#### Other Comments:

This SRSTP was designed where applicable in accordance with the SFTF Manual, but it does not qualify for the PAG-04 General Permit due to the use of a Coco Filter.

The Coco Filter unit is reportedly capable of meeting CBOD5 averages of 10 mg/l and TSS averages of 10 mg/l.

In accordance with the SOP, no water quality modeling was performed since this is a SRSTP.

#### **Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.


#### Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

|                             | Effluent Limitations     |                   |                       |                   |         | Monitoring Requirements |                          |                |
|-----------------------------|--------------------------|-------------------|-----------------------|-------------------|---------|-------------------------|--------------------------|----------------|
| Parameter                   | Mass Units (lbs/day) (1) |                   | Concentrations (mg/L) |                   |         |                         | Minimum <sup>(2)</sup>   | Required       |
|                             | Average<br>Monthly       | Average<br>Weekly | Minimum               | Annual<br>Average | Maximum | Instant.<br>Maximum     | Measurement<br>Frequency | Sample<br>Type |
| Flow (GPD)                  | Report<br>Annl Avg       | XXX               | XXX                   | XXX               | XXX     | XXX                     | 1/year                   | Estimate       |
| pH (S.U.)                   | XXX                      | XXX               | 6.0<br>Inst Min       | XXX               | XXX     | 9.0                     | Upon Request             | Grab           |
| BOD5                        | XXX                      | XXX               | XXX                   | 10.0              | XXX     | 20                      | 1/year                   | Grab           |
| TSS                         | XXX                      | XXX               | XXX                   | 10.0              | XXX     | 20                      | 1/year                   | Grab           |
| Fecal Coliform (No./100 ml) | XXX                      | XXX               | XXX                   | 200               | XXX     | XXX                     | 1/year                   | Grab           |

Compliance Sampling Location: <u>Outfall 001, after disinfection</u>

Other Comments: Flow is monitor only based on Chapter 92a.61. The limits for BOD<sub>5</sub> and Total Suspended Solids are BPJ limits based on the Small Flow Treatment Facilities Manual. Fecal Coliform is technology-based on Chapter 92a.47. The limits for pH are technology-based on Chapter 93.7.

## Attachment 1 eMap – Location Map



# Attachment 2 Google Earth Imagery

