

 Application Type
 New

 Wastewater Type
 Sewage

 Facility Type
 SRSTP

NPDES PERMIT FACT SHEET INDIVIDUAL SFTF/SRSTP

 Application No.
 PA0292885

 APS ID
 1079567

 Authorization ID
 1424525

Applicant, Facility and Project Information

Applicant Name	Anthony Puglisi	Facility Name	Anthony Puglisi SRSTP		
Applicant Address	223 Woodhawk Lane	Facility Address	811 Chicora Road		
	Butler, PA 16001-8395	_	Chicora, PA 16025		
Applicant Contact	Anthony Puglisi	Facility Contact	Anthony Puglisi		
Applicant Phone	(732) 822-6481	Facility Phone	(732) 822-6481		
Client ID	374823	Site ID	860986		
SIC Code	8800	Municipality	Oakland Township		
SIC Description	Private Households	County	Butler		
Date Application Receiv	vedJanuary 12, 2023	WQM Required	Yes		
Date Application Accepted		WQM App. No.	1023401		
Project Description	Single Residence Sewage Treatr	nent Plant.			

Summary of Review

This is a new discharge for an existing 1-bedroom home to repair an existing malfunctioning on-lot system.

Act 14 - Proof of Notification was submitted and received.

Proposed treatment will consist of (WQM Permit No. 1023401): A Premier Tech EC7-500-P-PACK Coco Filter unit with integrated septic tank and DiUV ultraviolet (UV) disinfection unit.

The EPA Waiver is in effect.

There are no open violations in WMS for the subject Client ID (374823) as of 4/27/2023. 5/1/2023 CWY

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date	
х		Jordan A. Frey, E.I.T. Jordan A. Frey, E.I.T. / Project Manager	April 27, 2023	
х		Chad W. Yurisic Chad W. Yurisic, P.E. / Environmental Engineer Manager	5/1/2023	

Discharge and Stream Data - 2 - Receiving Waters and PWS

Discharge, Receiving Waters and Water Supply Information

Outfall No. 001	Design Flow (MGD)	.0005 -79º 47' 58.03"			
Latitude <u>40° 55' 4.87"</u>	Longitude				
Quad Name East Butler	Quad Code	40079H7			
Wastewater Description: Sewage Effluent					
Unnamed Tributary to Bonnie					
Receiving Waters Brook	Stream Code	35178 0.5800 0.1 Default Warm Water Fishes (WWF)			
NHD Com ID 126217903	RMI Yield (cfs/mi²) Q ₇₋₁₀ Basis Slope (ft/ft) Chapter 02 Class				
Drainage Area 0.15					
Q ₇₋₁₀ Flow (cfs) 0.01					
Elevation (ft) 1310					
Watershed No. 20-C					
Existing Use	Existing Use Qualifier				
Exceptions to Use	Exceptions to Criteria				
Assessment Status Attaining Use(s)					
Cause(s) of Impairment					
Source(s) of Impairment					
TMDL Status	Name				
Background/Ambient Data	Data Source				
pH (SU) 7.0	Default				
Temperature (°F) 20	Default				
Hardness (mg/L) 100	Default				
Other:					
Nearest Downstream Public Water Supply Intake	Harmony Borough Water Authority				
Little Connoquenessing and					
PWS Waters Connoquenessing Creek	Flow at Intake (cfs)	2.0			
PWS RMI <u>1.14</u>	Distance from Outfall (mi)	>25			

Changes Since Last Permit Issuance: N/A – This is a proposed discharge (Planning was approved on January 10, 2023).

Other Comments:

This SRSTP was designed where applicable in accordance with the SFTF Manual, but it does not qualify for the PAG-04 General Permit due to the use of a Coco Filter. The proposed discharge is to resolve a repair of a malfunctioning on-lot system.

The Coco Filter unit is reportedly capable of meeting CBOD5 averages of 10 mg/l and TSS averages of 10 mg/l.

In accordance with the SOP, no water quality modeling was performed since this is a SRSTP.

Proposed Effluent Limitations and Monitoring Requirements


The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations				Monitoring Requirements			
	Mass Units (Ibs/day) ⁽¹⁾		Concentrations (mg/L)			Minimum ⁽²⁾	Required	
	Average Monthly	Average Weekly	Minimum	Annual Average	Maximum	Instant. Maximum	Measurement Frequency	Sample Type
Flow (GPD)	Report Annl Avg	XXX	xxx	XXX	XXX	XXX	1/year	Estimate
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	Upon Request	Grab
BOD5	XXX	XXX	XXX	10.0	XXX	20	1/year	Grab
TSS	ххх	XXX	xxx	10.0	xxx	20	1/year	Grab
Fecal Coliform (No./100 ml)	XXX	XXX	XXX	200	XXX	ХХХ	1/year	Grab

Compliance Sampling Location: Outfall 001, after disinfection

Other Comments: Flow is monitor only based on Chapter 92a.61. The limits for BOD₅ and Total Suspended Solids are BPJ limits based on the Small Flow Treatment Facilities Manual. Fecal Coliform is technology-based on Chapter 92a.47. The limits for pH are technology-based on Chapter 93.7.



Attachment 2 Google Earth Imagery

