

 Application Type
 New

 Wastewater Type
 Sewage

 Facility Type
 SRSTP

NPDES PERMIT FACT SHEET INDIVIDUAL SFTF/SRSTP

 Application No.
 PA0295621

 APS ID
 1103641

 Authorization ID
 1467089

Applicant, Facility and Project Information

| Applicant Name | Adam Beede | Facility Name | Adam Beede SRSTP | | |
|---------------------------|--------------------------------|------------------------------------|------------------------|--|--|
| Applicant Address | 795 Markman Park Road | Facility Address | 21805 Quehanna Highway | | |
| | Baden, PA 15005-2845 | | Weedville, PA 15868 | | |
| Applicant Contact | Adam Beede | Facility Contact | Adam Beede | | |
| Applicant Phone | (207) 485-4915 | Facility Phone | (207) 485-4915 | | |
| Client ID | 381816 | Site ID | 867198 | | |
| SIC Code | 8800 | Municipality | Benezette Township | | |
| SIC Description | Private Households | County | Elk | | |
| Date Application Receiv | vedDecember 18, 2023 | WQM Required | Yes | | |
| Date Application Accepted | | WQM App. No. | 2423403 | | |
| | | | | | |
| Project Description | Single Residence Sewage Treatr | e Sewage Treatment Plant. (SRSTP). | | | |

Summary of Review

This is a new discharge for a proposed 2-bedroom home.

Act 14 - Proof of Notification was submitted and received.

Proposed treatment will consist of (WQM Permit No. 2423403): A Premier Tech EC7-500-PACK Coco Filter unit with integrated UV unit.

The EPA Waiver is in effect.

There are no open violations in WMS for the subject Client ID (381816) as of 2/9/2024.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

| Approve | Deny | Signatures | Date | |
|---------|------|--|--------------------------------|--|
| х | | Jordan A, Frey, E.I.T. Jordan A. Frey, E.I.T. / Project Manager | February 9, 2024 | |
| | | Vacant / Environmental Engineer Manager | Okay to Draft JCD 2/12/2024 | |

Discharge and Stream Data - 2 - Receiving Waters and PWS

| Discharge, Receiving Waters and Water Supply Information | | | | | |
|--|--|--|--|--|--|
| | | | | | |

| Outfall No. 001 | Design Flow (MGD)0004 |
|---|---|
| Latitude 41º 16' 22.11" | Longitude |
| Quad Name Weedville | Quad Code 41078C4 |
| Wastewater Description: Sewage Effluent | |
| | |
| Receiving WatersMedix Run (HQ-CWF, MF) | Stream Code 24779 |
| NHD Com ID 61431706 | RMI 0.1100 |
| Drainage Area 24.9 | Yield (cfs/mi ²) 0.1 |
| Q ₇₋₁₀ Flow (cfs) 2.49 | Q ₇₋₁₀ Basis Default |
| Elevation (ft) 1099 | Slope (ft/ft) Default |
| Watershed No. 8-A | Chapter 93 Class. HQ-CWF, MF |
| Existing Use | Existing Use Qualifier |
| Exceptions to Use | Exceptions to Criteria |
| Assessment Status Attaining Use(s) | |
| Cause(s) of Impairment | |
| Source(s) of Impairment | |
| TMDL Status Final | Name Bennett Branch Sinnemahoning Creek |
| Background/Ambient Data | Data Source |
| pH (SU) 7.0 | Default |
| Temperature (°F) 20 | Default |
| Hardness (mg/L) 100 | Default |
| Other: | |
| Nearest Downstream Public Water Supply Intake | PA American White Deer – Milton |
| PWS Waters Susquehanna River | Flow at Intake (cfs) |
| PWS RMI | Distance from Outfall (mi) >25 |

Changes Since Last Permit Issuance: N/A – This is a proposed discharge (Planning was approved on December 15, 2023).

Other Comments:

This SRSTP was designed where applicable in accordance with the SFTF Manual, but it does not qualify for the PAG-04 General Permit due to the use of a Coco Filter. The proposed discharge is to resolve a repair of a malfunctioning on-lot system.

The Coco Filter unit is reportedly capable of meeting CBOD5 averages of 10 mg/l and TSS averages of 10 mg/l.

In accordance with the SOP, no water quality modeling was performed since this is a SRSTP.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

| | Effluent Limitations | | | | Monitoring Requirements | | | |
|-----------------------------|-------------------------------------|-------------------|-----------------------|-------------------|-------------------------|------------------------|--------------------------|----------------|
| Parameter | Mass Units (Ibs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | Minimum ⁽²⁾ | Required | |
| Parameter | Average Monthly | Average Weekly | Minimum | Annual Average | Maximum | Instant. Maximum | Measurement Frequency | Sample Type |
| Flow (GPD) | Report Annl Avg | XXX | XXX | xxx | XXX | XXX | 1/year | Estimate |
| pH (S.U.) | XXX | XXX | 6.0 Inst Min | XXX | XXX | 9.0 | 1/month | Grab |
| BOD5 | ххх | XXX | XXX | 10.0 | xxx | 20 | 1/year | Grab |
| TSS | xxx | XXX | XXX | 10.0 | xxx | 20 | 1/year | Grab |
| Fecal Coliform (No./100 ml) | ХХХ | XXX | XXX | 200 | XXX | XXX | 1/year | Grab |

Compliance Sampling Location: Outfall 001, after disinfection

Other Comments: Flow is monitor only based on Chapter 92a.61. The limits for BOD₅ and Total Suspended Solids are BPJ limits based on the Small Flow Treatment Facilities Manual. Fecal Coliform is technology-based on Chapter 92a.47. The limits for pH are technology-based on Chapter 93.7.

| Map eFacts Query Advanced Query © ESRI Streets & Imagery Topographic National Geographic Streets Imagery | Decimal Degrees DD/MM/SS |
|---|---|
| Image: Constraint of the system of the sy | Latitude: 41 16 21.55 Longitude: -78 24 9.98 Locate Close |
| agery: Source: Esri, Maxar, Earthstar Geographics, and the GIS User Community; ESRI Streets: Sources: Esri, HERE, Garmin, USGS, Intermap, INCREMENT P, NRCan, Esri Japan, METI, Esri StreetMap contributors, and the GIS User Community | ri China (Hong Kong), Esri Korea, Esri (Thailand), NGCC, (c) |

Attachment 2 Google Earth Imagery

