

Application Type New  
 Facility Type Storm Water  
 Major / Minor Minor

**NPDES PERMIT FACT SHEET  
 INDIVIDUAL INDUSTRIAL WASTE (IW)  
 AND IW STORMWATER**

Application No. PA0296244  
 APS ID 1115311  
 Authorization ID 1550193

**Applicant and Facility Information**

Applicant Name	<u>Amcor</u>	Facility Name	<u>Berry Plastics Brookville Plant</u>
Applicant Address	<u>2890 Maplevale Road</u> <u>Brookville, PA 15825-2318</u>	Facility Address	<u>2890 Maplevale Road</u> <u>Brookville, PA 15825-2318</u>
Applicant Contact	<u>Kelly Reiter</u>	Facility Contact	<u></u>
Applicant Phone	<u>(814) 849-4244</u>	Facility Phone	<u></u>
Client ID	<u>292161</u>	Site ID	<u>508538</u>
SIC Code	<u>3089</u>	Municipality	<u>Brookville Borough</u>
SIC Description	<u>Manufacturing - Plastics Products, Nec</u>	County	<u>Jefferson</u>
Date Application Received	<u>November 24, 2025</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u></u>	If No, Reason	<u></u>
Purpose of Application	<u>Discharge of Industrial Stormwater.</u>		

**Summary of Review**

This is a stormwater discharge that has been previously operating under a No Exposure Certification since 2004. The receiving stream for Outfalls 001 & 003 has been designated as High Quality, so an individual stormwater permit is now required as this site no longer qualifies for No Exposure.

An Anti-Degradation analysis has been performed as if this site were a new, non-point discharge. The site has maintained compliance with No Exposure benchmarks, which is suitable evidence that this discharge will be non-degrading.

BMPs for the relevant PAG-03 Appendix, in this case Appendix S, are included in the NPDES permit.

There are currently no open violations for this client as of 3/25/2026.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		Jordan A. Frey, E.I.T. Jordan A. Frey, E.I.T. / Project Manager	March 25, 2026
X		Adam Olesnanik Adam Olesnanik, P.E. / Environmental Engineer Manager	March 27, 2026

**Discharge, Receiving Waters and Water Supply Information**

Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0</u>
Latitude	<u>41° 10' 15.10"</u>	Longitude	<u>-79° 6' 5.21"</u>
Quad Name	<u>Brookville</u>	Quad Code	<u>41079B1</u>
Wastewater Description: <u>Stormwater</u>			

Receiving Waters	<u>Trib 48856 to North Fork Redbank Creek</u>	Stream Code	<u>48856</u>
NHD Com ID	<u>123854430</u>	RMI	<u>0.6900</u>
Drainage Area	<u>0.79</u>	Yield (cfs/mi <sup>2</sup> )	<u>0.04</u>
Q <sub>7-10</sub> Flow (cfs)	<u>0.03</u>	Q <sub>7-10</sub> Basis	<u>Default</u>
Elevation (ft)	<u>1568</u>	Slope (ft/ft)	<u>---</u>
Watershed No.	<u>17-C</u>	Chapter 93 Class.	<u>HQ-CWF</u>
Existing Use	<u></u>	Existing Use Qualifier	<u></u>
Exceptions to Use	<u></u>	Exceptions to Criteria	<u></u>
Assessment Status	<u>Impaired</u>		
Cause(s) of Impairment	<u>METALS</u>		
Source(s) of Impairment	<u>SOURCE UNKNOWN</u>		
TMDL Status	<u></u>	Name	<u></u>

Background/Ambient Data		Data Source	
pH (SU)	<u>7.0</u>	Default	<u></u>
Temperature (°F)	<u>20</u>	Default	<u></u>
Hardness (mg/L)	<u>100</u>	Default	<u></u>
Other:	<u></u>		<u></u>

Nearest Downstream Public Water Supply Intake	<u>Brookville Municipal Authority</u>		
PWS Waters	<u>North Fork Creek</u>	Flow at Intake (cfs)	<u>9.83</u>
PWS RMI	<u>0.3</u>	Distance from Outfall (mi)	<u>0.98</u>

Changes Since Last Permit Issuance: None.

Other Comments: This is the representative Outfall for Outfalls 002 and 003. Sampling in the permit will only be imposed at the representative outfall (Outfall 001).

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>002</u>	Design Flow (MGD)	<u>0</u>
Latitude	<u>41° 10' 26"</u>	Longitude	<u>-79° 5' 49"</u>
Quad Name	<u>Brookville</u>	Quad Code	<u>41079B1</u>
Wastewater Description: <u>Stormwater</u>			
Receiving Waters	<u>Clement Run (CWF)</u>	Stream Code	<u>48505</u>
NHD Com ID	<u>123854430</u>	RMI	<u>0.6900</u>
Drainage Area	_____	Yield (cfs/mi <sup>2</sup> )	_____
Q <sub>7-10</sub> Flow (cfs)	_____	Q <sub>7-10</sub> Basis	_____
Elevation (ft)	_____	Slope (ft/ft)	_____
Watershed No.	<u>17-C</u>	Chapter 93 Class.	<u>CWF</u>
Existing Use	_____	Existing Use Qualifier	_____
Exceptions to Use	_____	Exceptions to Criteria	_____
Assessment Status	<u>Impaired</u>		
Cause(s) of Impairment	<u>METALS</u>		
Source(s) of Impairment	<u>SOURCE UNKNOWN</u>		
TMDL Status	_____	Name	_____
Background/Ambient Data		Data Source	
pH (SU)	_____	_____	
Temperature (°F)	_____	_____	
Hardness (mg/L)	_____	_____	
Other:	_____	_____	
Nearest Downstream Public Water Supply Intake			
PWS Waters	_____	Flow at Intake (cfs)	_____
PWS RMI	_____	Distance from Outfall (mi)	_____

Changes Since Last Permit Issuance: None.

Other Comments:

**Discharge, Receiving Waters and Water Supply Information**

Outfall No.	<u>003</u>	Design Flow (MGD)	<u>0</u>
Latitude	<u>41° 10' 25"</u>	Longitude	<u>-79° 5' 40"</u>
Quad Name	<u>Brookville</u>	Quad Code	<u>41079B1</u>
Wastewater Description: <u>Stormwater</u>			

Receiving Waters	<u>Trib 48856 to North Fork Redbank Creek</u>	Stream Code	<u>48856</u>
NHD Com ID	<u>123854430</u>	RMI	<u>0.5400</u>
Drainage Area	<u></u>	Yield (cfs/mi <sup>2</sup> )	<u></u>
Q <sub>7-10</sub> Flow (cfs)	<u></u>	Q <sub>7-10</sub> Basis	<u></u>
Elevation (ft)	<u></u>	Slope (ft/ft)	<u></u>
Watershed No.	<u>17-C</u>	Chapter 93 Class.	<u>HQ-CWF</u>
Existing Use	<u></u>	Existing Use Qualifier	<u></u>
Exceptions to Use	<u></u>	Exceptions to Criteria	<u></u>
Assessment Status	<u>Impaired</u>		
Cause(s) of Impairment	<u>METALS</u>		
Source(s) of Impairment	<u>SOURCE UNKNOWN</u>		
TMDL Status	<u></u>	Name	<u></u>

Background/Ambient Data		Data Source
pH (SU)	<u></u>	<u></u>
Temperature (°F)	<u></u>	<u></u>
Hardness (mg/L)	<u></u>	<u></u>
Other:	<u></u>	<u></u>

Nearest Downstream Public Water Supply Intake		<u></u>
PWS Waters	<u></u>	Flow at Intake (cfs) <u></u>
PWS RMI	<u></u>	Distance from Outfall (mi) <u></u>

Changes Since Last Permit Issuance: None.

Other Comments:

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Daily Maximum	Instant. Maximum		
pH (S.U.)	XXX	XXX	XXX	XXX	Report	XXX	1/year	Grab
TSS	XXX	XXX	XXX	XXX	Report	XXX	1/year	Grab
Total Nitrogen	XXX	XXX	XXX	XXX	Report	XXX	1/year	Calculation
Total Phosphorus	XXX	XXX	XXX	XXX	Report	XXX	1/year	Grab
Total Zinc	XXX	XXX	XXX	XXX	Report	XXX	1/year	Grab

Compliance Sampling Location: Outfall 001, prior to mixing with any other waters.

Other Comments: None.

