

Northeast Regional Office CLEAN WATER PROGRAM

Application Type

Facility Type

Major / Minor

Minor

NPDES PERMIT FACT SHEET INDIVIDUAL INDUSTRIAL WASTE (IW) AND IW STORMWATER

 Application No.
 PAS232212

 APS ID
 732633

 Authorization ID
 1395467

Applicant Name	Piran	nal Critical Care Inc.	Facility Name	Piramal Critical Care Inc. Bethlehem Plant	
Applicant Address 3		Schelden Circle	Facility Address	3950 Schelden Circle	
	Bethl	ehem, PA 18017		Bethlehem, PA 18017	
Applicant Contact	Micha	ael Allison	Facility Contact	Michael Allison	
Applicant Phone	(610)	974-9760	Facility Phone	(610) 974-9760	
Client ID	2795	17	Site ID	505810	
SIC Code	2834		Municipality	Hanover Township	
SIC Description	Manufacturing - Pharmaceutical C Description Preparations		County	Northampton	
Date Application Received		May 2, 2022	EPA Waived?	Yes	
Date Application Accepted		May 2, 2022	If No, Reason	-	

Summary of Review

The applicant is requesting the renewal of their NPDES permit to discharge stormwater associated with industrial activity to an unnamed tributary to Monocacy Creek, a HQ-CWF/MF designated receiving stream in state water plan basin 02-C (Lower Lehigh River). As per the Department's current existing use list, the receiving stream does not have an existing use classification that is more protective than its designated use. The applicant is not proposing any changes to the site that would increase stormwater runoff.

The facility is categorized by SIC Code 2834 (Pharmaceutical Preparations) and falls under the monitoring requirements of Appendix F (Chemicals and Allied Products) of the PAG-03 general permit. Appendix F requires semiannual monitoring for the following parameters: pH, Chemical Oxygen Demand (COD) (mg/L), Total Suspended Solids (TSS) mg/L, Nitrate & Nitrite Nitrogen (mg/L), Total Phosphorous (mg/L), Total Lead (mg/L), Total Zinc (mg/L), Total Iron (mg/L), and Total Aluminum (mg/L). Benchmark values for COD and TSS are 120 mg/L and 100 mg/L respectively. The benchmark values are not effluent limitations, and exceedances do not constitute permit violations. However, if the permittee's sampling demonstrates exceedances of benchmark values for two consecutive monitoring periods, the permittee shall submit a corrective action plan within 90 days of the end of the monitoring period triggering the plan.

The Stormwater Part C requirements include Best Management Practices (BMPs), Routine Inspections, Preparedness, Prevention, and Contingency Plan, and Stormwater Monitoring Requirements. The permit requires implementation of a PPC plan and requires completion of an annual inspection and compliance evaluation.

The current permit expires on October 31, 2022, and the renewal application was received on time. There are no open violations for the client that would warrant withholding issuing the permit.

Approve	Deny	Signatures	Date
Х		Rory Sgarlat	
		Rory Sgarlat, EIT / Environmental Engineering Specialist	May 26, 2022
Х		Amy M. Bellanca (signed) Amy M. Bellanca, P.E. / Environmental Engineer Manager	6-10-22

Summary of Review

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.