



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
AIR QUALITY PROGRAM**

**STATE ONLY NATURAL MINOR OPERATING PERMIT**

Issue Date: May 22, 2023

Effective Date: May 22, 2023

Expiration Date: May 21, 2028

In accordance with the provisions of the Air Pollution Control Act, the Act of January 8, 1960, P.L. 2119, as amended, and 25 Pa. Code Chapter 127, the Owner, [and Operator if noted] (hereinafter referred to as permittee) identified below is authorized by the Department of Environmental Protection (Department) to operate the air emission source(s) more fully described in this permit. This Facility is subject to all terms and conditions specified in this permit. Nothing in this permit relieves the permittee from its obligations to comply with all applicable Federal, State and Local laws and regulations.

The regulatory or statutory authority for each permit condition is set forth in brackets. All terms and conditions in this permit are federally enforceable unless otherwise designated.

**State Only Permit No: 41-00049**

Natural Minor

Federal Tax Id - Plant Code: 51-0608522-1

**Owner Information**

Name: DANZER VENEER AMERICAS INC

Mailing Address: 240 N REACH RD  
PO BOX 3455  
WILLIAMSPORT, PA 17701-9101

**Plant Information**

Plant: DANZEER VENEER AMERICAS INC/WILLIAMSPORT VENEER MILL

Location: 41 Lycoming County 41001 Williamsport City

SIC Code: 2435 Manufacturing - Hardwood Veneer And Plywood

**Responsible Official**

Name: DAN RASTATTER

Title: VP OF ENGINEERING

Phone: (570) 322 - 4400

Email: dan.rastatter@danzer.com

**Permit Contact Person**

Name: PAUL SOUTH

Title: ASSISTANT PLANT MANAGER

Phone: (570) 322 - 4400

Email: paul.south@danzer.com

[Signature] \_\_\_\_\_

MUHAMMAD Q. ZAMAN, ENVIRONMENTAL PROGRAM MANAGER, NORTHCENTRAL REGION



## SECTION A. Table of Contents

### Section A. Facility/Source Identification

Table of Contents  
Site Inventory List

### Section B. General State Only Requirements

- #001 Definitions.
- #002 Operating Permit Duration.
- #003 Permit Renewal.
- #004 Operating Permit Fees under Subchapter I.
- #005 Transfer of Operating Permits.
- #006 Inspection and Entry.
- #007 Compliance Requirements.
- #008 Need to Halt or Reduce Activity Not a Defense.
- #009 Duty to Provide Information.
- #010 Revising an Operating Permit for Cause.
- #011 Operating Permit Modifications
- #012 Severability Clause.
- #013 De Minimis Emission Increases.
- #014 Operational Flexibility.
- #015 Reactivation
- #016 Health Risk-based Emission Standards and Operating Practice Requirements.
- #017 Circumvention.
- #018 Reporting Requirements.
- #019 Sampling, Testing and Monitoring Procedures.
- #020 Recordkeeping.
- #021 Property Rights.
- #022 Alternative Operating Scenarios.
- #023 Reporting
- #024 Report Format

### Section C. Site Level State Only Requirements

- C-I: Restrictions
- C-II: Testing Requirements
- C-III: Monitoring Requirements
- C-IV: Recordkeeping Requirements
- C-V: Reporting Requirements
- C-VI: Work Practice Standards
- C-VII: Additional Requirements
- C-VIII: Compliance Certification
- C-IX: Compliance Schedule

### Section D. Source Level State Only Requirements

- D-I: Restrictions
- D-II: Testing Requirements
- D-III: Monitoring Requirements
- D-IV: Recordkeeping Requirements
- D-V: Reporting Requirements
- D-VI: Work Practice Standards
- D-VII: Additional Requirements

Note: These same sub-sections are repeated for each source!

### Section E. Source Group Restrictions

- E-I: Restrictions



## SECTION A. Table of Contents

- E-II: Testing Requirements
- E-III: Monitoring Requirements
- E-IV: Recordkeeping Requirements
- E-V: Reporting Requirements
- E-VI: Work Practice Standards
- E-VII: Additional Requirements

### Section F. Alternative Operating Scenario(s)







- F-I: Restrictions
- F-II: Testing Requirements
- F-III: Monitoring Requirements
- F-IV: Recordkeeping Requirements
- F-V: Reporting Requirements
- F-VI: Work Practice Standards
- F-VII: Additional Requirements

### Section G. Emission Restriction Summary

### Section H. Miscellaneous


**SECTION A. Site Inventory List**

Source ID	Source Name	Capacity/Throughput	Fuel/Material
031	WOOD-FIRED BOILER	28.800 MMBTU/HR	
032	WOOD-FIRED BOILER	28.800 MMBTU/HR	
033	NATURAL GAS-FIRED BOILER	25.200 MMBTU/HR	
P101	FLITCH MILLING & VENEER CLIPPING OPERATION		
P102	PARTS WASHER		
P103	NATURAL GAS FIRED EMERGENCY GENERATORS		
P104	1000 GALLON GASOLINE UNDERGROUND TANK		
C031A	PRIMARY MULTI-CLONE COLLECTOR		
C031B	SECONDARY MULT-CLONE COLLECTOR		
C032A	PRIMARY MULT-CLONE COLLECTOR		
C032B	SECONDARY MULTI-CLONE COLLECTOR		
C101A	FABRIC COLLECTOR 1		
C101B	FABRIC COLLECTOR 2		
S031	WOOD-FIRED BOILER STACK		
S032	WOOD-FIRED BOILER STACK		
S033	NATURAL GAS-FIRED BOILER STACK		
S101A	FABRIC COLLECTOR 1 STACK		
S101B	FABRIC COLLECTOR 2 STACK		
S103	NATURAL GAS FIRED EMERGENCY GENERATORS STACKS		
Z001	FUGITIVE EMISSION		
Z102	PARTS WASHER EMISSIONS		

**PERMIT MAPS**



**PERMIT MAPS**



**SECTION B. General State Only Requirements****#001 [25 Pa. Code § 121.1]****Definitions.**

Words and terms that are not otherwise defined in this permit shall have the meanings set forth in Section 3 of the Air Pollution Control Act (35 P.S. § 4003) and in 25 Pa. Code § 121.1.

**#002 [25 Pa. Code § 127.446]****Operating Permit Duration.**

- (a) This operating permit is issued for a fixed term of five (5) years and shall expire on the date specified on Page 1 of this permit.
- (b) The terms and conditions of the expired permit shall automatically continue pending issuance of a new operating permit, provided the permittee has submitted a timely and complete application and paid applicable fees required under 25 Pa. Code Chapter 127, Subchapter I and the Department is unable, through no fault of the permittee, to issue or deny a new permit before the expiration of the previous permit.

**#003 [25 Pa. Code §§ 127.412, 127.413, 127.414, 127.446 & 127.703(b)]****Permit Renewal.**

- (a) The permittee shall submit a timely and complete application for renewal of the operating permit to the appropriate Regional Air Program Manager. The application for renewal of the operating permit shall be submitted at least six (6) months and not more than 18 months before the expiration date of this permit.
- (b) The application for permit renewal shall include the current permit number, a description of any permit revisions that occurred during the permit term, and any applicable requirements that were promulgated and not incorporated into the permit during the permit term. An application is complete if it contains sufficient information to begin processing the application, has the applicable sections completed and has been signed by a responsible official.
- (c) The permittee shall submit with the renewal application a fee for the processing of the application as specified in 25 Pa. Code § 127.703(b). The fees shall be made payable to "The Commonwealth of Pennsylvania Clean Air Fund" and submitted with the fee form to the respective regional office.
- (d) The renewal application shall also include submission of proof that the local municipality and county, in which the facility is located, have been notified in accordance with 25 Pa. Code § 127.413.
- (e) The application for renewal of the operating permit shall also include submission of supplemental compliance review forms in accordance with the requirements of 25 Pa. Code § 127.412(b) and § 127.412(j).
- (f) The permittee, upon becoming aware that any relevant facts were omitted or incorrect information was submitted in the permit application, shall promptly submit such supplementary facts or corrected information as necessary to address any requirements that become applicable to the source after the permittee submits a complete application, but prior to the date the Department takes action on the permit application.

**#004 [25 Pa. Code § 127.703]****Operating Permit Fees under Subchapter I.**

- (a) The permittee shall pay the annual operating permit maintenance fee according to the following fee schedule in either paragraph (1) or (2) in accordance with 25 Pa. Code § 127.703(d) on or before December 31 of each year for the next calendar year.
- (1) For a synthetic minor facility, a fee equal to:
- (i) Four thousand dollars (\$4,000) for calendar years 2021—2025.
  - (ii) Five thousand dollars (\$5,000) for calendar years 2026—2030.
  - (iii) Six thousand three hundred dollars (\$6,300) for the calendar years beginning with 2031.

**SECTION B. General State Only Requirements**

(2) For a facility that is not a synthetic minor, a fee equal to:

- (i) Two thousand dollars (\$2,000) for calendar years 2021—2025.
- (ii) Two thousand five hundred dollars (\$2,500) for calendar years 2026—2030.
- (iii) Three thousand one hundred dollars (\$3,100) for the calendar years beginning with 2031.

(b) The applicable fees shall be made payable to "The Commonwealth of Pennsylvania Clean Air Fund" with the permit number clearly indicated and submitted to the respective regional office.

**#005 [25 Pa. Code §§ 127.450 (a)(4) and 127.464]****Transfer of Operating Permits.**

(a) This operating permit may not be transferred to another person, except in cases of transfer-of-ownership that are documented and approved by the Department.

(b) In accordance with 25 Pa. Code § 127.450(a)(4), a change in ownership of the source shall be treated as an administrative amendment if the Department determines that no other change in the permit is required and a written agreement has been submitted to the Department identifying the specific date of the transfer of permit responsibility, coverage and liability between the current and the new permittee and a compliance review form has been submitted to, and the permit transfer has been approved by, the Department.

(c) This operating permit is valid only for those specific sources and the specific source locations described in this permit.

**#006 [25 Pa. Code § 127.441 and 35 P.S. § 4008]****Inspection and Entry.**

(a) Upon presentation of credentials and other documents as may be required by law, the permittee shall allow the Department or authorized representatives of the Department to perform the following:

(1) Enter at reasonable times upon the permittee's premises where a source is located or emissions related activity is conducted, or where records are kept under the conditions of this permit;

(2) Have access to and copy, at reasonable times, any records that are kept under the conditions of this permit;

(3) Inspect at reasonable times, any facilities, equipment including monitoring and air pollution control equipment, practices, or operations regulated or required under this permit;

(4) Sample or monitor, at reasonable times, any substances or parameters, for the purpose of assuring compliance with the permit or applicable requirements as authorized by the Clean Air Act, the Air Pollution Control Act, or the regulations promulgated under the Acts.

(b) Pursuant to 35 P.S. § 4008, no person shall hinder, obstruct, prevent or interfere with the Department or its personnel in the performance of any duty authorized under the Air Pollution Control Act or regulations adopted thereunder including denying the Department access to a source at this facility. Refusal of entry or access may constitute grounds for permit revocation and assessment of criminal and/or civil penalties.

(c) Nothing in this permit condition shall limit the ability of the EPA to inspect or enter the premises of the permittee in accordance with Section 114 or other applicable provisions of the Clean Air Act.

**#007 [25 Pa. Code §§ 127.441 & 127.444]****Compliance Requirements.**

(a) The permittee shall comply with the conditions of this operating permit. Noncompliance with this permit constitutes a violation of the Clean Air Act and the Air Pollution Control Act and is grounds for one or more of the following:

**SECTION B. General State Only Requirements**

- (1) Enforcement action
- (2) Permit termination, revocation and reissuance or modification
- (3) Denial of a permit renewal application

(b) A person may not cause or permit the operation of a source which is subject to 25 Pa. Code Article III unless the source(s) and air cleaning devices identified in the application for the plan approval and operating permit and the plan approval issued for the source is operated and maintained in accordance with specifications in the applications and the conditions in the plan approval and operating permit issued by the Department. A person may not cause or permit the operation of an air contamination source subject to 25 Pa. Code Chapter 127 in a manner inconsistent with good operating practices.

(c) For purposes of Sub-condition (b) of this permit condition, the specifications in applications for plan approvals and operating permits are the physical configurations and engineering design details which the Department determines are essential for the permittee's compliance with the applicable requirements in this State-Only permit. Nothing in this sub-condition shall be construed to create an independent affirmative duty upon the permittee to obtain a predetermination from the Department for physical configuration or engineering design detail changes made by the permittee.

**#008 [25 Pa. Code § 127.441]****Need to Halt or Reduce Activity Not a Defense.**

It shall not be a defense for the permittee in an enforcement action that it was necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit.

**#009 [25 Pa. Code §§ 127.442(a) & 127.461]****Duty to Provide Information.**

(a) The permittee shall submit reports to the Department containing information the Department may prescribe relative to the operation and maintenance of each source at the facility.

(b) The permittee shall furnish to the Department, in writing, information that the Department may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit, or to determine compliance with the permit. Upon request, the permittee shall also furnish to the Department copies of records that the permittee is required to maintain in accordance with this permit.

**#010 [25 Pa. Code § 127.461]****Revising an Operating Permit for Cause.**

This operating permit may be terminated, modified, suspended or revoked and reissued if one or more of the following applies:

- (1) The permittee constructs or operates the source subject to the operating permit so that it is in violation of the Air Pollution Control Act, the Clean Air Act, the regulations thereunder, a plan approval, a permit or in a manner that causes air pollution.
- (2) The permittee fails to properly or adequately maintain or repair an air pollution control device or equipment attached to or otherwise made a part of the source.
- (3) The permittee has failed to submit a report required by the operating permit or an applicable regulation.
- (4) The EPA determines that the permit is not in compliance with the Clean Air Act or the regulations thereunder.

**#011 [25 Pa. Code §§ 127.450, 127.462, 127.465 & 127.703]****Operating Permit Modifications**

(a) The permittee is authorized to make administrative amendments, minor operating permit modifications and significant operating permit modifications, under this permit, as outlined below:



**SECTION B. General State Only Requirements**

(b) Administrative Amendments. The permittee shall submit the application for administrative operating permit amendments (as defined in 25 Pa. Code § 127.450(a)), according to procedures specified in § 127.450 unless precluded by the Clean Air Act or its regulations.

(c) Minor Operating Permit Modifications. The permittee shall submit the application for minor operating permit modifications (as defined 25 Pa. Code § 121.1) in accordance with 25 Pa. Code § 127.462.

(d) Significant Operating Permit Modifications. The permittee shall submit the application for significant operating permit modifications in accordance with 25 Pa. Code § 127.465.

(e) The applicable fees shall be made payable to "The Commonwealth of Pennsylvania Clean Air Fund" with the permit number clearly indicated and submitted to the respective regional office.

**#012 [25 Pa. Code § 127.441]****Severability Clause.**

The provisions of this permit are severable, and if any provision of this permit is determined by a court of competent jurisdiction to be invalid or unenforceable, such a determination will not affect the remaining provisions of this permit.

**#013 [25 Pa. Code § 127.449]****De Minimis Emission Increases.**

(a) This permit authorizes de minimis emission increases in accordance with 25 Pa. Code § 127.449 so long as the permittee provides the Department with seven (7) days prior written notice before commencing any de minimis emissions increase. The written notice shall:

(1) Identify and describe the pollutants that will be emitted as a result of the de minimis emissions increase.

(2) Provide emission rates expressed in tons per year and in terms necessary to establish compliance consistent with any applicable requirement.

(b) The Department may disapprove or condition de minimis emission increases at any time.

(c) Except as provided below in (d), the permittee is authorized to make de minimis emission increases (expressed in tons per year) up to the following amounts without the need for a plan approval or prior issuance of a permit modification:

(1) Four tons of carbon monoxide from a single source during the term of the permit and 20 tons of carbon monoxide at the facility during the term of the permit.

(2) One ton of NO<sub>x</sub> from a single source during the term of the permit and 5 tons of NO<sub>x</sub> at the facility during the term of the permit.

(3) One and six-tenths tons of the oxides of sulfur from a single source during the term of the permit and 8.0 tons of oxides of sulfur at the facility during the term of the permit.

(4) Six-tenths of a ton of PM<sub>10</sub> from a single source during the term of the permit and 3.0 tons of PM<sub>10</sub> at the facility during the term of the permit. This shall include emissions of a pollutant regulated under Section 112 of the Clean Air Act unless precluded by the Clean Air Act, the regulations thereunder or 25 Pa. Code Article III.

(5) One ton of VOCs from a single source during the term of the permit and 5.0 tons of VOCs at the facility during the term of the permit. This shall include emissions of a pollutant regulated under Section 112 of the Clean Air Act unless precluded by the Clean Air Act, the regulations thereunder or 25 Pa. Code Article III.

(6) Other sources and classes of sources determined to be of minor significance by the Department.

(d) In accordance with § 127.14, the permittee is authorized to install the following minor sources without the need for a plan approval or permit modification:

**SECTION B. General State Only Requirements**

- (1) Air conditioning or ventilation systems not designed to remove pollutants generated or released from other sources.
  - (2) Combustion units rated at 2,500,000 or less Btu per hour of heat input.
  - (3) Combustion units with a rated capacity of less than 10,000,000 Btu per hour heat input fueled by natural gas supplied by a public utility or by commercial fuel oils which are No. 2 or lighter, viscosity less than or equal to 5.82 c St, and which meet the sulfur content requirements of 25 Pa. Code §123.22 (relating to combustion units). For purposes of this permit, commercial fuel oil shall be virgin oil which has no reprocessed, recycled or waste material added.
  - (4) Space heaters which heat by direct heat transfer.
  - (5) Laboratory equipment used exclusively for chemical or physical analysis.
  - (6) Other sources and classes of sources determined to be of minor significance by the Department.
- (e) This permit does not authorize de minimis emission increases if the emissions increase would cause one or more of the following:
- (1) Increase the emissions of a pollutant regulated under Section 112 of the Clean Air Act except as authorized in Subparagraphs (c)(4) and (5) of this permit condition.
  - (2) Subject the facility to the prevention of significant deterioration requirements in 25 Pa. Code Chapter 127, Subchapter D and/or the new source review requirements in Subchapter E.
  - (3) Violate any applicable requirement of this permit, the Air Pollution Control Act, the Clean Air Act, or the regulations promulgated under either of the acts.
- (f) Emissions authorized under this permit condition shall be included in the monitoring, recordkeeping and reporting requirements of this permit.
- (g) Except for de minimis emission increases, installation of minor sources made pursuant to this permit condition and Plan Approval Exemptions under 25 Pa. Code § 127.14 (relating to exemptions), the permittee is prohibited from making changes or engaging in activities that are not specifically authorized under this permit without first applying for a plan approval. In accordance with § 127.14(b), a plan approval is not required for the construction, modification, reactivation, or installation of the sources creating the de minimis emissions increase.
- (h) The permittee may not meet de minimis emission threshold levels by offsetting emission increases or decreases at the same source.

**#014 [25 Pa. Code § 127.3]****Operational Flexibility.**

The permittee is authorized to make changes within the facility in accordance with the regulatory provisions outlined in 25 Pa. Code § 127.3 (relating to operational flexibility) to implement the operational flexibility requirements provisions authorized under Section 6.1(i) of the Air Pollution Control Act and the operational flexibility terms and conditions of this permit. The provisions in 25 Pa. Code Chapter 127 which implement the operational flexibility requirements include the following:

- (1) Section 127.14 (relating to exemptions)
- (2) Section 127.447 (relating to alternative operating scenarios)
- (3) Section 127.448 (relating to emissions trading at facilities with Federally enforceable emissions caps)
- (4) Section 127.449 (relating to de minimis emission increases)
- (5) Section 127.450 (relating to administrative operating permit amendments)

**SECTION B. General State Only Requirements**

(6) Section 127.462 (relating to minor operating permit modifications)

(7) Subchapter H (relating to general plan approvals and general operating permits)

**#015 [25 Pa. Code § 127.11]****Reactivation**

(a) The permittee may not reactivate a source that has been out of operation or production for at least one year unless the reactivation is conducted in accordance with a plan approval granted by the Department or in accordance with reactivation and maintenance plans developed and approved by the Department in accordance with 25 Pa. Code § 127.11a(a).

(b) A source which has been out of operation or production for more than five (5) years but less than 10 years may be reactivated and will not be considered a new source if the permittee satisfies the conditions specified in 25 Pa. Code § 127.11a(b).

**#016 [25 Pa. Code § 127.36]****Health Risk-based Emission Standards and Operating Practice Requirements.**

(a) When needed to protect public health, welfare and the environment from emissions of hazardous air pollutants from new and existing sources, the permittee shall comply with the health risk-based emission standards or operating practice requirements imposed by the Department, except as precluded by §§ 6.6(d)(2) and (3) of the Air Pollution Control Act [35 P.S. § 4006.6(d)(2) and (3)].

(b) A person challenging a performance or emission standard established by the Department has the burden to demonstrate that performance or emission standard does not meet the requirements of Section 112 of the Clean Air Act.

**#017 [25 Pa. Code § 121.9]****Circumvention.**

No person may permit the use of a device, stack height which exceeds good engineering practice stack height, dispersion technique or other technique which, without resulting in reduction of the total amount of air contaminants emitted, conceals or dilutes an emission of air contaminants which would otherwise be in violation of 25 Pa. Code Article III, except that with prior approval of the Department, the device or technique may be used for control of malodors.

**#018 [25 Pa. Code §§ 127.402(d) & 127.442]****Reporting Requirements.**

(a) The permittee shall comply with the applicable reporting requirements of the Clean Air Act, the regulations thereunder, the Air Pollution Control Act and 25 Pa. Code Article III including Chapters 127, 135 and 139.

(b) The permittee shall submit reports to the Department containing information the Department may prescribe relative to the operation and maintenance of any air contamination source.

(c) Reports, test data, monitoring data, notifications and requests for renewal of the permit shall be submitted to the:

Regional Air Program Manager  
PA Department of Environmental Protection  
(At the address given in the permit transmittal letter, or otherwise notified)

(d) Any records or information including applications, forms, or reports submitted pursuant to this permit condition shall contain a certification by a responsible official as to truth, accuracy and completeness. The certifications submitted under this permit shall require a responsible official of the facility to certify that based on information and belief formed after reasonable inquiry, the statements and information in the documents are true, accurate and complete.

(e) Any records, reports or information submitted to the Department shall be available to the public except for such

**SECTION B. General State Only Requirements**

records, reports or information which meet the confidentiality requirements of § 4013.2 of the Air Pollution Control Act and §§ 112(d) and 114(c) of the Clean Air Act. The permittee may not request a claim of confidentiality for any emissions data generated for the facility.

**#019 [25 Pa. Code §§ 127.441(c) & 135.5]****Sampling, Testing and Monitoring Procedures.**

(a) The permittee shall comply with the monitoring, recordkeeping or reporting requirements of 25 Pa. Code Chapter 139 and the other applicable requirements of 25 Pa. Code Article III and additional requirements related to monitoring, reporting and recordkeeping required by the Clean Air Act and the regulations thereunder including the Compliance Assurance Monitoring requirements of 40 CFR Part 64, where applicable.

(b) Unless alternative methodology is required by the Clean Air Act and regulations adopted thereunder, sampling, testing and monitoring required by or used by the permittee to demonstrate compliance with any applicable regulation or permit condition shall be conducted in accordance with the requirements of 25 Pa. Code Chapter 139.

**#020 [25 Pa. Code §§ 127.441(c) and 135.5]****Recordkeeping.**

(a) The permittee shall maintain and make available, upon request by the Department, the following records of monitored information:

- (1) The date, place (as defined in the permit) and time of sampling or measurements.
- (2) The dates the analyses were performed.
- (3) The company or entity that performed the analyses.
- (4) The analytical techniques or methods used.
- (5) The results of the analyses.
- (6) The operating conditions as existing at the time of sampling or measurement.

(b) The permittee shall retain records of any required monitoring data and supporting information for at least five (5) years from the date of the monitoring, sample, measurement, report or application. Supporting information includes the calibration data and maintenance records and original strip-chart recordings for continuous monitoring instrumentation, and copies of reports required by the permit.

(c) The permittee shall maintain and make available to the Department upon request, records including computerized records that may be necessary to comply with the reporting, recordkeeping and emission statement requirements in 25 Pa. Code Chapter 135 (relating to reporting of sources). In accordance with 25 Pa. Code Chapter 135, § 135.5, such records may include records of production, fuel usage, maintenance of production or pollution control equipment or other information determined by the Department to be necessary for identification and quantification of potential and actual air contaminant emissions.

**#021 [25 Pa. Code § 127.441(a)]****Property Rights.**

This permit does not convey any property rights of any sort, or any exclusive privileges.

**#022 [25 Pa. Code § 127.447]****Alternative Operating Scenarios.**

The permittee is authorized to make changes at the facility to implement alternative operating scenarios identified in this permit in accordance with 25 Pa. Code § 127.447.

**SECTION B. General State Only Requirements****#023 [25 Pa. Code §135.3]****Reporting**

(a) If the facility is a Synthetic Minor Facility, the permittee shall submit by March 1 of each year an annual emissions report for the preceding calendar year. The report shall include information for all active previously reported sources, new sources which were first operated during the preceding calendar year, and sources modified during the same period which were not previously reported. All air emissions from the facility should be estimated and reported.

(b) A source owner or operator of a Synthetic Minor Facility may request an extension of time from the Department for the filing of an annual emissions report, and the Department may grant the extension for reasonable cause.

**#024 [25 Pa. Code §135.4]****Report Format**

If applicable, the emissions reports shall contain sufficient information to enable the Department to complete its emission inventory. Emissions reports shall be made by the source owner or operator in a format specified by the Department.

**SECTION C. Site Level Requirements****I. RESTRICTIONS.****Emission Restriction(s).****# 001 [25 Pa. Code §123.1]****Prohibition of certain fugitive emissions**

No person may permit the emission into the outdoor atmosphere of fugitive air contaminants from a source other than the following:

- (1) Construction or demolition of buildings or structures.
- (2) Grading, paving, and maintenance of roads and streets.
- (3) Use of roads and streets. Emissions from material in or on trucks, railroad cars, and other vehicular equipment are not considered as emissions from use of roads and streets.
- (4) Clearing of land.
- (5) Stockpiling of materials.
- (6) Open burning operations.
- (7) Sources and classes of sources other than those identified above, for which the permittee has obtained a determination from the Department that fugitive emissions from the source, after appropriate control, meet the following requirements:
  - (i) The emissions are of minor significance with respect to causing air pollution.
  - (ii) The emissions are not preventing or interfering with the attainment or maintenance of an ambient air quality standard.

**# 002 [25 Pa. Code §123.2]****Fugitive particulate matter**

No person may permit fugitive particulate matter to be emitted into the outdoor atmosphere from a source specified in Condition #001(1)-(7) above if the emissions are visible at the point the emissions pass outside the person's property.

**# 003 [25 Pa. Code §123.41]****Limitations**

No person may permit the emission into the outdoor atmosphere of visible air contaminants in such a manner that the opacity of the emission is either of the following:

- (1) Equal to or greater than 20% for a period or periods aggregating more than three minutes in any 1 hour.
- (2) Equal to or greater than 60% at any time.

**# 004 [25 Pa. Code §123.42]****Exceptions**

The emission limitations of 25 Pa. Code Section 123.41 shall not apply when:

- (1) The presence of uncombined water is the only reason for failure of the emission to meet the limitations.
- (2) The emission results from the operation of equipment used solely to train and test persons in observing the opacity of visible emissions.
- (3) The emission results from sources specified in 25 Pa. Code Section 123.1(a)(1)-(9).

**II. TESTING REQUIREMENTS.****# 005 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

[Additional authority for this permit condition is derived from existing operating permit 41-302-040B]

**SECTION C. Site Level Requirements**

If at any time the Department has cause to believe that air contaminant emissions from any source at this facility may be in excess of the limitations specified in this permit or established pursuant to any applicable limitation contained in 25 Pa. Code Sections 121-145, the company shall be required to conduct whatever tests are deemed necessary by the Department to determine the actual emission rate(s). Such testing shall be conducted in accordance with the provisions set forth in 25 Pa. Code Section 139, where applicable, and in accordance with any restrictions or limitations established by the Department at such time as it notifies the company that testing is required.

**# 006 [25 Pa. Code §139.1]****Sampling facilities.**

Upon the request of the Department, the permittee shall provide adequate sampling ports, safe sampling platforms, and adequate utilities for the performance by the Department of tests on such source. The Department will set forth, in the request, the time period in which the facilities shall be provided as well as the specifications for such facilities.

**# 007 [25 Pa. Code §139.11]****General requirements.**

(a) As specified in 25 Pa. Code Section 139.11(1), performance tests shall be conducted while the source is operating at maximum routine operating conditions or under such other conditions, within the capacity of the equipment, as may be requested by the Department.

(b) As specified in 25 Pa. Code Section 139.11(2), the Department will consider test results for approval where sufficient information is provided to verify the source conditions existing at the time of the test and where adequate data is available to show the manner in which the test was conducted. Information submitted to the Department shall include, as a minimum, all of the following:

- (1) A thorough source description, including a description of any air cleaning devices and the flue.
- (2) Process conditions, for example, the charging rate of raw material or rate of production of final product, boiler pressure, oven temperature, and other conditions which may affect emissions from the process.
- (3) The location of sampling ports.
- (4) Effluent characteristics, including velocity, temperature, moisture content, gas density (percentage of CO, CO<sub>2</sub>, O<sub>2</sub> and N<sub>2</sub>), static and barometric pressures.
- (5) Sample collection techniques employed, including procedures used, equipment descriptions, and data to verify that isokinetic sampling for particulate matter collection occurred and that acceptable test conditions were met.
- (6) Laboratory procedures and results.
- (7) Calculated results.

**III. MONITORING REQUIREMENTS.****# 008 [25 Pa. Code §123.43]****Measuring techniques**

Visible emissions may be measured using either of the following:

- (1) A device approved by the Department and maintained to provide accurate opacity measurements.
- (2) Observers, trained and qualified to measure plume opacity with the naked eye or with the aid of any devices approved by the Department.

**# 009 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

- (a) The permittee shall conduct a weekly inspection of the facility during daylight hours while the facility is operating to

**SECTION C. Site Level Requirements**

detect visible emissions, visible fugitive emissions, and malodors. Weekly inspections are necessary to determine:

- (1) The presence of visible emissions.
  - (2) The presence of visible fugitive emissions.
  - (3) The presence of malodors beyond the boundaries of the facility.
- (b) All detected visible emissions, visible fugitive emissions, or malodors that have the potential to exceed applicable limits shall be reported to the manager of the facility.

**IV. RECORDKEEPING REQUIREMENTS.****# 010 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

The permittee shall maintain a logbook of the weekly facility inspections and shall record instances of visible emissions, visible fugitive emissions and malodorous air emissions, the name of the company representative monitoring these instances, and the date and time of each occurrence. The permittee shall also record the corrective action(s) taken to abate each recorded deviation or to prevent future occurrences.

These records shall be retained for a minimum of five (5) years and shall be made available to the Department upon request.

**# 011 [25 Pa. Code §135.5]****Recordkeeping**

(a) The permittee shall maintain records including computerized records that may be necessary to comply with 25 Pa. Code Sections 135.3 and 135.21 (relating to reporting and emissions statements). These may include records of production, fuel usage, maintenance of production or pollution control equipment or other information determined by the Department to be necessary for identification and quantification of potential and actual air contaminant emissions.

(b) The above records shall be retained for a minimum of 5 years and shall be made available to the Department upon request.

**V. REPORTING REQUIREMENTS.****# 012 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

Upon request by the Department, the permittee shall submit all requested reports in accordance with the Department's suggested format.

**# 013 [25 Pa. Code §127.442]****Reporting requirements.**

(a) The permittee shall report malfunctions, emergencies or incidents of excess emissions to the Department. A malfunction is any sudden, infrequent, and not reasonably preventable failure of air pollution control equipment, process equipment, or a process to operate in a normal or usual manner. An emergency is any situation arising from sudden and reasonably unforeseeable events beyond the control of the owner or operator of a facility which requires immediate corrective action to restore normal operation and which causes the emission source to exceed emissions, due to unavoidable increases in emissions attributable to the situation. An emergency shall not include situations caused by improperly designed equipment, lack of preventive maintenance, careless or improper operation, or operator error.

(b) When the malfunction, emergency or incident of excess emissions poses an imminent danger to the public health, safety, welfare, or environment, it shall be reported to the Department and the County Emergency Management Agency by telephone within one (1) hour after the discovery of the malfunction, emergency or incident of excess emissions. The owner or operator shall submit a written or emailed report of instances of such malfunctions, emergencies or incidents of excess emissions to the Department within three (3) business days of the telephone report.

(c) The report shall describe the following:



**SECTION C. Site Level Requirements**

1. name, permit or authorization number, and location of the facility,
2. nature and cause of the malfunction, emergency or incident,
3. date and time when the malfunction, emergency or incident was first observed,
4. expected duration of excess emissions,
5. estimated rate of emissions,
6. corrective actions or preventative measures taken.

(d) Any malfunction, emergency or incident of excess emissions that is not subject to the notice requirements of paragraph (b) of this condition shall be reported to the Department by telephone within 24 hours (or by 4:00 PM of the next business day, whichever is later) of discovery and in writing or by e-mail within five (5) business days of discovery. The report shall contain the same information required by paragraph (c), and any permit specific malfunction reporting requirements.

(e) During an emergency an owner or operator may continue to operate the source at their discretion provided they submit justification for continued operation of a source during the emergency and follow all the notification and reporting requirements in accordance with paragraphs (b)-(d), as applicable, including any permit specific malfunction reporting requirements.

(f) Reports regarding malfunctions, emergencies or incidents of excess emissions shall be submitted to the appropriate DEP Regional Office Air Program Manager.

(g) Any emissions resulted from malfunction or emergency are to be reported in the annual emissions inventory report, if the annual emissions inventory report is required by permit or authorization.

**# 014 [25 Pa. Code §135.3]****Reporting**

(a) A person who owns or operates a source to which 25 Pa. Code Chapter 135 applies, and who has previously been advised by the Department to submit a source report, shall submit by March 1 of each year an Annual Air Information Management Systems (AIMS) Emissions report for the preceding calendar year. The report shall include information for all previously reported sources, new sources which were first operated during the preceding calendar year, and sources modified during the same period which were not previously reported.

(b) A person who receives initial notification by the Department that an Annual Air Information Management Systems (AIMS) Emissions report is necessary, shall submit an initial Annual Air Information Management Systems (AIMS) Emissions report within sixty (60) days after receiving the notification or by March 1 of the year following the year for which the report is required, whichever is later.

(c) The permittee may request an extension of time from the Department for the filing of an Annual Air Information Management Systems (AIMS) Emissions report, and the Department may grant the extension for reasonable cause.

**VI. WORK PRACTICE REQUIREMENTS.****# 015 [25 Pa. Code §123.1]****Prohibition of certain fugitive emissions**

The permittee shall take all reasonable actions for any source specified in 25 Pa. Code Section 123.1 (a)(1)-(9) to prevent particulate matter from becoming airborne. These actions shall include, but not be limited to, the following:

(1) Use, where possible, of water or chemicals for control of dust in the demolition of buildings or structures, construction operations, the grading of roads, or the clearing of land.

(2) Application of asphalt, oil, or suitable chemicals on dirt roads, material stockpiles, and other surfaces which may give rise to airborne dusts.

(3) Paving and maintenance of roadways.

(4) Prompt removal of earth or other material from paved streets onto which earth or other material has been transported by trucking or earth moving equipment, erosion by water, or other means.

**SECTION C. Site Level Requirements****VII. ADDITIONAL REQUIREMENTS.****# 016 [25 Pa. Code §121.7]****Prohibition of air pollution.**

No person may permit air pollution as that term is defined in the act [The Air Pollution Control Act (35 P.S. §§ 4001-4015)].

**# 017 [25 Pa. Code §123.31]****Limitations**

No person may permit the emission into the outdoor atmosphere of any malodorous air contaminants from any source in a manner that the malodors are detectable outside the property of the person on whose land the source is being operated.

**# 018 [25 Pa. Code §129.14]****Open burning operations**

No person may permit the open burning of material at this facility unless in accordance with 25 Pa. Code Section 129.14.

**VIII. COMPLIANCE CERTIFICATION.**

No additional compliance certifications exist except as provided in other sections of this permit including Section B (relating to State Only General Requirements).

**IX. COMPLIANCE SCHEDULE.**


No compliance milestones exist.

**SECTION D. Source Level Requirements**

Source ID: 031

Source Name: WOOD-FIRED BOILER

Source Capacity/Throughput: 28.800 MMBTU/HR

**I. RESTRICTIONS.****Emission Restriction(s).****# 001 [25 Pa. Code §123.22]****Combustion units**

[Compliance with the requirement specified in this streamlined permit condition assures compliance with the provision in 40 CFR 52.2020(c)]

No person may permit the emission into the outdoor atmosphere of sulfur oxides, expressed as SO<sub>2</sub>, from the exhaust of ID 031B associated with Source ID 031 in excess of the rate of 4 pounds per million Btu of heat input over any 1-hour period.

**# 002 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

[Additional authority for this permit condition is derived from previous operating permit 41-302-040B pursuant to 25 Pa. Code Sections 127.1 and 127.12. Compliance with this permit condition assures compliance with the particulate matter emission limitations specified in 25 Pa. Code Section 123.11]

No person may permit the emission of particulate matter from the exhaust of ID C031B associated with Source ID 031 into the outdoor atmosphere in excess of 0.20 pounds per million Btu of heat input.

**Fuel Restriction(s).****# 003 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

[Additional authority for this permit condition is derived from previous operating permit 41-302-040B pursuant to 25 Pa. Code Sections 127.1 and 127.12.]

Source ID 031 shall be fired on green and kiln-dried wood only. No coated or treated wood, laminated wood, particle board, flake-board or materials other than green and kiln-dried wood shall be burned in this boiler.

**II. TESTING REQUIREMENTS.**

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**III. MONITORING REQUIREMENTS.****# 004 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

[Additional authority for this permit condition is derived from previous operating permit 41-302-040B]

ID C031B shall be equipped with instrumentation to monitor the pressure drop across the collector on a continuous basis.

**# 005 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

[Additional authority for this permit condition is derived from previous operating permit 41-302-040B]

**SECTION D. Source Level Requirements**

(a) The internals of the multi-clone collectors (IDs 031A and 031B) associated with Source ID 031 shall be inspected at least twice each month and shall be cleaned and/or repaired as may be found necessary.

(b) The Department reserves the right to reduce the required inspection frequency if, based upon actual inspection results, it determines such a change is warranted.

**# 006 [25 Pa. Code §127.441]**

**Operating permit terms and conditions.**

Source ID 031 shall be equipped with instrumentation to monitor for the presence of visible emissions from the stack (S031) associated with Source ID 031 on a continuous basis.

**IV. RECORDKEEPING REQUIREMENTS.**

**# 007 [25 Pa. Code §127.441]**

**Operating permit terms and conditions.**

(a) The pressure drop reading from ID 031B shall be recorded at least twice each week.

(b) Records of pressure drop readings shall be retained for a minimum of five (5) years and shall be made available to the Department upon request.

**# 008 [25 Pa. Code §127.441]**

**Operating permit terms and conditions.**

[Additional authority for this permit condition is derived from previous operating permit 41-302-040B]

(a) The permittee shall keep records listing the inspection date for each multi-clone collector (IDs 031A and 031B) inspection as well as the inspection findings and what action, if any, was taken based upon those findings.

(b) These records shall be kept for a minimum of five (5) years and be made available to the Department upon request.

**# 009 [25 Pa. Code §127.441]**

**Operating permit terms and conditions.**

The results of monitoring for the presence of visible emissions of the stack (S031) associated with Source ID 031 shall be recorded at least once each day of operation.

The name of the individual who conducted the inspection for the presence of visible emissions and the results of the inspection shall be retained for a minimum of five (5) years and shall be made available to the Department upon request.

**# 010 [40 CFR Part 60 Standards of Performance for New Stationary Sources §40 CFR 60.48c]**

**Subpart Dc - Standards of Performance for Small Industrial- Commercial-Institutional Steam Generating Units Reporting and recordkeeping requirements.**

(a) The permittee shall keep records of the amount of fuel used in Source ID 031 on a daily basis.

(b) These records shall be kept for a minimum of five (5) years and be made available to the Department upon request.

**# 011 [40 CFR Part 63 NESHAPS for Source Categories §40 CFR 63.11225]**

**SUBPART JJJJJJ - National Emission Standards for Hazardous Air Pollutants for Industrial, Commercial, and Institutional Boilers Area Sources**

**What are my notification, reporting, and recordkeeping requirements?**

(a) You must keep a copy of each notification and report that you submitted to comply with Subpart JJJJJJ and all documentation supporting any Initial Notification or Notification of Compliance Status that you submitted.

(b) You must keep records of the date of tune-up, the procedures followed for tune-up, and the manufacturer's specifications to which the boiler was tuned.

**SECTION D. Source Level Requirements****V. REPORTING REQUIREMENTS.****# 012 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

[Additional authority for this permit condition is derived from previous operating permit 41-302-040B]

Upon request by the Department, the permittee shall provide analyses or samples of the wood fuel used in Source ID 031.

**# 013 [40 CFR Part 60 Standards of Performance for New Stationary Sources §40 CFR 60.4]****Subpart A - General Provisions****Address.**

The submission of all requests, reports, applications, submittals and other communications required by 40 CFR Part 60 Subpart Dc Section 60.40c through 60.48c shall be submitted to both the U.S. Environmental Protection Agency and the Department. The Environmental Protection Agency copies may be sent to:

EPA Region 3, Air and Radiation Division  
Permits Branch (3AD10)  
Four Penn Center, 1600 John F. Kennedy Boulevard  
Philadelphia, PA 19103-2852

and

The Pennsylvania Department of Environmental Protection  
Air Quality Program Manager  
208 W. Third Street, Suite 101  
Williamsport, PA 17701-6448

**VI. WORK PRACTICE REQUIREMENTS.****# 014 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

[Additional authority for this permit condition is derived from previous operating permit 41-302-040B]

The ash collected in the primary multi-clone collector (ID 031A) may, at the company's option, be re-injected into the firebox of Source ID 031 so long as the emissions from the exhaust of ID 031B associated with Source ID 031 do not exceed the emission limitations specified in this permit.

**# 015 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

[Additional authority for this permit condition is derived from previous operating permit 41-302-040B]

The ash removal and storage (or re-injection) systems associated with IDs 031A and 031B shall remain sealed from the open air at all times and shall discharge into completely covered disposal containers.

**# 016 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

The fire-tubes of Source ID 031 shall be cleaned twice each month and the cleaning of the fire-tubes shall not cause emission of any fugitive air contaminants into the outdoor atmosphere.

**# 017 [40 CFR Part 63 NESHAPS for Source Categories §40 CFR 63.11205]****SUBPART JJJJJJ - National Emission Standards for Hazardous Air Pollutants for Industrial, Commercial, and Institutional Boilers Area Sources****What are my general requirements for complying with this subpart?**

At all times you must operate and maintain any affected source, including associated air pollution control equipment and monitoring equipment, in a manner consistent with safety and good air pollution control practices for minimizing emissions.

**# 018 [40 CFR Part 63 NESHAPS for Source Categories §40 CFR 63.11223]****SUBPART JJJJJJ - National Emission Standards for Hazardous Air Pollutants for Industrial, Commercial, and Institutional Boilers Area Sources**

**SECTION D. Source Level Requirements****How do I demonstrate continuous compliance with the work practice and management practice standards?**

You must conduct a tune-up of the boiler biennially to demonstrate continuous compliance as specified in paragraphs (b)(1) through (7) of this section.

- (1) As applicable, inspect the burner, and clean or replace any components of the burner as necessary (you may delay the burner inspection until the next scheduled unit shutdown, but you must inspect each burner at least once every 36 months).
- (2) Inspect the flame pattern, as applicable, and adjust the burner as necessary to optimize the flame pattern. The adjustment should be consistent with the manufacturer's specifications, if available.
- (3) Inspect the system controlling the air-to-fuel ratio, as applicable, and ensure that it is correctly calibrated and functioning properly.
- (4) Optimize total emissions of carbon monoxide. This optimization should be consistent with the manufacturer's specifications, if available.
- (5) Measure the concentrations in the effluent stream of carbon monoxide in parts per million, by volume, and oxygen in volume percent, before and after the adjustments are made (measurements may be either on a dry or wet basis, as long as it is the same basis before and after the adjustments are made).
- (6) Maintain onsite and submit, if requested by the Administrator, biennial report containing the information in paragraphs (b)(6)(i) through (iii) of this section.
  - (i) The concentrations of CO in the effluent stream in parts per million, by volume, and oxygen in volume percent, measured before and after the tune-up of the boiler.
  - (ii) A description of any corrective actions taken as a part of the tune-up of the boiler.
  - (iii) The type and amount of fuel used over the 12 months prior to the biennial tune-up of the boiler.
- (7) If the unit is not operating on the required date for a tune-up, the tune-up must be conducted within one week of startup.

**VII. ADDITIONAL REQUIREMENTS.****# 019 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

Source ID 031 is subject to 40 CFR Part 60, Subpart Dc. The permittee shall comply with all the applicable requirements specified in 40 CFR Sections 60.40c through 60.48c including any recordkeeping and reporting requirements for Source ID 031.

**# 020 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

Source ID 031 consists of a wood-fired boiler (Hurst Boiler and Welding Company, Inc. Model# HYB-4000-300, underfeed stoker-type) with a maximum rated capacity of 28.8 MMBtu/hr. The particulate matter emissions from Source ID 031 shall be controlled by a primary 16-tube multi-clone (ID 031A) collector (Hurst Boiler and Welding Company, Inc. Model# 12K-16T) and a secondary 44-tube multi-clone (ID 031B) collector (Hurst Boiler and Welding Company, Inc. Model# 6-8K-44T) operating in series.

**# 021 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

The permittee shall not operate Source ID 031 without simultaneous operation of IDs 031A and 031B.

**# 022 [40 CFR Part 63 NESHAPS for Source Categories §40 CFR 63.11193]****SUBPART JJJJJJ - National Emission Standards for Hazardous Air Pollutants for Industrial, Commercial, and Institutional Boilers Area Sources****Am I subject to this subpart?**


Source ID 031 is subject to 40 CFR Part 63 Subpart JJJJJJ, National Emission Standards for Hazardous Air Pollutants for Industrial, Commercial, and Institutional Boilers Area Sources, Sections 63.11193 - 63.11237. The permittee shall comply with all applicable requirements of this subpart.

**SECTION D. Source Level Requirements**

Source ID: 032

Source Name: WOOD-FIRED BOILER

Source Capacity/Throughput: 28.800 MMBTU/HR

**I. RESTRICTIONS.****Emission Restriction(s).****# 001 [25 Pa. Code §123.22]****Combustion units**

[Compliance with the requirement specified in this streamlined permit condition assures compliance with the provision in 40 CFR 52.2020(c)]

No person may permit the emission into the outdoor atmosphere of sulfur oxides, expressed as SO<sub>2</sub>, from the exhaust of ID 032B associated with Source ID 032 in excess of the rate of 4 pounds per million Btu of heat input over any 1-hour period.

**# 002 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

[Additional authority for this permit condition is derived from previous operating permit 41-302-040B pursuant to 25 Pa. Code Sections 127.1 and 127.12. Compliance with this permit condition assures compliance with the particulate matter emission limitations specified in 25 Pa. Code Section 123.11]

No person may permit the emission of particulate matter from the exhaust of ID C032B associated with Source ID 032 into the outdoor atmosphere in excess of 0.20 pounds per million Btu of heat input.

**Fuel Restriction(s).****# 003 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

[Additional authority for this permit condition is derived from previous operating permit 41-302-040B pursuant to 25 Pa. Code Sections 127.1 and 127.12.]

Source ID 032 shall be fired on green and kiln-dried wood only. No coated or treated wood, laminated wood, particle board, flake-board or materials other than green and kiln-dried wood shall be burned in this boiler.

**II. TESTING REQUIREMENTS.**

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**III. MONITORING REQUIREMENTS.****# 004 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

[Additional authority for this permit condition is derived from previous operating permit 41-302-040B]

ID C032B shall be equipped with instrumentation to accurately monitor the pressure drop across the collector on a continuous basis.

**# 005 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

[Additional authority for this permit condition is derived from previous operating permit 41-302-040B]

**SECTION D. Source Level Requirements**

(a) The internals of the multi-clone collectors (IDs 032A and 032B) associated with Source ID 032 shall be inspected at least twice each month and shall be cleaned and/or repaired as may be found necessary.

(b) The Department reserves the right to reduce the required inspection frequency if, based upon actual inspection results, it determines such a change is warranted.

**# 006 [25 Pa. Code §127.441]**

**Operating permit terms and conditions.**

Source ID 032 shall be equipped with instrumentation to monitor for the presence of visible emissions from the stack (S032) associated with Source ID 032 on a continuous basis.

**IV. RECORDKEEPING REQUIREMENTS.**

**# 007 [25 Pa. Code §127.441]**

**Operating permit terms and conditions.**

(a) The pressure drop reading from ID 032B shall be recorded at least twice each week.

(b) Records of pressure drop readings shall be retained for a minimum of five (5) years and shall be made available to the Department upon request.

**# 008 [25 Pa. Code §127.441]**

**Operating permit terms and conditions.**

[Additional authority for this permit condition is derived from previous operating permit 41-302-040B]

(a) The permittee shall keep records listing the inspection date for each multi-clone collector inspection as well as the inspection findings and what action, if any, was taken based upon those findings.

(b) These records shall be kept for a minimum of five (5) years and be made available to the Department upon request.

**# 009 [25 Pa. Code §127.441]**

**Operating permit terms and conditions.**

The results of monitoring for the presence of visible emissions of the stack (S032) associated with Source ID 032 shall be recorded at least once each day of operation.

The name of the individual who conducted the inspection for the presence of visible emissions and the results of the inspection shall be retained for a minimum of five (5) years and shall be made available to the Department upon request.

**# 010 [40 CFR Part 60 Standards of Performance for New Stationary Sources §40 CFR 60.48c]**

**Subpart Dc - Standards of Performance for Small Industrial- Commercial-Institutional Steam Generating Units Reporting and recordkeeping requirements.**

(a) The permittee shall keep records of the amount of fuel used in Source ID 032 on a daily basis.

(b) These records shall be kept for a minimum of five (5) years and be made available to the Department upon request.

**# 011 [40 CFR Part 63 NESHAPS for Source Categories §40 CFR 63.11225]**

**SUBPART JJJJJJ - National Emission Standards for Hazardous Air Pollutants for Industrial, Commercial, and Institutional Boilers Area Sources**

**What are my notification, reporting, and recordkeeping requirements?**

(a) You must keep a copy of each notification and report that you submitted to comply with Subpart JJJJJJ and all documentation supporting any Initial Notification or Notification of Compliance Status that you submitted.

(b) You must keep records of the date of tune-up, the procedures followed for tune-up, and the manufacturer's specifications to which the boiler was tuned.



**SECTION D. Source Level Requirements****V. REPORTING REQUIREMENTS.****# 012 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

[Additional authority for this permit condition is derived from previous operating permit 41-302-040B]

Upon request by the Department, the permittee shall provide analyses or samples of the wood fuel used in Source ID 032.

**# 013 [40 CFR Part 60 Standards of Performance for New Stationary Sources §40 CFR 60.4]****Subpart A - General Provisions****Address.**

The submission of all requests, reports, applications, submittals and other communications required by 40 CFR Part 60 Subpart Dc Section 60.40c through 60.48c shall be submitted to both the U.S. Environmental Protection Agency and the Department. The Environmental Protection Agency copies may be sent to:

EPA Region 3, Air and Radiation Division  
Permits Branch (3AD10)  
Four Penn Center, 1600 John F. Kennedy Boulevard  
Philadelphia, PA 19103-2852

and

The Pennsylvania Department of Environmental Protection  
Air Quality Program Manager  
208 W. Third Street, Suite 101  
Williamsport, PA 17701-6448

**VI. WORK PRACTICE REQUIREMENTS.****# 014 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

[Additional authority for this permit condition is derived from previous operating permit 41-302-040B]

The ash collected in the multi-clone collector with ID 032B may, at the company's option, be re-injected into the firebox of Source ID 032 so long as the emissions from the exhaust of ID 032B associated with Source ID 032 do not exceed the emission limitations specified in this permit.

**# 015 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

[Additional authority for this permit condition is derived from previous operating permit 41-302-040B]

The ash removal and storage (or re-injection) systems associated with IDs 032A and 032B shall remain sealed from the open air at all times and shall discharge into completely covered disposal containers.

**# 016 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

The fire-tubes of Source ID 032 shall be cleaned twice each month and the cleaning of the fire-tubes shall not cause emission of any fugitive air contaminants into the outdoor atmosphere.

**# 017 [40 CFR Part 63 NESHAPS for Source Categories §40 CFR 63.11205]****SUBPART JJJJJJ - National Emission Standards for Hazardous Air Pollutants for Industrial, Commercial, and Institutional Boilers Area Sources****What are my general requirements for complying with this subpart?**

At all times you must operate and maintain any affected source, including associated air pollution control equipment and monitoring equipment, in a manner consistent with safety and good air pollution control practices for minimizing emissions.

**# 018 [40 CFR Part 63 NESHAPS for Source Categories §40 CFR 63.11223]****SUBPART JJJJJJ - National Emission Standards for Hazardous Air Pollutants for Industrial, Commercial, and Institutional Boilers Area Sources**

**SECTION D. Source Level Requirements****How do I demonstrate continuous compliance with the work practice and management practice standards?**

You must conduct a tune-up of the boiler biennially to demonstrate continuous compliance as specified in paragraphs (b)(1) through (7) of this section.

- (1) As applicable, inspect the burner, and clean or replace any components of the burner as necessary (you may delay the burner inspection until the next scheduled unit shutdown, but you must inspect each burner at least once every 36 months).
- (2) Inspect the flame pattern, as applicable, and adjust the burner as necessary to optimize the flame pattern. The adjustment should be consistent with the manufacturer's specifications, if available.
- (3) Inspect the system controlling the air-to-fuel ratio, as applicable, and ensure that it is correctly calibrated and functioning properly.
- (4) Optimize total emissions of carbon monoxide. This optimization should be consistent with the manufacturer's specifications, if available.
- (5) Measure the concentrations in the effluent stream of carbon monoxide in parts per million, by volume, and oxygen in volume percent, before and after the adjustments are made (measurements may be either on a dry or wet basis, as long as it is the same basis before and after the adjustments are made).
- (6) Maintain onsite and submit, if requested by the Administrator, biennial report containing the information in paragraphs (b)(6)(i) through (iii) of this section.
  - (i) The concentrations of CO in the effluent stream in parts per million, by volume, and oxygen in volume percent, measured before and after the tune-up of the boiler.
  - (ii) A description of any corrective actions taken as a part of the tune-up of the boiler.
  - (iii) The type and amount of fuel used over the 12 months prior to the biennial tune-up of the boiler.
- (7) If the unit is not operating on the required date for a tune-up, the tune-up must be conducted within one week of startup.

**VII. ADDITIONAL REQUIREMENTS.****# 019 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

Source ID 032 is subject to 40 CFR Part 60, Subpart Dc. The permittee shall comply with all the applicable requirements specified in 40 CFR Sections 60.40c through 60.48c including any recordkeeping and reporting requirements for Source ID 032.

**# 020 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

Source ID 032 consists of a wood-fired boiler (Hurst Boiler and Welding Company, Inc. Model# HYB-4000-300, underfeed stoker-type) with a maximum rated capacity of 28.8 million Btu per hour. The particulate matter emissions from Source ID 032 shall be controlled by a primary 16-tube multi-clone (ID 032A) collector (Hurst Boiler and Welding Company, Inc. Model# 12K-16T) and a secondary 44-tube multi-clone (ID 032B) collector (Hurst Boiler and Welding Company, Inc. Model# 6-8K-44T) operating in series.

**# 021 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

The permittee shall not operate Source ID 032 without simultaneous operation of IDs 032A and 032B.

**# 022 [40 CFR Part 63 NESHAPS for Source Categories §40 CFR 63.11193]****SUBPART JJJJJJ - National Emission Standards for Hazardous Air Pollutants for Industrial, Commercial, and Institutional Boilers Area Sources****Am I subject to this subpart?**


Source ID 032 is subject to 40 CFR Part 63 Subpart JJJJJJ, National Emission Standards for Hazardous Air Pollutants for Industrial, Commercial, and Institutional Boilers Area Sources, Sections 63.11193 - 63.11237. The permittee shall comply with all applicable requirements of this subpart.

**SECTION D. Source Level Requirements**

Source ID: 033

Source Name: NATURAL GAS-FIRED BOILER

Source Capacity/Throughput: 25.200 MMBTU/HR

**I. RESTRICTIONS.****Emission Restriction(s).****# 001 [25 Pa. Code §123.11]****Combustion units**

Pursuant to 25 Pa. Code Section 123.11(a)(1), no person may permit the emission into the outdoor atmosphere of particulate matter from Source ID 033 in excess of 0.4 pounds per million Btu of heat input.

**# 002 [25 Pa. Code §123.22]****Combustion units**

[Compliance with the requirement specified in this streamlined permit condition assures compliance with the provision in 40 CFR 52.2020(c)]

No person may permit the emission into the outdoor atmosphere of sulfur oxides, expressed as SO<sub>2</sub>, from Source ID 033 in excess of the rate of 4 pounds per million Btu of heat input over any 1-hour period.

**Fuel Restriction(s).****# 003 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

[Additional authority for this permit condition is derived from previous operating permit 41-302-040B pursuant to 25 Pa. Code Sections 127.1 and 127.12.]

Source ID 033 shall be fired only on natural gas.

**II. TESTING REQUIREMENTS.**

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**III. MONITORING REQUIREMENTS.**

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**IV. RECORDKEEPING REQUIREMENTS.****# 004 [40 CFR Part 60 Standards of Performance for New Stationary Sources §40 CFR 60.48c]****Subpart Dc - Standards of Performance for Small Industrial- Commercial-Institutional Steam Generating Units Reporting and recordkeeping requirements.**

(a) The permittee shall keep records of the amount of fuel used in Source ID 033 on a daily basis.

(b) These records shall be kept for a minimum of five (5) years and be made available to the Department upon request.

**SECTION D. Source Level Requirements****V. REPORTING REQUIREMENTS.****# 005 [40 CFR Part 60 Standards of Performance for New Stationary Sources §40 CFR 60.4]****Subpart A - General Provisions****Address.**

The submission of all requests, reports, applications, submittals and other communications required by 40 CFR Part 60 Subpart Dc Section 60.40c through 60.48c shall be submitted to both the U.S. Environmental Protection Agency and the Department. The Environmental Protection Agency copies may be sent to:

EPA Region 3, Air and Radiation Division  
Permits Branch (3AD10)  
Four Penn Center, 1600 John F. Kennedy Boulevard  
Philadelphia, PA 19103-2852

and

The Pennsylvania Department of Environmental Protection  
Air Quality Program Manager  
208 W. Third Street, Suite 101  
Williamsport, PA 17701-6448

**VI. WORK PRACTICE REQUIREMENTS.**

No additional work practice requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**VII. ADDITIONAL REQUIREMENTS.****# 006 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

Source ID 033 is subject to 40 CFR Part 60, Subpart Dc. The permittee shall comply with all the applicable requirements specified in 40 CFR Sections 60.40c through 60.48c including any recordkeeping and reporting requirements for Source ID 033.

**# 007 [25 Pa. Code §127.441]****Operating permit terms and conditions.**


Source ID 033 consists of a natural gas-fired boiler (Industrial Combustion Model# 600-3 including an Industrial Combustion Model# DG-252P burner unit) with a maximum rated capacity of 25.2 million Btu per hour.

**SECTION D. Source Level Requirements**

Source ID: P101

Source Name: FLITCH MILLING &amp; VENEER CLIPPING OPERATION

Source Capacity/Throughput:

**I. RESTRICTIONS.****Emission Restriction(s).****# 001 [25 Pa. Code §123.11]****Combustion units**

Pursuant to 25 Pa. Code Section 123.13(c)(1)(i), no person may permit the emission into the outdoor atmosphere of particulate matter from the exhaust of IDs C101A and C101B associated with Source ID P101 in a manner that the concentration of particulate matter in the effluent gas exceeds 0.04 grain per dry standard cubic foot.

**II. TESTING REQUIREMENTS.**

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**III. MONITORING REQUIREMENTS.****# 002 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

Each fabric collector (IDs C101A and C101B) associated with Source ID P101 shall be equipped with instrumentation to accurately monitor the pressure drop across each fabric collector.

**IV. RECORDKEEPING REQUIREMENTS.****# 003 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

The pressure drop readings from each fabric collector (IDs C101A and C101B) shall be recorded at least once per week.

Records of pressure drop readings shall be retained for a minimum of five (5) years and shall be made available to the Department upon request.

**V. REPORTING REQUIREMENTS.**

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**VI. WORK PRACTICE REQUIREMENTS.****# 004 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

The permittee shall keep on hand a sufficient quantity of spare fabric collector bags for each fabric collector (IDs C101A and C101B) associated with Source ID P101 in order to be able to immediately replace any bags requiring replacement due to deterioration resulting from routine operation of Source ID P101 and fabric collectors (IDs C101A and C101B).

**VII. ADDITIONAL REQUIREMENTS.****# 005 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

**SECTION D. Source Level Requirements**

Source ID P101 consists of the following flitch mill and veneer clipping operation equipment;

One (1) Precision chipper,  
One (1) Cremona flitch planar,  
One (1) Cremona flitch cleaner,  
Three (3) Sanborn split saws,  
Two (2) Cremona side clippers,  
Two (2) Cremona end clippers,  
One (1) Zeno Gmbh wood hog


The particulate emissions from Source ID P101 shall be controlled by a Scientific Dust Collectors Model# SPJ-289-4T81 (ID C101A) fabric collector and an Imperial Systems Model# 378BRF12 (ID C101B) fabric collector that are both exhausted outdoors. IDs C101A and C101B are used in parallel with one another in order to interchange operation when one hopper reaches maximum capacity.

**SECTION D. Source Level Requirements**

Source ID: P102

Source Name: PARTS WASHER

Source Capacity/Throughput:

**I. RESTRICTIONS.****Emission Restriction(s).**

# 001 [25 Pa. Code §127.441]

**Operating permit terms and conditions.**

The volatile organic compound (VOC) emissions from Source ID P102 shall not exceed 2.7 tons in any 12 consecutive month period.

**II. TESTING REQUIREMENTS.**

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**III. MONITORING REQUIREMENTS.**

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**IV. RECORDKEEPING REQUIREMENTS.**

# 002 [25 Pa. Code §127.441]

**Operating permit terms and conditions.**

The permittee shall keep records of the supporting calculations used to determine VOC emissions in any 12 consecutive month period from Source ID P102.

**V. REPORTING REQUIREMENTS.**

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**VI. WORK PRACTICE REQUIREMENTS.**

No additional work practice requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**VII. ADDITIONAL REQUIREMENTS.**

# 003 [25 Pa. Code §127.441]

**Operating permit terms and conditions.**


Source ID P102 consists of one (1) degreasing unit (ARMAKLEEN Model# 30300) having a capacity of 30 gallons and tub volume equal to 3.6 cubic foot (26.9 gallons). The solvent used in the parts washer is named ARMAKLEENTM MPC Cleaning Solution and has a VOC content equal to 0.0 pound per gallon.

**SECTION D. Source Level Requirements**

Source ID: P103

Source Name: NATURAL GAS FIRED EMERGENCY GENERATORS

Source Capacity/Throughput:

**I. RESTRICTIONS.****Emission Restriction(s).**

# 001 [25 Pa. Code §123.13]

**Processes**

The permittee shall not emit into the outdoor atmosphere of particulate matter, from Source ID P103, in a manner that the concentration of particulate matter in the effluent gas exceeds 0.04 grains per dry standard cubic foot.

# 002 [25 Pa. Code §123.21]

**General**

No person may permit the emission into the outdoor atmosphere of sulfur oxides, expressed as SO<sub>2</sub>, from Source ID P103 in a manner that the concentration of the sulfur oxides in the effluent gas exceeds 500 parts per million, by volume, dry basis.

**II. TESTING REQUIREMENTS.**

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**III. MONITORING REQUIREMENTS.**

# 003 [40 CFR Part 63 NESHAPS for Source Categories §40 CFR 63.6625]

**Subpart ZZZZ - National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines****What are my monitoring, installation, operation, and maintenance requirements?**

Each engine of Source ID P103 shall have a non-resettable hour meter installed.

**IV. RECORDKEEPING REQUIREMENTS.**

# 004 [25 Pa. Code §127.441]

**Operating permit terms and conditions.**

(a) The permittee shall maintain comprehensive accurate records of the number of hours each emergency generator set incorporated in Source P103 is operated each month.

(b) All records generated pursuant to this condition shall be retained for a minimum of 5 years and shall be made available to the Department upon request.

# 005 [40 CFR Part 63 NESHAPS for Source Categories §40 CFR 63.6655]

**Subpart ZZZZ - National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines****What records must I keep?**

You must keep records of the maintenance conducted on each stationary RICE in order to demonstrate that you operated and maintained the stationary RICE.

**V. REPORTING REQUIREMENTS.**

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).



**SECTION D. Source Level Requirements****VI. WORK PRACTICE REQUIREMENTS.****# 006 [40 CFR Part 63 NESHAPS for Source Categories §40 CFR 63.6625]****Subpart ZZZZ - National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines****What are my monitoring, installation, operation, and maintenance requirements?**

Each generator of Source ID P103 shall comply with the following:

- a. Change oil and filter every 500 hours of operation or annually, whichever comes first;
- b. Inspect air cleaner every 1,000 hours of operation or annually, whichever comes first; and
- c. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary.

**VII. ADDITIONAL REQUIREMENTS.****# 007 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

Source P103 consists of two (2) natural gas-fired emergency generator sets:

One (1) 22 Bhp Kohler Model# 10RM62

One (1) 67 Bhp Generac Model# 4143180100

**# 008 [40 CFR Part 63 NESHAPS for Source Categories §40 CFR 63.6585]****Subpart ZZZZ - National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines****Am I subject to this subpart?**


Source ID P103 is subject to the requirements of 40 CFR Part 63 Subpart ZZZZ, National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines, Sections 63.6580 - 63.6675. The permittee shall comply with all applicable requirements of this subpart.

**SECTION D. Source Level Requirements**

Source ID: P104

Source Name: 1000 GALLON GASOLINE UNDERGROUND TANK

Source Capacity/Throughput:

**I. RESTRICTIONS.**

No additional requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**II. TESTING REQUIREMENTS.**

No additional testing requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**III. MONITORING REQUIREMENTS.**

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**IV. RECORDKEEPING REQUIREMENTS.****# 001 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

[Additional authority for this permit condition is also derived from 40 CFR Section 63.11111(e)]

(a) The permittee shall keep records of the monthly gasoline throughput for Source ID P104.

(b) All records generated pursuant to this condition shall be retained for a minimum of five years and shall be made available to the Department upon request.

**V. REPORTING REQUIREMENTS.**

No additional reporting requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**VI. WORK PRACTICE REQUIREMENTS.**

No additional work practice requirements exist except as provided in other sections of this permit including Section B (State Only General Requirements).

**VII. ADDITIONAL REQUIREMENTS.****# 002 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

Source ID P104 is 1,000 gallons gasoline underground storage tank.

**# 003 [40 CFR Part 63 NESHAPS for Source Categories §40 CFR 63.11111]****Subpart CCCCCC - National Emission Standards for Hazardous Air Pollutants for Gasoline Dispensing Facilities  
Am I subject to the requirements in this subpart?**

Source ID P104 is subject to 40 CFR Part 63, Subpart CCCCCC, §§ 63.1110 – 63.11132, National Emissions Standards for Hazardous Air Pollutants for Gasoline Dispensing Facilities. The permittee shall comply with all applicable requirements of

**SECTION D. Source Level Requirements**

40 CFR Part 63, Subpart CCCCCC.



**SECTION E. Source Group Restrictions.**



## SECTION F. Alternative Operation Requirements.

No Alternative Operations exist for this State Only facility.

**SECTION G. Emission Restriction Summary.**

No emission restrictions listed in this section of the permit.

**SECTION H. Miscellaneous.**

The following air contaminant source is considered to be of minor significance to the Department and have been determined to be exempt from permit requirements. However, this determination does not exempt the source from compliance with all the applicable air quality regulations specified in 25 Pa. Code Chapters 121 through 145:

1. Green hardwood sent through six (6) drying ovens.



\*\*\*\*\* End of Report \*\*\*\*\*

---