



COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
AIR QUALITY PROGRAM

TITLE V/STATE OPERATING PERMIT

Issue Date: July 22, 2026

Effective Date: March 1, 2027

Expiration Date: February 29, 2032

In accordance with the provisions of the Air Pollution Control Act, the Act of January 8, 1960, P.L. 2119, as amended, and 25 Pa. Code Chapter 127, the Owner, [and Operator if noted] (hereinafter referred to as permittee) identified below is authorized by the Department of Environmental Protection (Department) to operate the air emission source(s) more fully described in this permit. This Facility is subject to all terms and conditions specified in this permit. Nothing in this permit relieves the permittee from its obligations to comply with all applicable Federal, State and Local laws and regulations.

The regulatory or statutory authority for each permit condition is set forth in brackets. All terms and conditions in this permit are federally enforceable applicable requirements unless otherwise designated as "State-Only" or "non-applicable" requirements.

TITLE V Permit No: 21-05002

Federal Tax Id - Plant Code: 81-3489093-6

Owner Information

Name: VITRO FLAT GLASS LLC
Mailing Address: 400 PARK DR
CARLISLE, PA 17015-9271

Plant Information

Plant: VITRO FLAT GLASS LLC/CARLISLE
Location: 21 Cumberland County 21926 South Middleton Township
SIC Code: 3211 Manufacturing - Flat Glass

Responsible Official

Name: DAVID SAMELLA
Title: PLANT MANAGER
Phone: (717) 486 - 3366 Ext.110 Email:

Permit Contact Person

Name: AMY HACKER
Title: ENVIRONMENTAL ENGINEER
Phone: (717) 486 - 0150 Email: AHACKER@vitro.com

[Signature] _____
WILLIAM R. WEAVER, SOUTHCENTRAL REGION AIR PROGRAM MANAGER



SECTION A. Table of Contents

Section A. Facility/Source Identification

Table of Contents
Site Inventory List

Section B. General Title V Requirements

- #001 Definitions
- #002 Prohibition of Air Pollution
- #003 Property Rights
- #004 Permit Expiration
- #005 Permit Renewal
- #006 Transfer of Ownership or Operational Control
- #007 Inspection and Entry
- #008 Compliance Requirements
- #009 Need to Halt or Reduce Activity Not a Defense
- #010 Duty to Provide Information
- #011 Reopening and Revising the Title V Permit for Cause
- #012 Reopening a Title V Permit for Cause by EPA
- #013 Operating Permit Application Review by the EPA
- #014 Significant Operating Permit Modifications
- #015 Minor Operating Permit Modifications
- #016 Administrative Operating Permit Amendments
- #017 Severability Clause
- #018 Fee Payment
- #019 Authorization for De Minimis Emission Increases
- #020 Reactivation of Sources
- #021 Circumvention
- #022 Submissions
- #023 Sampling, Testing and Monitoring Procedures
- #024 Compliance Certification
- #025 Recordkeeping Requirements
- #026 Reporting Requirements
- #027 Operational Flexibility
- #028 Risk Management
- #029 Approved Economic Incentives and Emission Trading Programs
- #030 Permit Shield
- #031 Reporting
- #032 Report Format

Section C. Site Level Title V Requirements

- C-I: Restrictions
- C-II: Testing Requirements
- C-III: Monitoring Requirements
- C-IV: Recordkeeping Requirements
- C-V: Reporting Requirements
- C-VI: Work Practice Standards
- C-VII: Additional Requirements
- C-VIII: Compliance Certification
- C-IX: Compliance Schedule

Section D. Source Level Title V Requirements

- D-I: Restrictions
- D-II: Testing Requirements
- D-III: Monitoring Requirements
- D-IV: Recordkeeping Requirements
- D-V: Reporting Requirements



SECTION A. Table of Contents

D-VI: Work Practice Standards
D-VII: Additional Requirements

Note: These same sub-sections are repeated for each source!

Section E. Source Group Restrictions

E-I: Restrictions
E-II: Testing Requirements
E-III: Monitoring Requirements
E-IV: Recordkeeping Requirements
E-V: Reporting Requirements
E-VI: Work Practice Standards
E-VII: Additional Requirements

Section F. Alternative Operating Scenario(s)

F-I: Restrictions
F-II: Testing Requirements
F-III: Monitoring Requirements
F-IV: Recordkeeping Requirements
F-V: Reporting Requirements
F-VI: Work Practice Standards
F-VII: Additional Requirements

Section G. Emission Restriction Summary


Section H. Miscellaneous

**SECTION A. Site Inventory List**

Source ID	Source Name	Capacity/Throughput		Fuel/Material
031	ORR & SEMBOWER BOILER 1	25.100	MMBTU/HR	
		167.000	Gal/HR	#2 Oil
		25.000	MCF/HR	NATURAL GAS
101	GLASS MELTING FURNACE 1	29.200	Tons/HR	FLAT GLASS
		1,500.000	Gal/HR	#2 OIL
		215.000	MCF/HR	NATURAL GAS
102	GLASS MELTING FURNACE 2	29.200	Tons/HR	FLAT GLASS
		1,500.000	Gal/HR	#2 Oil
		215.000	MCF/HR	NATURAL GAS
103	CULLET SYSTEM-STORAGE	58.100	Tons/HR	BROKEN GLASS
106	BATCH MIXING	100.000	Tons/HR	MIXED BATCH
107	BATCH GALLERY CONVEYORS	100.000	Tons/HR	RAW BATCH MIX
108	BATCH MATERIAL UNLOADING	400.000	Tons/HR	RAW MATERIALS
110	#2 CULLET/BATCH FEED	36.000	Tons/HR	CULLET
111	#1 CULLET/BATCH FEED	36.000	Tons/HR	CULLET
114A	EMER GENERATOR LINE 2, UNIT A (EAST)(1500 KW)	16.000	MMBTU/HR	
		115.400	Gal/HR	Diesel Fuel
114B	EMER GENERATOR LINE 2, UNIT B (WEST)(1500KW)	16.000	MMBTU/HR	
		115.400	Gal/HR	Diesel Fuel
114C	DETROIT DIESEL 9163-7301 EMER GENERATOR LINE 1 (2000 KW)	19.370	MMBTU/HR	
		141.000	Gal/HR	Diesel Fuel
114E	EMER FLOOD PUMP (SMALL)	2.000	MMBTU/HR	
		10.000	Gal/HR	Diesel Fuel
114F	EMER FLOOD PUMP (LARGE)	8.000	MMBTU/HR	
		60.000	Gal/HR	Diesel Fuel
114H	EMER FIRE PUMP (WEST)	2.000	MMBTU/HR	
		10.000	Gal/HR	Diesel Fuel
114I	EMER FIRE PUMP (EAST)	2.000	MMBTU/HR	
		10.000	Gal/HR	Diesel Fuel
115	TPO SYSTEM COATER	86.000	Lbs/HR	TPO SOLUTION
116	GLASS CUTTING	2.200	Lbs/HR	VOC
201	DEGREASERS	1.000	Lbs/HR	VOC
301	SURFACE PASSIVATION AREA 1	31.000	Lbs/HR	S02 SOLUTION
302	SURFACE PASSIVATION AREA 2	31.000	Lbs/HR	S02 SOLUTION
C03	MIKRO-PUL BAGHOUSE - CULLET SHED			
C07A	UAS CARTRIDGE FILTER - GALLERY			
C08	8 MIKRO-PUL BAGHOUSES - TRAIN SHED			
C10	LINE 2 FEED END DUST COLLECTOR			
C101	SNCR SYSTEM			
C102A	ELECTROSTATIC PRECIPITATOR			
C102B	SCR SYSTEM			








**SECTION A. Site Inventory List**

Source ID	Source Name	Capacity/Throughput	Fuel/Material
C11	MIKROPUL BAGHOUSE - LINE 1 FEED END		
C115	TPO SYSTEM SCRUBBER		
FM01	DIESEL SUPPLY		
FM03	#2 OIL SUPPLY - FURNACES		
FM25	NATURAL GAS LINE		
S02	FURNACE 2 STACK		
S03	C03 BAGHOUSE STACK		
S07A	C07A CARTRIDGE FILTER STACK		
S08	C08 BAGHOUSES STACK		
S10	C10 BAGHOUSE STACK		
S101	SNCR SYSTEM EXHAUST		
S102B	SCR SYSTEM EXHAUST		
S11	C11 BAGHOUSE STACK		
S115	TPO SCRUBBER EXHAUST		
S14A	GENERATOR STACK - LINE 2, UNIT A (EAST)		
S14B	GENERATOR STACK - LINE 2, UNIT B WEST		
S14C	GENERATOR STACK - LINE 1		
S14D	GENERATOR STACK - LINE 1		
S22	BOILER 1 STACK		
S31A	SO2 APP. STACK A		
S31B	SO2 APP. STACK B		
S32A	SO2 APP. STACK A		
S32B	SO2 APP. STACK B		
Z01	EMER EQUIP EXHAUST		
Z116	GLASS CUTTING VOC EMISSIONS		
Z201	DEGREASER EMISSIONS		

PERMIT MAPS











PERMIT MAPS





PERMIT MAPS



**SECTION B. General Title V Requirements****#001 [25 Pa. Code § 121.1]****Definitions**

Words and terms that are not otherwise defined in this permit shall have the meanings set forth in Section 3 of the Air Pollution Control Act (35 P.S. § 4003) and 25 Pa. Code § 121.1.

#002 [25 Pa. Code § 121.7]**Prohibition of Air Pollution**

No person may permit air pollution as that term is defined in the Air Pollution Control Act (35 P.S. §§ 4001-4015).

#003 [25 Pa. Code § 127.512(c)(4)]**Property Rights**

This permit does not convey property rights of any sort, or any exclusive privileges.

#004 [25 Pa. Code § 127.446(a) and (c)]**Permit Expiration**

This operating permit is issued for a fixed term of five (5) years and shall expire on the date specified on Page 1 of this permit. The terms and conditions of the expired permit shall automatically continue pending issuance of a new Title V permit, provided the permittee has submitted a timely and complete application and paid applicable fees required under 25 Pa. Code Chapter 127, Subchapter I and the Department is unable, through no fault of the permittee, to issue or deny a new permit before the expiration of the previous permit. An application is complete if it contains sufficient information to begin processing the application, has the applicable sections completed and has been signed by a responsible official.

#005 [25 Pa. Code §§ 127.412, 127.413, 127.414, 127.446(e), 127.503 & 127.704(b)]**Permit Renewal**

(a) An application for the renewal of the Title V permit shall be submitted to the Department at least six (6) months, and not more than 18 months, before the expiration date of this permit. The renewal application is timely if a complete application is submitted to the Department's Regional Air Manager within the timeframe specified in this permit condition.

(b) The application for permit renewal shall include the current permit number, the appropriate permit renewal fee, a description of any permit revisions and off-permit changes that occurred during the permit term, and any applicable requirements that were promulgated and not incorporated into the permit during the permit term. The fees shall be made payable to "The Commonwealth of Pennsylvania Clean Air Fund" and submitted with the fee form to the respective regional office.

(c) The renewal application shall also include submission of proof that the local municipality and county, in which the facility is located, have been notified in accordance with 25 Pa. Code § 127.413. The application for renewal of the Title V permit shall also include submission of compliance review forms which have been used by the permittee to update information submitted in accordance with either 25 Pa. Code § 127.412(b) or § 127.412(j).

(d) The permittee, upon becoming aware that any relevant facts were omitted or incorrect information was submitted in the permit application, shall promptly submit such supplementary facts or corrected information during the permit renewal process. The permittee shall also promptly provide additional information as necessary to address any requirements that become applicable to the source after the date a complete renewal application was submitted but prior to release of a draft permit.

#006 [25 Pa. Code §§ 127.450(a)(4) & 127.464(a)]**Transfer of Ownership or Operational Control**

(a) In accordance with 25 Pa. Code § 127.450(a)(4), a change in ownership or operational control of the source shall be treated as an administrative amendment if:

(1) The Department determines that no other change in the permit is necessary;

(2) A written agreement has been submitted to the Department identifying the specific date of the transfer of permit

**SECTION B. General Title V Requirements**

responsibility, coverage and liability between the current and the new permittee; and,

(3) A compliance review form has been submitted to the Department and the permit transfer has been approved by the Department.

(b) In accordance with 25 Pa. Code § 127.464(a), this permit may not be transferred to another person except in cases of transfer-of-ownership which are documented and approved to the satisfaction of the Department.

#007 [25 Pa. Code § 127.513, 35 P.S. § 4008 and § 114 of the CAA]**Inspection and Entry**

(a) Upon presentation of credentials and other documents as may be required by law for inspection and entry purposes, the permittee shall allow the Department of Environmental Protection or authorized representatives of the Department to perform the following:

(1) Enter at reasonable times upon the permittee's premises where a Title V source is located or emissions related activity is conducted, or where records are kept under the conditions of this permit;

(2) Have access to and copy or remove, at reasonable times, records that are kept under the conditions of this permit;

(3) Inspect at reasonable times, facilities, equipment including monitoring and air pollution control equipment, practices, or operations regulated or required under this permit;

(4) Sample or monitor, at reasonable times, substances or parameters, for the purpose of assuring compliance with the permit or applicable requirements as authorized by the Clean Air Act, the Air Pollution Control Act, or the regulations promulgated under the Acts.

(b) Pursuant to 35 P.S. § 4008, no person shall hinder, obstruct, prevent or interfere with the Department or its personnel in the performance of any duty authorized under the Air Pollution Control Act.

(c) Nothing in this permit condition shall limit the ability of the EPA to inspect or enter the premises of the permittee in accordance with Section 114 or other applicable provisions of the Clean Air Act.

#008 [25 Pa. Code §§ 127.25, 127.444, & 127.512(c)(1)]**Compliance Requirements**

(a) The permittee shall comply with the conditions of this permit. Noncompliance with this permit constitutes a violation of the Clean Air Act and the Air Pollution Control Act and is grounds for one (1) or more of the following:

(1) Enforcement action

(2) Permit termination, revocation and reissuance or modification

(3) Denial of a permit renewal application

(b) A person may not cause or permit the operation of a source, which is subject to 25 Pa. Code Article III, unless the source(s) and air cleaning devices identified in the application for the plan approval and operating permit and the plan approval issued to the source are operated and maintained in accordance with specifications in the applications and the conditions in the plan approval and operating permit issued by the Department. A person may not cause or permit the operation of an air contamination source subject to 25 Pa. Code Chapter 127 in a manner inconsistent with good operating practices.

(c) For purposes of Sub-condition (b) of this permit condition, the specifications in applications for plan approvals and operating permits are the physical configurations and engineering design details which the Department determines are essential for the permittee's compliance with the applicable requirements in this Title V permit.

**SECTION B. General Title V Requirements****#009 [25 Pa. Code § 127.512(c)(2)]****Need to Halt or Reduce Activity Not a Defense**

It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit.

#010 [25 Pa. Code §§ 127.411(d) & 127.512(c)(5)]**Duty to Provide Information**

(a) The permittee shall furnish to the Department, within a reasonable time, information that the Department may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit, or to determine compliance with the permit.

(b) Upon request, the permittee shall also furnish to the Department copies of records that the permittee is required to keep by this permit, or for information claimed to be confidential, the permittee may furnish such records directly to the Administrator of EPA along with a claim of confidentiality.

#011 [25 Pa. Code §§ 127.463, 127.512(c)(3) & 127.542]**Reopening and Revising the Title V Permit for Cause**

(a) This Title V permit may be modified, revoked, reopened and reissued or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay a permit condition.

(b) This permit may be reopened, revised and reissued prior to expiration of the permit under one or more of the following circumstances:

(1) Additional applicable requirements under the Clean Air Act or the Air Pollution Control Act become applicable to a Title V facility with a remaining permit term of three (3) or more years prior to the expiration date of this permit. The Department will revise the permit as expeditiously as practicable but not later than 18 months after promulgation of the applicable standards or regulations. No such revision is required if the effective date of the requirement is later than the expiration date of this permit, unless the original permit or its terms and conditions has been extended.

(2) Additional requirements, including excess emissions requirements, become applicable to an affected source under the acid rain program. Upon approval by the Administrator of EPA, excess emissions offset plans for an affected source shall be incorporated into the permit.

(3) The Department or the EPA determines that this permit contains a material mistake or inaccurate statements were made in establishing the emissions standards or other terms or conditions of this permit.

(4) The Department or the Administrator of EPA determines that the permit must be revised or revoked to assure compliance with the applicable requirements.

(c) Proceedings to revise this permit shall follow the same procedures which apply to initial permit issuance and shall affect only those parts of this permit for which cause to revise exists. The revision shall be made as expeditiously as practicable.

(d) Regardless of whether a revision is made in accordance with (b)(1) above, the permittee shall meet the applicable standards or regulations promulgated under the Clean Air Act within the time frame required by standards or regulations.

#012 [25 Pa. Code § 127.543]**Reopening a Title V Permit for Cause by EPA**

As required by the Clean Air Act and regulations adopted thereunder, this permit may be modified, reopened and reissued, revoked or terminated for cause by EPA in accordance with procedures specified in 25 Pa. Code § 127.543.

**SECTION B. General Title V Requirements****#013 [25 Pa. Code § 127.522(a)]****Operating Permit Application Review by the EPA**

The applicant may be required by the Department to provide a copy of the permit application, including the compliance plan, directly to the Administrator of the EPA. Copies of title V permit applications to EPA, pursuant to 25 PA Code §127.522(a), shall be submitted, if required, to the following EPA e-mail box:

R3_Air_Apps_and_Notices@epa.gov

Please place the following in the subject line: TV [permit number], [Facility Name].

#014 [25 Pa. Code § 127.541]**Significant Operating Permit Modifications**

When permit modifications during the term of this permit do not qualify as minor permit modifications or administrative amendments, the permittee shall submit an application for significant Title V permit modifications in accordance with 25 Pa. Code § 127.541. Notifications to EPA, pursuant to 25 PA Code §127.522(a), if required, shall be submitted, to the following EPA e-mail box:

R3_Air_Apps_and_Notices@epa.gov

Please place the following in the subject line: TV [permit number], [Facility Name].

#015 [25 Pa. Code §§ 121.1 & 127.462]**Minor Operating Permit Modifications**

The permittee may make minor operating permit modifications (as defined in 25 Pa. Code §121.1), on an expedited basis, in accordance with 25 Pa. Code §127.462 (relating to minor operating permit modifications). Notifications to EPA, pursuant to 25 PA Code §127.462(c), if required, shall be submitted, to the following EPA e-mail box:

R3_Air_Apps_and_Notices@epa.gov

Please place the following in the subject line: TV [permit number], [Facility Name].

#016 [25 Pa. Code § 127.450]**Administrative Operating Permit Amendments**

(a) The permittee may request administrative operating permit amendments, as defined in 25 Pa. Code §127.450(a). Copies of request for administrative permit amendment to EPA, pursuant to 25 PA Code §127.450(c)(1), if required, shall be submitted to the following EPA e-mail box:

R3_Air_Apps_and_Notices@epa.gov

Please place the following in the subject line: TV [permit number], [Facility Name].

(b) Upon final action by the Department granting a request for an administrative operating permit amendment covered under §127.450(a)(5), the permit shield provisions in 25 Pa. Code § 127.516 (relating to permit shield) shall apply to administrative permit amendments incorporated in this Title V Permit in accordance with §127.450(c), unless precluded by the Clean Air Act or the regulations thereunder.

#017 [25 Pa. Code § 127.512(b)]**Severability Clause**

The provisions of this permit are severable, and if any provision of this permit is determined by the Environmental Hearing Board or a court of competent jurisdiction, or US EPA to be invalid or unenforceable, such a determination will not affect the remaining provisions of this permit.

**SECTION B. General Title V Requirements****#018 [25 Pa. Code §§ 127.704, 127.705 & 127.707]****Fee Payment**

- (a) The permittee shall pay fees to the Department in accordance with the applicable fee schedules in 25 Pa. Code Chapter 127, Subchapter I (relating to plan approval and operating permit fees). The applicable fees shall be made payable to "The Commonwealth of Pennsylvania Clean Air Fund" with the permit number clearly indicated and submitted to the respective regional office.
- (b) Emission Fees. The permittee shall, on or before September 1st of each year, pay applicable annual Title V emission fees for emissions occurring in the previous calendar year as specified in 25 Pa. Code § 127.705. The permittee is not required to pay an emission fee for emissions of more than 4,000 tons of each regulated pollutant emitted from the facility.
- (c) As used in this permit condition, the term "regulated pollutant" is defined as a VOC, each pollutant regulated under Sections 111 and 112 of the Clean Air Act and each pollutant for which a National Ambient Air Quality Standard has been promulgated, except that carbon monoxide is excluded.
- (d) Late Payment. Late payment of emission fees will subject the permittee to the penalties prescribed in 25 Pa. Code § 127.707 and may result in the suspension or termination of the Title V permit. The permittee shall pay a penalty of fifty percent (50%) of the fee amount, plus interest on the fee amount computed in accordance with 26 U.S.C.A. § 6621(a)(2) from the date the emission fee should have been paid in accordance with the time frame specified in 25 Pa. Code § 127.705(c).
- (e) The permittee shall pay an annual operating permit maintenance fee according to the following fee schedule established in 25 Pa. Code § 127.704(d) on or before December 31 of each year for the next calendar year.
- (1) Eight thousand dollars (\$8,000) for calendar years 2021—2025.
 - (2) Ten thousand dollars (\$10,000) for calendar years 2026—2030.
 - (3) Twelve thousand five hundred dollars (\$12,500) for the calendar years beginning with 2031.

#019 [25 Pa. Code §§ 127.14(b) & 127.449]**Authorization for De Minimis Emission Increases**

- (a) This permit authorizes de minimis emission increases from a new or existing source in accordance with 25 Pa. Code §§ 127.14 and 127.449 without the need for a plan approval or prior issuance of a permit modification. The permittee shall provide the Department with seven (7) days prior written notice before commencing any de minimis emissions increase that would result from either: (1) a physical change of minor significance under § 127.14(c)(1); or (2) the construction, installation, modification or reactivation of an air contamination source. The written notice shall:

- (1) Identify and describe the pollutants that will be emitted as a result of the de minimis emissions increase.
- (2) Provide emission rates expressed in tons per year and in terms necessary to establish compliance consistent with any applicable requirement.

The Department may disapprove or condition de minimis emission increases at any time.

- (b) Except as provided below in (c) and (d) of this permit condition, the permittee is authorized during the term of this permit to make de minimis emission increases (expressed in tons per year) up to the following amounts without the need for a plan approval or prior issuance of a permit modification:

- (1) Four tons of carbon monoxide from a single source during the term of the permit and 20 tons of carbon monoxide at the facility during the term of the permit.
- (2) One ton of NO_x from a single source during the term of the permit and 5 tons of NO_x at the facility during the term of the permit.
- (3) One and six-tenths tons of the oxides of sulfur from a single source during the term of the permit and 8.0 tons of

**SECTION B. General Title V Requirements**

oxides of sulfur at the facility during the term of the permit.

(4) Six-tenths of a ton of PM₁₀ from a single source during the term of the permit and 3.0 tons of PM₁₀ at the facility during the term of the permit. This shall include emissions of a pollutant regulated under Section 112 of the Clean Air Act unless precluded by the Clean Air Act or 25 Pa. Code Article III.

(5) One ton of VOCs from a single source during the term of the permit and 5.0 tons of VOCs at the facility during the term of the permit. This shall include emissions of a pollutant regulated under Section 112 of the Clean Air Act unless precluded by the Clean Air Act or 25 Pa. Code Article III.

(c) In accordance with § 127.14, the permittee may install the following minor sources without the need for a plan approval:

(1) Air conditioning or ventilation systems not designed to remove pollutants generated or released from other sources.

(2) Combustion units rated at 2,500,000 or less Btu per hour of heat input.

(3) Combustion units with a rated capacity of less than 10,000,000 Btu per hour heat input fueled by natural gas supplied by a public utility, liquefied petroleum gas or by commercial fuel oils which are No. 2 or lighter, viscosity less than or equal to 5.82 c St, and which meet the sulfur content requirements of 25 Pa. Code § 123.22 (relating to combustion units). For purposes of this permit, commercial fuel oil shall be virgin oil which has no reprocessed, recycled or waste material added.

(4) Space heaters which heat by direct heat transfer.

(5) Laboratory equipment used exclusively for chemical or physical analysis.

(6) Other sources and classes of sources determined to be of minor significance by the Department.

(d) This permit does not authorize de minimis emission increases if the emissions increase would cause one or more of the following:

(1) Increase the emissions of a pollutant regulated under Section 112 of the Clean Air Act except as authorized in Subparagraphs (b)(4) and (5) of this permit condition.

(2) Subject the facility to the prevention of significant deterioration requirements in 25 Pa. Code Chapter 127, Subchapter D and/or the new source review requirements in Subchapter E.

(3) Violate any applicable requirement of the Air Pollution Control Act, the Clean Air Act, or the regulations promulgated under either of the acts.

(4) Changes which are modifications under any provision of Title I of the Clean Air Act and emission increases which would exceed the allowable emissions level (expressed as a rate of emissions or in terms of total emissions) under the Title V permit.

(e) Unless precluded by the Clean Air Act or the regulations thereunder, the permit shield described in 25 Pa. Code § 127.516 (relating to permit shield) shall extend to the changes made under 25 Pa. Code § 127.449 (relating to de minimis emission increases).

(f) Emissions authorized under this permit condition shall be included in the monitoring, recordkeeping and reporting requirements of this permit.

(g) Except for de minimis emission increases allowed under this permit, 25 Pa. Code § 127.449, or sources and physical changes meeting the requirements of 25 Pa. Code § 127.14, the permittee is prohibited from making physical changes or engaging in activities that are not specifically authorized under this permit without first applying for a plan approval. In accordance with § 127.14(b), a plan approval is not required for the construction, modification, reactivation, or installation of the sources creating the de minimis emissions increase.

**SECTION B. General Title V Requirements**

(h) The permittee may not meet de minimis emission threshold levels by offsetting emission increases or decreases at the same source.

#020 [25 Pa. Code §§ 127.11a & 127.215]**Reactivation of Sources**

(a) The permittee may reactivate a source at the facility that has been out of operation or production for at least one year, but less than or equal to five (5) years, if the source is reactivated in accordance with the requirements of 25 Pa. Code §§ 127.11a and 127.215. The reactivated source will not be considered a new source.

(b) A source which has been out of operation or production for more than five (5) years but less than 10 years may be reactivated and will not be considered a new source if the permittee satisfies the conditions specified in 25 Pa. Code § 127.11a(b).

#021 [25 Pa. Code §§ 121.9 & 127.216]**Circumvention**

(a) The owner of this Title V facility, or any other person, may not circumvent the new source review requirements of 25 Pa. Code Chapter 127, Subchapter E by causing or allowing a pattern of ownership or development, including the phasing, staging, delaying or engaging in incremental construction, over a geographic area of a facility which, except for the pattern of ownership or development, would otherwise require a permit or submission of a plan approval application.

(b) No person may permit the use of a device, stack height which exceeds good engineering practice stack height, dispersion technique or other technique which, without resulting in reduction of the total amount of air contaminants emitted, conceals or dilutes an emission of air contaminants which would otherwise be in violation of this permit, the Air Pollution Control Act or the regulations promulgated thereunder, except that with prior approval of the Department, the device or technique may be used for control of malodors.

#022 [25 Pa. Code §§ 127.402(d) & 127.513(1)]**Submissions**

(a) Reports, test data, monitoring data, notifications and requests for renewal of the permit shall be submitted to the:

Regional Air Program Manager
PA Department of Environmental Protection
(At the address given on the permit transmittal letter, or otherwise notified)

(b) Any report or notification for the EPA Administrator or EPA Region III should be addressed to:

Enforcement & Compliance Assurance Division
Air, RCRA and Toxics Branch (3ED21)
Four Penn Center
1600 John F. Kennedy Boulevard
Philadelphia, PA 19103-2852

The Title V compliance certification shall be emailed to EPA at R3_APD_Permits@epa.gov.

(c) An application, form, report or compliance certification submitted pursuant to this permit condition shall contain certification by a responsible official as to truth, accuracy, and completeness as required under 25 Pa. Code § 127.402(d). Unless otherwise required by the Clean Air Act or regulations adopted thereunder, this certification and any other certification required pursuant to this permit shall state that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate and complete.

#023 [25 Pa. Code §§ 127.441(c) & 127.463(e); Chapter 139; & 114(a)(3), 504(b) of the CAA]**Sampling, Testing and Monitoring Procedures**

(a) The permittee shall perform the emissions monitoring and analysis procedures or test methods for applicable requirements of this Title V permit. In addition to the sampling, testing and monitoring procedures specified in this

**SECTION B. General Title V Requirements**

permit, the Permittee shall comply with any additional applicable requirements promulgated under the Clean Air Act after permit issuance regardless of whether the permit is revised.

(b) The sampling, testing and monitoring required under the applicable requirements of this permit, shall be conducted in accordance with the requirements of 25 Pa. Code Chapter 139 unless alternative methodology is required by the Clean Air Act (including §§ 114(a)(3) and 504(b)) and regulations adopted thereunder.

#024 [25 Pa. Code § 127.513]**Compliance Certification**

(a) One year after the date of issuance of the Title V permit, and each year thereafter, unless specified elsewhere in the permit, the permittee shall submit to the Department and EPA Region III a certificate of compliance with the terms and conditions in this permit, for the previous year, including the emission limitations, standards or work practices. This certification shall include:

- (1) The identification of each term or condition of the permit that is the basis of the certification.
- (2) The compliance status.
- (3) The methods used for determining the compliance status of the source, currently and over the reporting period.
- (4) Whether compliance was continuous or intermittent.

(b) The compliance certification shall be postmarked or hand-delivered no later than thirty days after each anniversary of the date of issuance of this Title V Operating Permit, or on the submittal date specified elsewhere in the permit, to the Department in accordance with the submission requirements specified in Section B, Condition #022 of this permit. The Title V compliance certification shall be emailed to EPA at R3_APD_Permits@epa.gov.

#025 [25 Pa. Code §§ 127.511 & Chapter 135]**Recordkeeping Requirements**

(a) The permittee shall maintain and make available, upon request by the Department, records of required monitoring information that include the following:

- (1) The date, place (as defined in the permit) and time of sampling or measurements.
- (2) The dates the analyses were performed.
- (3) The company or entity that performed the analyses.
- (4) The analytical techniques or methods used.
- (5) The results of the analyses.
- (6) The operating conditions as existing at the time of sampling or measurement.

(b) The permittee shall retain records of the required monitoring data and supporting information for at least five (5) years from the date of the monitoring sample, measurement, report or application. Supporting information includes the calibration data and maintenance records and original strip-chart recordings for continuous monitoring instrumentation, and copies of reports required by the permit.

(c) The permittee shall maintain and make available to the Department upon request, records including computerized records that may be necessary to comply with the reporting, recordkeeping and emission statement requirements in 25 Pa. Code Chapter 135 (relating to reporting of sources). In accordance with 25 Pa. Code Chapter 135, § 135.5, such records may include records of production, fuel usage, maintenance of production or pollution control equipment or other information determined by the Department to be necessary for identification and quantification of potential and actual air contaminant emissions. If direct recordkeeping is not possible or practical, sufficient records shall be kept to provide the needed information by indirect means.

**SECTION B. General Title V Requirements****#026 [25 Pa. Code §§ 127.411(d), 127.442, 127.463(e) & 127.511(c)]****Reporting Requirements**

(a) The permittee shall comply with the reporting requirements for the applicable requirements specified in this Title V permit. In addition to the reporting requirements specified herein, the permittee shall comply with any additional applicable reporting requirements promulgated under the Clean Air Act after permit issuance regardless of whether the permit is revised.

(b) Pursuant to 25 Pa. Code § 127.511(c), the permittee shall submit reports of required monitoring at least every six (6) months unless otherwise specified in this permit. Instances of deviations (as defined in 25 Pa. Code § 121.1) from permit requirements shall be clearly identified in the reports. The reporting of deviations shall include the probable cause of the deviations and corrective actions or preventative measures taken, except that sources with continuous emission monitoring systems shall report according to the protocol established and approved by the Department for the source. The required reports shall be certified by a responsible official.

(c) Every report submitted to the Department under this permit condition shall comply with the submission procedures specified in Section B, Condition #022(c) of this permit.

(d) Any records, reports or information obtained by the Department or referred to in a public hearing shall be made available to the public by the Department except for such records, reports or information for which the permittee has shown cause that the documents should be considered confidential and protected from disclosure to the public under Section 4013.2 of the Air Pollution Control Act and consistent with Sections 112(d) and 114(c) of the Clean Air Act and 25 Pa. Code § 127.411(d). The permittee may not request a claim of confidentiality for any emissions data generated for the Title V facility.

#027 [25 Pa. Code § 127.3]**Operational Flexibility**

The permittee is authorized to make changes within the Title V facility in accordance with the following provisions in 25 Pa. Code Chapter 127 which implement the operational flexibility requirements of Section 502(b)(10) of the Clean Air Act and Section 6.1(i) of the Air Pollution Control Act:

- (1) Section 127.14 (relating to exemptions)
- (2) Section 127.447 (relating to alternative operating scenarios)
- (3) Section 127.448 (relating to emissions trading at facilities with federally enforceable emissions caps)
- (4) Section 127.449 (relating to de minimis emission increases)
- (5) Section 127.450 (relating to administrative operating permit amendments)
- (6) Section 127.462 (relating to minor operating permit amendments)
- (7) Subchapter H (relating to general plan approvals and operating permits)

#028 [25 Pa. Code §§ 127.441(d), 127.512(i) and 40 CFR Part 68]**Risk Management**

(a) If required by Section 112(r) of the Clean Air Act, the permittee shall develop and implement an accidental release program consistent with requirements of the Clean Air Act, 40 CFR Part 68 (relating to chemical accident prevention provisions) and the Federal Chemical Safety Information, Site Security and Fuels Regulatory Relief Act (P.L. 106-40).

(b) The permittee shall prepare and implement a Risk Management Plan (RMP) which meets the requirements of Section 112(r) of the Clean Air Act, 40 CFR Part 68 and the Federal Chemical Safety Information, Site Security and Fuels Regulatory Relief Act when a regulated substance listed in 40 CFR § 68.130 is present in a process in more than the listed threshold quantity at the Title V facility. The permittee shall submit the RMP to the federal Environmental Protection Agency according to the following schedule and requirements:

- (1) The permittee shall submit the first RMP to a central point specified by EPA no later than the latest of the following:

**SECTION B. General Title V Requirements**

- (i) Three years after the date on which a regulated substance is first listed under § 68.130; or,
 - (ii) The date on which a regulated substance is first present above a threshold quantity in a process.
- (2) The permittee shall submit any additional relevant information requested by the Department or EPA concerning the RMP and shall make subsequent submissions of RMPs in accordance with 40 CFR § 68.190.
- (3) The permittee shall certify that the RMP is accurate and complete in accordance with the requirements of 40 CFR Part 68, including a checklist addressing the required elements of a complete RMP.
- (c) As used in this permit condition, the term "process" shall be as defined in 40 CFR § 68.3. The term "process" means any activity involving a regulated substance including any use, storage, manufacturing, handling, or on-site movement of such substances or any combination of these activities. For purposes of this definition, any group of vessels that are interconnected, or separate vessels that are located such that a regulated substance could be involved in a potential release, shall be considered a single process.
- (d) If the Title V facility is subject to 40 CFR Part 68, as part of the certification required under this permit, the permittee shall:
- (1) Submit a compliance schedule for satisfying the requirements of 40 CFR Part 68 by the date specified in 40 CFR § 68.10(a); or,
 - (2) Certify that the Title V facility is in compliance with all requirements of 40 CFR Part 68 including the registration and submission of the RMP.
- (e) If the Title V facility is subject to 40 CFR Part 68, the permittee shall maintain records supporting the implementation of an accidental release program for five (5) years in accordance with 40 CFR § 68.200.
- (f) When the Title V facility is subject to the accidental release program requirements of Section 112(r) of the Clean Air Act and 40 CFR Part 68, appropriate enforcement action will be taken by the Department if:
- (1) The permittee fails to register and submit the RMP or a revised plan pursuant to 40 CFR Part 68.
 - (2) The permittee fails to submit a compliance schedule or include a statement in the compliance certification required under Section B, Condition #026 of this permit that the Title V facility is in compliance with the requirements of Section 112(r) of the Clean Air Act, 40 CFR Part 68, and 25 Pa. Code § 127.512(i).

#029 [25 Pa. Code § 127.512(e)]**Approved Economic Incentives and Emission Trading Programs**

No permit revision shall be required under approved economic incentives, marketable permits, emissions trading and other similar programs or processes for changes that are provided for in this Title V permit.

#030 [25 Pa. Code §§ 127.516, 127.450(d), 127.449(f) & 127.462(g)]**Permit Shield**

(a) The permittee's compliance with the conditions of this permit shall be deemed in compliance with applicable requirements (as defined in 25 Pa. Code § 121.1) as of the date of permit issuance if either of the following applies:

- (1) The applicable requirements are included and are specifically identified in this permit.
- (2) The Department specifically identifies in the permit other requirements that are not applicable to the permitted facility or source.

(b) Nothing in 25 Pa. Code § 127.516 or the Title V permit shall alter or affect the following:

- (1) The provisions of Section 303 of the Clean Air Act, including the authority of the Administrator of the EPA provided thereunder.
- (2) The liability of the permittee for a violation of an applicable requirement prior to the time of permit issuance.

**SECTION B. General Title V Requirements**

(3) The applicable requirements of the acid rain program, consistent with Section 408(a) of the Clean Air Act.

(4) The ability of the EPA to obtain information from the permittee under Section 114 of the Clean Air Act.

(c) Unless precluded by the Clean Air Act or regulations thereunder, final action by the Department incorporating a significant permit modification in this Title V Permit shall be covered by the permit shield at the time that the permit containing the significant modification is issued.

#031 [25 Pa. Code §135.3]**Reporting**

(a) The permittee shall submit by March 1 of each year an annual emissions report for the preceding calendar year. The report shall include information for all active previously reported sources, new sources which were first operated during the preceding calendar year, and sources modified during the same period which were not previously reported. All air emissions from the facility should be estimated and reported.

(b) A source owner or operator may request an extension of time from the Department for the filing of an annual emissions report, and the Department may grant the extension for reasonable cause.

#032 [25 Pa. Code §135.4]**Report Format**

Emissions reports shall contain sufficient information to enable the Department to complete its emission inventory. Emissions reports shall be made by the source owner or operator in a format specified by the Department.

**SECTION C. Site Level Requirements****I. RESTRICTIONS.****Emission Restriction(s).****# 001 [25 Pa. Code §123.1]****Prohibition of certain fugitive emissions**

No person shall permit the emission into the outdoor atmosphere of any fugitive air contaminant from a source other than the following:

- (a) Construction or demolition of buildings or structures.
- (b) Grading, paving and maintenance of roads and streets.
- (c) Use of roads and streets. Emissions from material in or on trucks, railroad cars and other vehicular equipment are not considered as emissions from use of roads and streets.
- (d) Clearing of land.
- (e) Stockpiling of materials.
- (f) Open burning operations
- (g) Sources and classes of sources other than those identified above, for which the operator has obtained a determination from the Department that fugitive emissions from the source, after appropriate control, meet the following requirements:
 - 1) the emissions are of minor significance with respect to causing air pollution;
 - 2) the emissions are not preventing or interfering with the attainment or maintenance of any ambient air standard.

002 [25 Pa. Code §123.2]**Fugitive particulate matter**

No person shall emit particulate matter into the outdoor atmosphere from a source specified in Section C, Condition #001 if the emissions are visible at the point the emissions pass outside the person's property.

003 [25 Pa. Code §123.31]**Limitations**

No person shall permit the emission into the outdoor atmosphere of any malodorous air contaminants from any source in such a manner that the malodors are detectable outside the property of the person on whose land the source is being operated.

004 [25 Pa. Code §123.41]**Limitations**

The permittee shall not permit the emission into the outdoor atmosphere of visible air contaminants in such a manner that the opacity of the emission is either of the following:

- 1) Equal to or greater than 20% for a period or periods aggregating more than three minutes in any 1 hour.
- 2) Equal to or greater than 60% at any time.

005 [25 Pa. Code §123.42]**Exceptions**

The emission limitations of Section 123.41 shall not apply when:

- 1) The presence of uncombined water is the only reason for failure of the emission to meet the limitation;
- 2) The emission results from the operation of equipment used solely to train and test persons in observing the opacity of visible emissions;
- 3) The emission results from sources specified in Section C, Condition #001 (relating to prohibition of certain fugitive emissions).

**SECTION C. Site Level Requirements****# 006 [25 Pa. Code §127.512]****Operating permit terms and conditions.**

The permittee shall report malfunctions which occur at the facility to the Department. A malfunction is defined as any sudden, infrequent, and not reasonably preventable failure of air pollution control equipment, process equipment, or a process to operate in a normal or usual manner. Failures that are caused in part by poor maintenance or careless operation are not malfunctions. Malfunctions shall be reported as follows:

(a) Malfunctions which occur at the facility and which pose an imminent danger to public health, safety, welfare and the environment, shall be immediately reported to the Department by telephone. The telephone report of such malfunctions shall occur no later than two hours after the incident. Telephone reports can be made to the Air Quality Program at (814) 946-7290 during normal business hours, or to the Department's Emergency Hotline at any time. Then current Emergency Hotline phone number can be found at <https://www.dep.pa.gov/About/Regional/SouthcentralRegion/Pages/default.aspx>. The permittee shall submit a written report of instances of such malfunctions to the Department, in writing, within three (3) days of the telephone report.

(b) Unless otherwise required by this permit, any other malfunction that is not subject to the reporting requirements of Condition #011 Section C, shall be reported to the Department, in writing, within five (5) days of discovery through the Department's Greenport PUP system available through: <https://greenport.pa.gov/ePermitPublicAccess/PublicSubmission/Home>.

007 [25 Pa. Code §129.14]**Open burning operations**

(a) No person shall conduct the open burning of materials in such a manner that:

(1) The emissions are visible, at any time, at the point such emissions pass outside the property of the person on whose land the open burning is being conducted.

(2) Malodorous air contaminants from the open burning are detectable outside the property of the person on whose land the open burning is being conducted.

(3) The emissions interfere with the reasonable enjoyment of life and property.

(4) The emissions cause damage to vegetation or property.

(5) The emissions are or may be deleterious to human or animal health.

(b) The requirements of Section (a), above, do not apply when the open burning operations result from:

(1) A fire set to prevent or abate a fire hazard, when approved by the Department and set by or under the supervision of a public officer.

(2) A fire set for the purpose of instructing personnel in fire fighting, when approved by the Department.

(3) A fire set for the prevention and control of disease or pests, when approved by the Department.

(4) A fire set solely for recreational or ceremonial purposes.

(5) A fire set solely for cooking food.

(c) This permit does not constitute authorization to burn solid waste pursuant to Section 610 (3) of the Solid Waste Management Act, 35 P.S. Section 6018.610 (3), or any other provision of the Solid Waste Management Act.

**SECTION C. Site Level Requirements****II. TESTING REQUIREMENTS.****# 008 [25 Pa. Code §127.511]****Monitoring and related recordkeeping and reporting requirements.**

The Department reserves the right to require exhaust stack testing of the sources and control devices referenced in this permit as necessary during the permit term to verify emissions for purposes including emission fees, malfunctions or permit condition violations.

009 [25 Pa. Code §139.1]**Sampling facilities.**

Upon the request of the Department, the permittee shall provide adequate sampling ports, safe sampling platforms and adequate utilities for the performance by the Department of tests on such sources. In the request, the Department will set forth the time period in which the facilities shall be provided, as well as the specifications for the facilities.

III. MONITORING REQUIREMENTS.**# 010 [25 Pa. Code §123.43]****Measuring techniques**

Visible emissions (referenced in Section C, Conditions 004, 005 and 011) may be measured using either of the following:

- (1) A device approved by the Department and maintained to provide accurate opacity measurements.
- (2) Observers, trained and certified in EPA Method 9, to measure plume opacity with the naked eye or with the aid of any devices approved by the Department.

011 [25 Pa. Code §127.441]**Operating permit terms and conditions.**

[Additional authority for this permit condition is also derived from 25 Pa. Code Section 127.511]

The permittee shall conduct a weekly inspection around the plant periphery during daylight hours when the plant is in production to detect visible stack emissions, visible emissions leaving the premises and odorous air emissions as follows:

- (a) Stack emissions in excess of the limits stated in Section C, Condition 004. Visible stack emissions may be measured according to the methods specified in Section C, Condition 010, or alternatively, plant personnel who observe visible stack emissions may report the incidence of visible stack emissions to the Department within two (2) hours of the incident and make arrangements for a certified observer to measure the visible stack emissions.
- (b) The presence of visible emissions beyond the plant boundaries as stated in Section C, Condition 002.
- (c) The presence of odorous air emissions beyond the plant boundaries as stated in Section C, Condition 003.

IV. RECORDKEEPING REQUIREMENTS.**# 012 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

[Additional authority for this permit condition is also derived from 25 Pa. Code Section 127.511]

The permittee shall maintain records of weekly inspections conducted in accordance with Section C, Condition 011. At a minimum, these records shall include the following information:

- (1) The name of the company representative conducting each inspection.
- (2) The date and time of each inspection.
- (3) The wind direction during each inspection.
- (4) A description of the emissions and/or malodors observed and the actions taken to mitigate them.

**SECTION C. Site Level Requirements**

The permittee shall maintain these records for a minimum of five years and shall make them available to Department representatives upon request.

013 [25 Pa. Code §127.511]**Monitoring and related recordkeeping and reporting requirements.**

The permittee shall maintain records of all fuel oil analyses or fuel oil certifications for each shipment of fuel oil received for the most recent five-year period. These records shall be made available to Department representatives upon request.

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

VI. WORK PRACTICE REQUIREMENTS.**# 014 [25 Pa. Code §123.1]****Prohibition of certain fugitive emissions**

The permittee shall take all reasonable actions to prevent particulate matter from the sources identified in Section C, Condition #001 (a) through (e) from becoming airborne. These actions shall include, but are not limited to, the following:

- (1) Use, where possible, of water or chemicals for control of dust in the demolition of buildings or structures, construction operations, the grading of roads or the clearing of land.
- (2) Application of asphalt, oil, water or suitable chemicals on dirt roads, materials stockpiles and other surfaces which may give rise to airborne dusts.
- (3) Paving and maintenance of roadways.
- (4) Prompt removal of earth or other material from paved streets onto which earth or other material has been transported by trucking or earth moving equipment, erosion by water, or other means.

VII. ADDITIONAL REQUIREMENTS.**# 015 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

The permittee shall continue to comply with the conditions of RACT Permit No. 21-2002, as those provisions are incorporated into the PA State Implementation Plan (SIP), unless and until the SIP is revised to modify those provisions.

016 [25 Pa. Code §127.444]**Compliance requirements.**

The permittee shall operate and maintain the emission sources and air cleaning devices referenced in this permit in accordance with the manufacturer's general recommendations and good air pollution control practices.

017 [25 Pa. Code §135.21]**Emission statements**

Per Site Level Category VIII COMPLIANCE CERTIFICATION below, forward EPA the annual compliance certification report electronically, in lieu of a hard copy version, to the following email address: 'R3_APD_Permits@epa.gov'.

VIII. COMPLIANCE CERTIFICATION.

The permittee shall submit within thirty days of 01/01/2027 a certificate of compliance with all permit terms and conditions set forth in this Title V permit as required under condition #026 of section B of this permit, and annually thereafter.

IX. COMPLIANCE SCHEDULE.

No compliance milestones exist.

***** Permit Shield In Effect *****


**SECTION D. Source Level Requirements**

Source ID: 031

Source Name: ORR & SEMBOWER BOILER 1

Source Capacity/Throughput:	25.100	MMBTU/HR	
	167.000	Gal/HR	#2 Oil
	25.000	MCF/HR	NATURAL GAS

Conditions for this source occur in the following groups: 001 BOILERS
008 PRESUMPTIVE RACT 3 REQUIREMENTS

**I. RESTRICTIONS.**

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

IV. RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

VII. ADDITIONAL REQUIREMENTS.

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

***** Permit Shield in Effect. *****


**SECTION D. Source Level Requirements**

Source ID: 101

Source Name: GLASS MELTING FURNACE 1

Source Capacity/Throughput:	29.200 Tons/HR	FLAT GLASS
	1,500.000 Gal/HR	#2 OIL
	215.000 MCF/HR	NATURAL GAS

Conditions for this source occur in the following groups: 002 GLASS FURNACES
006 GLASS NOX RACT REQUIREMENTS
007 CEMS REQUIREMENTS
011 GLASS RACT 3

**I. RESTRICTIONS.****Emission Restriction(s).**

001 [25 Pa. Code §127.512]

Operating permit terms and conditions.

The permittee may not allow the ammonia slip from the SNCR System (Control ID C101) to exceed 10 parts per million, by volume, dry basis, corrected to 15% oxygen.

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

IV. RECORDKEEPING REQUIREMENTS.

002 [25 Pa. Code §127.512]

Operating permit terms and conditions.

The permittee shall keep monthly records of ammonia usage in the SNCR system (Control ID C101). These records shall be kept on site for a period of five (5) years and be made available to the Department upon request.

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

**SECTION D. Source Level Requirements****VII. ADDITIONAL REQUIREMENTS.**

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

***** Permit Shield in Effect. *****


**SECTION D. Source Level Requirements**

Source ID: 102

Source Name: GLASS MELTING FURNACE 2

Source Capacity/Throughput:	29.200 Tons/HR	FLAT GLASS
	1,500.000 Gal/HR	#2 Oil
	215.000 MCF/HR	NATURAL GAS

Conditions for this source occur in the following groups: 002 GLASS FURNACES
006 GLASS NOX RACT REQUIREMENTS
007 CEMS REQUIREMENTS
011 GLASS RACT 3

**I. RESTRICTIONS.**

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

IV. RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

VII. ADDITIONAL REQUIREMENTS.

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).



SECTION D. Source Level Requirements

*** Permit Shield in Effect. ***

**SECTION D. Source Level Requirements**

Source ID: 103


Source Name: CULLET SYSTEM-STORAGE

Source Capacity/Throughput:

58.100 Tons/HR

BROKEN GLASS

Conditions for this source occur in the following groups: 004 RAW MATERIALS HANDLING

**I. RESTRICTIONS.**

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

IV. RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

VII. ADDITIONAL REQUIREMENTS.

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

***** Permit Shield in Effect. *****

**SECTION D. Source Level Requirements**

Source ID: 106


Source Name: BATCH MIXING

Source Capacity/Throughput:

100.000 Tons/HR

MIXED BATCH

Conditions for this source occur in the following groups: 004 RAW MATERIALS HANDLING

**I. RESTRICTIONS.**

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

IV. RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

VII. ADDITIONAL REQUIREMENTS.

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

***** Permit Shield in Effect. *****


**SECTION D. Source Level Requirements**

Source ID: 107

Source Name: BATCH GALLERY CONVEYORS

Source Capacity/Throughput: 100.000 Tons/HR RAW BATCH MIX

Conditions for this source occur in the following groups: 004 RAW MATERIALS HANDLING

**I. RESTRICTIONS.**

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

IV. RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

VII. ADDITIONAL REQUIREMENTS.

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

***** Permit Shield in Effect. *****


**SECTION D. Source Level Requirements**

Source ID: 108

Source Name: BATCH MATERIAL UNLOADING

Source Capacity/Throughput: 400.000 Tons/HR RAW MATERIALS

Conditions for this source occur in the following groups: 004 RAW MATERIALS HANDLING

**I. RESTRICTIONS.**

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

IV. RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

VII. ADDITIONAL REQUIREMENTS.

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

***** Permit Shield in Effect. *****


**SECTION D. Source Level Requirements**

Source ID: 110

Source Name: #2 CULLET/BATCH FEED

Source Capacity/Throughput: 36.000 Tons/HR CULLET

Conditions for this source occur in the following groups: 004 RAW MATERIALS HANDLING

**I. RESTRICTIONS.****Emission Restriction(s).**

001 [25 Pa. Code §123.13]

Processes

PM emissions from the Donaldson Torit cartridge collector exhaust shall not exceed 0.04 grains per dry standard cubic foot.

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

III. MONITORING REQUIREMENTS.

002 [25 Pa. Code §127.511]

Monitoring and related recordkeeping and reporting requirements.

The applicant shall operate and maintain instrumentation to measure and display the pressure differential across the Donaldson Torit cartridge collector.

IV. RECORDKEEPING REQUIREMENTS.

003 [25 Pa. Code §127.511]

Monitoring and related recordkeeping and reporting requirements.

(a) The applicant shall monitor and record the pressure differential across the Donaldson Torit cartridge collector. The pressure differential shall be recorded a minimum of once per week while the Line 2 Glass Melting Furnace and the Donaldson Torit cartridge collector are operating.

(b) The applicant shall retain these records for a minimum of five (5) years and shall make them available to the Department upon its request.

004 [25 Pa. Code §127.511]

Monitoring and related recordkeeping and reporting requirements.

(a) The applicant shall maintain detailed records of all maintenance performed on the Donaldson Torit cartridge collector.

(b) The applicant shall retain these records for a minimum of five (5) years and shall make them available to the Department upon its request.

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

**SECTION D. Source Level Requirements****VI. WORK PRACTICE REQUIREMENTS.****# 005 [25 Pa. Code §127.512]****Operating permit terms and conditions.**

The applicant shall operate the Donaldson Torit cartridge collector at all times that the Line 2 Glass Melting Furnace is operating.

006 [25 Pa. Code §127.512]**Operating permit terms and conditions.**

The applicant shall maintain on-site a sufficient quantity of spare cartridge collector cartridges for the Donaldson Torit cartridge collector in order to immediately replace any cartridges requiring replacement due to deterioration resulting from routine operation.

007 [25 Pa. Code §127.512]**Operating permit terms and conditions.**

The applicant shall operate and maintain the Line 2 Glass Melting Furnace and the associated Donaldson Torit cartridge collector:

- (a) in such a manner as not to cause air pollution;
- (b) in a manner consistent with good operating and maintenance practices; and
- (c) in accordance with the manufacturer's specifications.

VII. ADDITIONAL REQUIREMENTS.

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

***** Permit Shield in Effect. *****

**SECTION D. Source Level Requirements**

Source ID: 111


Source Name: #1 CULLET/BATCH FEED

Source Capacity/Throughput:

36.000 Tons/HR

CULLET

Conditions for this source occur in the following groups: 004 RAW MATERIALS HANDLING

**I. RESTRICTIONS.**

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

IV. RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

VII. ADDITIONAL REQUIREMENTS.

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

***** Permit Shield in Effect. *****

**SECTION D. Source Level Requirements**

Source ID: 114A

Source Name: EMER GENERATOR LINE 2, UNIT A (EAST)(1500 KW)


Source Capacity/Throughput:

16.000 MMBTU/HR

115.400 Gal/HR

Diesel Fuel

Conditions for this source occur in the following groups: 003 EMERGENCY EQUIPMENT
008 PRESUMPTIVE RACT 3 REQUIREMENTS
009 RICE MACT

**I. RESTRICTIONS.**

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

IV. RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

VII. ADDITIONAL REQUIREMENTS.

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

***** Permit Shield in Effect. *****

**SECTION D. Source Level Requirements**

Source ID: 114B

Source Name: EMER GENERATOR LINE 2, UNIT B (WEST)(1500KW)


Source Capacity/Throughput:

16.000 MMBTU/HR

115.400 Gal/HR

Diesel Fuel

Conditions for this source occur in the following groups: 003 EMERGENCY EQUIPMENT
008 PRESUMPTIVE RACT 3 REQUIREMENTS
009 RICE MACT

**I. RESTRICTIONS.**

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

IV. RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

VII. ADDITIONAL REQUIREMENTS.

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

***** Permit Shield in Effect. *****

**SECTION D. Source Level Requirements**

Source ID: 114C

Source Name: DETROIT DIESEL 9163-7301 EMER GENERATOR LINE 1 (2000 KW)

Source Capacity/Throughput: 19.370 MMBTU/HR

141.000 Gal/HR

Diesel Fuel

Conditions for this source occur in the following groups: 003 EMERGENCY EQUIPMENT
008 PRESUMPTIVE RACT 3 REQUIREMENTS
010 NSPS IIII

**I. RESTRICTIONS.****Emission Restriction(s).****# 001 [25 Pa. Code §127.512]****Operating permit terms and conditions.**

[Additional authority for this requirement is derived from Plan Approval No. GP9-21-05002A]

The Source ID 114C engine shall not exceed the following emission limits:

- (i) Total Hydrocarbon (THC) - 1.0 g/bhp-hr
- (ii) NOx - 6.9 g/hp-hr
- (iii) CO - 2.0 g/bhp-hr
- (iv) Particulate Matter - 0.4 g/bhp-hr

002 [25 Pa. Code §127.512]**Operating permit terms and conditions.**

[Additional authority for this requirement is derived from Plan Approval No. GP9-21-05002A]

Visible emissions from the Source ID 114C engine stack shall not exceed the following limitations:

- (1) Equal to or greater than 10% for a period or periods aggregating more than three (3) minutes in any one (1) hour; and
- (2) Equal to or greater than 30% at any time.

Fuel Restriction(s).**# 003 [25 Pa. Code §127.512]****Operating permit terms and conditions.**

[Additional authority for this requirement is derived from Plan Approval No. GP9-21-05002A]

Diesel fuel used by the Source ID 114C engine shall not exceed a maximum sulfur content of 0.3% by weight.

Operation Hours Restriction(s).**# 004 [25 Pa. Code §127.512]****Operating permit terms and conditions.**

[Additional authority for this requirement is derived from Plan Approval No. GP9-21-05002A]

The Source ID 114C engine shall not operate for more than 99.9 hours per 12-month rolling total period.

**SECTION D. Source Level Requirements****II. TESTING REQUIREMENTS.****# 005 [25 Pa. Code §127.512]****Operating permit terms and conditions.**

[Additional authority of this requirement is derived from Plan Approval No. GP9-21-05002A]

(1) The permittee shall stack test the Source ID 114C engine for the following pollutants:

(i) Total Hydrocarbons (THC)

(ii) Particulate Matter (PM)

(iii) Sulfur Oxides (expressed as SO₂)

(iv) Carbon Monoxide (CO)

(v) Opacity

(2) Stack testing shall be conducted within sixty (60) days after achieving the maximum production rate at which the affected facility will be operated, but no later than one hundred eighty (180) days after the initial startup of the source.

(3) At least sixty (60) days prior to the test, the company shall submit to the Department for approval the procedures for the test and a sketch with dimensions indicating the location of sampling ports and other data to ensure the collection of representative samples.

(4) At least thirty (30) days prior to the test, the Department shall be informed of the date and time of the test.

(5) Within sixty (60) days after the source test(s), two copies of the complete test report, including all operating conditions, shall be submitted to the Department.

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

IV. RECORDKEEPING REQUIREMENTS.**# 006 [25 Pa. Code §127.512]****Operating permit terms and conditions.**

[Additional authority for this requirement is derived from Plan Approval No. GP9-21-05002A]

(1) The permittee shall maintain accurate records of the following:

(i) Number of hours per calendar year that the Source ID 114C engine operated.

(ii) Amount of fuel used by the Source ID 114C engine per calendar year.

(2) Records shall be maintained for a minimum of five (5) years and be made available to the Department upon request.

007 [25 Pa. Code §127.512]**Operating permit terms and conditions.**

[Additional authority for this requirement is derived from Plan Approval No. GP9-21-05002A]

(1) The permittee shall maintain records of the following:

(i) Records including a description of testing methods, results, all engine operating data collected during the performance tests and a copy of the calculations performed to determine compliance with emission standards.

**SECTION D. Source Level Requirements**

(ii) Copies of the report that demonstrates that the engines were operating at rated brake horsepower and rated speed conditions during performance testing.

(2) Records shall be maintained for a minimum of five (5) years and be made available to the Department upon request.

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

VII. ADDITIONAL REQUIREMENTS.

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

***** Permit Shield in Effect. *****

**SECTION D. Source Level Requirements**

Source ID: 114E

Source Name: EMER FLOOD PUMP (SMALL)

Source Capacity/Throughput:

2.000 MMBTU/HR

10.000 Gal/HR

Diesel Fuel

Conditions for this source occur in the following groups: 003 EMERGENCY EQUIPMENT
009 RICE MACT

**I. RESTRICTIONS.**

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

IV. RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

VII. ADDITIONAL REQUIREMENTS.

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

***** Permit Shield in Effect. *****

**SECTION D. Source Level Requirements**

Source ID: 114F

Source Name: EMER FLOOD PUMP (LARGE)


Source Capacity/Throughput:

8.000 MMBTU/HR

60.000 Gal/HR

Diesel Fuel

Conditions for this source occur in the following groups: 003 EMERGENCY EQUIPMENT
008 PRESUMPTIVE RACT 3 REQUIREMENTS
009 RICE MACT

**I. RESTRICTIONS.**

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

IV. RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

VII. ADDITIONAL REQUIREMENTS.

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

***** Permit Shield in Effect. *****

**SECTION D. Source Level Requirements**

Source ID: 114H

Source Name: EMER FIRE PUMP (WEST)

Source Capacity/Throughput:

2.000 MMBTU/HR

10.000 Gal/HR

Diesel Fuel

Conditions for this source occur in the following groups: 003 EMERGENCY EQUIPMENT
009 RICE MACT

**I. RESTRICTIONS.**

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

IV. RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

VII. ADDITIONAL REQUIREMENTS.

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

***** Permit Shield in Effect. *****

**SECTION D. Source Level Requirements**

Source ID: 114I

Source Name: EMER FIRE PUMP (EAST)

Source Capacity/Throughput:

2.000 MMBTU/HR

10.000 Gal/HR

Diesel Fuel

Conditions for this source occur in the following groups: 003 EMERGENCY EQUIPMENT
009 RICE MACT

**I. RESTRICTIONS.**

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

IV. RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

VII. ADDITIONAL REQUIREMENTS.

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

***** Permit Shield in Effect. *****

**SECTION D. Source Level Requirements**


Source ID: 115

Source Name: TPO SYSTEM COATER

Source Capacity/Throughput:

86.000 Lbs/HR

TPO SOLUTION

**I. RESTRICTIONS.**

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

IV. RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

VII. ADDITIONAL REQUIREMENTS.

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

***** Permit Shield in Effect. *****

**SECTION D. Source Level Requirements**

Source ID: 116

Source Name: GLASS CUTTING

Source Capacity/Throughput:

2.200 Lbs/HR

VOC

PROC
116STAC
Z116**I. RESTRICTIONS.****Emission Restriction(s).****# 001 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

Total VOC emissions from glass cutting fluid/lubricant use shall not exceed 12 tons per consecutive 12-month period.

[The above emission limit is based upon a 12-month rolling average and applies to each consecutive 12-month period. Compliance verification requires emissions to be calculated for each month and each consecutive 12-month period. Calculation records shall be maintained on-site for the most recent five-year period and shall be made available to Department representatives upon request.]

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

IV. RECORDKEEPING REQUIREMENTS.**# 002 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

The permittee shall maintain monthly records of glass cutting fluid/ lubricant use and the corresponding VOC emissions. This data shall be included in the facility's annual emissions report.

003 [25 Pa. Code §127.441]**Operating permit terms and conditions.**

Material Safety Data Sheets and/or certified manufacturer's data for each cutting fluid/lubricant shall be maintained for the most recent five-year period; this information shall be made available to Department representatives upon request.

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

**SECTION D. Source Level Requirements****VII. ADDITIONAL REQUIREMENTS.**

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

***** Permit Shield in Effect. *****

**SECTION D. Source Level Requirements**

Source ID: 201

Source Name: DEGREASERS

Source Capacity/Throughput:

1.000 Lbs/HR

VOC

PROC
201STAC
Z201**I. RESTRICTIONS.**

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

IV. RECORDKEEPING REQUIREMENTS.**# 001 [25 Pa. Code §129.63]****Degreasing operations**

The permittee shall maintain the following records on and after December 22, 2002:

- (a) The name and address of the solvent supplier.
- (b) The type of solvent including the product or vendor identification number.
- (c) The vapor pressure of the solvent measured in mm Hg at 20°C (68°F).

An invoice, bill of sale, or certificate that corresponds to a number of sales, Material Safety Data Sheet (MSDS), or other appropriate documentation acceptable to the Department may be used to comply with this section.

The permittee shall retain these records for a minimum of five (5) years and shall make them available to the Department upon its request.

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

VI. WORK PRACTICE REQUIREMENTS.**# 002 [25 Pa. Code §129.63]****Degreasing operations**

Degreasing activities shall be conducted in accordance with the applicable requirements of 25 Pa. Code Section 129.63 to include the following:

- (a) After December 22, 2002, Source ID 201 units shall not employ any solvent with a vapor pressure of 1.0 millimeter of mercury (mm Hg) or greater and containing greater than 5% VOC by weight, measured at 20°C (68°F) containing VOCs.

- (b) This permit condition does not apply when:

**SECTION D. Source Level Requirements**

(1) Source ID 201 units are used in extreme cleaning service. Extreme cleaning service is defined as the use of a cold cleaning machine to clean parts used in the manufacture of the following gases or to clean parts exposed to these gases in manufacturing, production, research and development, analytical work, or other similar operations:

- (A) Oxygen in concentrations greater than 23%
- (B) Ozone
- (C) Nitrous oxide
- (D) Fluorine
- (E) Chlorine
- (F) Bromine
- (G) Halogenated compounds

(2) immersion cold cleaning machines have a freeboard ratio equal to or greater than 0.75.

(3) The permittee demonstrates, and the Department approves in writing, that compliance with this permit condition will result in unsafe operating conditions.

003 [25 Pa. Code §129.63]**Degreasing operations**

Each Source ID 201 unit shall be equipped with one of the following:

- (a) A cover that shall be closed at all times except during cleaning of parts or the addition or removal of solvent.
- (b) A perforated drain with a diameter of not more than six (6) inches, if the unit drains directly into the solvent storage reservoir.

004 [25 Pa. Code §129.63]**Degreasing operations**

The permittee shall operate each Source ID 201 unit in accordance with the following procedures:

- (a) Waste solvent shall be collected and stored in closed containers. The closed containers may contain a device that allows pressure relief, but does not allow liquid solvent to drain from the container.
- (b) Flushing of parts using a flexible hose or other flushing device shall be performed only within the unit. The solvent spray shall be a solid fluid stream, not an atomized or shower spray.
- (c) Sponges, fabric, wood, leather, paper products and other absorbent materials may not be cleaned in Source ID 201 units.
- (d) Air-agitated solvent baths may not be used.
- (e) Spills during solvent transfer and use of each Source ID 201 units shall be cleaned up immediately.

005 [25 Pa. Code §129.63]**Degreasing operations**

Each Source ID 201 unit shall have a permanent, conspicuous label summarizing the operating requirements in Condition #004. In addition, the label shall include the following discretionary good operating practices:

- (a) Cleaned parts should be drained at least 15 seconds or until dripping ceases, whichever is longer. Parts having cavities or blind holes shall be tipped or rotated while the part is draining. During the draining, tipping or rotating, the parts should be positioned so that solvent drains directly back to the unit.
- (b) When a pump-agitated solvent bath is used, the agitator should be operated to produce a rolling motion of the solvent with no observable splashing of the solvent against the tank walls or the parts being cleaned.

**SECTION D. Source Level Requirements**

(c) Work area fans should be located and positioned so that they do not blow across the opening of the degreaser unit.

006 [25 Pa. Code §129.63]

Degreasing operations

Source ID 201 units shall have a freeboard ratio of 0.50 or greater.

As defined at 25 Pa. Code Section 121.1, the freeboard ratio is defined as the distance from the liquid solvent in the idling mode to the top edge of the cleaning machine divided by the smaller dimension (length or width) of the cleaning machine.

VII. ADDITIONAL REQUIREMENTS.

007 [25 Pa. Code §129.63]

Degreasing operations

All of the aforementioned permit conditions apply to each Source ID 201 unit so long as the cold cleaning machine uses 2 gallons or more of solvents containing greater than 5% VOC content by weight for the cleaning of metal parts.

***** Permit Shield in Effect. *****

**SECTION D. Source Level Requirements**

Source ID: 301


Source Name: SURFACE PASSIVATION AREA 1

Source Capacity/Throughput:

31.000 Lbs/HR

SO2 SOLUTION

Conditions for this source occur in the following groups: 005 SO2 APPLICATION

**I. RESTRICTIONS.**

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

IV. RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

VII. ADDITIONAL REQUIREMENTS.

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

***** Permit Shield in Effect. *****

**SECTION D. Source Level Requirements**

Source ID: 302


Source Name: SURFACE PASSIVATION AREA 2

Source Capacity/Throughput:

31.000 Lbs/HR

SO2 SOLUTION

Conditions for this source occur in the following groups: 005 SO2 APPLICATION

**I. RESTRICTIONS.**

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

IV. RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

VII. ADDITIONAL REQUIREMENTS.

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements) and/or Section E (Source Group Restrictions).

***** Permit Shield in Effect. *****

**SECTION E. Source Group Restrictions.**

Group Name: 001 BOILERS

Group Description: Boilers

Sources included in this group

ID	Name
031	ORR & SEMBOWER BOILER 1

I. RESTRICTIONS.**Emission Restriction(s).****# 001 [25 Pa. Code §123.11]****Combustion units**

No person shall permit the emissions into the outdoor atmosphere of particulate matter from the Group 001 boilers in excess of 0.4 pound per million Btu of heat input per individual unit.

Fuel Restriction(s).**# 002 [25 Pa. Code §123.22]****Combustion units**

(a) Nonair basin areas. Combustion units in nonair basin areas must conform with the following:

(1) General provision. A person may not permit the emission into the outdoor atmosphere of sulfur oxides, expressed as SO₂, from a combustion unit in excess of the rate of 4 pounds per million Btu of heat input over a 1-hour period, except as provided in paragraph (4).

(2) Commercial fuel oil.

(i) Except as specified in subparagraphs (ii) and (iii), a person may not offer for sale, deliver for use, exchange in trade or permit the use of commercial fuel oil in nonair basin areas if the commercial fuel oil contains sulfur in excess of the applicable maximum allowable sulfur content set forth in the following tables:

Maximum Allowable Sulfur Content Through August 31, 2020,
Expressed as Parts per Million (ppm) by Weight or Percentage by Weight
Grades Commercial Fuel Oil (Consistent with ASTM D396)

No. 2 and lighter oil 500 ppm (0.05%)

Maximum Allowable Sulfur Content Beginning September 1, 2020,
Expressed as Parts per Million (ppm) by Weight or Percentage by Weight
Grades Commercial Fuel Oil (Consistent with ASTM D396)

No. 2 and lighter oil 15 ppm (0.0015%)

(ii) Commercial fuel oil that was stored in this Commonwealth by the ultimate consumer prior to September 1, 2020, which met the applicable maximum allowable sulfur content for commercial fuel oil through August 31, 2020, in subparagraph (i) at the time it was stored, may be used by the ultimate consumer in this Commonwealth on and after September 1, 2020.

(iii) The Department may temporarily suspend or increase the applicable maximum allowable sulfur content for a commercial fuel oil set forth in subparagraph (i) if the following occur:

(A) The Department receives a written request at the address specified in subsection (h) for a suspension or increase on the basis that compliant commercial fuel oil is not reasonably available in a nonair basin area. The request must include the following:

(I) The nonair basin county or counties for which the suspension or increase is requested.

**SECTION E. Source Group Restrictions.**

(II) The reason compliant commercial fuel oil is not reasonably available.

(III) The duration of time for which the suspension or increase is requested and the justification for the requested duration.

(B) The Department determines that an insufficient quantity of compliant commercial fuel oil is reasonably available in the nonair basin area and that the circumstances leading to the insufficiency are due to events that could not have been reasonably foreseen or prevented and are not due to lack of prudent planning on the part of the transferor of the commercial fuel oil into or within the specified nonair basin area.

(C) The Department approves the request, in writing, prior to the transferor distributing the noncompliant commercial fuel oil into or within the specified nonair basin area.

(iv) The Department will limit a suspension or increase in the applicable maximum allowable sulfur content granted under subparagraph (iii) to the shortest duration in which adequate supplies of compliant commercial fuel oil can be made reasonably available, but in no case longer than 60 days from the date the Department grants the suspension or increase.

(3) Equivalency provision. Paragraph (2) does not apply to a person who uses equipment or a process, or to the owner or operator of an installation where equipment or a process is used, to reduce the sulfur emissions from the burning of a fuel with a higher sulfur content than that specified in paragraph (2). The emissions may not exceed those which would result from the use of commercial fuel oil that meets the applicable maximum allowable sulfur content specified in paragraph (2).

(4) [NA - UNITS DO NOT BURN SOLID FUEL]

(b) - (e) [LISTED AIR BASINS NOT APPLICABLE]

(f) Sampling and testing.

(1) For the purpose of determining compliance with the requirements of this section, the actual sulfur content of commercial fuel oil shall be determined by one of the following:

(i) In accordance with the sample collection, test methods and procedures specified under § 139.16 (relating to sulfur in fuel oil).

(ii) Other methods developed or approved by the Department or the Administrator of the EPA, or both.

(2) [NA - NOT A REFINERY OWNER OR OPERATOR]

(3) Prior to offering for sale, delivering for use, exchanging in trade or permitting the use of commercial fuel oil in this Commonwealth, a person other than the ultimate consumer that accepts a shipment of commercial fuel oil from a refinery or other transferor, shall sample, test and calculate the actual sulfur content of the commercial fuel oil in accordance with paragraph (1) if the shipment lacks the record required under subsection (g)(1) that enables the transferee to determine if the sulfur content of the shipment of commercial fuel oil meets the applicable maximum allowable sulfur content.

(g) Recordkeeping and reporting.

(1) Beginning with the refinery owner or operator who sells or transfers commercial fuel oil into or within this Commonwealth for use in this Commonwealth and ending with the ultimate consumer, each time the physical custody of, or title to, a shipment of commercial fuel oil changes hands on or after July 1, 2016, the transferor shall provide to the transferee an electronic or paper record described in this paragraph. This record must legibly and conspicuously contain the following information:

(i) The date of the sale or transfer.

(ii) The name and address of the transferor.

(iii) The name and address of the transferee.

**SECTION E. Source Group Restrictions.**

- (iv) The volume of commercial fuel oil being sold or transferred.
- (v) The identification of the sulfur content of the shipment of commercial fuel oil, determined using the sampling and testing methods specified in subsection (f)(1), expressed as one of the following statements:
 - (A) For a shipment of No. 2 and lighter commercial fuel oil:
 - (I) Prior to September 1, 2020—"The sulfur content of this shipment is 500 ppm or below."
 - (II) On and after to September 1, 2020—"The sulfur content of this shipment is 15 ppm or below."
 - (B) - (C) [HEAVIER GRADE OIL NOT USED IN THESE UNITS]
- (vi) The location of the commercial fuel oil at the time of transfer.
- (vii) Except for a transfer to a truck carrier, an owner or operator of a retail outlet or an ultimate consumer, the transferor may substitute the information required under subparagraphs (i)—(vi) with the use of a product code if the following are met:
 - (A) The product code includes the information required under subparagraphs (i)—(vi).
 - (B) The product code is standardized throughout the distribution system in which it is used.
 - (C) Each downstream party is given sufficient information to know the full meaning of the product code.
- (2) [NA - NOT A REFINERY]
- (3) [NA - NOT A TERMINAL]
- (4) A person subject to this section shall do both of the following:
 - (i) Maintain the applicable records required under paragraphs (1)—(3) in electronic or paper format for 2 years unless a longer period is required under § 127.511(b)(2) (relating to monitoring and related recordkeeping and reporting requirements).
 - (ii) Provide an electronic or written copy of the applicable record to the Department upon request.
- (5) The ultimate consumer shall maintain in electronic or paper format the record containing the information listed in paragraph (1), except in either of the following situations: [EXCEPTIONS DO NOT APPLY IN THIS CASE]
 - (h) Written request. The written request for suspension of or increase in the sulfur content limit on the basis that compliant commercial fuel oil is not reasonably available shall be addressed to the Department of Environmental Protection, Bureau of Air Quality, Chief of the Division of Compliance and Enforcement, P. O. Box 8468, Harrisburg, Pennsylvania 17105-8468.

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

IV. RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

**SECTION E. Source Group Restrictions.****V. REPORTING REQUIREMENTS.**

No additional reporting requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

VII. ADDITIONAL REQUIREMENTS.

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

***** Permit Shield in Effect. *****

**SECTION E. Source Group Restrictions.**

Group Name: 002 GLASS FURNACES

Group Description: Glass Melting Furnaces

Sources included in this group

ID	Name
101	GLASS MELTING FURNACE 1
102	GLASS MELTING FURNACE 2

I. RESTRICTIONS.**Emission Restriction(s).****# 001 [25 Pa. Code §123.13]****Processes**

Particulate matter emissions from each of the Group 002 glass furnaces shall not exceed the rate determined by the following formula:

$A = 6000 E^{-1}$ where

A = allowable emissions in grains per dry standard cubic foot

E = effluent gas volume in dry standard cubic feet per minute

-1 = exponent

002 [25 Pa. Code §123.21]**General**

Sulfur oxides emissions, expressed as sulfur dioxide, from each of the Group 002 glass furnaces shall not exceed a concentration of 500 parts per million, by volume, dry basis, in the effluent gas.

Fuel Restriction(s).**# 003 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

The permittee shall operate the Group 002 glass furnaces on commercial natural gas or commercial No. 2 fuel oil with a maximum sulfur content in accordance with 25 Pa. Code Section 123.22(a)(2).

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

IV. RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

**SECTION E. Source Group Restrictions.****VI. WORK PRACTICE REQUIREMENTS.**

No additional work practice requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

VII. ADDITIONAL REQUIREMENTS.

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

***** Permit Shield in Effect. *****

**SECTION E. Source Group Restrictions.**

Group Name: 003 EMERGENCY EQUIPMENT

Group Description: Emergency generators, flood pumps and fire pumps

Sources included in this group

ID	Name
114A	EMER GENERATOR LINE 2, UNIT A (EAST)(1500 KW)
114B	EMER GENERATOR LINE 2, UNIT B (WEST)(1500KW)
114C	DETROIT DIESEL 9163-7301 EMER GENERATOR LINE 1 (2000 KW)
114E	EMER FLOOD PUMP (SMALL)
114F	EMER FLOOD PUMP (LARGE)
114H	EMER FIRE PUMP (WEST)
114I	EMER FIRE PUMP (EAST)

I. RESTRICTIONS.**Emission Restriction(s).**

001 [25 Pa. Code §123.13]

Processes

Particulate matter emissions from each of the Group 003 emergency units shall not exceed 0.04 grain per dry standard cubic foot.

002 [25 Pa. Code §123.21]

General

Sulfur oxides emissions, expressed as sulfur dioxide, from each of the Group 003 emergency units shall not exceed a concentration of 500 parts per million, by volume, dry basis, in the effluent gas.

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

III. MONITORING REQUIREMENTS.

003 [25 Pa. Code §127.511]

Monitoring and related recordkeeping and reporting requirements.

The permittee shall monitor the sulfur content in the fuel for the Group 003 emergency units by laboratory analysis or fuel supplier's certification for each fuel shipment received.

IV. RECORDKEEPING REQUIREMENTS.

004 [25 Pa. Code §127.511]

Monitoring and related recordkeeping and reporting requirements.

The permittee shall maintain records of all fuel oil analyses or fuel oil certifications for each fuel shipment received for the most recent five-year period. These records shall be maintained onsite and made available to Department representatives upon request.

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

**SECTION E. Source Group Restrictions.****VII. ADDITIONAL REQUIREMENTS.**

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

***** Permit Shield in Effect. *****

**SECTION E. Source Group Restrictions.**

Group Name: 004 RAW MATERIALS HANDLING

Group Description: Raw Materials Handling

Sources included in this group

ID	Name
103	CULLET SYSTEM-STORAGE
106	BATCH MIXING
107	BATCH GALLERY CONVEYORS
108	BATCH MATERIAL UNLOADING
110	#2 CULLET/BATCH FEED
111	#1 CULLET/BATCH FEED

I. RESTRICTIONS.**Emission Restriction(s).**

001 [25 Pa. Code §123.13]

Processes

No person shall permit the emission into the outdoor atmosphere of particulate matter from the individual Group 004 raw materials handling units in excess of 0.04 grain per dry standard cubic foot of effluent gas.

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

IV. RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

VII. ADDITIONAL REQUIREMENTS.

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

***** Permit Shield in Effect. *****

**SECTION E. Source Group Restrictions.**

Group Name: 005 SO2 APPLICATION

Group Description: SO2 Application Areas #1 and #2

Sources included in this group

ID	Name
301	SURFACE PASSIVATION AREA 1
302	SURFACE PASSIVATION AREA 2

I. RESTRICTIONS.**Emission Restriction(s).**

001 [25 Pa. Code §123.21]

General

Sulfur oxides emissions, expressed as sulfur dioxide, from each of the Group 005 SO2 application areas shall not exceed a concentration of 500 parts per million, by volume, dry basis, in the effluent gas.

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

IV. RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

VII. ADDITIONAL REQUIREMENTS.

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

***** Permit Shield in Effect. *****

**SECTION E. Source Group Restrictions.**

Group Name: 006 GLASS NOX RACT REQUIREMENTS

Group Description: Sections 129.301 - 129.310 Glass Furnace Requirements

Sources included in this group

ID	Name
101	GLASS MELTING FURNACE 1
102	GLASS MELTING FURNACE 2
C102A	ELECTROSTATIC PRECIPITATOR
C102B	SCR SYSTEM

I. RESTRICTIONS.**Emission Restriction(s).****# 001 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

The Group 006 glass furnaces are subject to 25 Pa. Code Sections 129.301 - 129.310 and shall comply with all applicable provisions of those sections.

002 [25 Pa. Code §127.441]**Operating permit terms and conditions.**

Nitrogen oxides (NO_x) emissions from the Group 006 glass furnaces shall not exceed the following rates except as specified elsewhere in the Group 006 requirements:

1. Source ID No. 101 glass furnace: 26.75 pounds of NO_x per ton of glass produced. This limit is an alternative emission limitation pursuant to 25 Pa. Code Section 129.304(c)(1) and is based on a 30-day rolling average.
2. Source ID No. 102 glass furnace: 7.0 pounds of NO_x per ton of glass produced and is based on a 30-day rolling average, per 25 Pa. Code Section 129.304(a)(4).

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

IV. RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

VII. ADDITIONAL REQUIREMENTS.**# 003 [25 Pa. Code §129.301.]****Purpose.**

§ 129.301. Purpose.

**SECTION E. Source Group Restrictions.**

The purpose of this section and § 129.302—129.310 is to annually limit the emissions of NO_x from glass melting furnaces.

§ 129.302. Applicability.

This section, §129.301 (relating to purpose) and §§129.303—129.310 apply to an owner or operator of a glass melting furnace in this Commonwealth, including those within the jurisdiction of local air pollution control agencies in Philadelphia and Allegheny Counties approved under section 12 of the act (35 P.S. § 4012), that emits or has the potential to emit NO_x at a rate greater than 50 tons per year.

§ 129.303. Exemptions.

(a) The emission requirements in § 129.304 (relating to emission requirements) do not apply during periods of start-up, shutdown, or idling as defined in § 121.1 (relating to definitions), if the owner or operator complies with the requirements in § § 129.305, 129.306 and 129.307 (relating to start-up requirements; shutdown requirements; and idling requirements).

(b) The owner or operator of a glass melting furnace claiming an exemption under subsection (a) shall notify the Department or the appropriate approved local air pollution control agency in writing within 24 hours after initiation of the operation for which the exemption is claimed. The methods for submitting the written notice may include e-mail, hand or courier delivery, certified mail or facsimile transmissions to the appropriate regional office described in §121.4 (relating to regional organization of the Department) or appropriate approved local air pollution control agency. The notification must include:

- (1) The date and time of the start of the exempt operation.
- (2) The reason for performing the operation and an estimated completion date.
- (3) Identification of the emission control system operating during the exemption period.

(c) The owner or operator of a glass melting furnace granted an exemption under this section shall maintain operating records or documentation, or both, necessary to support the claim for the exemption. The records shall be maintained for 5 years onsite and made available or submitted to the Department or appropriate approved local air pollution control agency, upon request.

(d) The owner or operator of a glass melting furnace shall notify the Department or the appropriate approved local air pollution control agencies in writing within 24 hours after completion of the operation for which the exemption is claimed.

§ 129.304. Emission requirements.

(a) Except as specified in § § 129.303, 129.304(c), 129.305, 129.306 and 129.307, the owner or operator of a glass melting furnace may not operate the glass melting furnace in a manner that results in NO_x emissions in excess of the following allowable limits or NO_x emission limits contained in the plan approval or operating permit, whichever are lower:

- (1) [NA – FURNACES ARE DEFINED AS FLAT GLASS FURNACES]
- (2) [NA – FURNACES ARE DEFINED AS FLAT GLASS FURNACES]
- (3) [NA – FURNACES ARE DEFINED AS FLAT GLASS FURNACES]

(4) 7.0 pounds of NO_x per ton of glass pulled for flat glass furnaces. [NOTE: GLASS MELTING FURNACE #1 IS SUBJECT TO A NO_x LIMIT OF 26.75 LB/TON AS AN ALTERNATE EMISSION LIMIT UNDER 25 PA. CODE 129.304(C)]

- (5) [NA – FURNACES ARE DEFINED AS FLAT GLASS FURNACES]

(b) [NA – 1/1/12 DATE HAS PASSED]

(c) An owner or operator of a glass melting furnace that does not meet the NO_x emission limits specified under this section

**SECTION E. Source Group Restrictions.**

by January 1, 2012, may petition the Department and appropriate approved local air pollution control agency for an alternative emission limitation or compliance schedule as follows:

(1) The owner or operator of a glass melting furnace subject to this section may submit, in writing, a petition requesting an alternative emission limitation. The petition must demonstrate to the satisfaction of the Department and appropriate approved local air pollution control agency that it is economically or technologically infeasible to meet the emission limitation under this section. The alternative emission limitation must be included in either a plan approval or an operating permit issued by the Department or a permit issued by the appropriate approved local air pollution control agency. [NOTE: GLASS MELTING FURNACE #1 IS SUBJECT TO A NOX LIMIT OF 26.75 LB/TON AS AN ALTERNATE EMISSION LIMIT UNDER 25 PA. CODE 129.304(C)]

(2) The owner or operator of a glass melting furnace for which the schedule for cold shutdown does not allow compliance by January 1, 2012 may submit a petition, in writing, requesting an alternative compliance schedule. The alternative compliance schedule for a cold shutdown which occurs after June 19, 2010, may not be extended beyond 180 days from the start-up of the furnace after the cold shutdown, unless approved, in writing, by the Department.

(3) A petition must include the following:

- (i) A brief description, including make, model and location, of each affected glass melting furnace.
 - (ii) A list of all air pollution control technologies and measures that have been installed on each affected glass melting furnace and are operating to control emissions of NOx.
 - (iii) The date of installation and original commencement of operation for each of the technologies and measures listed in accordance with subparagraph (ii).
 - (iv) An explanation of how the NOx control technology or measure installed has been optimized for the maximum NOx emission reduction for each of the technologies and measures listed in accordance with subparagraph (ii).
 - (v) The results of each stack test and other emissions measurements for the affected glass melting furnace following the installation and commencement of operation of the air pollution control technologies and measures listed in accordance with subparagraph (ii).
 - (vi) The date of last scheduled cold shutdown for each affected furnace.
 - (vii) The date of next scheduled cold shutdown of each affected furnace.
 - (viii) Other relevant information requested, in writing, by the Department or appropriate approved local air pollution control agency.
- (4) If an alternative compliance schedule is sought to meet the requirements of this section, the owner or operator shall submit a proposed schedule containing proposed interim milestone dates for completing each phase of the required work and a proposed final compliance date. The petition must also include a proposed interim emission limitation until compliance is achieved with the requirements specified in this section.
- (5) If an alternative emission limitation is sought to meet the requirements of this section, the conditions or special circumstances which demonstrate that the applicable requirements are technologically or economically infeasible.
- (6) If an alternative emission limitation is sought to meet the requirements of this section, the owner or operator shall propose emission limitations in the petition.
- (7) Approved interim milestone dates or emission limitations determined to be necessary for effective monitoring of progress toward full compliance with the requirements of this section, § § 129.301—129.303 and 129.305—129.310 shall be specified in a plan approval or operating permit issued by the Department or a permit issued by the appropriate approved local air pollution control agency.
- (d) During routine maintenance of an add-on emission control system or systems, or maintenance or repair measures on

**SECTION E. Source Group Restrictions.**

furnace components, the owner or operator of a glass melting furnace subject to the emission limits specified under subsection (a) is exempt from these limits if:

- (1) All routine maintenance of an add-on emission control system or maintenance or repair measures on furnace components, or both, combined, in each calendar year does not exceed 144 hours total.
- (2) The routine maintenance or maintenance or repair measure, or both, is conducted in a manner consistent with good air pollution control practices for minimizing emissions.

§ 129.305. Start-up requirements.

(a) The owner or operator of the glass melting furnace shall submit, in writing, to the Department or appropriate approved local air pollution control agency, no later than 30 days prior to the anticipated date of start-up, information requested by the Department or appropriate approved local air pollution control agency to assure proper operation of the furnace. The information must include the following:

- (1) A detailed list of activities to be performed during start-up and an explanation for the length of time needed to complete each activity.
- (2) A description of the material process flow rates and system operating parameters and other information that the owner or operator plans to evaluate during the process optimization.

(b) The owner or operator of a glass melting furnace may submit a request for a start-up exemption in conjunction with the plan approval application if required. The actual length of the start-up exemption, if any, will be determined by the Department or appropriate approved local air pollution control agency at the time of the issuance of the plan approval or operating permit.

(c) The length of the start-up exemption following activation of the primary furnace combustion system may not exceed:

(1) [NA – FURNACES ARE DEFINED AS FLAT GLASS FURNACES]

(2) [NA – FURNACES ARE DEFINED AS FLAT GLASS FURNACES]

(3) One hundred and four days for a flat glass furnace and for all other glass melting furnaces not covered under paragraphs (1) and (2).

(d) The requirements of subsection (c) notwithstanding, if the NO_x control system is not in common use or is not readily available from a commercial supplier, the length of the maximum start-up exemption following activation of the primary furnace combustion system is as follows:

(1) [NA – FURNACES ARE DEFINED AS FLAT GLASS FURNACES]

(2) [NA – FURNACES ARE DEFINED AS FLAT GLASS FURNACES]

(3) Two hundred and eight days for a flat glass furnace and for all other glass melting furnaces not covered under paragraphs (1) and (2).

(e) The Department or appropriate approved local air pollution control agency may approve start-up exemptions, as appropriate, to the extent that the submittal clearly:

- (1) Identifies the control technologies or strategies to be used.
- (2) Describes the physical conditions that prevail during start-up periods that prevent the controls from being effective.
- (3) Provides a reasonably precise estimate as to when physical conditions will have reached a state that allows for the effective control of emissions.

**SECTION E. Source Group Restrictions.**

(f) During the start-up period, the owner or operator of a glass melting furnace shall maintain the stoichiometric ratio of the primary furnace combustion system so as not to exceed 5% excess oxygen, as calculated from the actual fuel and oxidant flow measurements for combustion in the glass melting furnace.

(g) The owner or operator shall place the emission control system in operation as soon as technologically feasible during start-up to minimize emissions.

§ 129.306. Shutdown requirements.

(a) The duration of a glass melting furnace shutdown, as measured from the time the furnace operations drop below 25% of the permitted production capacity or fuel use capacity to when all emissions from the furnace cease, may not exceed 20 days.

(b) The owner or operator of a glass melting furnace shall operate the emission control system whenever technologically feasible, as approved by the Department or appropriate approved local air pollution control agency, during shutdown to minimize emissions.

§ 129.307. Idling requirements.

(a) The owner or operator of a glass melting furnace shall operate the emission control system whenever technologically feasible, as approved by the Department or appropriate approved local air pollution control agency, during idling to minimize emissions.

(b) The NO_x emissions during idling may not exceed the amount calculated using the following equation:
Pounds per day emission limit of NO_x = (Applicable NO_x emission limit specified in § 129.304(a) (relating to emission requirements) expressed in pounds per ton of glass produced) x (Furnace permitted production capacity in tons of glass produced per day)

§ 129.308. Compliance determination.

(a) Not later than 14 days prior to the applicable compliance date under § 129.304(b) or (c), the owner or operator of a glass melting furnace subject to this section, § § 129.301—129.307, 129.309 and 129.310 shall install, operate and maintain continuous emissions monitoring systems (CEMS, as defined in § 121.1 (relating to definitions)) for NO_x and other monitoring systems to convert data to required reporting units in compliance with Chapter 139, Subchapter C (relating to requirements for source monitoring for stationary sources) and calculate actual emissions using the CEMS data reported to the Department. The owner or operator of a glass melting furnace may install or operate, or both, an alternate NO_x emissions monitoring system or method, approved in writing by the Department or appropriate approved local air pollution control agency.

(b) Data invalidated under Chapter 139, Subchapter C, shall be substituted with the following if approved in writing by the Department or appropriate approved local air pollution control agency:

(1) The highest valid 1-hour emission value that occurred under similar source operating conditions during the reporting quarter.

(2) If no valid data were collected during the reporting quarter, one of the following shall be reported to the Department or appropriate approved local air pollution control agency:

(i) The highest valid 1-hour emission value that occurred under similar source operating conditions during the most recent quarter for which valid data were collected.

(ii) The highest valid 1-hour emission value that occurred under similar source operating conditions during an alternative reporting period.

(3) An alternative method of data substitution.

(c) Instead of data substitution, the Department or appropriate approved local air pollution control agency may approve an

**SECTION E. Source Group Restrictions.**

alternative procedure to quantify NO_x emissions and glass production.

(d) The owner or operator of a glass furnace subject to this section shall submit to the Department or the appropriate approved local air pollution control agencies quarterly reports of CEMS monitoring data in pounds of NO_x emitted per hour, in a format approved by the Department and in compliance with Chapter 139, Subchapter C, or a format approved by the appropriate approved local air pollution control agencies.

(e) The CEMS or approved monitoring system or method for NO_x installed under this section must meet the minimum data availability requirements in Chapter 139, Subchapter C.

§ 129.309. Compliance demonstration.

(a) The owner or operator of a glass melting furnace shall calculate and report to the Department or appropriate approved local air pollution control agency on a quarterly basis, no later than 30 days after the end of the quarter, the CEMS data and glass production data used to show compliance with the allowable NO_x emission limitation specified in § 129.304 (relating to emission requirements). The glass production data must consist of the quantity of glass, in tons, pulled per day for each furnace.

(b) The owner or operator of a glass melting furnace shall demonstrate compliance with the emission requirements of § 129.304(a) using one of the following methods:

(1) On a furnace-by-furnace basis.

(2) Facility-wide emissions averaging.

(3) System-wide emissions averaging among glass melting furnaces under common control of the same owner or operator in this Commonwealth.

(c) The owner or operator of a glass melting furnace for which the Department or the appropriate approved local air pollution control agency has granted approval to voluntarily opt into a market-based program may not demonstrate compliance on an emissions averaging basis under subsection (b). An emission reduction obtained by emissions averaging to demonstrate compliance with the emission requirements of § 129.304(a) will not be considered surplus for emission reduction credit purposes. The owner or operator of a glass melting furnace shall demonstrate compliance with the emission requirements of § 129.304(a) in accordance with subsection (d).

(d) Compliance with the emission requirements of § 129.304(a) shall be determined on a 30-day rolling average basis.

§ 129.310. Recordkeeping.

(a) The owner or operator of a glass melting furnace subject to this section and §§ 129.301—129.309 shall maintain records to demonstrate compliance. The records must include an operating log maintained for each glass melting furnace that includes, on a daily basis:

(1) The total hours of operation.

(2) The type and quantity of fuel used.

(3) The quantity of glass pulled.

(b) The owner or operator of a glass melting furnace shall maintain records of:

(1) Source tests and operating parameters established during the initial source test.

(2) Maintenance, repairs, malfunctions, idling, start-up and shutdown.

(c) The owner or operator claiming that a glass melting furnace is exempt from the requirements of §§ 129.301—129.309 based on the furnace's potential to emit shall maintain records that clearly demonstrate to the Department or appropriate

**SECTION E. Source Group Restrictions.**

approved local air pollution control agency that the furnace is not subject to § § 129.301—129.309.

(d) The records required under this section shall be maintained onsite for 5 years. The records shall be made available or submitted to the Department or appropriate approved local air pollution control agency upon request.

***** Permit Shield in Effect. *****

**SECTION E. Source Group Restrictions.**

Group Name: 007 CEMS REQUIREMENTS

Group Description: Continuous Emissions Monitoring Systems

Sources included in this group

ID	Name
101	GLASS MELTING FURNACE 1
102	GLASS MELTING FURNACE 2

I. RESTRICTIONS.

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

III. MONITORING REQUIREMENTS.**# 001 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

The following continuous emission monitoring system (CEMS) and components must be installed, approved by the Department, operated and maintained in accordance with the requirements of 25 Pa. Code Chapter 139, Subchapter C (relating to requirements for source monitoring for stationary sources), and the Submittal and Approval, Record Keeping and Reporting, and Quality Assurance requirements of Revision No. 8 of the Department's Continuous Source Monitoring Manual, 274-0300-001.

1. Exhaust Gas Flow CEMS

- a. Sources to be Monitored: Sources 101 and 102
- b. Parameter to be Reported: Exhaust Gas Flow
- c. Units of Measurement to be Reported: SCFM
- d. Moisture Basis of Measurement to be Reported: NA
- e. Correction basis of Measurements to be Reported: NA
- f. Data Substitution Required: No
- g. Emission Standard: NA
- h. Averaging Period: NA

2. NOx CEMS

- a. Sources to be Monitored: Sources 101 and 102
- b. Parameter to be Reported: NOx (as NO₂)
- c. Units of Measurement to be Reported: lb/hr
- d. Moisture Basis of Measurement to be Reported: NA
- e. Correction basis of Measurements to be Reported: NA
- f. Data Substitution Required: Yes, per Chapter 129.301 - 310
- g. NOx Emission Standard: There is not a NOx lb/hr emission standard. The NOx CEMS data will be used to determine compliance with Chapter 129.301 - 310, to determine compliance with Condition 004 in Section E for Group 006, and to develop emission inventories.
- h. Averaging Period: (1) one-hour average, block, and (2) 12-month sum, rolling by 1 month

Compliance with any subsequently issued revisions to the Continuous Source Monitoring Manual will constitute compliance with the regulations.

002 [25 Pa. Code §127.441]**Operating permit terms and conditions.**

Continuous emission monitoring for NOx (lb/hr) shall meet the following minimum data availability requirements

- a.) In accordance with 25 Pa. Code Section 139.101(12), required monitoring shall, at a minimum, meet one of the following

**SECTION E. Source Group Restrictions.**

data availability requirements unless otherwise stipulated in this permit, a plan approval, Title 25 or an order issued under Section 4 of the Air Pollution Control Act:

1.) In each calendar month, at least 90% of the time periods for which each emission standard applies, shall be valid as set forth in the Quality Assurance section of Revision No.8 of the Department's Continuous Source Monitoring Manual, 274-0300-001, or

2.) In each calendar quarter, at least 95% of the hours shall be valid as set forth in the Quality Assurance section of Revision No. 8 of the Department's Continuous Source Monitoring Manual, 274-0300-001.

Compliance with any subsequently issued revisions to the Continuous Source Monitoring Manual will constitute compliance with the regulations.

IV. RECORDKEEPING REQUIREMENTS.**# 003 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

1. The permittee shall comply with the recordkeeping requirements established in 25 Pa. Code Chapter 139, Subchapter C (relating to requirements for source monitoring for stationary sources), the "Record Keeping and Reporting" requirements in the Department's Continuous Source Monitoring Manual, Revision No. 8, 274-0300-001.

2. Records shall be retained for at least 5 years and shall be made available to the Department upon request.

Note: Compliance with any subsequently issued revision to the Continuous Source Monitoring Manual will constitute compliance with this condition.

V. REPORTING REQUIREMENTS.**# 004 [25 Pa. Code §127.441]****Operating permit terms and conditions.**

The permittee shall submit quarterly reports of continuous emission monitoring to the Department in accordance with the requirements established in 25 Pa. Code Chapter 139, Subchapter C (relating to requirements for source monitoring for stationary sources), and the Record Keeping and Reporting requirements as established in Revision No. 8 of the Department's Continuous Source Monitoring Manual, 274-0300-001, and

The permittee shall report emissions for all periods of unit operation, including startup, shutdown and malfunction.

Initial quarterly reports following system certification shall be submitted to the Department within 35 days following the date upon which the Department notifies the owner or operator, in writing, of the approval of the continuous source monitoring system for use in determining compliance with applicable emission standards.

Subsequent quarterly reports shall be submitted to the Department within 30 days after the end of each calendar quarter.

Failure to submit required reports of continuous emission monitoring within the time periods specified in this Condition, shall constitute violations of this Permit, unless approved in advance by the Department in writing.

Compliance with any subsequently issued revision to the Continuous Source Monitoring Manual will constitute compliance with this permit condition.

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

**SECTION E. Source Group Restrictions.****VII. ADDITIONAL REQUIREMENTS.**

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

***** Permit Shield in Effect. *****

**SECTION E. Source Group Restrictions.**

Group Name: 008 PRESUMPTIVE RACT 3 REQUIREMENTS

Group Description: Sources subject to presumptive RACT requirements

Sources included in this group

ID	Name
031	ORR & SEMBOWER BOILER 1
114A	EMER GENERATOR LINE 2, UNIT A (EAST)(1500 KW)
114B	EMER GENERATOR LINE 2, UNIT B (WEST)(1500KW)
114C	DETROIT DIESEL 9163-7301 EMER GENERATOR LINE 1 (2000 KW)
114F	EMER FLOOD PUMP (LARGE)

I. RESTRICTIONS.**Emission Restriction(s).****# 001 [25 Pa. Code §129.111]****Applicability**

§ 129.111. Applicability.

(a) Except as specified in subsection (c), the NO_x requirements of this section and §§ 129.112—129.115 apply Statewide to the owner and operator of a major NO_x emitting facility that commenced operation on or before August 3, 2018, and the VOC requirements of this section and §§ 129.112—129.115 apply Statewide to the owner and operator of a major VOC emitting facility that commenced operation on or before August 3, 2018, for which a requirement or emission limitation, or both, has not been established in §§ 129.51, 129.52(a)—(k) and Table I categories 1—11, 129.52a—129.52e, 129.54—129.63a, 129.64—129.69, 129.71—129.75, 129.77 and 129.101—129.107. The owner or operator shall identify and list the sources and facilities subject to this subsection in the written notification required under § 129.115(a) (relating to written notification, compliance demonstration and recordkeeping and reporting requirements) as follows:

(1) The sources and facilities that commenced operation on or before August 3, 2018, for which a requirement or emission limitation has not been established in §§ 129.51, 129.52(a)—(k) and Table I categories 1—11, 129.52a—129.52e, 129.54—129.63a, 129.64—129.69, 129.71—129.75, 129.77 and 129.101—129.107.

(2) [NA – SOURCES IN THIS GROUP ARE NOT SUBJECT TO REFERENCED SECTIONS]

(b) Except as specified in subsection (c), the NO_x requirements of this section and §§ 129.112—129.115 apply Statewide to the owner and operator of a NO_x emitting facility that commenced operation on or before August 3, 2018, and the VOC requirements of this section and §§ 129.112—129.115 apply Statewide to the owner and operator of a VOC emitting facility that commenced operation on or before August 3, 2018, when the installation and operation of a new source after August 3, 2018, or a modification or change in operation after August 3, 2018, of a source that commenced operation on or before August 3, 2018, results in the source or facility meeting the definition of a major NO_x emitting facility or a major VOC emitting facility and for which a requirement or an emission limitation, or both, has not been established in §§ 129.51, 129.52(a)—(k) and Table I categories 1—11, 129.52a—129.52e, 129.54—129.63a, 129.64—129.69, 129.71—129.75, 129.77 and 129.101—129.107. The owner or operator shall identify and list the sources and facilities subject to this subsection in the written notification required under § 129.115(a) as follows: [NOTE: FACILITY IS CURRENTLY A MAJOR NO_x EMITTING FACILITY ONLY]

(1) The sources and facilities for which a requirement or emission limitation has not been established in §§ 129.51, 129.52(a)—(k) and Table I categories 1—11, 129.52a—129.52e, 129.54—129.63a, 129.64—129.69, 129.71—129.75, 129.77 and 129.101—129.107.

(2) The sources and facilities subject to §§ 129.51, 129.52(a)—(k) and Table I categories 1—11, 129.52a—129.52e, 129.54—129.63a, 129.64—129.69, 129.71—129.75, 129.77 and 129.101—129.107.

(c) [NA – SOURCES IN THIS GROUP HAVE PTE > 1 TPY]

(d) Except as specified in subsection (e), this section and §§ 129.112—129.115 do not apply to the owner and operator of a facility that commenced operation on or before August 3, 2018, that is not a major NO_x emitting facility or a major VOC emitting facility on or before December 31, 2022. [NOTE: FACILITY IS CURRENTLY A MAJOR NO_x EMITTING FACILITY]

**SECTION E. Source Group Restrictions.**

ONLY; THEREFORE, THIS SUBSECTION ONLY APPLIES TO VOC EMISSIONS]

(e) If the owner and operator of a facility that complied with subsection (d) meets the definition of a major NO_x emitting facility or a major VOC emitting facility after December 31, 2022, then the owner and operator shall comply with subsection (b).

§ 129.112. Presumptive RACT requirements, RACT emission limitations and petition for alternative compliance schedule.

(a) The owner and operator of a source listed in one or more of subsections (b)—(k) located at a major NO_x emitting facility or major VOC emitting facility subject to § 129.111 (relating to applicability) shall comply with the applicable presumptive RACT requirement or RACT emission limitation, or both, beginning with the specified compliance date as follows, unless an alternative compliance schedule is submitted and approved under subsections (n)—(p) or § 129.114 (relating to alternative RACT proposal and petition for alternative compliance schedule):

(1) January 1, 2023, for a source subject to § 129.111(a).

(2) [NA - SOURCES IN THIS GROUP ARE NOT SUBJECT TO § 129.111(b)]

(b) The owner and operator of a source listed in this subsection that is located at a major NO_x emitting facility or major VOC emitting facility subject to § 129.111 shall comply with the applicable presumptive RACT requirements in paragraph (1) and recordkeeping and reporting requirements in paragraph (2).

(1) The owner or operator of a:

(i) Combustion unit or process heater with a rated heat input equal to or greater than 20 million Btu/hour and less than 50 million Btu/hour shall conduct a biennial tune-up in accordance with the procedures in 40 CFR 63.11223 (relating to how do I demonstrate continuous compliance with the work practice and management practice standards?). [NOTE: APPLIES ONLY TO SOURCE ID 031]

(A) Each biennial tune-up shall occur not less than 3 months and not more than 24 months after the date of the previous tune-up.

(B) The biennial tune-up must include, at a minimum, the following:

(I) Inspection and cleaning or replacement of fuel-burning equipment, including the burners and components, as necessary, for proper operation as specified by the manufacturer.

(II) Inspection of the flame pattern and adjustment of the burner, as necessary, to optimize the flame pattern to minimize total emissions of NO_x and, to the extent possible, emissions of CO.

(III) Inspection and adjustment, as necessary, of the air-to-fuel ratio control system to ensure proper calibration and operation as specified by the manufacturer.

(ii) [NA – NO COMBUSTION UNIT OR PROCESS HEATER WITH OXYGEN TRIM SYSTEM]

(2) The applicable recordkeeping and reporting requirements of § 129.115(f) and (i) (relating to written notification, compliance demonstration and recordkeeping and reporting requirements).

(3) Compliance with the applicable presumptive RACT requirements in paragraph (1) and recordkeeping and reporting requirements in paragraph (2) assures compliance with the provisions in § 129.93(b)(2), (3), (4) and (5) and 129.97(b)(1), (2) and (3) (relating to presumptive RACT emissions limitations; and presumptive RACT requirements, RACT emission limitations and petition for alternative compliance schedule).

(c) The owner and operator of a source listed in this subsection that is located at a major NO_x emitting facility or major VOC emitting facility subject to § 129.111 shall install, maintain and operate the source in accordance with the manufacturer's specifications and with good operating practices:

**SECTION E. Source Group Restrictions.**

(1) - (9) [NA – SOURCE CATEGORIES DO NOT APPLY]

(10) An emergency standby engine operating less than 500 hours in a 12-month rolling period. [NOTE: APPLIES TO SOURCE IDs 114A, 114B, 114E, 114F, 114H, 114I]

(11) [NA – NO ELECTRIC ARC FURNACE]

(d) [NA – NOT A MAJOR VOC EMITTING FACILITY]

(e) [NA – NOT A MUNICIPAL SOLID WASTE LANDFILL]

(f) [NA – NO MUNICIPAL WASTE COMBUSTOR]

(g) [NA – SOURCE CATEGORIES DO NOT APPLY]

(h) [NA – NO PORTLAND CEMENT KILN]

(i) The owner and operator of a glass melting furnace subject to § 129.111 shall comply with the following presumptive RACT emission limitations as applicable:

(1) – (3) [NA – FURNACES ARE FLAT GLASS FURNACES]

(4) 7.0 pounds of NO_x per ton of glass pulled for flat glass furnaces.

(5) [NA – FURNACES ARE FLAT GLASS FURNACES]

(j) [NA – NO LIME KILN]

(k) [NA – SOURCE CATEGORIES DO NOT APPLY]

(l) The requirements and emission limitations of this section supersede the requirements and emission limitations of a RACT permit issued to the owner or operator of an air contamination source subject to one or more of subsections (b)–(k) prior to November 12, 2022, under § § 129.91–129.95 (relating to stationary sources of NO_x and VOCs) or under § § 129.96–129.100 (relating to additional RACT requirements for major sources of NO_x and VOCs) to control, reduce or minimize NO_x emissions or VOC emissions, or both, from the air contamination source unless the permit contains more stringent requirements or emission limitations, or both.

(m) The requirements and emission limitations of this section supersede the requirements and emission limitations of § § 129.201–129.205, 129.301–129.310, 145.111–145.113 and 145.141–145.146 unless the requirements or emission limitations of § § 129.201–129.205, § § 129.301–129.310, § § 145.111–145.113 or § § 145.141–145.146 are more stringent.

(n) The owner or operator of a major NO_x emitting facility or a major VOC emitting facility subject to § 129.111 that includes an air contamination source subject to one or more of subsections (b)–(k) that cannot meet the applicable presumptive RACT requirement or RACT emission limitation without installation of an air cleaning device may submit a petition, in writing or electronically, requesting an alternative compliance schedule in accordance with the following: [NOTE: THIS SUBSECTION APPLIES TO SOURCE ID 101]

(1) The petition shall be submitted to the Department or appropriate approved local air pollution control agency as soon as possible but not later than:

(i) December 31, 2022, for a source subject to § 129.111(a).

(ii) December 31, 2022, or 6 months after the date that the source meets the definition of a major NO_x emitting facility or a major VOC emitting facility, whichever is later, for a source subject to § 129.111(b).

(2) The petition must include:

**SECTION E. Source Group Restrictions.**

(i) A description, including make, model and location, of each affected source subject to a RACT requirement or a RACT emission limitation in one or more of subsections (b)—(k).

(ii) A description of the proposed air cleaning device to be installed.

(iii) A schedule containing proposed interim dates for completing each phase of the required work to install the air cleaning device described in subparagraph (ii).

(iv) A proposed interim emission limitation that will be imposed on the affected source until compliance is achieved with the applicable RACT requirement or RACT emission limitation.

(v) A proposed final compliance date that is as soon as possible but not later than 3 years after the written approval of the petition by the Department or the appropriate approved local air pollution control agency. The approved petition shall be incorporated in an applicable operating permit or plan approval.

(o) The Department or appropriate approved local air pollution control agency will review the timely and complete written petition requesting an alternative compliance schedule submitted in accordance with subsection (n) and approve or deny the petition in writing.

(p) Approval or denial under subsection (o) of the timely and complete petition for an alternative compliance schedule submitted under subsection (n) will be effective on the date the letter of approval or denial of the petition is signed by the authorized representative of the Department or appropriate approved local air pollution control agency.

(q) The Department will submit each petition for an alternative compliance schedule approved under subsection (o) to the Administrator of the EPA for approval as a revision to the Commonwealth's SIP. The owner and operator of the facility shall bear the costs of public hearings and notifications, including newspaper notices, required for the SIP submittal.

§ 129.113. Facility-wide or system-wide NO_x emissions averaging plan general requirements. [NA – NO FACILITY-WIDE OR SYSTEM-WIDE AVERAGING PLAN]

§ 129.114. Alternative RACT proposal and petition for alternative compliance schedule. [NOTE: ALTERNATIVE RACT REQUIREMENTS ADDRESSED IN SOURCE GROUP 012]

§ 129.115. Written notification, compliance demonstration and recordkeeping and reporting requirements.

(a) [NA – NOTIFICATION DATE IN PAST; SUBMITTED TIMELY]

(b) Except as specified in subsection (d), the owner and operator of an air contamination source subject to a NO_x RACT requirement or RACT emission limitation or VOC RACT requirement or RACT emission limitation, or both, listed in § 129.112 (relating to presumptive RACT requirements, RACT emission limitations and petition for alternative compliance schedule) shall demonstrate compliance with the applicable RACT requirement or RACT emission limitation by performing the following monitoring or testing procedures:

(1) For an air contamination source with a CEMS, monitoring and testing in accordance with the requirements of Chapter 139, Subchapter C (relating to requirements for source monitoring for stationary sources) using a 30-operating day rolling average, except for municipal waste combustors subject to § 129.112(f), combustion units or process heaters subject to § 129.112(g)(1) and direct-fired heaters, furnaces, ovens or other combustion sources subject to § 129.112(k). [NOTE: THIS APPLIES ONLY TO SOURCE IDs 101 AND 102]

(i) A 30-operating day rolling average emission rate for each applicable RACT emission limitation shall be calculated for an affected air contamination source for each consecutive operating day.

(ii) Each 30-operating day rolling average emission rate for an affected air contamination source must include the emissions that occur during the entire operating day, including emissions from start-ups, shutdowns and malfunctions.

(2) – (5) [NA – SOURCE CATEGORIES DO NOT APPLY]

**SECTION E. Source Group Restrictions.**

(6) [NA – SOURCES SUBJECT TO EMISSION LIMITATIONS ARE EQUIPPED WITH CEMS]

(c) [NA – NO COMBINED CYCLE COMBUSTION TURBINE]

(d) Except as specified in § 129.112(n) and § 129.114(l) (relating to alternative RACT proposal and petition for alternative compliance schedule), the owner and operator of an air contamination source subject to subsection (b) shall demonstrate compliance with the applicable RACT requirement or RACT emission limitation in accordance with the procedures in subsection (a) not later than: [NOTE: DOES NOT APPLY TO SOURCE ID 101]

(1) January 1, 2023, for a source subject to § 129.111(a) (relating to applicability).

(2) January 1, 2023, or 1 year after the date that the source meets the definition of a major NO_x emitting facility or major VOC emitting facility, whichever is later, for a source subject to § 129.111(b).

(e) [NA – NO WAIVER REQUESTED]

(f) The owner and operator of an air contamination source subject to this section and § § 129.111—129.114 shall keep records to demonstrate compliance with § § 129.111—129.114 and submit reports to the Department or appropriate approved local air pollution control agency in accordance with the applicable regulations in Part I, Subpart C, Article III (relating to air resources) and as specified in the operating permit or plan approval for the air contamination source as follows:

(1) The records shall include sufficient data and calculations to demonstrate that the requirements of § § 129.111—129.114 are met.

(2) Data or information required to determine compliance shall be recorded and maintained in a time frame consistent with the averaging period of the requirement.

(3) The records necessary to determine compliance shall be reported to the Department or appropriate approved local air pollution control agency on a schedule specified in the applicable regulation or as otherwise specified in the operating permit or plan approval for the air contamination source.

(g) Beginning with the compliance date specified in § 129.112(a), the owner or operator of an air contamination source claiming that the air contamination source is exempt from the applicable NO_x emission rate threshold specified in § 129.114(b) and the requirements of § 129.112 based on the air contamination source's potential to emit shall maintain records that demonstrate to the Department or appropriate approved local air pollution control agency that the air contamination source is not subject to the specified emission rate threshold.

(h) [NA – NOT A MAJOR VOC EMITTING FACILITY]

(i) The owner or operator of a combustion unit or process heater subject to § 129.112(b) shall record each adjustment conducted under the procedures in § 129.112(b). This record must contain, at a minimum: [NOTE: ONLY APPLIES TO SOURCE ID 031]

(1) The date of the tuning procedure.

(2) The name of the service company and the technician performing the procedure.

(3) The final operating rate or load.

(4) The final NO_x and CO emission rates.

(5) The final excess oxygen rate.

(6) Other information required by the applicable operating permit.

(j) [NA – NO PORTLAND CEMENT KILN]

**SECTION E. Source Group Restrictions.**

(k) The records shall be retained by the owner or operator for 5 years and made available to the Department or appropriate approved local air pollution control agency upon receipt of a written request from the Department or appropriate approved local air pollution control agency.

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

IV. RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

VII. ADDITIONAL REQUIREMENTS.

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

***** Permit Shield in Effect. *****

**SECTION E. Source Group Restrictions.**

Group Name: 009 RICE MACT

Group Description: 40 CFR Part 63, Subpart ZZZZ Requirements for Emergency Engines

Sources included in this group

ID	Name
114A	EMER GENERATOR LINE 2, UNIT A (EAST)(1500 KW)
114B	EMER GENERATOR LINE 2, UNIT B (WEST)(1500KW)
114E	EMER FLOOD PUMP (SMALL)
114F	EMER FLOOD PUMP (LARGE)
114H	EMER FIRE PUMP (WEST)
114I	EMER FIRE PUMP (EAST)

I. RESTRICTIONS.

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

IV. RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

VII. ADDITIONAL REQUIREMENTS.

001 [40 CFR Part 63 NESHAPS for Source Categories §40 CFR 63.6585]

Subpart ZZZZ - National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines

Am I subject to this subpart?

§ 63.6585 Am I subject to this subpart?

You are subject to this subpart if you own or operate a stationary RICE at a major or area source of HAP emissions, except if the stationary RICE is being tested at a stationary RICE test cell/stand.

(a) A stationary RICE is any internal combustion engine which uses reciprocating motion to convert heat energy into mechanical work and which is not mobile. Stationary RICE differ from mobile RICE in that a stationary RICE is not a non-road engine as defined at 40 CFR 1068.30, and is not used to propel a motor vehicle or a vehicle used solely for competition.

(b) A major source of HAP emissions is a plant site that emits or has the potential to emit any single HAP at a rate of 10 tons (9.07 megagrams) or more per year or any combination of HAP at a rate of 25 tons (22.68 megagrams) or more per

**SECTION E. Source Group Restrictions.**

year, except that for oil and gas production facilities, a major source of HAP emissions is determined for each surface site.

(c) An area source of HAP emissions is a source that is not a major source.

(d) If you are an owner or operator of an area source subject to this subpart, your status as an entity subject to a standard or other requirements under this subpart does not subject you to the obligation to obtain a permit under 40 CFR part 70 or 71, provided you are not required to obtain a permit under 40 CFR 70.3(a) or 40 CFR 71.3(a) for a reason other than your status as an area source under this subpart. Notwithstanding the previous sentence, you must continue to comply with the provisions of this subpart as applicable.

(e) [NA – NOT USED FOR NATIONAL SECURITY PURPOSES]

(f) [NA – RICE NOT RESIDENTIAL, COMMERCIAL OR INSTITUTIONAL]

[69 FR 33506, June 15, 2004, as amended at 73 FR 3603, Jan. 18, 2008; 78 FR 6700, Jan. 30, 2013; 87 FR 48607, Aug. 10, 2022]

§ 63.6590 What parts of my plant does this subpart cover?

This subpart applies to each affected source.

(a) Affected source. An affected source is any existing, new, or reconstructed stationary RICE located at a major or area source of HAP emissions, excluding stationary RICE being tested at a stationary RICE test cell/stand.

(1) Existing stationary RICE.

(i) [NA – NOT A MAJOR HAP SOURCE]

(ii) [NA – NOT A MAJOR HAP SOURCE]

(iii) For stationary RICE located at an area source of HAP emissions, a stationary RICE is existing if you commenced construction or reconstruction of the stationary RICE before June 12, 2006.

(iv) A change in ownership of an existing stationary RICE does not make that stationary RICE a new or reconstructed stationary RICE.

(2) New stationary RICE.

(i) [NA – NOT A MAJOR HAP SOURCE]

(ii) [NA – NOT A MAJOR HAP SOURCE]

(iii) [NA – NOT A NEW SOURCE]

(3) [NA – NOT A RECONSTRUCTED SOURCE]

(b) Stationary RICE subject to limited requirements. (1) An affected source which meets either of the criteria in paragraphs (b)(1)(i) through (ii) of this section does not have to meet the requirements of this subpart and of subpart A of this part except for the initial notification requirements of § 63.6645(f).

(i) [NA – NOT A MAJOR HAP SOURCE]

(ii) [NA – NOT A MAJOR HAP SOURCE]

(2) [NA – NOT A MAJOR HAP SOURCE AND DOES NOT COMBUST LFG]

(3) The following stationary RICE do not have to meet the requirements of this subpart and of subpart A of this part,

**SECTION E. Source Group Restrictions.**

including initial notification requirements:

- (i) [NA – NOT A MAJOR HAP SOURCE]
- (ii) [NA – NOT A MAJOR HAP SOURCE]
- (iii) [NA – NOT A MAJOR HAP SOURCE]
- (iv) [NA – NOT A MAJOR HAP SOURCE]
- (v) [NA – NOT A MAJOR HAP SOURCE AND DOES NOT COMBUST LFG]
- (c) [NA – NOT SUBJECT TO SUBPARTS IIII OR JJJJ]

[69 FR 33506, June 15, 2004, as amended at 73 FR 3604, Jan. 18, 2008; 75 FR 9674, Mar. 3, 2010; 75 FR 37733, June 30, 2010; 75 FR 51588, Aug. 20, 2010; 78 FR 6700, Jan. 30, 2013; 87 FR 48607, Aug. 10, 2022]

§ 63.6595 When do I have to comply with this subpart?

(a) Affected sources. (1) If you have an existing stationary RICE, excluding existing non-emergency CI stationary RICE, with a site rating of more than 500 brake HP located at a major source of HAP emissions, you must comply with the applicable emission limitations, operating limitations and other requirements no later than June 15, 2007. IF YOU HAVE an existing non-emergency CI stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, an existing stationary CI RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions, or AN EXISTING STATIONARY CI RICE LOCATED AT AN AREA SOURCE OF HAP EMISSIONS, YOU MUST COMPLY WITH THE APPLICABLE EMISSION LIMITATIONS, OPERATING LIMITATIONS, AND OTHER REQUIREMENTS NO LATER THAN MAY 3, 2013.

IF YOU HAVE an existing stationary SI RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions, or AN EXISTING STATIONARY SI RICE LOCATED AT AN AREA SOURCE OF HAP EMISSIONS, YOU MUST COMPLY WITH THE APPLICABLE EMISSION LIMITATIONS, OPERATING LIMITATIONS, AND OTHER REQUIREMENTS NO LATER THAN OCTOBER 19, 2013.

- (2) [NA – NOT A MAJOR HAP SOURCE]
- (3) [NA – NOT A MAJOR HAP SOURCE]
- (4) [NA – NOT A MAJOR HAP SOURCE]
- (5) [NA – NOT A MAJOR HAP SOURCE]
- (6) [NA – NOT SUBJECT TO EMISSION OR OPERATING LIMITATIONS]
- (7) [NA – NOT SUBJECT TO EMISSION OR OPERATING LIMITATIONS]

(b) Area sources that become major sources. If you have an area source that increases its emissions or its potential to emit such that it becomes a major source of HAP, the compliance dates in paragraphs (b)(1) and (2) of this section apply to you.

(1) Any stationary RICE for which construction or reconstruction is commenced after the date when your area source becomes a major source of HAP must be in compliance with this subpart upon startup of your affected source.

(2) Any stationary RICE for which construction or reconstruction is commenced before your area source becomes a major source of HAP must be in compliance with the provisions of this subpart that are applicable to RICE located at major sources within 3 years after your area source becomes a major source of HAP.

(c) If you own or operate an affected source, you must meet the applicable notification requirements in § 63.6645 and in 40 CFR part 63, subpart A.

**SECTION E. Source Group Restrictions.**

[69 FR 33506, June 15, 2004, as amended at 73 FR 3604, Jan. 18, 2008; 75 FR 9675, Mar. 3, 2010; 75 FR 51589, Aug. 20, 2010; 78 FR 6701, Jan. 30, 2013]

Emission and Operating Limitations

§ 63.6600 What emission limitations and operating limitations must I meet if I own or operate a stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions?

[NA – NOT SUBJECT TO EMISSION OR OPERATING LIMITATIONS]

§ 63.6601 What emission limitations must I meet if I own or operate a new or reconstructed 4SLB stationary RICE with a site rating of greater than or equal to 250 brake HP and less than or equal to 500 brake HP located at a major source of HAP emissions?

[NA – NOT SUBJECT TO EMISSION OR OPERATING LIMITATIONS]

§ 63.6602 What emission limitations and other requirements must I meet if I own or operate an existing stationary RICE with a site rating of equal to or less than 500 brake HP located at a major source of HAP emissions?

[NA – NOT SUBJECT TO EMISSION OR OPERATING LIMITATIONS]

§ 63.6603 What emission limitations, operating limitations, and other requirements must I meet if I own or operate an existing stationary RICE located at an area source of HAP emissions?

Compliance with the numerical emission limitations established in this subpart is based on the results of testing the average of three 1-hour runs using the testing requirements and procedures in § 63.6620 and Table 4 to this subpart.

(a) If you own or operate an existing stationary RICE located at an area source of HAP emissions, YOU MUST COMPLY WITH THE REQUIREMENTS IN TABLE 2d to this subpart and the operating limitations in Table 2b to this subpart that apply to you.

TABLE 2d REQUIREMENTS:

4. For each EMERGENCY STATIONARY CI RICE and black start stationary CI RICE**, you must meet the following requirement, except during periods of startup:

- a. Change oil and filter every 500 hours of operation or within 1 year + 30 days of the previous change, whichever comes first*;
- b. Inspect air cleaner every 1,000 hours of operation or within 1 year + 30 days of the previous change, whichever comes first, and replace as necessary; and
- c. Inspect all hoses and belts every 500 hours of operation or within 1 year + 30 days of the previous change, whichever comes first, and replace as necessary.

5. For each EMERGENCY STATIONARY SI RICE; black start stationary SI RICE; non-emergency, non-black start 4SLB stationary RICE >500 HP that operate 24 hours or less per calendar year; non-emergency, non-black start 4SRB stationary RICE >500 HP that operate 24 hours or less per calendar year**, you must meet the following requirement, except during periods of startup:

- a. Change oil and filter every 500 hours of operation or within 1 year + 30 days of the previous change, whichever comes first*;
- b. Inspect spark plugs every 1,000 hours of operation or within 1 year + 30 days of the previous change, whichever comes first, and replace as necessary; and

**SECTION E. Source Group Restrictions.**

c. Inspect all hoses and belts every 500 hours of operation or within 1 year + 30 days of the previous change, whichever comes first, and replace as necessary.

*Sources have the option to utilize an oil analysis program as described in § 63.6625(i) or (j) in order to extend the specified oil change requirement in Table 2d of this subpart.

**If an emergency engine is operating during an emergency and it is not possible to shut down the engine in order to perform the management practice requirements on the schedule required in Table 2d of this subpart, or if performing the management practice on the required schedule would otherwise pose an unacceptable risk under federal, state, or local law, the management practice can be delayed until the emergency is over or the unacceptable risk under federal, state, or local law has abated. The management practice should be performed as soon as practicable after the emergency has ended or the unacceptable risk under federal, state, or local law has abated. Sources must report any failure to perform the management practice on the schedule required and the federal, state or local law under which the risk was deemed unacceptable.

[END OF TABLE 2d REQUIREMENTS]

(b) [NA – EMERGENCY ENGINE(S)]

(c) [NA – EMERGENCY ENGINE(S)]

(d) [NA – EMERGENCY ENGINE(S)]

(e) [NA – EMERGENCY ENGINE(S)]

(f) [NA – EMERGENCY ENGINE(S)]

[75 FR 9675, Mar. 3, 2010, as amended at 75 FR 51589, Aug. 20, 2010; 76 FR 12866, Mar. 9, 2011; 78 FR 6701, Jan. 30, 2013; 89 FR 70515, Aug. 30, 2024]

§ 63.6604 What fuel requirements must I meet if I own or operate a stationary CI RICE?

(a) [NA – EMERGENCY ENGINE(S)]

(b) Beginning January 1, 2015, if you own or operate an existing emergency CI stationary RICE with a site rating of more than 100 brake HP and a displacement of less than 30 liters per cylinder that uses diesel fuel and operates for the purpose specified in § 63.6640(f)(4)(ii), you must use diesel fuel that meets the requirements in 40 CFR 1090.305 for nonroad diesel fuel, except that any existing diesel fuel purchased (or otherwise obtained) prior to January 1, 2015, may be used until depleted.

(c) (Reserved)

(d) [NA – NOT IN SPECIFIED GEOGRAPHIC LOCATIONS]

[78 FR 6702, Jan. 30, 2013, as amended at 85 FR 78463, Dec. 4, 2020; 87 FR 48607, Aug. 10, 2022]

General Compliance Requirements

§ 63.6605 What are my general requirements for complying with this subpart?

(a) You must be in compliance with the emission limitations, operating limitations, and other requirements in this subpart that apply to you at all times.

(b) At all times you must operate and maintain any affected source, including associated air pollution control equipment and monitoring equipment, in a manner consistent with safety and good air pollution control practices for minimizing emissions. The general duty to minimize emissions does not require you to make any further efforts to reduce emissions if levels required by this standard have been achieved. Determination of whether such operation and maintenance procedures are

**SECTION E. Source Group Restrictions.**

being used will be based on information available to the Administrator which may include, but is not limited to, monitoring results, review of operation and maintenance procedures, review of operation and maintenance records, and inspection of the source.

[75 FR 9675, Mar. 3, 2010, as amended at 78 FR 6702, Jan. 30, 2013]

Testing and Initial Compliance Requirements

§ 63.6610 By what date must I conduct the initial performance tests or other initial compliance demonstrations if I own or operate a stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions?

[NA – NOT A MAJOR HAP SOURCE]

§ 63.6611 By what date must I conduct the initial performance tests or other initial compliance demonstrations if I own or operate a new or reconstructed 4SLB SI stationary RICE with a site rating of greater than or equal to 250 and less than or equal to 500 brake HP located at a major source of HAP emissions?

[NA – NOT A MAJOR HAP SOURCE]

§ 63.6612 By what date must I conduct the initial performance tests or other initial compliance demonstrations if I own or operate an existing stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions or an existing stationary RICE located at an area source of HAP emissions?

[NA – NO PERFORMANCE TESTING REQUIRED]

§ 63.6615 When must I conduct subsequent performance tests?

[NA – NOT SUBJECT TO EMISSION OR OPERATING LIMITATIONS]

§ 63.6620 What performance tests and other procedures must I use?

[NA – NO PERFORMANCE TESTING REQUIRED]

§ 63.6625 What are my monitoring, installation, collection, operation, and maintenance requirements?

(a) [NA – CEMS NOT REQUIRED]

(b) [NA – CPMS NOT REQUIRED]

(c) [NA – LFG NOT USED]

(d) [NA – NOT A MAJOR HAP SOURCE]

(e) If you own or operate any of the following stationary RICE, you must operate and maintain the stationary RICE and after-treatment control device (if any) according to the manufacturer's emission-related written instructions or develop your own maintenance plan which must provide to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions:

(1) [NA – NOT A MAJOR HAP SOURCE]

(2) [NA – NOT A MAJOR HAP SOURCE]

(3) An existing emergency or black start stationary RICE located at an area source of HAP emissions;

(4) [NA – EMERGENCY ENGINE(S)]

(5) [NA – EMERGENCY ENGINE(S)]

**SECTION E. Source Group Restrictions.**

(6) [NA – EMERGENCY ENGINE(S)]

(7) [NA – EMERGENCY ENGINE(S)]

(8) [NA – EMERGENCY ENGINE(S)]

(9) [NA – EMERGENCY ENGINE(S)]

(10) [NA – EMERGENCY ENGINE(S)]

(f) If you own or operate an existing emergency stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions or an existing emergency stationary RICE located at an area source of HAP emissions, you must install a non-resettable hour meter if one is not already installed.

(g) [NA – EMERGENCY ENGINE(S)]

(h) If you operate a new, reconstructed, or existing stationary engine, you must minimize the engine's time spent at idle during startup and minimize the engine's startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes, after which time the emission standards applicable to all times other than startup in Tables 1a, 2a, 2c, and 2d to this subpart apply.

(i) If you own or operate a stationary CI engine that is subject to the work, operation or management practices in items 1 or 2 of table 2c to this subpart or in items 1 or 4 of table 2d to this subpart, you have the option of utilizing an oil analysis program in order to extend the specified oil and filter change requirement in tables 2c and 2d to this subpart. The oil analysis must be performed at the same frequency specified for changing the oil and filter in table 2c or 2d to this subpart. The analysis program must at a minimum analyze the following three parameters: Total Base Number, viscosity, and percent water content. The condemning limits for these parameters are as follows: Total Base Number is less than 30 percent of the Total Base Number of the oil when new; viscosity of the oil has changed by more than 20 percent from the viscosity of the oil when new; or percent water content (by volume) is greater than 0.5. If all of these condemning limits are not exceeded, the engine owner or operator is not required to change the oil and filter. If any of the limits are exceeded, the engine owner or operator must change the oil and filter within 2 business days of receiving the results of the analysis; if the engine is not in operation when the results of the analysis are received, the engine owner or operator must change the oil and filter within 2 business days or before commencing operation, whichever is later. The owner or operator must keep records of the parameters that are analyzed as part of the program, the results of the analysis, and the oil and filter changes for the engine. The analysis program must be part of the maintenance plan for the engine.

(j) If you own or operate a stationary SI engine that is subject to the work, operation or management practices in items 6, 7, or 8 of Table 2c to this subpart or in items 5, 6, 7, 9, or 11 of Table 2d to this subpart, you have the option of utilizing an oil analysis program in order to extend the specified oil change requirement in Tables 2c and 2d to this subpart. The oil analysis must be performed at the same frequency specified for changing the oil in Table 2c or 2d to this subpart. The analysis program must at a minimum analyze the following three parameters: Total Acid Number, viscosity, and percent water content. The condemning limits for these parameters are as follows: Total Acid Number increases by more than 3.0 milligrams of potassium hydroxide (KOH) per gram from Total Acid Number of the oil when new; viscosity of the oil has changed by more than 20 percent from the viscosity of the oil when new; or percent water content (by volume) is greater than 0.5. If all of these condemning limits are not exceeded, the engine owner or operator is not required to change the oil. If any of the limits are exceeded, the engine owner or operator must change the oil within 2 business days of receiving the results of the analysis; if the engine is not in operation when the results of the analysis are received, the engine owner or operator must change the oil within 2 business days or before commencing operation, whichever is later. The owner or operator must keep records of the parameters that are analyzed as part of the program, the results of the analysis, and the oil changes for the engine. The analysis program must be part of the maintenance plan for the engine.

[69 FR 33506, June 15, 2004, as amended at 73 FR 3606, Jan. 18, 2008; 75 FR 9676, Mar. 3, 2010; 75 FR 51589, Aug. 20, 2010; 76 FR 12866, Mar. 9, 2011; 78 FR 6703, Jan. 30, 2013; 89 FR 70516, Aug. 30, 2024]

§ 63.6630 How do I demonstrate initial compliance with the emission limitations, operating limitations, and other requirements?

**SECTION E. Source Group Restrictions.**

(a) You must demonstrate initial compliance with each emission limitation, operating limitation, and other requirement that applies to you according to Table 5 of this subpart. [NA – NONE OF THE CATEGORIES IN TABLE 5 APPLY TO EMERGENCY ENGINES]

(b) [NA – PERFORMANCE TESTING NOT REQUIRED]

(c) [NA – NOCS NOT REQUIRED FOR EXISTING EMERGENCY RICE]

(d) [NA – EMERGENCY ENGINE(S)]

(e) [NA – EMERGENCY ENGINE(S)]

[69 FR 33506, June 15, 2004, as amended at 78 FR 6704, Jan. 30, 2013]

Continuous Compliance Requirements

§ 63.6635 How do I monitor and collect data to demonstrate continuous compliance?

[NA – NOT SUBJECT TO EMISSION OR OPERATING LIMITATIONS]

§ 63.6640 How do I demonstrate continuous compliance with the emission limitations, operating limitations, and other requirements?

(a) You must demonstrate continuous compliance with each emission limitation, operating limitation, and other requirements in Tables 1a and 1b, Tables 2a and 2b, Table 2c, and Table 2d to this subpart that apply to you according to methods specified in Table 6 to this subpart.

TABLE 6 REQUIREMENTS

9. FOR EACH existing emergency and black start stationary RICE ≤ 500 HP located at a major source of HAP, existing non-emergency stationary RICE < 100 HP located at a major source of HAP, EXISTING EMERGENCY and black start STATIONARY RICE LOCATED AT AN AREA SOURCE OF HAP, existing non-emergency stationary CI RICE ≈ 300 HP located at an area source of HAP, existing non-emergency 2SLB stationary RICE located at an area source of HAP, existing non-emergency stationary SI RICE located at an area source of HAP which combusts landfill or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, existing non-emergency 4SLB and 4SRB stationary RICE ≤ 500 HP located at an area source of HAP, existing non-emergency 4SLB and 4SRB stationary RICE > 500 HP located at an area source of HAP that operate 24 hours or less per calendar year, and existing non-emergency 4SLB and 4SRB stationary RICE > 500 HP located at an area source of HAP that are remote stationary RICE, complying with the requirement to "Work or Management practices", you must demonstrate continuous compliance by:

i. Operating and maintaining the stationary RICE according to the manufacturer's emission-related operation and maintenance instructions; or

ii. Develop and follow your own maintenance plan which must provide to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions.

[END OF TABLE 6 REQUIREMENTS]

(b) [NA – NOT SUBJECT TO EMISSION OR OPERATING LIMITATIONS]

(c) [NA – ANNUAL COMPLIANCE DEMONSTRATION NOT REQUIRED]

(d) [NA – NOT SUBJECT TO EMISSION OR OPERATING LIMITATIONS]

(e) You must also report each instance in which you did not meet the requirements in Table 8 to this subpart that apply to you. If you own or operate a new or reconstructed stationary RICE with a site rating of less than or equal to 500 brake HP

**SECTION E. Source Group Restrictions.**

located at a major source of HAP emissions (except new or reconstructed 4SLB engines greater than or equal to 250 and less than or equal to 500 brake HP), a new or reconstructed stationary RICE located at an area source of HAP emissions, or any of the following RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you do not need to comply with the requirements in Table 8 to this subpart: An existing 2SLB stationary RICE, an existing 4SLB stationary RICE, an existing emergency stationary RICE, an existing limited use stationary RICE, or an existing stationary RICE which fires landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis. If you own or operate any of the following RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you do not need to comply with the requirements in Table 8 to this subpart, except for the initial notification requirements: a new or reconstructed stationary RICE that combusts landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, a new or reconstructed emergency stationary RICE, or a new or reconstructed limited use stationary RICE. [EXISTING EMERGENCY RICE AT AREA HAP SOURCES ARE NOT AMONG THOSE EXEMPTED FROM THIS SECTION]

(f) If you own or operate an emergency stationary RICE, you must operate the emergency stationary RICE according to the requirements in paragraphs (f)(1) through (4) of this section. In order for the engine to be considered an emergency stationary RICE under this subpart, any operation other than emergency operation, maintenance and testing, and operation in non-emergency situations for 50 hours per year, as described in paragraphs (f)(1) through (4), is prohibited. If you do not operate the engine according to the requirements in paragraphs (f)(1) through (4), the engine will not be considered an emergency engine under this subpart and must meet all requirements for non-emergency engines.

(1) There is no time limit on the use of emergency stationary RICE in emergency situations.

(2) You may operate your emergency stationary RICE for the purpose specified in paragraph (f)(2)(i) of this section for a maximum of 100 hours per calendar year. Any operation for non-emergency situations as allowed by paragraphs (f)(3) and (4) of this section counts as part of the 100 hours per calendar year allowed by this paragraph (f)(2).

(i) Emergency stationary RICE may be operated for maintenance checks and readiness testing, provided that the tests are recommended by federal, state or local government, the manufacturer, the vendor, the regional transmission organization or equivalent balancing authority and transmission operator, or the insurance company associated with the engine. The owner or operator may petition the Administrator for approval of additional hours to be used for maintenance checks and readiness testing, but a petition is not required if the owner or operator maintains records indicating that federal, state, or local standards require maintenance and testing of emergency RICE beyond 100 hours per calendar year.

(ii)-(iii) [Reserved]

(3) [NA – NOT A MAJOR HAP SOURCE]

(4) Emergency stationary RICE located at area sources of HAP may be operated for up to 50 hours per calendar year in non-emergency situations. The 50 hours of operation in non-emergency situations are counted as part of the 100 hours per calendar year for maintenance and testing provided in paragraph (f)(2) of this section. Except as provided in paragraphs (f)(4)(i) and (ii) of this section, the 50 hours per year for non-emergency situations cannot be used for peak shaving or non-emergency demand response, or to generate income for a facility to an electric grid or otherwise supply power as part of a financial arrangement with another entity.

(i) Prior to May 3, 2014, the 50 hours per year for non-emergency situations can be used for peak shaving or non-emergency demand response to generate income for a facility, or to otherwise supply power as part of a financial arrangement with another entity if the engine is operated as part of a peak shaving (load management program) with the local distribution system operator and the power is provided only to the facility itself or to support the local distribution system.

(ii) The 50 hours per year for non-emergency situations can be used to supply power as part of a financial arrangement with another entity if all of the following conditions are met:

(A) The engine is dispatched by the local balancing authority or local transmission and distribution system operator.

(B) The dispatch is intended to mitigate local transmission and/or distribution limitations so as to avert potential voltage collapse or line overloads that could lead to the interruption of power supply in a local area or region.

**SECTION E. Source Group Restrictions.**

(C) The dispatch follows reliability, emergency operation or similar protocols that follow specific NERC, regional, state, public utility commission or local standards or guidelines.

(D) The power is provided only to the facility itself or to support the local transmission and distribution system.

(E) The owner or operator identifies and records the entity that dispatches the engine and the specific NERC, regional, state, public utility commission or local standards or guidelines that are being followed for dispatching the engine. The local balancing authority or local transmission and distribution system operator may keep these records on behalf of the engine owner or operator.

[69 FR 33506, June 15, 2004, as amended at 71 FR 20467, Apr. 20, 2006; 73 FR 3606, Jan. 18, 2008; 75 FR 9676, Mar. 3, 2010; 75 FR 51591, Aug. 20, 2010; 78 FR 6704, Jan. 30, 2013; 87 FR 48607, Aug. 10, 2022]

Notifications, Reports, and Records**§ 63.6645 What notifications must I submit and when?**

(a) You must submit all of the notifications in §§ 63.7(b) and (c), 63.8(e), (f)(4) and (f)(6), 63.9(b) through (e), and (g) and (h) that apply to you by the dates specified if you own or operate any of the following;

(1) [NA – NOT A MAJOR HAP SOURCE]

(2) [NA PER (5) BELOW]

(3) [NA – NOT A MAJOR HAP SOURCE]

(4) [NA – NOT A MAJOR HAP SOURCE]

(5) THIS REQUIREMENT DOES NOT APPLY IF YOU OWN OR OPERATE an existing stationary RICE less than 100 HP, AN EXISTING STATIONARY EMERGENCY RICE, OR AN EXISTING STATIONARY RICE THAT IS NOT SUBJECT TO ANY NUMERICAL EMISSION STANDARDS.

(b) [NA – NOT A MAJOR HAP SOURCE]

(c) [NA – NOT A MAJOR HAP SOURCE]

(d) [NA – NOT A MAJOR HAP SOURCE]

(e) [NA – NOT A MAJOR HAP SOURCE]

(f) [NA – 63.6590(b) DOES NOT APPLY]

(g) [NA – PERFORMANCE TEST NOT REQUIRED]

(h) [NA – PERFORMANCE TEST NOT REQUIRED]

(i) [NA – EMERGENCY ENGINE(S)]

[73 FR 3606, Jan. 18, 2008, as amended at 75 FR 9677, Mar. 3, 2010; 75 FR 51591, Aug. 20, 2010; 78 FR 6705, Jan. 30, 2013; 85 FR 73912, Nov. 19, 2020; 89 FR 70516, Aug. 30, 2024]

§ 63.6650 What reports must I submit and when?

(a) You must submit each report in Table 7 of this subpart that applies to you.

TABLE 7 REQUIREMENTS

**SECTION E. Source Group Restrictions.**

4. For each emergency stationary RICE that operate for the purposes specified in § 63.6640(f)(4)(ii), you must submit a Report. The report must contain the information in § 63.6650(h)(1). You must submit the report annually according to the requirements in § 63.6650(h)(2)-(3).

END OF TABLE 7 REQUIREMENTS

(b) Unless the Administrator has approved a different schedule for submission of reports under § 63.10(a), you must submit each report by the date in Table 7 of this subpart and according to the requirements in paragraphs (b)(1) through (b)(9) of this section.

(1) [NA – ANNUAL REPORT REQUIRED, ONLY UNDER CERTAIN CONDITIONS]

(2) [NA – ANNUAL REPORT REQUIRED, ONLY UNDER CERTAIN CONDITIONS]

(3) [NA – ANNUAL REPORT REQUIRED, ONLY UNDER CERTAIN CONDITIONS]

(4) [NA – ANNUAL REPORT REQUIRED, ONLY UNDER CERTAIN CONDITIONS]

(5) [NA – ANNUAL REPORT REQUIRED, ONLY UNDER CERTAIN CONDITIONS]

(6) For annual Compliance reports, the first Compliance report must cover the period beginning on the compliance date that is specified for your affected source in § 63.6595 and ending on December 31.

(7) For annual Compliance reports, the first Compliance report must be postmarked or delivered no later than January 31 following the end of the first calendar year after the compliance date that is specified for your affected source in § 63.6595.

(8) For annual Compliance reports, each subsequent Compliance report must cover the annual reporting period from January 1 through December 31.

(9) For annual Compliance reports, each subsequent Compliance report must be postmarked or delivered no later than January 31.

(c) [NA – “COMPLIANCE REPORT” NOT REQUIRED]

(d) [NA – NOT SUBJECT TO EMISSION OR OPERATING LIMITATIONS]

(e) [NA – NOT SUBJECT TO EMISSION OR OPERATING LIMITATIONS]

(f) [NA – NOT SUBJECT TO TITLE V PERMITTING]

(g) [NA – LFG NOT USED]

(h) If you own or operate an emergency stationary RICE with a site rating of more than 100 brake HP that operates for the purpose specified in § 63.6640(f)(4)(ii), you must submit an annual report according to the requirements in paragraphs (h)(1) through (3) of this section.

(1) The report must contain the following information:

(i) Company name and address where the engine is located.

(ii) Date of the report and beginning and ending dates of the reporting period.

(iii) Engine site rating in brake HP, year construction of the engine commenced (as defined in § 63.2, where the exact year is not known, provide the best estimate), and type of engine (CI, SI 2SLB, SI 4SLB, SI 4SRB).

(iv) Latitude and longitude of the engine in decimal degrees reported to the fifth decimal place.

**SECTION E. Source Group Restrictions.**

(v)-(vi) {Reserved}

(vi) Hours spent for operation for the purpose specified in § 63.6640(f)(4)(ii), including the date, start time, and end time for engine operation for the purposes specified in § 63.6640(f)(4)(ii). The report must also identify the entity that dispatched the engine and the situation that necessitated the dispatch of the engine.

(vii) If there were no deviations from the fuel requirements in § 63.6604 that apply to the engine (if any), a statement that there were no deviations from the fuel requirements during the reporting period.

(ix) If there were deviations from the fuel requirements in § 63.6604 that apply to the engine (if any), information on the number, duration (in hours), and cause of deviations, and the corrective action taken.

(2) The first annual report must cover the calendar year 2015 and must be submitted no later than March 31, 2016. Subsequent annual reports for each calendar year must be submitted no later than March 31 of the following calendar year.

(3) Before February 26, 2025, the annual report must be submitted electronically using the subpart specific reporting form in the Compliance and Emissions Data Reporting Interface (CEDRI) that is accessed through EPA's Central Data Exchange (CDX) (<https://cdx.epa.gov/>). However, if the reporting form specific to this subpart is not available in CEDRI at the time that the report is due, the written report must be submitted to the Administrator at the appropriate address listed in § 63.13. Beginning on February 26, 2025, the annual report must be submitted according to paragraph (i) of this section.

(i) Beginning on February 26, 2025 for the annual report specified in § 63.6650(h) and February 26, 2025 or one year after the report becomes available in CEDRI, whichever is later for all other semiannual or annual reports, submit all semiannual and annual subsequent compliance reports using the appropriate electronic report template on the CEDRI website (<https://www.epa.gov/electronic-reporting-air-emissions/cedri>) for this subpart and following the procedure specified in § 63.9(k), except any CBI must be submitted according to the procedures in § 63.6645(h). The date report templates become available will be listed on the CEDRI website. Unless the Administrator or delegated state agency or other authority has approved a different schedule for submission of reports, the report must be submitted by the deadline specified in this subpart, regardless of the method in which the report is submitted.

[69 FR 33506, June 15, 2004, as amended at 75 FR 9677, Mar. 3, 2010; 78 FR 6705, Jan. 30, 2013; 87 FR 48607, Aug. 10, 2022; 89 FR 70517, Aug. 30, 2024]

§ 63.6655 What records must I keep?

(a) [NA – NOT SUBJECT TO EMISSION OR OPERATING LIMITATIONS]

(b) [NA – NO CEMS OR CPMS]

(c) [NA – LFG NOT USED]

(d) [NA – NOT SUBJECT TO EMISSION OR OPERATING LIMITATIONS]

(e) You must keep records of the maintenance conducted on the stationary RICE in order to demonstrate that you operated and maintained the stationary RICE and after-treatment control device (if any) according to your own maintenance plan if you own or operate any of the following stationary RICE;

(1) [NA – NOT A MAJOR HAP SOURCE]

(2) An existing stationary emergency RICE.

(3) An existing stationary RICE located at an area source of HAP emissions subject to management practices as shown in Table 2d to this subpart.

(f) If you own or operate any of the stationary RICE in paragraphs (f)(1) through (2) of this section, you must keep records of the hours of operation of the engine that is recorded through the non-resettable hour meter. The owner or operator must document how many hours are spent for emergency operation, including what classified the operation as emergency and

**SECTION E. Source Group Restrictions.**

how many hours are spent for non-emergency operation. If the engine is used for the purpose specified in § 63.6640(f)(4)(ii), the owner or operator must keep records of the notification of the emergency situation, and the date, start time, and end time of engine operation for these purposes.

(1) [NA – NOT A MAJOR HAP SOURCE]

(2) An existing emergency stationary RICE located at an area source of HAP emissions that does not meet the standards applicable to non-emergency engines.

[69 FR 33506, June 15, 2004, as amended at 75 FR 9678, Mar. 3, 2010; 75 FR 51592, Aug. 20, 2010; 78 FR 6706, Jan. 30, 2013; 87 FR 48607, Aug. 10, 2022; 89 FR 70518, Aug. 30, 2024]

§ 63.6660 In what form and how long must I keep my records?

(a) Your records must be in a form suitable and readily available for expeditious review according to § 63.10(b)(1).

(b) As specified in § 63.10(b)(1), you must keep each record for 5 years following the date of each occurrence, measurement, maintenance, corrective action, report, or record.

(c) You must keep each record readily accessible in hard copy or electronic form for at least 5 years after the date of each occurrence, measurement, maintenance, corrective action, report, or record, according to § 63.10(b)(1).

[69 FR 33506, June 15, 2004, as amended at 75 FR 9678, Mar. 3, 2010]

Other Requirements and Information

§ 63.6665 What parts of the General Provisions apply to me?

Table 8 to this subpart shows which parts of the General Provisions in §§ 63.1 through 63.15 apply to you. If you own or operate a new or reconstructed stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions (except new or reconstructed 4SLB engines greater than or equal to 250 and less than or equal to 500 brake HP), a new or reconstructed stationary RICE located at an area source of HAP emissions, or any of the following RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you do not need to comply with any of the requirements of the General Provisions specified in Table 8: An existing 2SLB stationary RICE, an existing 4SLB stationary RICE, an existing stationary RICE that combusts landfill or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, an existing emergency stationary RICE, or an existing limited use stationary RICE. If you own or operate any of the following RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you do not need to comply with the requirements in the General Provisions specified in Table 8 except for the initial notification requirements: A new stationary RICE that combusts landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, a new emergency stationary RICE, or a new limited use stationary RICE. [EXISTING EMERGENCY RICE AT AREA HAP SOURCES ARE NOT AMONG THOSE EXEMPTED FROM THIS SECTION]

[75 FR 9678, Mar. 3, 2010]

§ 63.6670 Who implements and enforces this subpart?

(a) This subpart is implemented and enforced by the U.S. EPA, or a delegated authority such as your State, local, or tribal agency. If the U.S. EPA Administrator has delegated authority to your State, local, or tribal agency, then that agency (as well as the U.S. EPA) has the authority to implement and enforce this subpart. You should contact your U.S. EPA Regional Office to find out whether this subpart is delegated to your State, local, or tribal agency.

(b) In delegating implementation and enforcement authority of this subpart to a State, local, or tribal agency under 40 CFR part 63, subpart E, the authorities contained in paragraph (c) of this section are retained by the Administrator of the U.S. EPA and are not transferred to the State, local, or tribal agency.

(c) The authorities that will not be delegated to State, local, or tribal agencies are:

**SECTION E. Source Group Restrictions.**

- (1) Approval of alternatives to the non-opacity emission limitations and operating limitations in § 63.6600 under § 63.6(g).
- (2) Approval of major alternatives to test methods under § 63.7(e)(2)(ii) and (f) and as defined in § 63.90.
- (3) Approval of major alternatives to monitoring under § 63.8(f) and as defined in § 63.90.
- (4) Approval of major alternatives to recordkeeping and reporting under § 63.10(f) and as defined in § 63.90.
- (5) Approval of a performance test which was conducted prior to the effective date of the rule, as specified in § 63.6610(b).
- (6) Approval of an alternative to any electronic reporting to the EPA required by this subpart.

[69 FR 33506, June 15, 2004, as amended at 89 FR 70518, Aug. 30, 2024]

§ 63.6675 What definitions apply to this subpart? [INCORPORATED BY REFERENCE]

Regulatory Changes:

Individual sources within this source group that are subject to 40 CFR Part 63 Subpart ZZZZ -National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines shall comply with all applicable requirements of the Subpart. 40 CFR 63.13(a) requires submission of copies of all requests, reports and other communications to both the Department and the EPA. The EPA copies shall be forwarded to:

United States Environmental Protection Agency
Region III, Air and Radiation Division
Permits Branch (3AD10)
Four Penn Center
1600 John F. Kennedy Boulevard
Philadelphia, Pennsylvania 19103-2852

Unless otherwise approved by DEP, the DEP copies shall be reported through the Department's Greenport PUP system available through: <https://greenport.pa.gov/ePermitPublicAccess/PublicSubmission/Home>.

In the event that the Federal Subpart that is the subject of this Source Group is revised, the permittee shall comply with the revised version of the subpart, and shall not be required to comply with any provisions in this permit designated as having the subpart as their authority, to the extent that such permit provisions would be inconsistent with the applicable provisions of the revised subpart.

***** Permit Shield in Effect. *****

**SECTION E. Source Group Restrictions.**

Group Name: 010 NSPS IIII

Group Description: 40 CFR Part 60, Subpart IIII Requirements for Emergency Stationary CI RICE

Sources included in this group

ID	Name
114C	DETROIT DIESEL 9163-7301 EMER GENERATOR LINE 1 (2000 KW)

I. RESTRICTIONS.

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

IV. RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

VII. ADDITIONAL REQUIREMENTS.

**# 001 [40 CFR Part 60 Standards of Performance for New Stationary Sources §40 CFR 60.4200]
Subpart IIII - Standards of Performance for Stationary Compression Ignition Internal Combustion Engines
Am I subject to this subpart?**

What This Subpart Covers

§ 60.4200 Am I subject to this subpart?

(a) The provisions of this subpart are applicable to manufacturers, owners, and operators of stationary compression ignition (CI) internal combustion engines (ICE) and other persons as specified in paragraphs (a)(1) through (4) of this section. For the purposes of this subpart, the date that construction commences is the date the engine is ordered by the owner or operator.

(1) [NA – NOT AN ENGINE MANUFACTURER]

(2) Owners and operators of stationary CI ICE that commence construction after July 11, 2005, where the stationary CI ICE are:

(i) Manufactured after April 1, 2006, and are not fire pump engines, or

(ii) [NA – NOT A FIRE PUMP]

**SECTION E. Source Group Restrictions.**

(3) [NA – NOT MODIFIED OR RECONSTRUCTED]

(4) The provisions of § 60.4208 of this subpart are applicable to all owners and operators of stationary CI ICE that commence construction after July 11, 2005.

(b) [NA – NO TEST CELL/STAND]

(c) If you are an owner or operator of an area source subject to this subpart, you are exempt from the obligation to obtain a permit under 40 CFR part 70 or 40 CFR part 71, provided you are not required to obtain a permit under 40 CFR 70.3(a) or 40 CFR 71.3(a) for a reason other than your status as an area source under this subpart. Notwithstanding the previous sentence, you must continue to comply with the provisions of this subpart applicable to area sources.

(d) Stationary CI ICE may be eligible for exemption from the requirements of this subpart as described in 40 CFR part 1068, subpart C, except that owners and operators, as well as manufacturers, may be eligible to request an exemption for national security.

(e) [NA – NO TEMPORARY REPLACEMENT UNIT(S)]

[71 FR 39172, July 11, 2006, as amended at 76 FR 37967, June 28, 2011; 86 FR 34357, June 29, 2021]

Emission Standards for Manufacturers

[NA – NOT AN ENGINE MANUFACTURER]

Emission Standards for Owners and Operators

§ 60.4204 What emission standards must I meet for non-emergency engines if I am an owner or operator of a stationary CI internal combustion engine?

[NA – ENGINE IS EMERGENCY USE]

§ 60.4205 What emission standards must I meet for emergency engines if I am an owner or operator of a stationary CI internal combustion engine?

(a) [NA – ENGINE WAS MANUFACTURED AFTER 2007]

(b) Owners and operators of 2007 model year and later emergency stationary CI ICE with a displacement of less than 30 liters per cylinder that are not fire pump engines must comply with the emission standards for new nonroad CI engines in § 60.4202, for all pollutants, for the same model year and maximum engine power for their 2007 model year and later emergency stationary CI ICE.

60.4202 REQUIREMENTS

60.4202(a) Stationary CI internal combustion engine manufacturers must certify their 2007 model year and later emergency stationary CI ICE with a maximum engine power less than or equal to 2,237 KW (3,000 HP) and a displacement of less than 10 liters per cylinder that are not fire pump engines to the emission standards specified in paragraphs (a)(1) through (2) of this section.

(a)(1) [NA - UNIT(S) > 50 HP]

(a)(2) For engines with a rated power greater than or equal to 37 KW (50 HP), the Tier 2 or Tier 3 emission standards for new nonroad CI engines for the same rated power as described in 40 CFR part 1039, appendix I, for all pollutants and the smoke standards as specified in 40 CFR 1039.105 beginning in model year 2007.

NOTE: ENGINES ARE EPA TIER 2 COMPLIANT.

FROM 1039.105

**SECTION E. Source Group Restrictions.**

(b) Measure smoke opacity as specified in § 1039.501(c). Smoke opacity from your engines may not exceed the following standards:

(b)(1) 20 percent during the acceleration mode.

(b)(2) 15 percent during the lugging mode.

(b)(3) 50 percent during the peaks in either the acceleration or lugging modes.

END OF 60.4202 REQUIREMENTS

(c) [NA – ENGINE IS NOT A FIRE PUMP]

(d) [NA – ENGINE CYLINDER VOLUME IS LESS THAN 30 L/CYLINDER]

(e) [NA – ENGINE IS EXEMPT FROM PERFORMANCE TESTING]

(f) [NA – ENGINE IS NOT MODIFIED OR RECONSTRUCTED]

[71 FR 39172, July 11, 2006, as amended at 76 FR 37969, June 28, 2011; 86 FR 34358, June 29, 2021]

§ 60.4206 How long must I meet the emission standards if I am an owner or operator of a stationary CI internal combustion engine?

Owners and operators of stationary CI ICE must operate and maintain stationary CI ICE that achieve the emission standards as required in §§ 60.4204 and 60.4205 over the entire life of the engine.

[76 FR 37969, June 28, 2011]

Fuel Requirements for Owners and Operators

§ 60.4207 What fuel requirements must I meet if I am an owner or operator of a stationary CI internal combustion engine subject to this subpart?

(a) [Reserved]

(b) Beginning October 1, 2010, owners and operators of stationary CI ICE subject to this subpart with a displacement of less than 30 liters per cylinder that use diesel fuel must use diesel fuel that meets the requirements of 40 CFR 1090.305 for nonroad diesel fuel, except that any existing diesel fuel purchased (or otherwise obtained) prior to October 1, 2010, may be used until depleted.

(c) [Reserved]

(d) Beginning June 1, 2012, owners and operators of stationary CI ICE subject to this subpart with a displacement of greater than or equal to 30 liters per cylinder must use diesel fuel that meets a maximum per-gallon sulfur content of 1,000 parts per million (ppm).

(e) Stationary CI ICE that have a national security exemption under § 60.4200(d) are also exempt from the fuel requirements in this section.

[71 FR 39172, July 11, 2006, as amended at 76 FR 37969, June 28, 2011; 78 FR 6695, Jan. 30, 2013; 85 FR 78463, Dec. 4, 2020]

Other Requirements for Owners and Operators

§ 60.4208 What is the deadline for importing or installing stationary CI ICE produced in previous model years?

**SECTION E. Source Group Restrictions.**

(a) After December 31, 2008, owners and operators may not install stationary CI ICE (excluding fire pump engines) that do not meet the applicable requirements for 2007 model year engines.

(b) [NA – ENGINE IS GREATER THAN 25 HP]

(c) [NA – ENGINE IS EMERGENCY USE]

(d) [NA – ENGINE IS EMERGENCY USE]

(e) [NA – ENGINE IS EMERGENCY USE]

(f) [NA – ENGINE IS EMERGENCY USE]

(g) [NA – ENGINE IS EMERGENCY USE]

(h) [NA - IMPORTATION NOT RELEVANT IN THIS CASE]

(i) The requirements of this section do not apply to owners or operators of stationary CI ICE that have been modified, reconstructed, and do not apply to engines that were removed from one existing location and reinstalled at a new location.

[71 FR 39172, July 11, 2006, as amended at 76 FR 37969, June 28, 2011]

§ 60.4209 What are the monitoring requirements if I am an owner or operator of a stationary CI internal combustion engine?

If you are an owner or operator, you must meet the monitoring requirements of this section. In addition, you must also meet the monitoring requirements specified in § 60.4211.

(a) If you are an owner or operator of an emergency stationary CI internal combustion engine that does not meet the standards applicable to non-emergency engines, you must install a non-resettable hour meter prior to startup of the engine.

(b) [NA – NO DIESEL PARTICULATE FILTERS]

[71 FR 39172, July 11, 2006, as amended at 76 FR 37969, June 28, 2011]

Compliance Requirements

§ 60.4210 What are my compliance requirements if I am a stationary CI internal combustion engine manufacturer?

[NA – NOT AN ENGINE MANUFACTURER]

§ 60.4211 What are my compliance requirements if I am an owner or operator of a stationary CI internal combustion engine?

(a) If you are an owner or operator and must comply with the emission standards specified in this subpart, you must do all of the following, except as permitted under paragraph (g) of this section:

(1) Operate and maintain the stationary CI internal combustion engine and control device according to the manufacturer's emission-related written instructions;

(2) Change only those emission-related settings that are permitted by the manufacturer; and

(3) Meet the requirements of 40 CFR part 1068, as they apply to you.

(b) [NA – ENGINE WAS MANUFACTURED AFTER 2007]

(c) If you are an owner or operator of a 2007 model year and later stationary CI internal combustion engine and must comply with the emission standards specified in § 60.4204(b) or § 60.4205(b), or if you are an owner or operator of a CI fire pump

**SECTION E. Source Group Restrictions.**

engine that is manufactured during or after the model year that applies to your fire pump engine power rating in table 3 to this subpart and must comply with the emission standards specified in § 60.4205(c), you must comply by purchasing an engine certified to the emission standards in § 60.4204(b), or § 60.4205(b) or (c), as applicable, for the same model year and maximum (or in the case of fire pumps, NFPA nameplate) engine power. The engine must be installed and configured according to the manufacturer's emission-related specifications, except as permitted in paragraph (g) of this section.

(d) [NA – ENGINE IS EMERGENCY USE]

(e) [NA – ENGINE IS EMERGENCY USE AND NOT EQUIPPED WITH AN AECD]

(f) If you own or operate an emergency stationary ICE, you must operate the emergency stationary ICE according to the requirements in paragraphs (f)(1) through (3) of this section. In order for the engine to be considered an emergency stationary ICE under this subpart, any operation other than emergency operation, maintenance and testing, and operation in non-emergency situations for 50 hours per year, as described in paragraphs (f)(1) through (3), is prohibited. If you do not operate the engine according to the requirements in paragraphs (f)(1) through (3), the engine will not be considered an emergency engine under this subpart and must meet all requirements for non-emergency engines. [NOTE: SOURCE ID 114C IS SUBJECT TO THE MORE STRINGENT LIMIT OF NO MORE THAN 99.9 TOTAL HOURS OF OPERATION PER 12-MONTH ROLLING TOTAL PERIOD AS PER GP9-21-05002A ISSUED ON JUNE 19, 2019]

(1) There is no time limit on the use of emergency stationary ICE in emergency situations.

(2) You may operate your emergency stationary ICE for the purpose specified in paragraph (f)(2)(i) of this section for a maximum of 100 hours per calendar year. Any operation for non-emergency situations as allowed by paragraph (f)(3) of this section counts as part of the 100 hours per calendar year allowed by this paragraph (f)(2).

(i) Emergency stationary ICE may be operated for maintenance checks and readiness testing, provided that the tests are recommended by federal, state or local government, the manufacturer, the vendor, the regional transmission organization or equivalent balancing authority and transmission operator, or the insurance company associated with the engine. The owner or operator may petition the Administrator for approval of additional hours to be used for maintenance checks and readiness testing, but a petition is not required if the owner or operator maintains records indicating that federal, state, or local standards require maintenance and testing of emergency ICE beyond 100 hours per calendar year.

(ii)-(iii) [Reserved]

(3) Emergency stationary ICE may be operated for up to 50 hours per calendar year in non-emergency situations. The 50 hours of operation in non-emergency situations are counted as part of the 100 hours per calendar year for maintenance and testing provided in paragraph (f)(2) of this section. Except as provided in paragraph (f)(3)(i) of this section, the 50 hours per calendar year for non-emergency situations cannot be used for peak shaving or non-emergency demand response, or to generate income for a facility to an electric grid or otherwise supply power as part of a financial arrangement with another entity.

(i) The 50 hours per year for non-emergency situations can be used to supply power as part of a financial arrangement with another entity if all of the following conditions are met:

(A) The engine is dispatched by the local balancing authority or local transmission and distribution system operator;

(B) The dispatch is intended to mitigate local transmission and/or distribution limitations so as to avert potential voltage collapse or line overloads that could lead to the interruption of power supply in a local area or region.

(C) The dispatch follows reliability, emergency operation or similar protocols that follow specific NERC, regional, state, public utility commission or local standards or guidelines.

(D) The power is provided only to the facility itself or to support the local transmission and distribution system.

(E) The owner or operator identifies and records the entity that dispatches the engine and the specific NERC, regional, state, public utility commission or local standards or guidelines that are being followed for dispatching the engine. The local balancing authority or local transmission and distribution system operator may keep these records on behalf of the engine

**SECTION E. Source Group Restrictions.**

owner or operator.

(ii) [Reserved]

(g) If you do not install, configure, operate, and maintain your engine and control device according to the manufacturer's emission-related written instructions, or you change emission-related settings in a way that is not permitted by the manufacturer, you must demonstrate compliance as follows:

(1) [NA – ENGINE IS GREATER THAN 100 HP]

(2) [NA – ENGINE IS GREATER THAN 500 HP]

(3) If you are an owner or operator of a stationary CI internal combustion engine greater than 500 HP, you must keep a maintenance plan and records of conducted maintenance and must, to the extent practicable, maintain and operate the engine in a manner consistent with good air pollution control practice for minimizing emissions. In addition, you must conduct an initial performance test to demonstrate compliance with the applicable emission standards within 1 year of startup, or within 1 year after an engine and control device is no longer installed, configured, operated, and maintained in accordance with the manufacturer's emission-related written instructions, or within 1 year after you change emission-related settings in a way that is not permitted by the manufacturer. You must conduct subsequent performance testing every 8,760 hours of engine operation or 3 years, whichever comes first, thereafter to demonstrate compliance with the applicable emission standards.

(h) [NA – ENGINE IS NOT EQUIPPED WITH AN AECD]

[71 FR 39172, July 11, 2006, as amended at 76 FR 37970, June 28, 2011; 78 FR 6695, Jan. 30, 2013; 81 FR 44219, July 7, 2016; 86 FR 34359, June 29, 2021; 87 FR 48605, Aug. 10, 2022]

Testing Requirements for Owners and Operators

§ 60.4212 What test methods and other procedures must I use if I am an owner or operator of a stationary CI internal combustion engine with a displacement of less than 30 liters per cylinder?

[NA – TESTING IS NOT REQUIRED FOR CERTIFIED UNITS]

§ 60.4213 What test methods and other procedures must I use if I am an owner or operator of a stationary CI internal combustion engine with a displacement of greater than or equal to 30 liters per cylinder?

[NA – ENGINE CYLINDER VOLUME IS GREATER THAN 30 L/CYL]

Notification, Reports, and Records for Owners and Operators

§ 60.4214 What are my notification, reporting, and recordkeeping requirements if I am an owner or operator of a stationary CI internal combustion engine?

(a) [NA – ENGINE IS EMERGENCY USE]

(b) If the stationary CI internal combustion engine is an emergency stationary internal combustion engine, the owner or operator is not required to submit an initial notification. Starting with the model years in table 5 to this subpart, if the emergency engine does not meet the standards applicable to non-emergency engines in the applicable model year, the owner or operator must keep records of the operation of the engine in emergency and non-emergency service that are recorded through the non-resettable hour meter. The owner must record the time of operation of the engine and the reason the engine was in operation during that time.

(c) [NA – ENGINE IS NOT EQUIPPED WITH DIESEL PARTICULATE FILTERS]

(d) If you own or operate an emergency stationary CI ICE with a maximum engine power more than 100 HP that operates for the purpose specified in § 60.4211(f)(3)(i), you must submit an annual report according to the requirements in paragraphs

**SECTION E. Source Group Restrictions.**

(d)(1) through (3) of this section.

(1) The report must contain the following information:

(i) Company name and address where the engine is located.

(ii) Date of the report and beginning and ending dates of the reporting period.

(iii) Engine site rating and model year.

(iv) Latitude and longitude of the engine in decimal degrees reported to the fifth decimal place.

(v)-(vi) [Reserved]

(vi) Hours spent for operation for the purposes specified in § 60.4211(f)(3)(i), including the date, start time, and end time for engine operation for the purposes specified in § 60.4211(f)(3)(i). The report must also identify the entity that dispatched the engine and the situation that necessitated the dispatch of the engine.

(2) The first annual report must cover the calendar year 2015 and must be submitted no later than March 31, 2016. Subsequent annual reports for each calendar year must be submitted no later than March 31 of the following calendar year.

(3) The annual report must be submitted electronically using the subpart specific reporting form in the Compliance and Emissions Data Reporting Interface (CEDRI) that is accessed through EPA's Central Data Exchange (CDX) (<https://cdx.epa.gov/>). However, if the reporting form specific to this subpart is not available in CEDRI at the time that the report is due, the written report must be submitted to the Administrator at the appropriate address listed in § 60.4. Beginning on February 26, 2025, submit annual report electronically according to paragraph (g) of this section.

(e) [NA – ENGINE IS NOT EQUIPPED WITH AN AECD]

(f) Beginning on February 26, 2025, within 60 days after the date of completing each performance test required by this subpart, you must submit the results of the performance test required under this section following the procedures specified in paragraphs (f)(1) and (2) of this section.

(1) Data collected using test methods supported by the EPA's Electronic Reporting Tool (ERT) as listed on the EPA's ERT website (<https://www.epa.gov/electronic-reporting-air-emissions/electronic-reporting-tool-ert>) at the time of the test. Submit the results of the performance test to the EPA via the Compliance and Emissions Data Reporting Interface (CEDRI), according to paragraph (g) of this section. The data must be submitted in a file format generated using the EPA's ERT. Alternatively, you may submit an electronic file consistent with the extensible markup language (XML) schema listed on the EPA's ERT website.

(2) Data collected using test methods that are not supported by the EPA's ERT as listed on the EPA's ERT website at the time of the test. The results of the performance test must be included as an attachment in the ERT or an alternate electronic file consistent with the XML schema listed on the EPA's ERT website. Submit the ERT generated package or alternative file to the EPA via CEDRI according to paragraph (g) of this section.

(g) If you are required to submit notifications or reports following the procedure specified in this paragraph (g), you must submit notifications or reports to the EPA via the Compliance and Emissions Data Reporting Interface (CEDRI), which can be accessed through the EPA's Central Data Exchange (CDX) (<https://cdx.epa.gov/>). The EPA will make all the information submitted through CEDRI available to the public without further notice to you. Do not use CEDRI to submit information you claim as CBI. Although we do not expect persons to assert a claim of CBI, if you wish to assert a CBI claim for some of the information in the report or notification, you must submit a complete file in the format specified in this subpart, including information claimed to be CBI, to the EPA following the procedures in paragraphs (g)(1) and (2) of this section. Clearly mark the part or all of the information that you claim to be CBI. Information not marked as CBI may be authorized for public release without prior notice. Information marked as CBI will not be disclosed except in accordance with procedures set forth in 40 CFR part 2. All CBI claims must be asserted at the time of submission. Anything submitted using CEDRI cannot later be claimed CBI. Furthermore, under CAA section 114(c), emissions data is not entitled to confidential treatment, and the EPA is required to make emissions data available to the public. Thus, emissions data will not be protected as CBI and will

**SECTION E. Source Group Restrictions.**

be made publicly available. You must submit the same file submitted to the CBI office with the CBI omitted to the EPA via the EPA's CDX as described earlier in this paragraph (g).

(1) The preferred method to receive CBI is for it to be transmitted electronically using email attachments, File Transfer Protocol, or other online file sharing services. Electronic submissions must be transmitted directly to the OAQPS CBI Office at the email address oaqpscbi@epa.gov, and as described in paragraph (g) of this section, should include clear CBI markings. ERT files should be flagged to the attention of the Group Leader, Measurement Policy Group; all other files should be flagged to the attention of the Stationary Compression Ignition Internal Combustion Engine Sector Lead. If assistance is needed with submitting large electronic files that exceed the file size limit for email attachments, and if you do not have your own file sharing service, please email oaqpscbi@epa.gov to request a file transfer link.

(2) If you cannot transmit the file electronically, you may send CBI information through the postal service to the following address: OAQPS Document Control Officer (C404-02), OAQPS, U.S. Environmental Protection Agency, 109 T.W. Alexander Drive, P.O. Box 12055, Research Triangle Park, North Carolina 27711. ERT files should be sent to the attention of the Group Leader, Measurement Policy Group, and all other files should be sent to the attention of the Stationary Compression Ignition Internal Combustion Engine Sector Lead. The mailed CBI material should be double wrapped and clearly marked. Any CBI markings should not show through the outer envelope.

(h) If you are required to electronically submit a report through CEDRI in the EPA's CDX, you may assert a claim of EPA system outage for failure to timely comply with that reporting requirement. To assert a claim of EPA system outage, you must meet the requirements outlined in paragraphs (h)(1) through (7) of this section.

(1) You must have been or will be precluded from accessing CEDRI and submitting a required report within the time prescribed due to an outage of either the EPA's CEDRI or CDX systems.

(2) The outage must have occurred within the period of time beginning five business days prior to the date that the submission is due.

(3) The outage may be planned or unplanned.

(4) You must submit notification to the Administrator in writing as soon as possible following the date you first knew, or through due diligence should have known, that the event may cause or has caused a delay in reporting.

(5) You must provide to the Administrator a written description identifying:

(i) The date(s) and time(s) when CDX or CEDRI was accessed and the system was unavailable;

(ii) A rationale for attributing the delay in reporting beyond the regulatory deadline to EPA system outage;

(iii) A description of measures taken or to be taken to minimize the delay in reporting; and

(iv) The date by which you propose to report, or if you have already met the reporting requirement at the time of the notification, the date you reported.

(6) The decision to accept the claim of EPA system outage and allow an extension to the reporting deadline is solely within the discretion of the Administrator.

(7) In any circumstance, the report must be submitted electronically as soon as possible after the outage is resolved.

(i) If you are required to electronically submit a report through CEDRI in the EPA's CDX, you may assert a claim of force majeure for failure to timely comply with that reporting requirement. To assert a claim of force majeure, you must meet the requirements outlined in paragraphs (i)(1) through (5) of this section.

(1) You may submit a claim if a force majeure event is about to occur, occurs, or has occurred or there are lingering effects from such an event within the period of time beginning five business days prior to the date the submission is due. For the purposes of this section, a force majeure event is defined as an event that will be or has been caused by circumstances beyond the control of the affected facility, its contractors, or any entity controlled by the affected facility that prevents you from

**SECTION E. Source Group Restrictions.**

complying with the requirement to submit a report electronically within the time period prescribed. Examples of such events are acts of nature (e.g., hurricanes, earthquakes, or floods), acts of war or terrorism, or equipment failure or safety hazard beyond the control of the affected facility (e.g., large scale power outage).

(2) You must submit notification to the Administrator in writing as soon as possible following the date you first knew, or through due diligence should have known, that the event may cause or has caused a delay in reporting.

(3) You must provide to the Administrator:

(i) A written description of the force majeure event;

(ii) A rationale for attributing the delay in reporting beyond the regulatory deadline to the force majeure event;

(iii) A description of measures taken or to be taken to minimize the delay in reporting; and

(iv) The date by which you propose to report, or if you have already met the reporting requirement at the time of the notification, the date you reported.

(4) The decision to accept the claim of force majeure and allow an extension to the reporting deadline is solely within the discretion of the Administrator.

(5) In any circumstance, the reporting must occur as soon as possible after the force majeure event occurs.

(j) Any records required to be maintained by this subpart that are submitted electronically via the EPA's CEDRI may be maintained in electronic format. This ability to maintain electronic copies does not affect the requirement for facilities to make records, data, and reports available upon request to a delegated air agency or the EPA as part of an on-site compliance evaluation.

[71 FR 39172, July 11, 2006, as amended at 78 FR 6696, Jan. 30, 2013; 81 FR 44219, July 7, 2016; 87 FR 48606, Aug. 10, 2022; 89 FR 70512, Aug. 30, 2024]

Special Requirements

§ 60.4215 What requirements must I meet for engines used in Guam, American Samoa, or the Commonwealth of the Northern Mariana Islands?

[NA – NOT LOCATED IN REFERENCED GEOGRAPHIC AREAS]

§ 60.4216 What requirements must I meet for engines used in Alaska?

[NA – NOT LOCATED IN ALASKA]

§ 60.4217 What emission standards must I meet if I am an owner or operator of a stationary internal combustion engine using special fuels?

[NA – ENGINE DOES NOT USE A SPECIAL FUEL]

General Provisions

§ 60.4218 What General Provisions and confidential information provisions apply to me?

(a) Table 8 to this subpart shows which parts of the General Provisions in §§ 60.1 through 60.19 apply to you.

(b) The provisions of 40 CFR 1068.10 and 1068.11 apply for engine manufacturers. For others, the general confidential business information (CBI) provisions apply as described in 40 CFR part 2.

[88 FR 4471, Jan. 24, 2023]

**SECTION E. Source Group Restrictions.****Definitions**

§ 60.4219 What definitions apply to this subpart? [INCORPORATED BY REFERENCE]

Regulatory Changes

Individual sources within this source group that are subject to 40 CFR Part 60 Subpart IIII shall comply with all applicable requirements of the Subpart. 40 CFR 60.4 requires submission of copies of all requests, reports and other communications to both the Department and the EPA. The EPA copies shall be forwarded to:

United States Environmental Protection Agency
Region III, Air and Radiation Division
Permits Branch (3AD10)
Four Penn Center
1600 John F. Kennedy Boulevard
Philadelphia, Pennsylvania 19103-2852

Unless otherwise approved by DEP, the DEP copies shall be reported through the Department's Greenport PUP system available through: <https://greenport.pa.gov/ePermitPublicAccess/PublicSubmission/Home>.

In the event that the Federal Subpart that is the subject of this Source Group is revised, the permittee shall comply with the revised version of the subpart, and shall not be required to comply with any provisions in this permit designated as having the subpart as their authority, to the extent that such permit provisions would be inconsistent with the applicable provisions of the revised subpart.

***** Permit Shield in Effect. *****

**SECTION E. Source Group Restrictions.**

Group Name: 011 GLASS RACT 3

Group Description: Glass Furnace RACT 3 Case-by-Case Requirements

Sources included in this group

ID	Name
101	GLASS MELTING FURNACE 1
102	GLASS MELTING FURNACE 2

I. RESTRICTIONS.

No additional requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

II. TESTING REQUIREMENTS.

No additional testing requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

III. MONITORING REQUIREMENTS.

No additional monitoring requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

IV. RECORDKEEPING REQUIREMENTS.

No additional record keeping requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

V. REPORTING REQUIREMENTS.

No additional reporting requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

VI. WORK PRACTICE REQUIREMENTS.

No additional work practice requirements exist except as provided in other sections of this permit including Section B (Title V General Requirements).

VII. ADDITIONAL REQUIREMENTS.

001 [25 Pa. Code §127.512]

Operating permit terms and conditions.

I. The following requirements constitute a case-by-case NO_x RACT 3 determination for Furnaces 1 and 2:

(a) A glass furnace "Operating Day" is defined as any calendar day (i.e. period that begins at midnight local time and ends 24 hours later at midnight) in which glass is pulled from the furnace.

(b) A glass furnace "Non-Operating Day" is defined as any calendar day (i.e. period that begins at midnight local time and ends 24 hours later at midnight) in which glass is not pulled from the furnace.

(c) As of January 1, 2023 for Furnace 2, and as of August 3, 2024 for Furnace 1, the permittee shall comply with the following NO_x emission limitations:

(1) During any Operating Days, the glass furnaces shall comply with the presumptive RACT 3 NO_x emission limitation of 7.0 pounds of NO_x per ton of glass pulled for flat glass furnaces, pursuant to 25 Pa. Code §129.112(i)(4).

(2) During any Non-Operating Days, the NO_x emissions for each glass furnace averaged over consecutive non-operating days may not exceed the amount calculated using the following equation: Pounds per day emission limit of NO_x = 7.0 pounds per ton of glass produced x Furnace permitted production capacity in tons of glass produced per day

(d) The permittee shall keep the following records, which shall be retained by the permittee for a period of five (5) years and

**SECTION E. Source Group Restrictions.**

be made available to DEP upon request:

- (1) CEMS data and calculations necessary to demonstrate compliance with the emission limitations above.
 - (2) Documentation of all maintenance performed on control devices.
 - (3) All periods each control device was not operating while the associated furnace was operating, including:
 - (i) Start and end times of each period.
 - (ii) Explanation for the occurrence of each period.
 - (iii) Calculations or data of emissions which occurred during each period.
 - (e) Data or information required to determine compliance shall be recorded and maintained in a time frame consistent with the averaging period of the emissions limitation.
 - (f) Records, data, and calculations necessary to demonstrate compliance with the emission limitations above, shall be provided with the facility's annual emissions report required by Section B.
 - (h) As of January 1, 2023 for Furnace 2, and as of August 3, 2024 for Furnace 1, the permittee shall operate the glass furnace NO_x control systems whenever technologically feasible during non-operating days (as defined above) to minimize emissions.
 - (i) The permittee shall install, maintain and operate the NO_x control devices in accordance with the manufacturer's specifications and with good operating practices.
- II. Per 25 Pa. Code Section 129.112(p), DEP hereby approves a RACT 3 alternative compliance schedule, and interim emission limitations for Furnace 1, as follows:
- (a) By no later than August 3, 2024, the permittee shall install and begin operating the necessary NO_x controls on Furnace 1 in order to ensure that during any Operating Days, Furnace 1 complies with the presumptive RACT 3 NO_x emission limitation of 7.0 pounds of NO_x per ton of glass pulled for flat glass furnaces, pursuant to 25 Pa. Code §129.112(i)(4).
 - (b) Until Furnace 1 NO_x controls are installed pursuant to II.(a), the permittee shall ensure that during any Operating Days, Furnace 1 complies with an interim RACT 3 NO_x emission limitation of 23.0 pounds of NO_x per ton of glass pulled for flat glass furnaces.
 - (c) Until Furnace 1 NO_x controls are installed pursuant to II.(a), the permittee shall ensure that during any Non-Operating Days, Furnace 1 complies with an interim RACT 3 NO_x emission limitation calculated over consecutive non-operating days, not to exceed the amount allowable using the following equation: Pounds per day emission limit of NO_x = 23.0 pounds per ton of glass produced × Furnace permitted production capacity in tons of glass produced per day.

***** Permit Shield in Effect. *****

**SECTION F. Alternative Operation Requirements.**

No Alternative Operations exist for this Title V facility.

**SECTION G. Emission Restriction Summary.**

No emission restrictions listed in this section of the permit.

**SECTION H. Miscellaneous.**

The following sources and activities are not subject to any specific emission limitations, restrictions, work practice standards, testing, monitoring, recordkeeping or reporting requirements:

1. Air conditioning and ventilation systems
2. Office equipment (copiers, printers, FAX, etc.)
3. Janitorial activities
4. Plant maintenance (painting, welding, paving, cleaning, etc.)
5. Mobile sources (trucks, forklifts, snowblowers, etc.)
6. Boiler water treatment
7. Liquid petroleum products storage tanks and handling
8. Laboratory sources and activities
9. Niagara cooling towers and coater cooling towers
10. Employee parking lot
11. Equalization basin
12. Cullet handling and storage
13. Silo vents (dolomite, cullet, sand, soda ash, limestone, salt cake)
14. Batch House dust collector
15. Batch unloading operations
16. C06 Mikro-Pul baghouse relocation/installation in Batch House RFD 0252 (3/23/11)
17. Roof ventilators for Lines 1 and 2 tanks
18. Cafeteria equipment
19. Tank roof ventilators
20. Coater #4 and Coater #5 vacuum pump venting
21. "W" Spray System Lines 1 and 2
22. Furnace 2 stack burner (50 mmBtu/hour) RFD 0795 (8/26/13)
23. Low Iron Sand Vent #1 Cartridge filter installation RFD 1146 (4/12/2015)
24. Tempering Line 2 Electric furnace installation RFD 0092 (7/12/10)
25. Cold Rebuild of Furnace #1 RFD 1579 (4/20/17)
26. Furnace 2 W Spray Replacement RFD 6155 (6/26/17)
27. Furnace 2 Lip Replacement RFD 6578 (9/14/17)
28. Furnace 2 Feed End Baghouse Replacement RFD 6621 (10/5/17)
29. Furnace 1 Emergency Cullet Dust Collector Replacement RFD 6643 (10/18/17)
30. Glass Furnace 1 Geometry Reallocation RFD 10618 (4/11/24)
31. Line 2 Feed System RFD 10897 (10/23/24)
32. Wareroom Dust Collector Replacement RFD 11224 (7/21/25)
33. Two (2) PK Velox N1500-VX natural gas boilers rated at 1.5 MMBtu/hr each (Office Building and Lockers)
34. Two (2) AO Smith BTH-300(A) natural gas water heaters rated at 0.3 MMBtu/hr each (Office Building and Lockers)
35. AO Smith BTH-120 natural gas water heater rated at 0.12 MMBtu/hr (Wareroom Offices)
36. AAON RN-040 natural gas heater rated at 0.54 MMBtu/hr (Office Building)
37. Cambridge S400 natural gas heater rated at 0.4 MMBtu/hr (Wareroom)
38. Cambridge S1200 natural gas heater rated at 1.2 MMBtu/hr (Wareroom)
39. Two (2) Cambridge S1600 natural gas heaters rated at 1.372 MMBtu/hr each (Wareroom)
40. Three (3) Cambridge S1850 natural gas heaters rated at 1.85 MMBtu/hr each (Wareroom)
41. Two (2) Cambridge S2200 natural gas heaters rated at 2.2 MMBtu/hr each (Wareroom)

Conditions:

"1. Pursuant to 25 Pa. Code §123.13(c)(1)(i), PM emissions from the Donaldson Torit cartridge collector exhaust shall not exceed 0.04 grain per dry standard cubic foot.

2. The applicant shall operate and maintain instrumentation to measure and display the pressure differential across the Donaldson Torit cartridge collector.

3. (a) The applicant shall monitor and record the pressure differential across the Donaldson Torit cartridge collector. The pressure differential shall be recorded a minimum of once per week while the Line 2 Glass Melting Furnace and the Donaldson Torit cartridge collector are operating; and

(b) The applicant shall retain these records for a minimum of five (5) years and shall make them available to the Department upon its request.

**SECTION H. Miscellaneous.**

4. (a) The applicant shall maintain detailed records of all maintenance performed on the Donaldson Torit cartridge collector; and
- (b) The applicant shall retain these records for a minimum of five (5) years and shall make them available to the Department upon its request.
5. The applicant shall operate the Donaldson Torit cartridge collector at all times that the Lehr building is being loaded through glass dumping from Lines 1 and 2 Glass Melting Furnace.
6. The applicant shall maintain on-site a sufficient quantity of spare cartridge collector cartridges for the Donaldson Torit cartridge collector in order to immediately replace any cartridges requiring replacement due to deterioration resulting from routine operation.
7. The applicant shall operate and maintain the Line 2 Glass Melting Furnace and the associated Donaldson Torit cartridge collector:
- (a) in such a manner as not to cause air pollution;
- (b) in a manner consistent with good operating and maintenance practices; and (c) in accordance with the manufacturer's specifications.
8. (a) The applicant shall calculate the monthly air emissions from the Lines 1 and 2 Glass Melting Furnace using AP-42 emission factors, manufacturer-supplied emission factors, mass material balance, performance (stack) test data, or other method s) acceptable to the Department. The permittee shall maintain records of the monthly air emissions.
- (b) The applicant shall calculate the cumulative Lines 1 and 2 Glass Melting Furnace air emissions for each consecutive 12-month period. The permittee shall maintain records of the cumulative Line 2 Glass Melting Furnace air emissions for each consecutive 12-month period in order to demonstrate compliance with aforementioned Conditions, listed above.
- (c) The applicant shall retain these records for a minimum of five (5) years. The records shall be made available to the Department upon its request."
43. Cold Rebuild of Furnace #2 RFD 1813 (4/12/18)
44. Solargreen C5 Production RFD 8413 (4/2/20)
45. Alternate TPO Coating Trial RFD 8697 (8/14/20)
46. Temporary Diesel Portable Generator Use RFD 9129 (3/31/21)
47. Furnace #1 Oil Firing System Replacement RFD 9224 (5/24/21)
48. Furnace #2 W Spray Replacement RFD 9309 (9/13/21)
49. Additional Cutting Fluid Usage RFD 9368 (8/30/21)
50. Furnace #2 Oil Firing System Replacement RFD 1997 (3/14/19)

The site emergency equipment includes the following:

- Source ID 114A Emergency Generator Line 2 Unit A (East) CI Detroit Diesel, 1,500 eKW, installed 1995.
- Source ID 114B Emergency Generator Line 2 Unit B (West) CI Detroit Diesel, 1,500 eKW, installed 1995.
- Source ID 114C Emergency Generator Line 1 Cummins Diesel, 2,922 BHP (2,000 eKW), installed 2021.
- Source ID 114E Emergency Flood Pump (Small) CI Detroit Diesel 160 HP, installed in 1972.
- Source ID 114F Emergency Flood Pump (Large) CI Detroit Diesel 238 HP, installed in 1972.
- Source ID 114H Emergency Fire Pump (West) Cummins CI, 255 HP diesel, installed in 1972.
- Source ID 114I Emergency Fire Pump (East) Cummins CI, 255 HP diesel, installed in 1972.



***** End of Report *****
