K.A.R. § 28-15-19

This document is current through Kansas Register Volume 34, Number 19 May 7, 2015

Kansas Administrative Regulations > ***AGENCY 28 DEPARTMENT OF HEALTH AND ENVIRONMENT*** > ***ARTICLE 15. APPLICATION FOR PERMITS; DOMESTIC WATER SUPPLY***

28-15-19. Disinfection of drinking water.

(a) All drinking water supplied to the public from a public water supply system shall be disinfected.

(b) When chlorination is employed, a sufficient amount of chlorine shall be added to the water to maintain a distribution system chlorine residual of at least 0.2 mg/l of free chlorine or 1.0 mg/l of combined chlorine.

(1) Failure to maintain a residual as specified above in more than five percent of measurements taken each month, in any two consecutive months shall be deemed a violation of this regulation.

(2) Each day the public water supply system serves water to its customers, the operator shall make a determination of the chlorine residual. The data shall be recorded in such a manner that the department can determine whether the requirements of this rule and regulation have been met.

Statutory Authority

Authorized by and implementing *K.S.A. 65-171m*

History

Effective
May 1, 1982; amended Sept. 26, 1994.