327 IAC 8-2-1

Current with amendments received through the Indiana Weekly Collection Dated January 28, 2015

Indiana Administrative Code > ***TITLE 327. WATER POLLUTION CONTROL DIVISION*** > ***ARTICLE 8. PUBLIC WATER SUPPLY*** > ***RULE 2. DRINKING WATER STANDARDS***

327 IAC 8-2-1 Definitions

.

(98) "Undetectable disinfectant residual" means a disinfectant residual level that is less than:

(A) two-tenths (0.2) milligram per liter measured as free chlorine;

(B) five-tenths (0.5) milligram per liter measured as combined chlorine (chloramines); or

(C) one-tenth (0.1) milligram per liter measured as chlorine dioxide.

The commissioner may require a system to demonstrate the level of chloramines present when measured as combined chlorine under clause (B).

Statutory Authority

Authority:

IC 13-13-5; *IC 13-14-8-7*; IC 13-14-9; IC 13-18-3; IC 13-18-16

Affected:
IC 13-11-2; IC 13-18

History

HISTORY:
(Water Pollution Control Division; *327 IAC 8-2-1*; filed Sep 24, 1987, 3:00 p.m.: 11 Ind. Reg. 705; filed Dec 28, 1990, 5:10 p.m.: 14 Ind. Reg. 1003; errata filed Jan 9, 1991, 2:30 p.m.: 14 Ind. Reg. 1070; errata filed Aug 6, 1991, 3:45 p.m.: 14 Ind. Reg. 2258; filed Apr 12, 1993, 11:00 a.m.: 16 Ind. Reg. 2151; filed Aug 24, 1994, 8:15 a.m.: 18 Ind. Reg. 19; errata filed Oct 11, 1994, 2:45 p.m.: 18 Ind. Reg. 531; filed Oct 24, 1997, 4:30 p.m.: 21 Ind. Reg. 932; filed Mar 6, 2000, 7:56 a.m.: 23 Ind. Reg. 1623; filed Nov 20, 2001, 10:20 a.m.: 25 Ind. Reg. 1075; filed May 1, 2003, 12:00 p.m.: 26 Ind. Reg. 2808; filed Jun 13, 2005, 2:30 p.m.: 28 Ind. Reg. 3184; filed