35 Ill. Adm. Code *653.604*

This document is current through March 20, 2015

§ *653.604* Distribution System Residuals.

a) A minimum free chlorine residual of 0.2 mg/l or a minimum combined residual of 0.5 mg/l shall be maintained in all active parts of the distribution system at all times.

b) Chlorine residual test shall be made at frequent and regular intervals to determine the amount and type of residuals existing at different points in the distribution system.

Annotations

Research References & Practice Aids

Hierarchy Notes:

Authority & General Source

ILLINOIS ADMINISTRATIVE CODE