

1053 SPRUCE ROAD * P.O. BOX 3348 * ALLENTOWN, PA 18106-0348 610-398-2503 * FAX 610-398-8413 * www.lehighcountyauthority.org email: service@lehighcountyauthority.org

September 22, 2022

Lowhill Township Planning Commission 2175 Seipstown Road Fogelsville, PA 18051

SUBJECT: CRG Services Management, LLC C/O CRG

2951 Betz Court – Warehouse/Distribution Facility

Lowhill Township, Lehigh County, PA

Water Service - Will Serve

Dear Members:

Lehigh County Authority (LCA) is willing to provide water service for the estimated demand of 3,000 gallons per day for a proposed 299,880 square foot warehouse / distribution facility, as shown on the Site Plan entitled "2951 Betz Court Site for CRG Services Management, LLC, Lowhill Township, Lehigh County, Pennsylvania" prepared by Snyder, Secary & Associates, Project No. 21-0482-006 CRGXX22001, Sheet 3 of 20, dated March 14, 2022, last revised September 12, 2022.

Water service is conditioned upon the following:

- 1. LCA approval of developer-prepared water system plans designed in conformance with LCA's *Main Extension Policy* and *General Specifications for Water System Construction*.
- 2. Developer compliance with the terms and conditions of LCA's *Rules and Regulation for Water Service*, including completion of an Application for Water Service and payment of applicable connection fees for each service connection.
- 3. Developer obtaining all permits needed to construct the water system, including without limitation those from PA DEP, as well as any construction and road-opening permits issued by the municipality or PennDOT.
- 4. Developer installation of the water system in accordance with the approved plans and applicable LCA policies and regulations.
- 5. LCA approval of the site, plumbing and fire protection system plans, as applicable.

The developer shall submit a complete set of plans to LCA for review and approval.

If you have any questions, please contact me at 610-398-2503, ext. 144 or at edhoyle@lehighcountyauthority.org.

Sincerely,

Edward L. Hoyle, Jr., P.E.

Edward & Hyl V

Chief Engineer

Cc: Joshua Hoffman, Pennoni (via email)