

Table 1
Potable Well Analytical Results Summary

Sample Location	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethylbenzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethylbenzene (µg/L)	1,3,5-Trimethylbenzene (µg/L)	1,2-Dichloroethane (EDC) (µg/L)	1,2-Dibromoethane (EDB) (µg/L)	Lead (µg/L)	
DEP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5	
[REDACTED]	Unknown	Unknown	Kitchen Sink Pressure Tank	02/08/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0096	0.27 J	
				02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0096	0.27 J
				02/15/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	2.4
[REDACTED]	Estimated few hundred	Unknown	Post Holding Tank #1 Post Holding Tank #2	02/18/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12	
				02/25/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.35 J
[REDACTED]	500	Unknown	Pressure Tank	02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	3.4	
				02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	1.8	
[REDACTED]	255	240	Kitchen Sink	02/14/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12	
				02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.17 J		
[REDACTED]	Unknown	Unknown	Kitchen Sink	02/05/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.82		
[REDACTED]	~200	133	Kitchen Sink (Effluent)	02/04/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	0.13 J	
				03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			Pressure Tank (Basement)	02/17/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.45 J	
			Influent	03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			Midfluent	03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
[REDACTED]	Unknown	Unknown	Outside Spigot	02/13/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	0.11 J	ND<0.0094	0.19 J	
				02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	0.19 J	ND<0.0094	0.36 J	
[REDACTED]	Unknown	Unknown	Kitchen Sink	02/25/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.14 J	
				03/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J	
[REDACTED]	60-80	Unknown	Kitchen Sink	02/07/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.42 J	
				02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.19 J	
			Influent	03/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			Midfluent	03/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			Effluent	03/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
[REDACTED]	Unknown	Unknown	Kitchen Sink	02/12/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0092	ND<0.12	
				02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12	
			Influent	03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			Midfluent	03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			Effluent	03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
[REDACTED]	Unknown	Unknown	Second Kitchen	02/10/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	ND<0.12		
				02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.17 J		
[REDACTED]	Unknown	Unknown	Kitchen Sink	02/11/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0093	ND<0.12		
				02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12		
[REDACTED]	Unknown	Unknown	Kitchen Sink	02/08/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12		
[REDACTED]	Unknown	Unknown	Kitchen Sink	02/11/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12	
				02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
			Influent	03/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			Midfluent	03/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			Effluent	03/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	8.1	

Table 1
Potable Well Analytical Results Summary

Sample Location	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene	Toluene	Ethylbenzene	Total Xylenes	MTBE	Isopropyl Benzene	Naphthalene	1,2,4-Trimethylbenzene	1,3,5-Trimethylbenzene	1,2-Dichloroethane (EDC)	1,2-Dibromoethane (EDB)	Lead	
					(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)
DEP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5	
[REDACTED]	Unknown	Unknown	Outside Spigot	02/08/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12	
				02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.29 J
				03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J	
[REDACTED]	Unknown	Unknown	Kitchen Sink	02/03/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
				02/21/2025	0.52	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	0.31 J	0.46 J	ND<0.10	ND<0.0094	ND<0.12	
			Influent	02/28/2025	0.18 J	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				03/10/2025	0.42 J	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	0.41 J	0.30 J	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			Midfluent	02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0096	ND<0.12
				03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			Effluent	02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0096	ND<0.12
				03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
[REDACTED]	143	100	Outside Spigot	09/28/2023	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	-	-	-	
				01/28/2025	0.92	6.6	ND<0.50	100	ND<0.50	1.0	84	47	23	ND<0.50	ND<0.0094	0.017 J	
			Influent	02/19/2025	0.13 J	0.27 J	0.72	29	ND<0.10	1.7	47	2.1	1.3	ND<0.10	ND<0.0094	ND<0.12	
				02/24/2025	ND<0.10	ND<0.10	0.44 J	13	ND<0.10	0.94	30	0.32 J	0.22 J	ND<0.10	ND<0.0094	0.13 J	
			Midfluent	02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	ND<0.12
Effluent	02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12			
	02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12			
[REDACTED]	Unknown	Unknown	Bathroom Sink	09/28/2023	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	-	-	-	
				01/30/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12	
[REDACTED]	Unknown	Unknown	Utility Sink Kitchen Sink	02/11/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	ND<0.12	
				02/24/2025	0.63	ND<0.10	ND<0.10	0.63	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
[REDACTED]	~100	Unknown	Kitchen Sink Bladder Tank	01/28/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	ND<0.12	
				02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	0.47 J
[REDACTED]	Unknown	Unknown	Kitchen Sink	01/28/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	0.15 J	
				02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.15 J
[REDACTED]	182	180	Kitchen Sink	01/23/2025	12	ND<0.50	ND<0.50	0.29	ND<0.50	ND<0.50	1.3	ND<0.50	ND<0.50	ND<0.50	ND<0.0091	ND<0.12	
				01/30/2025	12	ND<0.50	ND<0.50	0.19	ND<0.50	ND<0.50	1.3	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.25 J	
			Post-Treatment	02/12/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
				Influent	02/25/2025	14	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	2.0	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
			Midfluent	02/25/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				Effluent	02/25/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
[REDACTED]	Unknown	Unknown	Utility Sink	01/29/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	ND<0.12	
				02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12	
[REDACTED]	503	340	Kitchen Sink	01/23/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0092	ND<0.12	
				Influent	03/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Midfluent	03/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				Effluent	03/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3

Table 1
Potable Well Analytical Results Summary

Sample Location	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethylbenzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethylbenzene (µg/L)	1,3,5-Trimethylbenzene (µg/L)	1,2-Dichloroethane (EDC) (µg/L)	1,2-Dibromoethane (EDB) (µg/L)	Lead (µg/L)	
DEP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5	
[REDACTED]	300	Unknown	Bladder Tank	01/28/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0092	0.16 J	
			Pressure Tank (Influent)	02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
			Kitchen Sink (Effluent)	02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
[REDACTED]	220	Unknown	Bladder Tank	01/23/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0091	0.19 J	
			Kitchen Sink (First Floor)	02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
[REDACTED]	Unknown	Unknown	Kitchen Sink	01/23/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0092	ND<0.12	
				02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12		
[REDACTED]	Unknown	Unknown	Bladder Tank	01/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.63	
				02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.36 J		
			Basement (Influent)	02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12	
				02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
[REDACTED]	250	Unknown	Kitchen Sink	01/31/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12		
				Kitchen Sink (First Floor)	02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12	
[REDACTED]	Unknown	Unknown	Kitchen Sink	02/03/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	ND<0.12	
			Basement (Influent)	02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	0.23 J	
			Kitchen Sink (Effluent)	02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	ND<0.12	
[REDACTED]	200-220	~180	Kitchen Sink	02/04/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12	
			Pressure Tank (Influent)	02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	1.5	
			Kitchen Sink (Effluent)	02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
[REDACTED]	180	Unknown	Front Spigot	02/07/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.28 J		
				02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.36 J	
[REDACTED]	Unknown	Unknown	Pressure Tank	02/13/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	0.93	
			Pressure Tank (Influent)	02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	5.3	
			Laundry Room Sink (Effluent)	02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.42 J	
[REDACTED]	~400-600	Unknown	Kitchen Sink	02/15/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12		
				03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
[REDACTED]	Unknown	Unknown	Pressure Tank	01/31/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0093	0.41 J	
			Influent	03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			Midfluent	03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			Effluent	03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
[REDACTED]	Unknown	Unknown	Kitchen Sink	02/04/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.46 J		
			Pressure Tank	02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.30 J		

Table 1
Potable Well Analytical Results Summary

Sample Location	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethylbenzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethylbenzene (µg/L)	1,3,5-Trimethylbenzene (µg/L)	1,2-Dichloroethane (EDC) (µg/L)	1,2-Dibromoethane (EDB) (µg/L)	Lead (µg/L)	
DEP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5	
[REDACTED]	Unknown	180	Bladder Tank	01/28/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12	
				02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	0.16 J	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.13 J	
			Influent	02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	0.22 J	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0096	0.14 J	
			Midfluent	02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12	
			Effluent	02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12	
[REDACTED]	Unknown	Unknown	Utility Sink	01/29/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	0.59	
				02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	1.6	
			Influent	03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	0.31 J	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			Midfluent	03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			Effluent	03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
[REDACTED]	295	Unknown	Bladder Tank	01/24/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	0.12	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	ND<0.12	
			Kitchen Sink	02/06/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12	
			Influent	02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.15 J	
			Midfluent	02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12	
			Effluent	02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12	
[REDACTED]	290 - 300	250	Bladder Tank	01/24/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	1.7	
			Influent	02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	0.12 J	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.50	ND<0.0093	3.1	
			Effluent	02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.50	ND<0.0093	0.13 J	
[REDACTED]	~600	~400	Bladder Tank	01/23/2025	15	6.7	2.7	49	ND<0.50	1.3	19	48	39	ND<0.50	ND<0.0092	5.2	
			Kitchen Sink (Post Treatment)	01/31/2025	8.9	3.7	1.7	25	ND<0.50	0.94	7.3	29	22	ND<0.50	ND<0.0093	0.23 J	
			Influent	02/15/2025	25	6.7	4.1	44	0.12 J	1.9	20	49	34	ND<0.50	ND<0.0095	ND<0.12	
				02/24/2025	28	4.6	4.6	42	0.14 J	2.1	22	55	41	ND<0.50	ND<0.0094	0.15 J	
			Midfluent	02/15/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0093	ND<0.12
				02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.50	ND<0.0094	0.17 J	
			Effluent	02/15/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
02/24/2025	ND<0.10	ND<0.10		ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.50	ND<0.0094	ND<0.12				
[REDACTED]	400	230	Bladder Tank	01/23/2025	20	51	32	640	ND<0.50	7.6	120	310	120	ND<0.50	ND<0.0093	0.23 J	
			Post Treatment	02/07/2025	0.35 J	2.3	1.2	46	ND<0.50	0.26 J	29	19	11	ND<0.50	ND<0.0094	0.75	
[REDACTED]	450	430	Bladder Tank	01/23/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0093	1.4	
			Influent	02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	0.12 J	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.29 J	
			Effluent	02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	0.11 J	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
[REDACTED]	Possibly 300	Unknown	Kitchen Sink	01/24/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12	
				02/17/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	ND<0.12	

Table 1
Potable Well Analytical Results Summary

Sample Location	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethylbenzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethylbenzene (µg/L)	1,3,5-Trimethylbenzene (µg/L)	1,2-Dichloroethane (EDC) (µg/L)	1,2-Dibromoethane (EDB) (µg/L)	Lead (µg/L)	
DEP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5	
[REDACTED]	550-585	540 or 550	Kitchen Sink	01/24/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12	
				02/17/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	0.22 J
			Influent	03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Midfluent	03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Effluent	03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
[REDACTED]	550	Unknown	Supply Tank Spigot	02/17/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.20 J	
[REDACTED]	Unknown	Unknown	Pressure Tank	02/17/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0096	1.3	
[REDACTED]	Unknown	Unknown	Kitchen Sink	01/27/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12	
[REDACTED]	Unknown	Unknown	Kitchen Sink	02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.19 J	
[REDACTED]	Unknown	Unknown	Kitchen Sink	02/14/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	ND<0.12	
				02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
[REDACTED]	86	Unknown	Kitchen Sink	02/04/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.29 J	
				02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.19 J
[REDACTED]	80	Unknown	Pressure Tank	02/15/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12	
			Influent	03/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			Midfluent	03/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			Effluent	03/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
[REDACTED]	125	125	Pressure Tank	02/03/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	41	
			Influent	03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	3.9	
			Effluent	03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
[REDACTED]	~200	180	Pressure Tank	02/05/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	0.66	
			Pressure Tank (Influent)	02/25/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.95
			Kitchen Sink (Effluent)	02/25/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	0.55
[REDACTED]	Unknown	Unknown	Kitchen Sink	02/05/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	ND<0.12	
			Influent	02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.14 J
			Midfluent	02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
			Effluent	02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
[REDACTED]	150	Unknown	Kitchen Sink	02/04/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
			Influent	02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
			Effluent	02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12

Table 1
Potable Well Analytical Results Summary

Sample Location	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethylbenzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethylbenzene (µg/L)	1,3,5-Trimethylbenzene (µg/L)	1,2-Dichloroethane (EDC) (µg/L)	1,2-Dibromoethane (EDB) (µg/L)	Lead (µg/L)	
DEP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5	
[REDACTED]	89 or 109	Unknown	Kitchen Sink	02/04/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
			Pre-Treatment (Basement)	02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	1.1
			Kitchen Sink (Effluent)	02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.12 J
			Influent	03/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Midfluent	03/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Effluent	03/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
[REDACTED]	120	Unknown	Pressure Tank	02/03/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	0.68	
			Influent	02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
			Midfluent	02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12	
			Effluent	02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12	
[REDACTED]	705	Unknown	Bathroom Sink	02/04/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	2.1		
				02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.38 J		
[REDACTED]	Unknown	Unknown	Kitchen Sink	02/04/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12		
[REDACTED]	Unknown	Unknown	Kitchen Sink	02/10/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
				02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.22 J	
[REDACTED]	~80	Unknown	Kitchen Sink	02/07/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	ND<0.12		
				02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12		
			Influent	02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
				03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3		
			Midfluent	02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
				02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0096	ND<0.12	
03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3						
Effluent	02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12			
	02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0096	ND<0.12				
	03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3					
[REDACTED]	Unknown	Unknown	Kitchen Sink	01/27/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0093	0.12		
[REDACTED]	300	>180	Kitchen Sink Outside Spigot	02/05/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0093	ND<0.12		
				03/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
[REDACTED]	Unknown	100	Kitchen Sink	01/25/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0093	ND<0.12 B		
				02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12	
[REDACTED]	Unknown	Unknown	Kitchen Sink	02/05/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.13 J		
				02/25/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.16 J	
[REDACTED]	600	334	Kitchen Sink	01/23/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	0.17 J	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0093	0.31 J	
				02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	0.16 J	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12	
			Influent	03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	0.17 J	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
			Midfluent	03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
				02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
Effluent	03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				

Table 1
Potable Well Analytical Results Summary

Sample Location	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethylbenzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethylbenzene (µg/L)	1,3,5-Trimethylbenzene (µg/L)	1,2-Dichloroethane (EDC) (µg/L)	1,2-Dibromoethane (EDB) (µg/L)	Lead (µg/L)	
DEP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5	
[REDACTED]	~44	Unknown	Pressure Tank	02/03/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0092	0.34 J	
			Influent	02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	1.2
			Midfluent	02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
			Effluent	02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
[REDACTED]	>800	Unknown	Outside Spigot - Untreated	02/03/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	0.40 J	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	0.32 J	
			Kitchen Sink	02/18/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	0.47 J	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
			Pressure Tank	02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	1.2	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	1.3	
			Influent	03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	0.16 J	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			Midfluent	03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			Effluent	03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
[REDACTED]	~150-200	~150-200	Kitchen Sink	02/08/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	0.16 J	ND<0.50	0.23 J	1.1	0.71	ND<0.50	ND<0.0094	ND<0.12	
				02/18/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	0.27 J	ND<0.10	ND<0.20	1.2	0.69	ND<0.10	ND<0.0095	ND<0.12	
			Influent	03/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	0.18 J	ND<0.13	ND<0.14	0.27 J	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			Midfluent	03/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			Effluent	03/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
[REDACTED]	Unknown	Unknown	Bathroom Sink	09/26/2023	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	-	-	-	
				01/31/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12	
				02/06/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12	
			Pressure Tank	02/25/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.16 J
[REDACTED]	Unknown	<250	Outside Spigot	02/05/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	4.0	
				02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	1.1	
			Kitchen Sink (post charcoal treatment)	02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12	
			Influent	03/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			Midfluent	03/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			Effluent	03/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
[REDACTED]	400	Unknown	Outside Spigot	09/25/2023	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	-	-	-	
			Outside Spigot (Pre Treatment)	01/31/2025	39	7.9	49	230	0.2	18	160	ND<0.50	180	ND<0.50	ND<0.0094	ND<0.12	
			Kitchen Sink (Post Treatment)	01/31/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.63	
			Influent	02/14/2025	92	80	41	310	0.33 J	13	110	280	120	ND<0.10	ND<0.0095	ND<0.12	
				02/24/2025	58	9.4	ND<0.10	250	0.42 J	ND<0.10	140	450	200	ND<0.10	ND<0.0094	ND<0.12	
			Midfluent	02/14/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
				02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12	
			Effluent	02/14/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
	02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	ND<0.12				

Table 1
Potable Well Analytical Results Summary

Sample Location	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethylbenzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethylbenzene (µg/L)	1,3,5-Trimethylbenzene (µg/L)	1,2-Dichloroethane (EDC) (µg/L)	1,2-Dibromoethane (EDB) (µg/L)	Lead (µg/L)	
DEP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5	
[REDACTED]	Unknown	Unknown	Bladder Tank	01/31/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
				02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0092	ND<0.12
			Kitchen Sink	02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0092	0.17 J
[REDACTED]	400	380	Pressure Tank	02/05/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.52	
				02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094
[REDACTED]	124	100	Laundry Room Sink	02/06/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12	
			Kitchen Sink	03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
[REDACTED]	+340	340	Kitchen Sink	01/31/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0093	ND<0.12	
			Influent	02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
			Midfluent	02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
			Effluent	02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
[REDACTED]	Unknown	Unknown	Kitchen Sink	02/04/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	0.26 J	
				02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.13 J
[REDACTED]	Unknown	Unknown	Kitchen Sink	02/10/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0093	0.38 J	
				02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
			Basement (Influent)	02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	2.8
			Influent	03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.7	
			Midfluent	03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
Effluent	03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3				
[REDACTED]	Unknown	Unknown	Wellhead with Bailer	02/17/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	0.78		
[REDACTED]	~200	~200	Utility Sink	02/06/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12	
			Pressure Tank (Influent)	02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0096	0.78
			Utility Sink (Effluent)	02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.36 J
[REDACTED]	147	~115	Kitchen Sink	02/06/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.18 J		
				03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
[REDACTED]	Unknown	Unknown	Pre-Carbon Treatment	02/03/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.52	
			Influent	02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.14 J
			Effluent	02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
			Irrigation Well	02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	6.5
[REDACTED]	Unknown	Unknown	Kitchen Sink	02/03/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.20 J		
				02/15/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	ND<0.12	

Table 1
Potable Well Analytical Results Summary

Sample Location	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethylbenzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethylbenzene (µg/L)	1,3,5-Trimethylbenzene (µg/L)	1,2-Dichloroethane (EDC) (µg/L)	1,2-Dibromoethane (EDB) (µg/L)	Lead (µg/L)	
DEP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5	
█	430	400	Kitchen Sink	02/07/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12	
				03/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
█	~600	Unknown	Pressure Tank	02/08/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12	
			Spigot in Basement	03/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
█	Unknown	Unknown	Kitchen Sink *bypassed carbon treatment in basement	02/05/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0093	ND<0.12	
			Pressure Tank (Influent)	03/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	3.0	
			Kitchen Sink (Effluent)	03/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
█	Unknown	Unknown	Backyard Spigot	02/13/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	0.14 J	
█	700	700	Pressure Tank	02/03/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	5.6	
			Kitchen Sink	03/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
█	Unknown	Unknown	Kitchen Sink	02/13/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12	
█	Unknown	Unknown	Pressure Tank (Influent)	02/05/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0092	ND<0.12
				03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			Midfluent	03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			Effluent	03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
█	400	Unknown	Utility Sink	02/04/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0096	0.33 J	
				02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.54	
█	340	Unknown	Kitchen Sink	02/04/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0093	ND<0.12	
				03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
█	137	120	Kitchen Sink	02/07/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12	
█	~350	Unknown	Pressure Tank	02/06/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	24	
				02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	1.7	
█	Unknown	Unknown	Bathroom Next to Kitchen	02/14/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12	
				02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0097	0.16 J	
█	105	75	Kitchen Sink	02/05/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.25 J	
				03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
█	Unknown	Unknown	Pressure Tank	02/04/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.66 J	
			Influent	02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	2.2	
			Effluent	02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.17 J	
█	~70-80	Unknown	Bathroom Sink	02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	0.45 J	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	1.2	
				03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.8 J	
█	300	150	Kitchen Sink	02/13/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12	
				02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.13 J	
█	Unknown	Unknown	Laundry Sink	03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
█	90	70-90	Kitchen Sink	02/15/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12	
				03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
█	~120	Unknown	Kitchen Sink	02/15/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12	
				03/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	

Table 1
Potable Well Analytical Results Summary

Sample Location	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethylbenzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethylbenzene (µg/L)	1,3,5-Trimethylbenzene (µg/L)	1,2-Dichloroethane (EDC) (µg/L)	1,2-Dibromoethane (EDB) (µg/L)	Lead (µg/L)	
DEP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5	
[REDACTED]	140	Unknown	Kitchen Sink	02/11/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12	
				03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
[REDACTED]	Unknown	Unknown	Kitchen Sink	02/13/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0093	1.0	
				02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	1.9	
[REDACTED]	Unknown	Unknown	Kitchen Sink	02/13/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	ND<0.12	
[REDACTED]	212	Unknown	Kitchen Sink	02/03/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	ND<0.12	
			Pressure Tank	02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	2.3	
[REDACTED]	200-400	250-300	Kitchen Sink	02/10/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12	
			Bladder Tank (Influent)	02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.86	
			Kitchen Sink (Effluent)	02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12	
			Influent	03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			Midfluent	03/10/2025	ND<0.19	0.29 J	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			Effluent	03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
[REDACTED]	193	180	Kitchen Sink	02/05/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12	
			Pressure Tank (Influent)	02/14/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0096	ND<0.12	
				02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	2.0	
				02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
[REDACTED]	~135	Unknown	Kitchen Sink (Effluent)	02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
			Kitchen Sink	02/03/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.23 J	
			Basement (Influent)	02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
			Basement (Midfluent)	02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12	
			Kitchen (Effluent)	02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12	
			Influent	03/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			Midfluent	03/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
[REDACTED]	Unknown	Unknown	Pressure Tank	02/05/2025	0.85	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.80	
			Pre POET Treatment	02/18/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0093	ND<0.12	
[REDACTED]	163	162	Kitchen Sink	02/04/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12	
			Pressure Tank (Influent)	02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.73	
			Kitchen Sink (Effluent)	02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12	
			Influent	03/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			Midfluent	03/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
			Effluent	03/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	

Table 1
Potable Well Analytical Results Summary

Sample Location	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethylbenzene (µg/L)	1,3,5-Trimethylbenzene (µg/L)	1,2-Dichloroethane (EDC) (µg/L)	1,2-Dibromoethane (EDB) (µg/L)	Lead (µg/L)	
DEP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5	
[REDACTED]	500	170	Kitchen Sink	02/11/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12	
				02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094
[REDACTED]	740	150	Kitchen Sink	02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
[REDACTED]	Unknown	Unknown	Pressure Tank	02/13/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.63	
[REDACTED]	150-160	120-130	Kitchen Sink	02/07/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	0.17 J	
				02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.20 J
[REDACTED]	Unknown	Unknown	Pressure Tank	02/14/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	2.5	
			Kitchen Sink	03/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
[REDACTED]	250	~240	Bar sink- bypassed softener	02/05/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.76	
				02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	0.91
[REDACTED]	~90	~65	Bathroom Sink	02/10/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.66	
			Bathroom Sink (Basement)	02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
[REDACTED]	223	Unknown	Kitchen Sink	02/03/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0095	0.65	
			Bladder Tank (Basement)	02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
			Influent	03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Midfluent	03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Effluent	03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
[REDACTED]	Unknown	Unknown	Kitchen Sink	02/10/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12	
				02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
[REDACTED]	~ 200	Unknown	Kitchen Sink	02/06/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12	
				02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
[REDACTED]	180	Unknown	Outside Spigot - Influent	02/12/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0093	1.3	
				02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	1.7
			Kitchen Sink - Effluent	02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
[REDACTED]	Unknown	Unknown	Kitchen Sink	02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12		
[REDACTED]	Unknown	Unknown	Kitchen Sink	02/08/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12	
			Pre -Water Softener	02/15/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12	
			Pressure Tank	03/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	0.23 J	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
[REDACTED]	Unknown	Unknown	Kitchen Sink	02/06/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12	
				02/14/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12	
			Outside Spigot Next to Front Door	02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.60
[REDACTED]	900	609	Kitchen Sink	02/06/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12	
				02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
[REDACTED]	225	Unknown	Kitchen Sink	02/14/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12	
				02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12

Table 1
Potable Well Analytical Results Summary

Sample Location	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethylbenzene (µg/L)	1,3,5-Trimethylbenzene (µg/L)	1,2-Dichloroethane (EDC) (µg/L)	1,2-Dibromoethane (EDB) (µg/L)	Lead (µg/L)
DEP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5
[REDACTED]	400	~400	Kitchen Sink	02/05/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0093	0.37 J
			Influent	03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Midfluent	03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
			Effluent	03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
[REDACTED]	232	Unknown	Kitchen Sink	02/05/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	0.16 J	
				03/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J
[REDACTED]	75	65	Kitchen Sink	02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
[REDACTED]	~35	Unknown	Kitchen Sink	03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
[REDACTED]	~140	Unknown	Kitchen Sink	03/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
[REDACTED]	Unknown	Unknown	Kitchen Sink (Effluent)	03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
[REDACTED]	Unknown	Unknown	Kitchen Sink	02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.24 J
[REDACTED]	Unknown	Unknown	Kitchen Sink	02/17/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
				03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
[REDACTED]	Unknown	Unknown	Kitchen Sink	02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.19 J
[REDACTED]	Unknown	Unknown	Kitchen Sink	02/15/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
				03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
[REDACTED]	Unknown	Unknown	Kitchen Sink (First Floor)	02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0096	ND<0.12
[REDACTED]	~50	Close to the bottom	Pressure Tank	02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	220
			Pressure Tank - Influent	03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.7 J
			Kitchen Sink - Effluent	03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
[REDACTED]	~250	Close to the bottom	Kitchen Sink	02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
[REDACTED]	300	~100	Kitchen Sink	02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
[REDACTED]	~50	Close to the bottom	Kitchen Sink	02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
[REDACTED]	Unknown	Unknown	Basement Pre-Treatment	02/18/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.44 J
				03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.4
			Kitchen Sink (Effluent)	03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
[REDACTED]	Unknown	Unknown	Kitchen Sink	02/07/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0092	ND<0.12
				03/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
[REDACTED]	Unknown	Unknown	Kitchen Sink	02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0096	ND<0.12
				03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
[REDACTED]	Unknown	Unknown	Pre-Treatment Pressure Tank	02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
			Kitchen Sink	03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
[REDACTED]	149	147	Kitchen Faucet (Effluent)	03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
				03/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
[REDACTED]	Unknown	Unknown	Bladder Tank	02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	2.2

Table 1
Potable Well Analytical Results Summary

Sample Location	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethylbenzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethylbenzene (µg/L)	1,3,5-Trimethylbenzene (µg/L)	1,2-Dichloroethane (EDC) (µg/L)	1,2-Dibromoethane (EDB) (µg/L)	Lead (µg/L)
DEP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5
[REDACTED]	150 - 160	137	Outside Spigot on Back Deck	02/27/2025	ND<0.10	0.12 J	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.40 J
			Kitchen Sink	03/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
[REDACTED]	Unknown	Unknown	Outside spigot adjacent to front door	02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.50 J
[REDACTED]	~80	Unknown	Kitchen Sink	02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
[REDACTED]	200	Unknown	Kennel	02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
	100	Unknown	Main House	02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
[REDACTED]	~150	Jet Pump	Kitchen Sink	02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
[REDACTED]	65-70 maybe 80	Unknown	Pressure Tank	02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.23 J
[REDACTED]	500-600	360-400	Kitchen Sink	02/07/2025	0.18 J	120	ND<0.50	ND<0.50	ND<0.50	0.12 J	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12
				02/18/2025	0.14 J	80	ND<0.10	ND<0.10	ND<0.10	0.11 J	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	2.3
[REDACTED]	Unknown	Unknown	Kitchen Sink	02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
[REDACTED]	~25	Unknown	Kitchen Sink	02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.13 J
				03/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J	
[REDACTED]	26'9"	20	Basement Bathroom	02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.20 J
			Kitchen Sink	03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
[REDACTED]	90	Unknown	Kitchen Sink	02/14/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
			Pressure Tank	03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.6 J	
[REDACTED]	~40	40	Kitchen Sink	02/07/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0092	0.22 J
			Kitchen Sink	02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.19 J
			Basement	02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.24 J
[REDACTED]	45-50	Unknown	Laundry Room Utility Sink	02/18/2025	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.50	ND<0.0094	ND<0.12	
			Kitchen Sink	03/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
[REDACTED]	Unknown	Unknown	Kitchen Sink	02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
[REDACTED]	~240	Unknown	Kitchen Sink	02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.17 J
			Pressure Tank	03/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	2.7	
[REDACTED]	115	100	Bathroom Sink (Basement)	02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
			Pre-Treatment Pressure Tank	02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0098	ND<0.12

Table 1
Potable Well Analytical Results Summary

Sample Location	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethylbenzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethylbenzene (µg/L)	1,3,5-Trimethylbenzene (µg/L)	1,2-Dichloroethane (EDC) (µg/L)	1,2-Dibromoethane (EDB) (µg/L)	Lead (µg/L)	
DEP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5	
██████████	Unknown	80-100	Kitchen Sink	02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12	
██████████	~150	Unknown	Kitchen Sink	02/18/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	ND<0.12	
				03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
██████████	~140	Unknown	Kitchen Sink	02/18/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
				03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
██████████	Unknown	Unknown	Kitchen Sink	02/14/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12	
██████████	280	270	Kitchen Sink	02/10/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
				03/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
██████████	Unknown	Unknown	Kitchen Sink	03/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
██████████	~300	~293	Kitchen Sink	02/10/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
██████████	Unknown	Unknown	Kitchen Sink	02/25/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12	
██████████	Unknown	Unknown	Kitchen Sink	02/18/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12	
				03/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
██████████	Unknown	Unknown	Pressure Tank	02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	4.2	
				03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	9.7	
██████████	~80	Unknown	Kitchen Sink	02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
				03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
██████████	~200	Unknown	Kitchen Sink	02/14/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
				03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
██████████	85-88	~70	Kitchen Sink	02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
				03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
██████████	~90	Unknown	Kitchen Sink	02/06/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.41 J	
				03/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.6 J	
██████████	Unknown	Unknown	Kitchen Sink	02/13/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
██████████	123	Unknown	Office Downstairs Kitchen Sink	02/14/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12	
			Kitchen Sink	03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
██████████	90	~90	Basement (Pre-Treatment)	02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
			Kitchen Sink (Effluent)	02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
██████████	Unknown	Unknown	Kitchen Sink	02/10/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
				03/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
██████████	Unknown	Unknown	Kitchen Sink	02/18/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.0095	0.50 J		
██████████	26	26	Kitchen Sink	03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	

Table 1
Potable Well Analytical Results Summary

Sample Location	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethylbenzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethylbenzene (µg/L)	1,3,5-Trimethylbenzene (µg/L)	1,2-Dichloroethane (EDC) (µg/L)	1,2-Dibromoethane (EDB) (µg/L)	Lead (µg/L)
DEP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5
[REDACTED]	Unknown	Unknown	Kitchen Sink	02/07/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
[REDACTED]	200	~75	Untreated hose in closet	02/07/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	0.30 J	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	2.6
			Kitchen Sink	02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.12 J
[REDACTED]	265	210	Pressure Tank (Influent)	02/07/2025	0.44 J	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.21 J
				02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
			Utility Sink (Effluent)	02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
[REDACTED]	165	Unknown	Kitchen Sink	02/14/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
			Kitchen Sink	03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
[REDACTED]	~30	Unknown	Kitchen Sink	02/15/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	ND<0.12
				03/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
[REDACTED]	Unknown	Unknown	Kitchen Sink	02/15/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				03/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
[REDACTED]	120	100	Kitchen Sink	02/25/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
[REDACTED]	Unknown	Unknown	Kitchen Sink	02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
[REDACTED]	Unknown	Unknown	Outside Spigot	02/14/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
			Utility Sink	03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
[REDACTED]	Unknown	Unknown	Pressure Tank	02/13/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.32 J
			Kitchen Sink	03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
[REDACTED]	Unknown	Unknown	Kitchen Sink	02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0096	ND<0.12
				03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J	
[REDACTED]	Unknown	Unknown	Pre-Treatment Pressure Tank	02/18/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.14 J
				03/03/2025	ND<0.19	14	ND<0.13	ND<0.19	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
[REDACTED]	100	100	Kitchen Sink	02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.51 J
				02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.48 J	
[REDACTED]	Unknown	Unknown	Pre-Treatment Pressure Tank	02/18/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
[REDACTED]	62	Unknown	Kitchen Sink	02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	0.16 J
[REDACTED]	Unknown	Unknown	Kitchen Sink	03/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
[REDACTED]	470	Unknown	Kitchen Sink	02/06/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0096	ND<0.12	
[REDACTED]	500	460	Kitchen Sink	02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
[REDACTED]	Unknown	Unknown	Pressure Tank	02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.15 J
			Basement Sink (Effluent)	03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	

Table 1
Potable Well Analytical Results Summary

Sample Location	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethylbenzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethylbenzene (µg/L)	1,3,5-Trimethylbenzene (µg/L)	1,2-Dichloroethane (EDC) (µg/L)	1,2-Dibromoethane (EDB) (µg/L)	Lead (µg/L)	
DEP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5	
[REDACTED]	400	340	Influent	02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	0.20 J	
			Effluent	02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
[REDACTED]	Unknown	Unknown	POET Influent	02/11/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.38 J	
[REDACTED]	Unknown	Unknown	POET Influent	02/11/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	1.3	
[REDACTED]	>1,000	520	POET Influent	02/11/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
[REDACTED]	Unknown	Unknown	Sink Near Kitchen	02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.24 J	
[REDACTED]	91	60	Utility Sink (Basement)	02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.13 J	
[REDACTED]	Unknown	Unknown	Kitchen Sink	02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.16 J	
[REDACTED]				03/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
[REDACTED]	Unknown	Unknown	Kitchen Sink	02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12	
[REDACTED]				02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.19 J
[REDACTED]				03/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J
[REDACTED]	Unknown	Unknown	Pressure Tank (Influent)	02/15/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12	
[REDACTED]				03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
[REDACTED]				03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
[REDACTED]	Unknown	Unknown	Pressure Tank	02/12/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	0.52	
[REDACTED]	Unknown	Unknown	Pre-Treatment Pressure Tank	02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	1.4	
[REDACTED]			Post-Treatment Kitchen Sink	02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
[REDACTED]	250	Unknown	Pre-Treatment Pressure Tank	02/18/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	1.3	
[REDACTED]			Laundry Room Sink	03/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
[REDACTED]	Unknown	Unknown	Pre-Treatment Pressure Tank	02/18/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12	
[REDACTED]	Unknown	Unknown	Pre-Treatment Pressure Tank	02/13/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	2.3	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12	
[REDACTED]				02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	3.2	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	1.2	
[REDACTED]				02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.13 J
[REDACTED]	600	Unknown	Sink - Post Treatment (Non-RO Treatment)	02/20/2025	ND<0.10	ND<0.10	ND<0.10	0.24 J	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	ND<0.12	
[REDACTED]				02/20/2025	ND<0.10	ND<0.10	ND<0.10	0.24 J	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	ND<0.12
[REDACTED]	600	Unknown	Kitchen Sink	02/18/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	0.40 J	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
[REDACTED]				03/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	0.39 J	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	
[REDACTED]	Unknown	Unknown	Pre-Treatment	02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	0.11 J	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
[REDACTED]			Post Treatment	02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	0.10 J	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
[REDACTED]	Unknown	Unknown	Basement Bathroom Sink	02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
[REDACTED]	300 +	Unknown	Outside Spigot	02/13/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
[REDACTED]			Kitchen Sink	03/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3	

Table 1
Potable Well Analytical Results Summary

Sample Location	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethylbenzene (µg/L)	1,3,5-Trimethylbenzene (µg/L)	1,2-Dichloroethane (EDC) (µg/L)	1,2-Dibromoethane (EDB) (µg/L)	Lead (µg/L)
DEP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5
[REDACTED]	720	340	Pressure Tank	02/13/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
[REDACTED]			First Floor Kitchen Sink (Effluent)	03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
[REDACTED]	Unknown	400	Outside Spigot (South Side of House)	02/14/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
[REDACTED]	600 - 700	Unknown	Kitchen Sink	02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	1.8
[REDACTED]				03/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.9
[REDACTED]	Unknown	300	Spigot Near Blue Pressure Tank	02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0096	1.6
[REDACTED]	~290	Unknown	Kitchen Sink	02/12/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	ND<0.12
[REDACTED]				03/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
[REDACTED]	~350	Unknown	Pre-Treatment Pressure Tank (Influent)	02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
[REDACTED]				03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	0.34 J	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
[REDACTED]			Kitchen Sink (Effluent)	03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
[REDACTED]	310	280	Kitchen Sink (First Floor)	02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
[REDACTED]	Unknown	Unknown	Kitchen Sink	02/13/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
[REDACTED]	Unknown	Unknown	Kitchen Sink	02/13/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
[REDACTED]				03/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
[REDACTED]	Unknown	Unknown	Spigot	02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	1.7
[REDACTED]			Pressure Tank	02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.16 J
[REDACTED]	340	120	Kitchen Sink	02/18/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
[REDACTED]	Unknown	Unknown	Pressure Tank	02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	1.2
[REDACTED]	Unknown	Unknown	Kitchen Sink	02/18/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
[REDACTED]	~500-600	Unknown	Pressure Tank	02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
[REDACTED]	400	380	Pressure Tank (Influent)	02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	1.8
[REDACTED]			Basement Bathroom Sink (Effluent)	02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
[REDACTED]	400	380	Pressure Tank (Influent)	02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	1.5
[REDACTED]			Kitchen Sink (Effluent)	02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
[REDACTED]	600	50	Pre-Treatment	02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
[REDACTED]			Spigot Near Supply Tank (Influent)	03/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
[REDACTED]			Bathroom Sink (Effluent)	03/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3

Table 1
Potable Well Analytical Results Summary

Sample Location	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethylbenzene (µg/L)	1,3,5-Trimethylbenzene (µg/L)	1,2-Dichloroethane (EDC) (µg/L)	1,2-Dibromoethane (EDB) (µg/L)	Lead (µg/L)
DEP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5
██████████	280	260	Bathroom Sink (Basement)	02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
██████████	400	360	Pre-Treatment	02/15/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.12 J
██████████	Unknown	Unknown	Kitchen Sink Island	02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
██████████	400	380	Outside Spigot	02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0096	ND<0.12
██████████	500	480	Kitchen Sink	02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.12 J
			Bladder Tank	03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.7
██████████	600	500	Kitchen Sink Filtered Drinking Water Faucet	02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
██████████	Unknown	Unknown	Kitchen Sink	02/14/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
██████████	Unknown	Unknown	Kitchen Sink	02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
██████████	600	500	Pressure Tank (Influent)	02/14/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	1.3
				03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.6
			Kitchen Sink (Effluent)	03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
██████████	Unknown	Unknown	Kitchen Sink	02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
██████████	650	Unknown	Kitchen Sink	02/18/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				03/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
██████████	265	Unknown	Kitchen Sink	02/13/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
██████████	~700	Unknown	Kitchen Sink	02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.0094	ND<0.12	
██████████	~300+	Unknown	Pressure Tank	02/14/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
██████████	Maybe 200	Unknown	Kitchen Sink	02/13/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
██████████	188	Unknown	Kitchen Sink	02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
				03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
██████████	Unknown	Unknown	Kitchen Sink	02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
				03/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3

Table 1
Potable Well Analytical Results Summary

Sample Location	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethylbenzene (µg/L)	1,3,5-Trimethylbenzene (µg/L)	1,2-Dichloroethane (EDC) (µg/L)	1,2-Dibromoethane (EDB) (µg/L)	Lead (µg/L)
DEP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5
[REDACTED]	300	150	Kitchen Sink	02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.19 J
[REDACTED]	Unknown	Unknown	Kitchen Sink	02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
[REDACTED]	25	~25	Kitchen Sink	02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.15 J
[REDACTED]	33	Unknown	Kitchen Sink	02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
[REDACTED]				03/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
[REDACTED]	65	Unknown	Kitchen Sink	02/17/2025	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
[REDACTED]	57	48	Pressure Tank	02/17/2025	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	2.5
[REDACTED]				03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.8 J
[REDACTED]	Unknown	Unknown	Kitchen Sink	02/25/2025	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.38 J
[REDACTED]	45	40	Port closest to well in the basement.	02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	1.2
[REDACTED]	35-50	Unknown	Kitchen Sink	02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
[REDACTED]	Unknown	Unknown	Kitchen Sink	02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
[REDACTED]	Unknown	Unknown	Kitchen Sink	03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
[REDACTED]	Unknown	Unknown	Kitchen Sink	02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.14 J
[REDACTED]	Unknown	Unknown	Kitchen Sink	02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
[REDACTED]				03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.0
[REDACTED]	Unknown	Unknown	Upstairs Kitchen Sink	02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.12 J
[REDACTED]				03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.6 J
[REDACTED]	450 or 650	Unknown	Kitchen Sink	03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
[REDACTED]	80	60	Kitchen Sink	03/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
[REDACTED]	60-70	60	Kitchen Sink	03/04/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
[REDACTED]	<400	Unknown	Pressure Tank	02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0097	ND<0.12
[REDACTED]	Unknown	Unknown	Kitchen Sink	02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
[REDACTED]				03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
[REDACTED]				03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J
[REDACTED]	530	Unknown	Spigot attached to Barn	02/18/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
[REDACTED]	305	Unknown	Backyard Spigot Attached to House	02/18/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
[REDACTED]	300	300	Pressure Tank	02/15/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	3.5
[REDACTED]	Unknown	Unknown	Pressure Tank	03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
[REDACTED]	~20 - 28	Unknown	Kitchen Sink	02/25/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0093	0.43 J
[REDACTED]				03/03/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	1.1
[REDACTED]	155	Unknown	Kitchen Sink	03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
[REDACTED]	Unknown	Unknown	Outside Spigot	02/15/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
[REDACTED]				03/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
[REDACTED]	860	~40	Kitchen Sink	02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
[REDACTED]	450	~350-400	Utility Sink	02/13/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12

Table 1
Potable Well Analytical Results Summary

Sample Location	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethylbenzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethylbenzene (µg/L)	1,3,5-Trimethylbenzene (µg/L)	1,2-Dichloroethane (EDC) (µg/L)	1,2-Dibromoethane (EDB) (µg/L)	Lead (µg/L)
DEP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5
██████████	Unknown	Unknown	Kitchen Sink	02/15/2025 03/05/2025	ND<0.10 ND<0.19	ND<0.10 ND<0.19	ND<0.10 ND<0.13	ND<0.10 ND<0.19	ND<0.10 ND<0.13	ND<0.10 ND<0.13	ND<0.20 ND<0.14	ND<0.10 ND<0.13	ND<0.10 ND<0.15	ND<0.10 ND<0.15	ND<0.0094 ND<0.005	0.61 1.0 J
██████████	300	~270	Bathroom Sink	02/15/2025 03/07/2025	ND<0.10 ND<0.19	ND<0.10 ND<0.19	ND<0.10 ND<0.13	ND<0.10 ND<0.19	ND<0.10 ND<0.13	ND<0.10 ND<0.13	ND<0.20 ND<0.14	ND<0.10 ND<0.13	ND<0.10 ND<0.15	ND<0.10 ND<0.15	ND<0.0094 ND<0.005	ND<0.12 ND<0.3
██████████	~700-800	Unknown	Outside Spigot - Warehouse	02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.71
			Outside Spigot - House	03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.7 J
██████████	Unknown	Unknown	Kitchen Sink	02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
██████████	~500-800	Unknown	Laundry Room Sink	02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
██████████	Unknown	Unknown	Kitchen Sink	02/25/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
██████████	Unknown	Unknown	Kitchen Sink (First Floor)	02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
██████████	~200	70	Pressure Tank Spigot	03/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.8 J
██████████	Unknown	Unknown	Kitchen	02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
			Garage Spigot	02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
██████████	Unknown	Unknown	Bladder Tank	02/27/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0096	1.4
██████████	Unknown	Unknown	Influent	03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.4 J
			Effluent	03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
██████████	Unknown	Unknown	Kitchen Sink (First Floor)	02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
██████████	~60-90	Unknown	Kitchen Sink	02/17/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
██████████	~70-90	Unknown	Kitchen Sink	02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.19 J
██████████	Unknown	Unknown	Kitchen Sink	03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
██████████	146	Unknown	Kitchen Sink	02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
██████████			Pressure Tank	02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.0095	1.2

Table 1
Potable Well Analytical Results Summary

Sample Location	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethyl-benzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethylbenzene (µg/L)	1,3,5-Trimethylbenzene (µg/L)	1,2-Dichloroethane (EDC) (µg/L)	1,2-Dibromoethane (EDB) (µg/L)	Lead (µg/L)
DEP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5
	Unknown	460	Kitchen Sink	02/25/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
	~300	Unknown	Kitchen Sink	02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
	Unknown	Unknown	Kitchen Sink	02/25/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.16 J
	Unknown	Unknown	Kitchen Sink	02/25/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.55
	41	Unknown	Kitchen Sink	02/24/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.18 J
	~70	Unknown	Kitchen Sink	03/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	Unknown	Kitchen Sink	02/18/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
	Unknown	Unknown	Kitchen Sink	02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
	Unknown	Unknown	Kitchen Sink	03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	~200	Unknown	Kitchen Sink (First Floor)	02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
	~200	Unknown	Pre-Treatment Basement	02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
	300	Unknown	Kitchen Sink	02/26/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
	144	Unknown	Pressure Tank	02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
	144	Unknown	Pressure Tank	03/11/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	7.2
	~75	Unknown	Bathroom Sink	02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.39 J
	~75	Unknown	Bathroom Sink	03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	Unknown	Kitchen Sink - (Cottage)	02/21/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
	Unknown	Unknown	Basement (Influent)	03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	0.8 J
	Unknown	Unknown	Kitchen Sink - First Floor (Effluent)	03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	90-100	100	Kitchen Sink (First Floor)	02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
	Couple Hundred Feet	Unknown	Kitchen Sink	03/12/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Well 1															
	500	480	Kitchen Sink-1	02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.55
	Well 2															
	480	400-420	Kitchen Sink -2	02/28/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0096	0.18 J
	Unknown	Unknown	Kitchen Sink	03/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	450	~440	Kitchen Sink	03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	270	270	Pressure Tank	02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
	270	270	Utility Sink in Garage	02/22/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	0.34 J
	Unknown	Unknown	Pressure Tank	02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.017 J
	Unknown	Unknown	Kitchen Sink	03/10/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	~100	Unknown	Kitchen Sink	02/20/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0094	ND<0.12
	140	Unknown	Pressure Tank	03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	128	Unknown	Kitchen Sink	03/06/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3

Table 1
Potable Well Analytical Results Summary

Sample Location	Well Depth (feet)	Pump Depth (feet)	Sample Location	Date	Benzene (µg/L)	Toluene (µg/L)	Ethylbenzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Isopropyl Benzene (µg/L)	Naphthalene (µg/L)	1,2,4-Trimethylbenzene (µg/L)	1,3,5-Trimethylbenzene (µg/L)	1,2-Dichloroethane (EDC) (µg/L)	1,2-Dibromoethane (EDB) (µg/L)	Lead (µg/L)
DEP MSCs for a Residential, Used Aquifer					5	1,000	700	10,000	20	840	100	130	130	5	0.05	5
[REDACTED]	300	Unknown	Pressure Tank	02/19/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	ND<0.12
			Kitchen Sink	03/05/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
[REDACTED]	Unknown	Unknown	Spigot	02/13/2025	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.10	ND<0.20	ND<0.10	ND<0.10	ND<0.10	ND<0.0095	0.52
			Kitchen Sink	03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
[REDACTED]	350	300	Kitchen Sink	03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
[REDACTED]	Unknown	Unknown	Kitchen Sink	03/01/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
[REDACTED]	15	Unknown	Kitchen Sink	03/08/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
[REDACTED]	200	Unknown	Well 15	03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3
	Unknown	300	Well 9	03/07/2025	ND<0.19	ND<0.19	ND<0.13	ND<0.19	ND<0.13	ND<0.13	ND<0.14	ND<0.13	ND<0.15	ND<0.15	ND<0.005	ND<0.3

Notes:

DEP = Pennsylvania Department of Environmental Protection

MSCs = Medium-Specific Concentrations per 25 Pa. Code Chapter 250

µg/L = Micrograms/Liter

ND<# = Not Detected (# is method detection limit)

NA = Not Available or Not Analyzed

MDL = Method Detection Limit

RL = Reporting Limit

PID = Photoionization Detector

ppm = Parts Per Million

J = Approximate value; result is < RL and ≥ MDL

* = See laboratory report for qualifiers

Bold = Exceeds the DEP MSC for a Used, Residential Aquifer < 2,500 mg/L total dissolved solids

Volatiles analyzed via EPA Method 524.2

EDB analyzed via EPA Method 8011 through 2/28/2025; samples collected beginning 3/1/2025 analyzed via EPA Method 504

Dissolved Lead analyzed via EPA Method 200.8