

Table 1
Potable Well Analytical Results Summary

| Sample Address | Well Depth (feet) | Pump Depth (feet) | Sample Location | Date | Benzene (µg/L) | Toluene (µg/L) | Ethyl-benzene (µg/L) | Total Xylenes (µg/L) | MTBE (µg/L) | Isopropyl Benzene (µg/L) | Naphthalene (µg/L) | 1,2,4-Trimethylbenzene (µg/L) | 1,3,5-Trimethylbenzene (µg/L) | 1,2-Dichloroethane (µg/L) | 1,2-Dibromoethane (µg/L) | Dissolved Lead (µg/L) | | |
|--|-------------------|--------------------------|-----------------|------------|----------------|----------------|----------------------|----------------------|-------------|--------------------------|--------------------|-------------------------------|-------------------------------|---------------------------|--------------------------|-----------------------|-----------|---------|
| DEP MSCs for a Residential, Used Aquifer | | | | | | 5 | 1,000 | 700 | 10,000 | 20 | 840 | 100 | 130 | 130 | 5 | 0.05 | | |
| Unknown | Unknown | Kitchen Sink | 02/03/2025 | 02/21/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | ND<0.12 | |
| | | | 02/21/2025 | 0.52 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | ND<0.12 |
| | | POET-Influent | 02/28/2025 | 0.18 J | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0095 | ND<0.12 |
| | | | 03/10/2025 | 0.42 J | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.13 | 0.41 J | 0.30 J | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.005 | ND<0.3 |
| | | | 04/08/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.005 | ND<0.3 |
| | | | 05/07/2025 | 0.23 J | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.005 | ND<0.3 |
| | | 06/05/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.005 | ND<0.3 | |
| | | POET-Midfluent | 02/28/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0096 | ND<0.12 |
| | | | 03/10/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.005 | ND<0.3 |
| | | | 04/08/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.005 | ND<0.3 |
| | | | 05/07/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.005 | ND<0.3 |
| | | 06/05/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.005 | ND<0.3 | |
| POET-Effluent | 02/28/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0096 | ND<0.12 | | |
| | 03/10/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.005 | ND<0.3 | | |
| | 04/08/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.005 | ND<0.3 | | |
| | 05/07/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.005 | ND<0.3 | | |
| 06/05/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.005 | ND<0.3 | | | |
| 146-160 | 100 | Outside Spigot | 09/28/2023 | 01/28/2025 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | - | - | - | |
| | | | 01/28/2025 | 0.92 | 6.6 | ND<0.50 | 100 | ND<0.50 | 1.0 | 84 | 47 | 23 | ND<0.50 | ND<0.0094 | 0.017 J | | | |
| | | POET-Influent | 02/19/2025 | 0.13 J | 0.27 J | 0.72 | 29 | ND<0.10 | 1.7 | 47 | 2.1 | 1.3 | ND<0.10 | ND<0.0094 | ND<0.12 | | | |
| | | | 02/24/2025 | ND<0.10 | ND<0.10 | 0.44 J | 13 | ND<0.10 | 0.94 | 30 | 0.32 J | 0.22 J | ND<0.10 | ND<0.0094 | 0.13 J | | | |
| | | | 03/20/2025 | ND<0.19 | ND<0.19 | 0.29 J | 4.2 J | ND<0.13 | 1.3 | 19 | 2.8 | 1.4 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| | | | 03/27/2025 | ND<0.19 | ND<0.19 | 0.18 J | 4.4 | ND<0.13 | 0.98 | 18 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| | | | 04/10/2025 | ND<0.19 | ND<0.19 | 0.13 J | 8.2 | ND<0.13 | 0.70 | 12 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| | | | 04/10/2025 | ND<0.19 | ND<0.19 | ND<0.13 | 6.5 | ND<0.13 | 0.52 | 11 | ND<0.13 | ND<0.15 | ND<0.15 | - | - | | | |
| | | | 05/07/2025 | 0.21 J | ND<0.19 | ND<0.13 | 5.1 | ND<0.13 | 0.53 | 11 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| | | | 07/01/2025 | ND<0.19 | ND<0.19 | ND<0.13 | 1.5 | ND<0.13 | ND<0.13 | 2.1 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| | | 08/18/2025 | ND<0.19 | ND<0.19 | ND<0.13 | 0.61 | ND<0.13 | ND<0.13 | 0.66 | 0.21 J | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | | |
| | | POET-Midfluent | 02/19/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.50 | ND<0.0095 | ND<0.12 | |
| 02/24/2025 | ND<0.10 | | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.50 | ND<0.0093 | ND<0.12 | | | |
| 03/20/2025 | ND<0.19 | | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | | | |
| 03/27/2025 | ND<0.19 | | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | | | |
| 04/10/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | | | | |
| 04/10/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | - | - | | | | | | |
| 05/07/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | | | | |
| 07/01/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | | | | |
| 08/18/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | | | | |
| POET-Effluent | 02/19/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.50 | ND<0.0094 | ND<0.12 | | | |
| | 02/24/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.50 | ND<0.0095 | ND<0.12 | | | |
| | 03/20/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | 0.45 J | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | | | |
| | 03/27/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | 0.42 J | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | | | |
| 04/10/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | 0.43 J | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | | | | |
| 04/10/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | - | - | | | | | | |
| 05/07/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | | | | |
| 07/01/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | | | | |
| 08/18/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | | | | |
| NA | NA | Bottom of Saltwater Pool | 03/17/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| ~100 | Unknown | Bathroom Sink | 09/28/2023 | 01/30/2025 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | - | - | - | | |
| | | | 01/30/2025 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.0094 | ND<0.12 | | | |
| | | Upstairs Bathroom Sink | 03/28/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| | | | 04/25/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| | | POET-Influent | 06/30/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| | | | 08/12/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| | | POET-Midfluent | 04/25/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| | | | 06/30/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| | | 08/12/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | | |
| | | POET-Effluent | 04/25/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| | | | 06/30/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| | | 08/12/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | | |

Table 1
Potable Well Analytical Results Summary

| Sample Address | Well Depth (feet) | Pump Depth (feet) | Sample Location | Date | Benzene (µg/L) | Toluene (µg/L) | Ethyl-benzene (µg/L) | Total Xylenes (µg/L) | MTBE (µg/L) | Isopropyl Benzene (µg/L) | Naphthalene (µg/L) | 1,2,4-Trimethylbenzene (µg/L) | 1,3,5-Trimethylbenzene (µg/L) | 1,2-Dichloroethane (µg/L) | 1,2-Dibromoethane (µg/L) | Dissolved Lead (µg/L) | | |
|--|-------------------|-------------------|------------------|--------------|----------------|----------------|----------------------|----------------------|-------------|--------------------------|--------------------|-------------------------------|-------------------------------|---------------------------|--------------------------|-----------------------|-----------|-----------|
| DEP MSCs for a Residential, Used Aquifer | | | | | | 5 | 1,000 | 700 | 10,000 | 20 | 840 | 100 | 130 | 130 | 5 | 0.05 | 5 | |
| Unknown | Unknown | Unknown | Utility Sink | 02/11/2025 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.0095 | ND<0.12 | |
| | | | Kitchen Sink | 02/24/2025 | 0.63 | ND<0.10 | ND<0.10 | 0.63 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | ND<0.12 |
| | | | POET - Influent | 03/31/2025 | 28 | 25 | 0.64 | 250 | ND<0.13 | 0.17 J | 48 | 130 | 70 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | | | 06/04/2025 | 17 | 2.0 | 0.21 J | 62 | ND<0.13 | 1.4 | 50 | 2.5 | 1.0 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | | | 08/01/2025 | 14 | 0.48 J | ND<0.13 | 42 | ND<0.13 | 0.74 | 34 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | | POET - Midfluent | 03/31/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | | | 06/04/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | | | 08/01/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | | POET - Effluent | 03/31/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | | | 06/04/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | | | 08/01/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | | ~100 | Unknown | Kitchen Sink | 01/28/2025 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.0095 |
| 02/24/2025 | ND<0.10 | ND<0.10 | | | | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0093 | 0.47 J | | |
| Pressure Tank | 03/20/2025 | ND<0.19 | | | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | 0.5 J | | |
| | 04/08/2025 | ND<0.19 | | | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| | 04/16/2025 | ND<0.19 | | | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| POET-Influent | 05/12/2025 | ND<0.19 | | | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| | 07/24/2025 | ND<0.19 | | | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| | 04/08/2025 | ND<0.19 | | | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | 0.31 J | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| POET-Midfluent | 04/16/2025 | ND<0.19 | | | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| | 05/12/2025 | ND<0.19 | | | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| | 07/24/2025 | ND<0.19 | | | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| POET-Effluent | 04/08/2025 | ND<0.19 | | | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| | 04/16/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | | | |
| | 05/12/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | | | |
| 07/24/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | | | | |
| Unknown | Unknown | Kitchen Sink | 01/28/2025 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.0095 | 0.15 J | | |
| | | | 02/24/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | 0.15 J | | |
| | | POET-Influent | 04/02/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| | | | 07/22/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| | | | 04/02/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| | | POET-Midfluent | 07/22/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| | | | 07/22/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| | | | 07/22/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | 0.4 J | | | |
| | | Basement Sink | 04/02/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| | | | 04/02/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| | | ~182 | 180 | Kitchen Sink | 01/23/2025 | 12 | ND<0.50 | ND<0.50 | 0.29 | ND<0.50 | ND<0.50 | 1.3 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.0091 | ND<0.12 |
| | | | | | 01/30/2025 | 12 | ND<0.50 | ND<0.50 | 0.19 | ND<0.50 | ND<0.50 | 1.3 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.0094 | 0.25 J |
| Post-Treatment | 02/12/2025 | | | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.0094 | ND<0.12 | |
| | 02/25/2025 | | | 14 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | 2.0 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | ND<0.12 | |
| | 03/25/2025 | | | 8.8 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.13 | 1.2 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | 05/06/2025 | | | 3.6 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | 06/25/2025 | | | 1.3 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.13 | 0.89 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| 08/22/2025 | 0.42 J | | | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.13 | 0.42 J | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| POET-Midfluent | 02/25/2025 | | | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0095 | ND<0.12 | |
| | 03/25/2025 | | | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| | 05/06/2025 | | | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| POET-Effluent | 06/25/2025 | | | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| | 08/22/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | | | |
| | 02/25/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | ND<0.12 | | | | | |
| Pool Water | 03/25/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | | | |
| | 05/06/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | | | |
| | 06/25/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | | | |
| 08/22/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | | | | |
| Unknown | Unknown | Utility Sink | 01/29/2025 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.0095 | ND<0.12 | | |
| | | | 02/26/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0095 | ND<0.12 | | |
| | | Laundry Room Sink | 03/26/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| | | | 04/21/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| | | | 06/03/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| | | POET-Influent | 04/21/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| | | | 06/03/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| | | | 04/21/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| | | POET-Midfluent | 06/03/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| | | | 06/03/2 | | | | | | | | | | | | | | | |

Table 1
Potable Well Analytical Results Summary

| Sample Address | Well Depth (feet) | Pump Depth (feet) | Sample Location | Date | Benzene (µg/L) | Toluene (µg/L) | Ethyl-benzene (µg/L) | Total Xylenes (µg/L) | MTBE (µg/L) | Isopropyl Benzene (µg/L) | Naphthalene (µg/L) | 1,2,4-Trimethylbenzene (µg/L) | 1,3,5-Trimethylbenzene (µg/L) | 1,2-Dichloroethane (µg/L) | 1,2-Dibromoethane (µg/L) | Dissolved Lead (µg/L) |
|---|-------------------|----------------------------|-----------------|---------|----------------|----------------|----------------------|----------------------|-------------|--------------------------|--------------------|-------------------------------|-------------------------------|---------------------------|--------------------------|-----------------------|
| DEP MSCs for a Residential, Used Aquifer | | | | | 5 | 1,000 | 700 | 10,000 | 20 | 840 | 100 | 130 | 130 | 5 | 0.05 | 5 |
| 503 | 340 | Kitchen Sink | 01/23/2025 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.0092 | ND<0.12 |
| | | | 03/04/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | 03/28/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | POET-Influent | 05/12/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | 07/29/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | 03/04/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | POET-Midfluent | 03/28/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | 05/12/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | 07/29/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | POET-Effluent | 03/04/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | 03/28/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | 05/12/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| 300 | 200 | Bladder Tank Pressure Tank | 01/28/2025 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.0092 | 0.16 J |
| | | | 02/21/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0095 | ND<0.12 |
| | | POET-Influent | 03/13/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | 0.4 J | |
| | | | 04/09/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | 0.5 J | |
| | | | 05/06/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | POET-Midfluent | 07/28/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | 03/13/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | 04/09/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | Kitchen Sink (Effluent) | 05/06/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | 07/28/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | 02/21/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | ND<0.12 |
| | | Effluent | 03/13/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| 04/09/2025 | ND<0.19 | | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| 220 | 220 | Pressure Tank | 01/23/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0091 | 0.19 J |
| | | | 03/21/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | 06/18/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | POET-Midfluent | 08/19/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | 06/18/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | 1.0 | |
| | | Kitchen Sink (First Floor) | 08/19/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | 02/22/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | ND<0.12 |
| | | | 04/24/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| Upstairs Bathroom Sink | 06/18/2025 | ND<0.19 | 0.49 J | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | 0.36 J | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| | 08/19/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | 0.4 J | | | |
| Unknown | Unknown | Kitchen Sink | 01/23/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0092 | ND<0.12 |
| | | | 02/21/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0095 | ND<0.12 |
| | | | 03/20/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | POET - Influent | 04/29/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | 07/03/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | 03/20/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | POET - Midfluent | 04/29/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | 07/03/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | 03/20/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | POET - Effluent | 04/29/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | 07/03/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |

Table 1
Potable Well Analytical Results Summary

| Sample Address | Well Depth (feet) | Pump Depth (feet) | Sample Location | Date | Benzene (µg/L) | Toluene (µg/L) | Ethyl-benzene (µg/L) | Total Xylenes (µg/L) | MTBE (µg/L) | Isopropyl Benzene (µg/L) | Naphthalene (µg/L) | 1,2,4-Trimethylbenzene (µg/L) | 1,3,5-Trimethylbenzene (µg/L) | 1,2-Dichloroethane (µg/L) | 1,2-Dibromoethane (µg/L) | Dissolved Lead (µg/L) | |
|---|-------------------|-------------------|-----------------|--------------|----------------|----------------|----------------------|----------------------|-------------|--------------------------|--------------------|-------------------------------|-------------------------------|---------------------------|--------------------------|-----------------------|---------|
| DEP MSCs for a Residential, Used Aquifer | | | | | | 5 | 1,000 | 700 | 10,000 | 20 | 840 | 100 | 130 | 130 | 5 | 0.05 | 5 |
| ~303 | ~240-252 | Bladder Tank | 01/24/2025 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.0094 | 1.7 | |
| | | | 02/24/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | 0.12 J | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.50 | ND<0.0093 | 3.1 | |
| | | | 03/15/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | POET -Influent | 04/09/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.15 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | 04/30/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | 06/02/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | 08/06/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | 08/25/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | 03/15/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | POET -Midfluent | 04/09/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | 04/30/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | 06/02/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | 08/06/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | POET - Effluent | 02/24/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.50 | ND<0.0093 | 0.13 J |
| | | | 03/15/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | 04/09/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | 04/30/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | 06/02/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | 08/06/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | 08/25/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | ~600-700 | ~400 | Bladder Tank | 01/23/2025 | 15 | 6.7 | 2.7 | 49 | ND<0.50 | 1.3 | 19 | 48 | 39 | ND<0.50 | ND<0.0092 | 5.2 |
| | | | | | 01/31/2025 | 8.9 | 3.7 | 1.7 | 25 | ND<0.50 | 0.94 | 7.3 | 29 | 22 | ND<0.50 | ND<0.0093 | 0.23 J |
| | | | | Kitchen Sink | 02/15/2025 | 25 | 6.7 | 4.1 | 44 | 0.12 J | 1.9 | 20 | 49 | 34 | ND<0.50 | ND<0.0095 | ND<0.12 |
| | | | | | 02/24/2025 | 28 | 4.6 | 4.6 | 42 | 0.14 J | 2.1 | 22 | 55 | 41 | ND<0.50 | ND<0.0094 | 0.15 J |
| 03/24/2025 | 15 | | | | 2.3 | 3.8 | 19 | ND<0.13 | 2.0 | 18 | 77 | 48 | 0.40 J | ND<0.005 | ND<0.3 | | |
| 05/19/2025 | 5.6 | | | | 1.4 | 2.3 | 13 | ND<0.13 | 1.5 | 14 | 68 | 40 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| 07/17/2025 | 7.0 | | | | 1.4 | 2.1 | 14 | ND<0.13 | 1.3 | 13 | 54 | 30 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| 08/13/2025 | 15 | | | | 2.2 | 2.7 | 13 | ND<0.13 | 1.3 | 14 | 46 | 23 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| POET -Influent | 02/15/2025 | | | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.0093 | ND<0.12 | |
| | 02/24/2025 | | | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | 0.17 J | |
| | 03/24/2025 | | | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | 05/19/2025 | | | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | 07/17/2025 | | | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | 08/13/2025 | | | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| POET -Midfluent | 02/15/2025 | | | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.0094 | ND<0.12 | |
| | 02/24/2025 | | | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | ND<0.12 | |
| | 03/24/2025 | | | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | 05/19/2025 | | | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | 07/17/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| | 08/13/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| POET -Effluent | 02/15/2025 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.0094 | ND<0.12 | | | |
| | 02/24/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | ND<0.12 | | | |
| | 03/24/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| | 05/19/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| | 07/17/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| | 08/13/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| 400 | 230 | Bladder Tank | 01/23/2025 | 20 | 51 | 32 | 640 | ND<0.50 | 7.6 | 120 | 310 | 120 | ND<0.50 | ND<0.0093 | 0.23 J | | |
| | | Post Treatment | 02/07/2025 | 0.35 J | 2.3 | 1.2 | 46 | ND<0.50 | 0.26 J | 29 | 19 | 11 | ND<0.50 | ND<0.0094 | 0.75 | | |
| This well was taken out of service on February 17, 2025 | | | | | | | | | | | | | | | | | |
| 420-450 | 300-430 | Bladder Tank | 01/23/2025 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.0093 | 1.4 | |
| | | | Basement | 02/21/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | 0.11 J | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | ND<0.12 |
| | | | Kitchen Sink | 02/21/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | 0.12 J | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | 0.29 J |
| | | POET -Influent | 03/14/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | 04/24/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | 05/19/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | 07/08/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | POET -Midfluent | 03/14/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | 04/24/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | 05/19/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | 07/08/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | POET -Effluent | 03/14/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| 04/24/2025 | ND<0.19 | | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| 05/19/2025 | ND<0.19 | | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| 07/08/2025 | ND<0.19 | | ND<0.19 | ND<0.13 | ND<0.19 | | | | | | | | | | | | |

Table 1
Potable Well Analytical Results Summary

| Sample Address | Well Depth (feet) | Pump Depth (feet) | Sample Location | Date | Benzene (µg/L) | Toluene (µg/L) | Ethyl-benzene (µg/L) | Total Xylenes (µg/L) | MTBE (µg/L) | Isopropyl Benzene (µg/L) | Naphthalene (µg/L) | 1,2,4-Trimethylbenzene (µg/L) | 1,3,5-Trimethylbenzene (µg/L) | 1,2-Dichloroethane (µg/L) | 1,2-Dibromoethane (µg/L) | Dissolved Lead (µg/L) | |
|--|-------------------|-------------------|--------------------------|--------------|----------------|----------------|----------------------|----------------------|-------------|--------------------------|--------------------|-------------------------------|-------------------------------|---------------------------|--------------------------|-----------------------|---------|
| DEP MSCs for a Residential, Used Aquifer | | | | | | 5 | 1,000 | 700 | 10,000 | 20 | 840 | 100 | 130 | 130 | 5 | 0.05 | 5 |
| [REDACTED] | ~120-150 | Unknown | POET-Midfluent | 08/14/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | | 03/21/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | | | 04/22/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | | | 06/03/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | | 08/14/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| | | | 02/21/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | ND<0.12 | | | |
| | 03/21/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | | | |
| | 04/22/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | | | |
| | 06/03/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | | | |
| | 08/14/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | | | |
| | [REDACTED] | 89 or 109 | Unknown | Kitchen Sink | 02/04/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | ND<0.12 |
| | | | | | 02/22/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0095 | 0.12 J | |
| 02/22/2025 | | | | | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0095 | 1.1 | | |
| POET-Influent | | | | 03/08/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | | 04/05/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | | 05/10/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | | 07/01/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| 08/22/2025 | | | | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| POET-Midfluent | | | | 03/08/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | | 04/05/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | | 05/10/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | | 07/01/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| 08/22/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | | | |
| POET-Effluent | 03/08/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | | |
| | 04/05/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | | |
| | 05/10/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | | |
| | 07/01/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | | |
| 08/22/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | | | |
| [REDACTED] | ~120 | Unknown | Pressure Tank (Influent) | 02/03/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0093 | 0.68 | |
| | | | | 02/24/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | ND<0.12 | | |
| | | | | 03/24/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | POET - Influent | 04/28/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | | 06/05/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | | 08/06/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | | | | | | | | | | | | | | | |
| | | | POET - Midfluent | 02/24/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0095 | ND<0.12 |
| | | | | 03/24/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | | 04/28/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | | 06/05/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | 08/06/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| Kitchen Sink (Effluent) | 02/24/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0095 | ND<0.12 | | | |
| | 03/24/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | | |
| | 04/28/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | | |
| | 06/05/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | | |
| 08/06/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | | | |

Table 1
Potable Well Analytical Results Summary

| Sample Address | Well Depth (feet) | Pump Depth (feet) | Sample Location | Date | Benzene (µg/L) | Toluene (µg/L) | Ethyl-benzene (µg/L) | Total Xylenes (µg/L) | MTBE (µg/L) | Isopropyl Benzene (µg/L) | Naphthalene (µg/L) | 1,2,4-Trimethylbenzene (µg/L) | 1,3,5-Trimethylbenzene (µg/L) | 1,2-Dichloroethane (µg/L) | 1,2-Dibromoethane (µg/L) | Dissolved Lead (µg/L) | |
|--|-------------------|-------------------|--|------------|----------------|----------------|----------------------|----------------------|-------------|--------------------------|--------------------|-------------------------------|-------------------------------|---------------------------|--------------------------|-----------------------|---------|
| DEP MSCs for a Residential, Used Aquifer | | | | | 5 | 1,000 | 700 | 10,000 | 20 | 840 | 100 | 130 | 130 | 5 | 0.05 | 5 | |
| 100-150 | Jet Pump | | Kitchen Sink | 02/19/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | ND<0.12 | |
| | | | Influent | 03/26/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | Midfluent | 03/26/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | Effluent | 03/26/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| Unknown | Unknown | | Pressure Tank | 02/19/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | 0.23 J | | |
| 500-600 | 360-400 | | Kitchen Sink | 02/07/2025 | 0.18 J | 120 | ND<0.50 | ND<0.50 | ND<0.50 | 0.12 J | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.0094 | ND<0.12 | |
| | | | | 02/18/2025 | 0.14 J | 80 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | 0.11 J | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0095 | 2.3 |
| | | | | 03/25/2025 | ND<0.19 | 40 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 |
| | | | | 05/02/2025 | ND<0.19 | 13 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 |
| | | | | 08/25/2025 | ND<0.19 | 4.1 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 |
| 240 | 200 | | Outside Spigot | 04/04/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| 06/12/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | | |
| Unknown | Unknown | | Kitchen Sink | 02/27/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0095 | ND<0.12 | | |
| ~25 | Jet Pump | | Kitchen Sink | 02/19/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | 0.13 J | |
| | | | | 03/06/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | 0.4 J | |
| | | | | 04/09/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| 26'9" | 20 | | Basement Bathroom | 02/20/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0095 | 0.20 J | |
| | | | Kitchen Sink | 03/07/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| 90-92 | 60-92 | | Pressure Tank (Influent) | 03/05/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | 0.6 J | |
| | | | | 05/03/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | | 03/24/2025 | ND<0.19 | ND<0.19 | 0.17 J | 0.50 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | 05/03/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | | Midfluent | 03/24/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | | 05/03/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| Kitchen Sink (Effluent) | 02/14/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0095 | ND<0.12 | | | |
| | 03/24/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | | |
| | 05/03/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | | |
| ~40 | 32-40 | | Kitchen Sink | 02/07/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0092 | 0.22 J | |
| | | | | 02/26/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | 0.19 J | |
| | | | 04/21/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | | 06/18/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| Basement Kitchen Sink | 02/26/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | 0.24 J | | | |
| | 03/26/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | | |
| 45-50 | Unknown | | Laundry Room Utility Sink | 02/18/2025 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.50 | ND<0.0094 | ND<0.12 | | |
| | | | Kitchen Sink | 03/11/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| Unknown | Unknown | | Kitchen Sink | 02/20/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0095 | ND<0.12 | |
| | | | | 03/18/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | Island Sink | 05/05/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| Unknown | Unknown | | Kitchen Sink | 03/17/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | | 04/15/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| ~240 | Unknown | | Kitchen Sink | 02/20/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0095 | 0.17 J | |
| | | | | 03/25/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | Pressure Tank | 03/03/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | 2.7 | |
| | | | Influent | 04/25/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | Midfluent | 04/25/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| Effluent | 04/25/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | | |
| Unknown | Unknown | | Kitchen Sink | 03/26/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | | 05/03/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| 115 | 100 | | Pre-Treatment Pressure Tank (Influent) | 02/22/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0098 | ND<0.12 | |
| | | | | 03/15/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | Basement Sink (Effluent) | 02/22/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | ND<0.12 |
| | | | | 03/15/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| Kitchen Sink (First Floor) | 05/16/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |

Table 1
Potable Well Analytical Results Summary

| Sample Address | Well Depth (feet) | Pump Depth (feet) | Sample Location | Date | Benzene (µg/L) | Toluene (µg/L) | Ethyl-benzene (µg/L) | Total Xylenes (µg/L) | MTBE (µg/L) | Isopropyl Benzene (µg/L) | Naphthalene (µg/L) | 1,2,4-Trimethylbenzene (µg/L) | 1,3,5-Trimethylbenzene (µg/L) | 1,2-Dichloroethane (µg/L) | 1,2-Dibromoethane (µg/L) | Dissolved Lead (µg/L) | |
|--|-------------------|-------------------|-----------------------------|------------|----------------|----------------|----------------------|----------------------|-------------|--------------------------|--------------------|-------------------------------|-------------------------------|---------------------------|--------------------------|-----------------------|--------|
| DEP MSCs for a Residential, Used Aquifer | | | | | 5 | 1,000 | 700 | 10,000 | 20 | 840 | 100 | 130 | 130 | 5 | 0.05 | 5 | |
| NA | NA | NA | Northwest Side of Pond | 03/17/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| Unknown | Unknown | Unknown | Well (Outfall Pipe) | 03/17/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| Unknown | Unknown | Unknown | Bathroom Sink (First Floor) | 03/31/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| Unknown | 80-100 | Unknown | Kitchen Sink | 02/27/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0095 | ND<0.12 | |
| | | | Kitchen Sink | 03/17/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 |
| | | | Influent | 04/03/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | 0.6 J |
| | | | Midfluent | 04/03/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 |
| | | | Effluent | 04/03/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 |
| ~150 | Unknown | Unknown | Kitchen Sink | 02/18/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0093 | ND<0.12 | |
| | | | Kitchen Sink | 03/10/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 |
| | | | POET-Influent | 04/12/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 |
| | | | POET-Midfluent | 04/12/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 |
| ~140 | Unknown | Unknown | POET-Effluent | 04/12/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | | Kitchen Sink | 02/18/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | ND<0.12 | |
| | | | Kitchen Sink | 03/07/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 |
| Unknown | Unknown | Unknown | POET-Influent | 04/15/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | | POET-Midfluent | 04/15/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | | POET-Effluent | 04/15/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | | Kitchen Sink | 02/14/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0095 | ND<0.12 | |
| Unknown | Unknown | Unknown | Kitchen Sink | 03/14/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | | Influent | 04/04/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | | Midfluent | 04/04/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | | Effluent | 04/04/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| Unknown | Unknown | Unknown | Kitchen Sink (First Floor) | 03/13/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | | Influent | 04/03/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | | Midfluent | 04/03/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | | Effluent | 04/03/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| 280 | 270 | Unknown | Kitchen Sink | 02/10/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | ND<0.12 | |
| | | | Kitchen Sink | 03/11/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 |
| | | | Influent | 03/28/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 |
| | | | Midfluent | 03/28/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 |
| Unknown | Unknown | Unknown | Effluent | 03/28/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | | Influent (Carbon Filter) | 04/10/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | 2.8 | | |
| | | | POET-Influent | 05/08/2025 | ND<0.19 | ND<0.19 | 0.21 J | 0.87 J | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | POET-Midfluent | 05/08/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 |
| Unknown | Unknown | Unknown | Kitchen Sink (Effluent) | 04/10/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | 0.4 J | | |
| | | | POET-Effluent | 05/08/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | | Kitchen Sink | 03/06/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | | Kitchen Sink | 04/22/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| Unknown | Unknown | Unknown | Kitchen Sink | 07/14/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | | POET-Influent | 06/24/2025 | ND<0.19 | ND<0.19 | 0.22 J | 0.65 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | POET-Midfluent | 06/24/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | | POET-Effluent | 06/24/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |

Table 1
Potable Well Analytical Results Summary

| Sample Address | Well Depth (feet) | Pump Depth (feet) | Sample Location | Date | Benzene (µg/L) | Toluene (µg/L) | Ethyl-benzene (µg/L) | Total Xylenes (µg/L) | MTBE (µg/L) | Isopropyl Benzene (µg/L) | Naphthalene (µg/L) | 1,2,4-Trimethylbenzene (µg/L) | 1,3,5-Trimethylbenzene (µg/L) | 1,2-Dichloroethane (µg/L) | 1,2-Dibromoethane (µg/L) | Dissolved Lead (µg/L) | | |
|---|-------------------|----------------------------|--------------------------|--------------|----------------|----------------|----------------------|----------------------|-------------|--------------------------|--------------------|-------------------------------|-------------------------------|---------------------------|--------------------------|-----------------------|-----------|---------|
| DEP MSCs for a Residential, Used Aquifer | | | | | 5 | 1,000 | 700 | 10,000 | 20 | 840 | 100 | 130 | 130 | 5 | 0.05 | 5 | | |
| ~300 | ~297 | Kitchen Sink | 02/10/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | ND<0.12 | | |
| | | | Influent (Pressure Tank) | 03/15/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | 0.4 J | |
| | | | | 04/10/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | 0.5 J | |
| | | POET-Midfluent | 05/22/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | 0.7 J | | |
| | | | 03/15/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | Effluent (Sink) | 04/10/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | | 05/22/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | 500 | 480 | Kitchen Sink | 04/01/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | 600 | 500 | Kitchen Sink | 04/01/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | Unknown | Unknown | Kitchen Sink | 02/25/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0095 | ND<0.12 |
| | | | | Influent | 03/28/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 |
| | | | | Midfluent | 03/28/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 |
| Effluent | 03/28/2025 | | | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| Unknown | Unknown | Kitchen Sink | 02/18/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0095 | ND<0.12 | | |
| | | Kitchen Sink (First Floor) | 03/04/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | | 03/31/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | POET-Influent | 04/16/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | POET-Midfluent | 04/16/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| POET-Effluent | 04/16/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | | |
| 460 | 40 | Kitchen Sink | 03/25/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | POET-Influent | 05/21/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | POET-Midfluent | 05/21/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | POET-Effluent | 05/21/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| 65 | Unknown | Pressure Tank | 02/17/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0095 | 4.2 | | |
| | | Kitchen Sink | 03/07/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | 9.7 | | |
| | | | 04/09/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | POET - Influent | 04/09/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | POET - Midfluent | 04/09/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| POET - Effluent | 04/09/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | | |
| ~80 | Unknown | Kitchen Sink | 02/19/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | ND<0.12 | | |
| | | | 03/05/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | | 04/04/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | | 05/30/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| ~200 | Unknown | Kitchen Sink | 02/14/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | ND<0.12 | | |
| | | | 03/12/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | | 04/17/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| 85-88 | ~70 | Kitchen Sink | 02/19/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | ND<0.12 | | |
| | | | 03/10/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | | 04/14/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| 310 | ~240 | Basement Spigot | 05/06/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| Unknown | Unknown | Kitchen Sink (Effluent) | Influent | 03/21/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | 4.2 | | |
| | | | 03/21/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | 0.5 J | | |
| ~90 | Unknown | Kitchen Sink | 02/06/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | 0.41 J | | |
| | | | 03/04/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | 0.6 J | | |
| | | | 03/28/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| Unknown | Unknown | Kitchen Sink | 02/13/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | ND<0.12 | | |
| | | | 03/17/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | | 06/06/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |

Table 1
Potable Well Analytical Results Summary

| Sample Address | Well Depth (feet) | Pump Depth (feet) | Sample Location | Date | Benzene (µg/L) | Toluene (µg/L) | Ethyl-benzene (µg/L) | Total Xylenes (µg/L) | MTBE (µg/L) | Isopropyl Benzene (µg/L) | Naphthalene (µg/L) | 1,2,4-Trimethylbenzene (µg/L) | 1,3,5-Trimethylbenzene (µg/L) | 1,2-Dichloroethane (µg/L) | 1,2-Dibromoethane (µg/L) | Dissolved Lead (µg/L) | | | |
|--|-------------------|-------------------|--|------------|----------------|----------------|----------------------|----------------------|-------------|--------------------------|--------------------|-------------------------------|-------------------------------|---------------------------|--------------------------|-----------------------|---------|-----------|---------|
| DEP MSCs for a Residential, Used Aquifer | | | | | 5 | 1,000 | 700 | 10,000 | 20 | 840 | 100 | 130 | 130 | 5 | 0.05 | 5 | | | |
| Unknown | Unknown | Unknown | Pre-Treatment Pressure Tank | 02/13/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | 2.3 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0095 | ND<0.12 | | | |
| | | | Sink - Post Treatment (Non-RO Treatment) | 02/20/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | 3.2 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | 1.2 | | |
| | | | Post-Treatment - RO Spigot at | 02/20/2025 | ND<0.10 | ND<0.10 | ND<0.10 | 0.24 J | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0093 | ND<0.12 | | |
| | | | POET-Influent | 03/28/2025 | ND<0.19 | 16 | ND<0.13 | ND<0.19 | 2.9 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | | | 04/25/2025 | ND<0.19 | 1.9 | ND<0.13 | ND<0.19 | 2.8 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | | | 05/22/2025 | ND<0.19 | 0.37 J | ND<0.13 | ND<0.19 | 3.5 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | | POET-Midfluent | 03/28/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | | | 05/22/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | | POET-Effluent | 03/28/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | | | 05/22/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | | 600 | Unknown | Unknown | Kitchen Sink | 02/18/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | 0.40 J | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | ND<0.12 |
| | | | | | | | 03/04/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | 0.39 J | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 |
| 03/25/2025 | ND<0.19 | ND<0.19 | | | | | ND<0.13 | ND<0.19 | 0.42 J | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| 04/25/2025 | ND<0.19 | ND<0.19 | | | | | ND<0.13 | ND<0.19 | 0.36 J | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| 05/30/2025 | ND<0.19 | ND<0.19 | | | | | ND<0.13 | ND<0.19 | 0.18 J | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| 300 | Unknown | Unknown | Pre-Treatment (Pressure Tank) | 02/20/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | 0.11 J | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | ND<0.12 | | | |
| | | | Post-Treatment (Kitchen Sink) | 02/20/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | 0.10 J | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0095 | ND<0.12 | | | |
| | | | Pressure Tank | 03/27/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| | | | After Water Softener | 05/29/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | 5.2 | | | |
| Unknown | Unknown | Unknown | Basement Bathroom Sink | 02/21/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | ND<0.12 | | | |
| | | | Influent (Pressure Tank) | 03/24/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | 0.9 J | | | |
| | | | Effluent (Basement Bathroom) | 03/24/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| 300+ | ~300 | ~300 | Outside Spigot | 02/13/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | ND<0.12 | | | |
| | | | Kitchen Sink | 03/03/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| | | | | 03/29/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | 0.5 J | | | |
| | | | POET - Influent | 04/26/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| | | | POET - Midfluent | 04/26/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| Unknown | Unknown | Unknown | Kitchen Sink | 04/11/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| | | | | 05/28/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| 700-720 | 340-350 | 340-350 | Pressure Tank Spigot | 02/13/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | ND<0.12 | | | |
| | | | | 03/07/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| | | | | 04/04/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| | | | First Floor Kitchen Sink (Effluent) | 03/07/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| | | | | 04/04/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| Unknown | 400 | 400 | Outside Spigot (South Side of House) | 02/14/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | ND<0.12 | | | |
| | | | Outside Spigot | 03/28/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | 0.3 J | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| | | | POET-Influent | 05/13/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| | | | POET-Effluent | 05/13/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| 600 - 700 | Unknown | Unknown | Kitchen Sink | 02/27/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0095 | 1.8 | | | |
| | | | | 03/04/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | 1.9 | | | |
| | | | | 03/25/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | 1.9 | | | |
| | | | POET-Influent | 05/06/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | 1.7 | | | |
| | | | | 07/10/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | 1.9 | | | |
| | | | POET-Midfluent | 05/06/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| | | | | 07/10/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| POET-Effluent | 05/06/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | | | | |
| | 07/10/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | | | | |

Table 1
Potable Well Analytical Results Summary

| Sample Address | Well Depth (feet) | Pump Depth (feet) | Sample Location | Date | Benzene (µg/L) | Toluene (µg/L) | Ethyl-benzene (µg/L) | Total Xylenes (µg/L) | MTBE (µg/L) | Isopropyl Benzene (µg/L) | Naphthalene (µg/L) | 1,2,4-Trimethylbenzene (µg/L) | 1,3,5-Trimethylbenzene (µg/L) | 1,2-Dichloroethane (µg/L) | 1,2-Dibromoethane (µg/L) | Dissolved Lead (µg/L) |
|--|-------------------|---------------------------------------|-----------------|---------|----------------|----------------|----------------------|----------------------|-------------|--------------------------|--------------------|-------------------------------|-------------------------------|---------------------------|--------------------------|-----------------------|
| DEP MSCs for a Residential, Used Aquifer | | | | | 5 | 1,000 | 700 | 10,000 | 20 | 840 | 100 | 130 | 130 | 5 | 0.05 | 5 |
| 280-400 | 260 | Bathroom Sink (Basement) | 02/22/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | ND<0.12 |
| | | | 04/01/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| 400 | 360 | Pre-Treatment | 02/15/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | 0.12 J | |
| Unknown | Unknown | Kitchen Sink Pressure Tank (Influent) | 03/14/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 |
| | | | 04/17/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | 0.9 J | | |
| | | | 04/17/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| Unknown | Unknown | Midfluent | 04/17/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | 04/17/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | | 04/17/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| Unknown | Unknown | Basement Sink (Effluent) | 04/17/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | 02/26/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | ND<0.12 | | |
| | | | 03/19/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| Unknown | Unknown | Kitchen Sink Island | 04/16/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | 04/16/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| 400 | 380 | Outside Spigot | 02/17/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0096 | ND<0.12 | |
| | | | 04/24/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| 500 | 480 | Kitchen Sink | 02/17/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | 0.12 J | |
| | | | 03/05/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | 1.7 | | |
| | | Bladder Tank | 04/03/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | 2.2 | | |
| | | | 05/03/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | 2.7 | | |
| | | | 06/02/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | 6.6 | | |
| | | Refrigerator | 04/03/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | | 06/02/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| 600 | 500 | Filtered Drinking Water Faucet | 02/28/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | ND<0.12 | |
| | | | 02/28/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.0094 | ND<0.12 | | | |
| | | | 04/21/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| Unknown | Unknown | Kitchen Sink | 02/14/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.0094 | ND<0.12 | | |
| | | | 03/07/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| 500 | 480 | Kitchen Sink | 02/20/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | ND<0.12 | |
| | | | 03/17/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | | 04/11/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| 600 | 500 | Pressure Tank (Influent) | 02/14/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.0094 | 1.3 | | |
| | | | 03/05/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | 1.6 | | |
| Unknown | Unknown | Kitchen Sink (Effluent) | 03/05/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | 02/17/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | ND<0.12 | | |
| 650 | Unknown | Kitchen Sink | 02/18/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0095 | ND<0.12 | |
| | | | 03/11/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | | 04/15/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| 265-360 | 260 | Pressure Tank | 04/15/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | 04/15/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | | 04/15/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| 265-360 | 260 | Kitchen Sink | 02/13/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | ND<0.12 | |
| | | | 03/10/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | | 04/11/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | 0.6 J | | |
| 265-360 | 260 | Influent | 04/11/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | 04/11/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | | 04/11/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| 300 | 260 | Pressure Tank | 04/01/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| ~700 | 240 | Kitchen Sink | 02/19/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | ND<0.12 | |
| | | | 03/18/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | | 04/28/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |

Table 1
Potable Well Analytical Results Summary

| Sample Address | Well Depth (feet) | Pump Depth (feet) | Sample Location | Date | Benzene (µg/L) | Toluene (µg/L) | Ethyl-benzene (µg/L) | Total Xylenes (µg/L) | MTBE (µg/L) | Isopropyl Benzene (µg/L) | Naphthalene (µg/L) | 1,2,4-Trimethylbenzene (µg/L) | 1,3,5-Trimethylbenzene (µg/L) | 1,2-Dichloroethane (µg/L) | 1,2-Dibromoethane (µg/L) | Dissolved Lead (µg/L) | |
|----------------|-------------------|---------------------------------------|--|---------|----------------|----------------|----------------------|----------------------|-------------|--------------------------|--------------------|-------------------------------|-------------------------------|---------------------------|--------------------------|-----------------------|--------|
| | | | DEP MSCs for a Residential, Used Aquifer | | 5 | 1,000 | 700 | 10,000 | 20 | 840 | 100 | 130 | 130 | 5 | 0.05 | 5 | |
| ~300+ | Unknown | Pressure Tank | 02/14/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | ND<0.12 | |
| | | | 03/12/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | 04/11/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | 04/11/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| Maybe 200 | Unknown | Kitchen Sink | 02/13/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | ND<0.12 | |
| | | | 03/10/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | POET-Influent | 04/04/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.13 | 0.31 J | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 |
| | | | 04/14/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 |
| | | POET-Midfluent | 04/04/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 |
| | | | 04/14/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 |
| | | POET-Effluent | 04/04/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 |
| | | | 04/14/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 |
| 188 | Unknown | Kitchen Sink | 02/17/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | ND<0.12 | |
| | | | 03/05/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | 03/26/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| Unknown | Unknown | POET-Influent | 04/24/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | 04/24/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | POET-Midfluent | 04/24/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| Unknown | Unknown | Kitchen Sink | 02/17/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0095 | ND<0.12 | |
| | | | 03/06/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | Influent | 04/08/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | Midfluent | 04/08/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| 300 | 150 | Effluent | 04/08/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | | 04/08/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | | 04/08/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| 60 | 45 | Pressure Tank | 02/24/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | 0.19 J | |
| | | | 06/03/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | 3.0 | |
| | | | 06/03/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| Unknown | Unknown | Kitchen Sink | 03/15/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | | 02/19/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | ND<0.12 | |
| 25 | ~25 | Kitchen Sink | 03/14/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | 02/24/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | 0.15 J | |
| 33 | Unknown | Kitchen Sink | 02/17/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0095 | ND<0.12 | |
| | | | 03/08/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| 65 | Unknown | Kitchen Sink | 02/17/2025 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0095 | ND<0.12 | | |
| 57 | 48 | Pressure Tank | 02/17/2025 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | 2.5 | |
| | | | 03/05/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | 0.8 J | |
| Unknown | Unknown | Kitchen Sink | 02/25/2025 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | 0.38 J | |
| | | | 03/24/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| 45 | 40 | Port closest to well in the basement. | 02/26/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | 1.2 | |
| 35-50 | Unknown | Kitchen Sink | 02/21/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0095 | ND<0.12 | |
| Unknown | Unknown | Kitchen Sink | 02/19/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0095 | ND<0.12 | |
| Unknown | Unknown | Kitchen Sink | 03/01/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| ~150 | Unknown | Kitchen Sink | 02/27/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | 0.14 J | |
| | | | 03/20/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | 04/15/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |

Table 1
Potable Well Analytical Results Summary

| Sample Address | Well Depth (feet) | Pump Depth (feet) | Sample Location | Date | Benzene (µg/L) | Toluene (µg/L) | Ethyl-benzene (µg/L) | Total Xylenes (µg/L) | MTBE (µg/L) | Isopropyl Benzene (µg/L) | Naphthalene (µg/L) | 1,2,4-Trimethylbenzene (µg/L) | 1,3,5-Trimethylbenzene (µg/L) | 1,2-Dichloroethane (µg/L) | 1,2-Dibromoethane (µg/L) | Dissolved Lead (µg/L) | | |
|--|---------------------------|-----------------------------------|---------------------------|-------------------------|------------------------|----------------|----------------------|----------------------|-------------|--------------------------|--------------------|-------------------------------|-------------------------------|---------------------------|--------------------------|-----------------------|----------|-------|
| DEP MSCs for a Residential, Used Aquifer | | | | | 5 | 1,000 | 700 | 10,000 | 20 | 840 | 100 | 130 | 130 | 5 | 0.05 | 5 | | |
| Main House Well - Unknown | Unknown | Unknown | Kitchen Sink | 02/17/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | ND<0.12 | | |
| | | | | 03/05/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.005 | 1.0 | | | | |
| | | | | 04/01/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.005 | 0.4 J | | | | |
| | Unknown | Unknown | Upstairs Kitchen Sink | 02/17/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0095 | 0.12 J | | |
| | | | | 03/05/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.005 | 0.6 J | | | | |
| | | | | 03/27/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.005 | ND<0.3 | | | | |
| | 450 or 650 | Unknown | Kitchen Sink | 03/12/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | | | 04/23/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.005 | ND<0.3 | | | | |
| | | | | | | | | | | | | | | | | | | |
| | 60-80 | 45-60 | Kitchen Sink | 03/04/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | | | 03/26/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.005 | ND<0.3 | | | | |
| | | | | 04/25/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.005 | ND<0.3 | | | | |
| Unknown | Unknown | Pressure Tank | 03/31/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.005 | ND<0.3 | | | | |
| 60-70 | 60-65 | Kitchen Sink | 03/04/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.005 | ND<0.3 | | | | |
| >400 | Unknown | Pressure Tank | 02/17/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0097 | ND<0.12 | | | |
| | | | 03/17/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.005 | ND<0.3 | | | | | |
| | | | 04/03/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.005 | ND<0.3 | | | | | |
| | | | 04/03/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.005 | ND<0.3 | | | | | |
| Main House Well - Unknown | Main House Well - Unknown | Main House Well - Unknown | Kitchen Sink | 02/20/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.0094 | ND<0.12 | | | |
| | | | | 03/07/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.005 | ND<0.3 | | | | |
| | | | Main House POET-Influent | 04/21/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| | | | | 08/25/2025 | ND<0.19 | ND<0.19 | ND<0.13 | 0.40 J | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| | | | Main House POET-Midfluent | 08/25/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| | | | | 08/25/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| | | | Guest House Well - 810 | Guest House Well - 800 | Guest House Well - 800 | Guest House | 03/07/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.005 | 0.4 J |
| | | | | | | | 04/21/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.005 | 0.5 J | |
| Guest House POET-Influent | 08/25/2025 | ND<0.19 | | | | ND<0.19 | 0.44 J | 1.7 J | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.005 | 0.4 J | | | |
| | 08/25/2025 | ND<0.19 | | | | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| 650 | 450 | Kitchen Sink (Effluent) | 03/18/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.005 | ND<0.3 | | | | |
| | | | 04/16/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.005 | ND<0.3 | | | | | |
| 530-935 | Unknown | Spigot attached to Barn | 02/18/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | ND<0.12 | | | |
| | | | 03/13/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.005 | ND<0.3 | | | | |
| 305 | Unknown | Backyard Spigot Attached to House | Influent | 04/07/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| | | | | 02/18/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.0094 | ND<0.12 | | | |
| | | | | 03/13/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| 280-300 | 300 | Pressure Tank (Influent) | Midfluent | 04/11/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| | | | | 04/11/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.005 | ND<0.3 | | | | |
| | | | | 04/11/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.005 | ND<0.3 | | | | |
| 280-300 | 300 | Pressure Tank (Influent) | Midfluent | 02/15/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | 3.5 | | |
| | | | | 03/19/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.005 | 2.3 | | | |
| | | | | 04/23/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.005 | 3.8 | | | |
| | | | | 04/30/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.005 | 3.5 | | | |
| | | | | 06/17/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.005 | 2.4 | | | |
| | | Kitchen Sink (Effluent) | Bar Sink (Effluent) | Kitchen Sink (Effluent) | 03/19/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | | | | 04/23/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | | | | 04/30/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | | | | 04/30/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | | | | 06/17/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.005 | ND<0.3 | | |

Table 1
Potable Well Analytical Results Summary

| Sample Address | Well Depth (feet) | Pump Depth (feet) | Sample Location | Date | Benzene (µg/L) | Toluene (µg/L) | Ethyl-benzene (µg/L) | Total Xylenes (µg/L) | MTBE (µg/L) | Isopropyl Benzene (µg/L) | Naphthalene (µg/L) | 1,2,4-Trimethylbenzene (µg/L) | 1,3,5-Trimethylbenzene (µg/L) | 1,2-Dichloroethane (µg/L) | 1,2-Dibromoethane (µg/L) | Dissolved Lead (µg/L) |
|--|-------------------|--|-----------------|---------|----------------|----------------|----------------------|----------------------|-------------|--------------------------|--------------------|-------------------------------|-------------------------------|---------------------------|--------------------------|-----------------------|
| DEP MSCs for a Residential, Used Aquifer | | | | | 5 | 1,000 | 700 | 10,000 | 20 | 840 | 100 | 130 | 130 | 5 | 0.05 | 5 |
| 425 | Unknown | Pressure Tank Utility Sink (basement) POET - Influent POET - Midfluent POET - Effluent | 03/01/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | 03/19/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | 04/14/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | 06/09/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | 06/09/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| ~20 - 28 | Unknown | Kitchen Sink | 02/25/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0093 | 0.43 J | |
| | | | 03/03/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | 1.1 | |
| | | | 03/24/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | 04/28/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | 0.4 J | |
| 155 | Unknown | Kitchen Sink Kitchen Sink (First Floor) | 03/07/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | 04/02/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| ~140 | Unknown | Outside Spigot Kitchen Sink | 02/15/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | ND<0.12 | |
| | | | 03/06/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| ~860-900 | ~40 | Kitchen Sink | 02/19/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0095 | ND<0.12 | |
| | | | 04/22/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| 450 | ~350-400 | Utility Sink | 02/13/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0095 | ND<0.12 | |
| | | | 04/03/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| Unknown | Unknown | Kitchen Sink | 02/15/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | 0.81 | |
| | | | 03/05/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | 1.0 J | |
| | | | 04/07/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | 0.6 J | |
| 300 | ~270 | Bathroom Sink Outside Spigot | 02/15/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | ND<0.12 | |
| | | | 03/07/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | 04/22/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| ~700-800 | Unknown | Outside Spigot - Warehouse Outside Spigot - House Outside Spigot | 02/27/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | 0.71 | |
| | | | 03/01/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | 0.7 J | |
| | | | 04/22/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | 1.2 | |
| Unknown | Unknown | Kitchen Sink | 02/17/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0095 | ND<0.12 | | |
| | | | 03/25/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| ~500-800 | Unknown | Laundry Room Sink | 02/28/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0095 | ND<0.12 | |
| | | | 03/25/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| Unknown | Unknown | Kitchen Sink POET-Influent POET-Midfluent POET-Effluent | 02/25/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0095 | ND<0.12 | |
| | | | 03/18/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | 05/21/2025 | ND<0.19 | ND<0.19 | 0.21 J | 0.73 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | 05/21/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| Unknown | Unknown | Kitchen Sink | 02/21/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0095 | ND<0.12 | |
| | | | 03/15/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | 04/12/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| ~200 | 70 | Pressure Tank Spigot Kitchen Sink | 03/08/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | 0.8 J | |
| | | | 04/08/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| Unknown | Unknown | Kitchen Sink (non-RO) Laundry Room Sink | 03/20/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | 04/15/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| Unknown | Unknown | Garage Spigot | 02/28/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0095 | ND<0.12 | |
| | | | 04/14/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | Outside Spigot | 05/06/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | 03/18/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | Kitchen Sink | 02/28/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0095 | ND<0.12 | |
| | | | 03/18/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| Unknown | Unknown | Bladder Tank | 02/27/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0096 | 1.4 | | |
| | | | 03/07/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | 0.4 J | |
| Unknown | Unknown | Influent Effluent | 03/07/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | 03/07/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| Unknown | Unknown | Kitchen Sink (First Floor) Kitchen Sink | 02/22/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | ND<0.12 | | |
| | | | 03/18/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| ~60-90 | Unknown | Kitchen Sink | 02/17/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | ND<0.12 | | |
| ~70-90 | Unknown | Kitchen Sink | 02/22/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | 0.19 J | | |
| Unknown | Unknown | Kitchen Sink | 03/01/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| 146 | Unknown | Kitchen Sink Pressure Tank | 02/20/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | ND<0.12 | |
| | | | 02/20/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0095 | 1.2 | |

Table 1
Potable Well Analytical Results Summary

| Sample Address | Well Depth (feet) | Pump Depth (feet) | Sample Location | Date | Benzene (µg/L) | Toluene (µg/L) | Ethyl-benzene (µg/L) | Total Xylenes (µg/L) | MTBE (µg/L) | Isopropyl Benzene (µg/L) | Naphthalene (µg/L) | 1,2,4-Trimethylbenzene (µg/L) | 1,3,5-Trimethylbenzene (µg/L) | 1,2-Dichloroethane (µg/L) | 1,2-Dibromoethane (µg/L) | Dissolved Lead (µg/L) |
|--|---------------------|-------------------|--|--|-------------------------------|-------------------------------|-------------------------------|-------------------------------|-------------------------------|-------------------------------|-------------------------------|-------------------------------|-------------------------------|-------------------------------|-----------------------------------|-----------------------------|
| DEP MSCs for a Residential, Used Aquifer | | | | | 5 | 1,000 | 700 | 10,000 | 20 | 840 | 100 | 130 | 130 | 5 | 0.05 | 5 |
| | Unknown | 460 | Kitchen Sink | 02/25/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | ND<0.12 |
| | ~300 | Unknown | Kitchen Sink | 02/22/2025 03/19/2025 | ND<0.10 ND<0.19 | ND<0.10 ND<0.19 | ND<0.10 ND<0.13 | ND<0.10 ND<0.19 | ND<0.10 ND<0.13 | ND<0.10 ND<0.13 | ND<0.20 ND<0.14 | ND<0.10 ND<0.13 | ND<0.10 ND<0.15 | ND<0.10 ND<0.15 | ND<0.0094 ND<0.005 | ND<0.12 ND<0.3 |
| | 60 | Unknown | Kitchen Sink | 02/25/2025 03/18/2025 04/16/2025 | ND<0.10 ND<0.19 ND<0.19 | ND<0.10 ND<0.19 ND<0.19 | ND<0.10 ND<0.13 ND<0.13 | ND<0.10 ND<0.19 ND<0.19 | ND<0.10 ND<0.13 ND<0.13 | ND<0.10 ND<0.13 ND<0.13 | ND<0.20 ND<0.14 ND<0.14 | ND<0.10 ND<0.13 ND<0.13 | ND<0.10 ND<0.15 ND<0.15 | ND<0.10 ND<0.15 ND<0.15 | ND<0.0094 ND<0.005 ND<0.005 | 0.16 J ND<0.3 ND<0.3 |
| | ~60-70 | Unknown | Kitchen Sink | 03/18/2025 04/16/2025 | ND<0.19 ND<0.19 | ND<0.19 ND<0.19 | ND<0.13 ND<0.13 | ND<0.19 ND<0.19 | ND<0.13 ND<0.13 | ND<0.13 ND<0.13 | ND<0.14 ND<0.14 | ND<0.13 ND<0.13 | ND<0.15 ND<0.15 | ND<0.15 ND<0.15 | ND<0.005 ND<0.005 | ND<0.3 ND<0.3 |
| | Unknown | Unknown | Kitchen Sink | 02/25/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | 0.55 |
| | 41 | Unknown | Kitchen Sink | 02/24/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | 0.18 J |
| | ~70 | Unknown | Kitchen Sink | 03/08/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 |
| | Unknown | Unknown | Kitchen Sink | 02/18/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | ND<0.12 |
| | Unknown | Unknown | Kitchen Sink | 02/20/2025 03/05/2025 | ND<0.10 ND<0.19 | ND<0.10 ND<0.19 | ND<0.10 ND<0.13 | ND<0.10 ND<0.19 | ND<0.10 ND<0.13 | ND<0.10 ND<0.13 | ND<0.20 ND<0.14 | ND<0.10 ND<0.13 | ND<0.10 ND<0.15 | ND<0.10 ND<0.15 | ND<0.0094 ND<0.005 | ND<0.12 ND<0.3 |
| | ~200 | Unknown | Kitchen Sink (First Floor) Pre-Treatment Basement | 02/22/2025 02/22/2025 | ND<0.10 ND<0.10 | ND<0.10 ND<0.10 | ND<0.10 ND<0.10 | ND<0.10 ND<0.10 | ND<0.10 ND<0.10 | ND<0.10 ND<0.10 | ND<0.20 ND<0.20 | ND<0.10 ND<0.10 | ND<0.10 ND<0.10 | ND<0.10 ND<0.10 | ND<0.0094 ND<0.0095 | ND<0.12 ND<0.12 |
| | 300 | Unknown | Kitchen Sink | 02/26/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | ND<0.12 |
| | 144 | Unknown | Pressure Tank | 02/19/2025 03/11/2025 | ND<0.10 ND<0.19 | ND<0.10 ND<0.19 | ND<0.10 ND<0.13 | ND<0.10 ND<0.19 | ND<0.10 ND<0.13 | ND<0.10 ND<0.13 | ND<0.20 ND<0.14 | ND<0.10 ND<0.13 | ND<0.10 ND<0.15 | ND<0.10 ND<0.15 | ND<0.0095 ND<0.005 | ND<0.12 7.2 |
| | ~75 | Unknown | Bathroom Sink | 02/21/2025 03/07/2025 | ND<0.10 ND<0.19 | ND<0.10 ND<0.19 | ND<0.10 ND<0.13 | ND<0.10 ND<0.19 | ND<0.10 ND<0.13 | ND<0.10 ND<0.13 | ND<0.20 ND<0.14 | ND<0.10 ND<0.13 | ND<0.10 ND<0.15 | ND<0.10 ND<0.15 | ND<0.0095 ND<0.005 | 0.39 J ND<0.3 |
| | Unknown | Unknown | Kitchen Sink - (Cottage) Kitchen Sink | 02/21/2025 03/18/2025 | ND<0.10 ND<0.19 | ND<0.10 ND<0.19 | ND<0.10 ND<0.13 | ND<0.10 ND<0.19 | ND<0.10 ND<0.13 | ND<0.10 ND<0.13 | ND<0.20 ND<0.14 | ND<0.10 ND<0.13 | ND<0.10 ND<0.15 | ND<0.10 ND<0.15 | ND<0.0094 ND<0.005 | ND<0.12 ND<0.3 |
| | 120 | 100 | Kitchen Sink | 02/20/2025 03/31/2025 | ND<0.10 ND<0.19 | ND<0.10 ND<0.19 | ND<0.10 ND<0.13 | ND<0.10 ND<0.19 | ND<0.10 ND<0.13 | ND<0.10 ND<0.13 | ND<0.20 ND<0.14 | ND<0.10 ND<0.13 | ND<0.10 ND<0.15 | ND<0.10 ND<0.15 | ND<0.0094 ND<0.005 | ND<0.12 ND<0.3 |
| | Couple Hundred Feet | Unknown | Kitchen Sink | 03/12/2025 04/21/2025 | ND<0.19 ND<0.19 | ND<0.19 ND<0.19 | ND<0.13 ND<0.13 | ND<0.19 ND<0.19 | ND<0.13 ND<0.13 | ND<0.13 ND<0.13 | ND<0.14 ND<0.14 | ND<0.13 ND<0.13 | ND<0.15 ND<0.15 | ND<0.15 ND<0.15 | ND<0.005 ND<0.005 | ND<0.3 ND<0.3 |
| | 270 | 260 | Pressure Tank Kitchen Sink Pressure Tank | 02/20/2025 03/08/2025 04/24/2025 | ND<0.10 ND<0.19 ND<0.19 | ND<0.10 ND<0.19 ND<0.19 | ND<0.10 ND<0.13 ND<0.13 | ND<0.10 ND<0.19 ND<0.19 | ND<0.10 ND<0.13 ND<0.13 | ND<0.10 ND<0.13 ND<0.13 | ND<0.20 ND<0.14 ND<0.14 | ND<0.10 ND<0.13 ND<0.13 | ND<0.10 ND<0.15 ND<0.15 | ND<0.10 ND<0.15 ND<0.15 | ND<0.0095 ND<0.005 ND<0.005 | ND<0.12 ND<0.3 ND<0.3 |
| | 500 | 460-480 | Kitchen Sink-1 Apartment (Effluent1) | 02/28/2025 03/18/2025 04/16/2025 | ND<0.10 ND<0.19 ND<0.19 | ND<0.10 ND<0.19 ND<0.19 | ND<0.10 ND<0.13 ND<0.13 | ND<0.10 ND<0.19 ND<0.19 | ND<0.10 ND<0.13 ND<0.13 | ND<0.10 ND<0.13 ND<0.13 | ND<0.20 ND<0.14 ND<0.14 | ND<0.10 ND<0.13 ND<0.13 | ND<0.10 ND<0.15 ND<0.15 | ND<0.10 ND<0.15 ND<0.15 | ND<0.0094 ND<0.005 ND<0.005 | 0.55 ND<0.3 ND<0.3 |
| | 460-480 | 400-445 | Kitchen Sink-2 House (Effluent2) | 02/28/2025 03/18/2025 04/16/2025 | ND<0.10 ND<0.19 ND<0.19 | ND<0.10 ND<0.19 ND<0.19 | ND<0.10 ND<0.13 ND<0.13 | ND<0.10 ND<0.19 ND<0.19 | ND<0.10 ND<0.13 ND<0.13 | ND<0.10 ND<0.13 ND<0.13 | ND<0.20 ND<0.14 ND<0.14 | ND<0.10 ND<0.13 ND<0.13 | ND<0.10 ND<0.15 ND<0.15 | ND<0.10 ND<0.15 ND<0.15 | ND<0.0096 ND<0.005 ND<0.005 | 0.18 J 0.6 J 0.4 J |

Table 1
Potable Well Analytical Results Summary

| Sample Address | Well Depth (feet) | Pump Depth (feet) | Sample Location | Date | Benzene (µg/L) | Toluene (µg/L) | Ethyl-benzene (µg/L) | Total Xylenes (µg/L) | MTBE (µg/L) | Isopropyl Benzene (µg/L) | Naphthalene (µg/L) | 1,2,4-Trimethylbenzene (µg/L) | 1,3,5-Trimethylbenzene (µg/L) | 1,2-Dichloroethane (µg/L) | 1,2-Dibromoethane (µg/L) | Dissolved Lead (µg/L) | | |
|---|-------------------|-----------------------------|--------------------------|------------|------------------------|----------------|----------------------|----------------------|-------------|--------------------------|--------------------|-------------------------------|-------------------------------|---------------------------|--------------------------|-----------------------|-----------|--------|
| DEP MSCs for a Residential, Used Aquifer | | | | | 5 | 1,000 | 700 | 10,000 | 20 | 840 | 100 | 130 | 130 | 5 | 0.05 | 5 | | |
| [REDACTED] | Unknown | Unknown | Basement (Influent) | 03/05/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | 0.8 J | | |
| | | | Pressure Tank (Influent) | 03/27/2025 | 0.72 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | | 04/04/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.13 | 0.35 J | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | | 04/11/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | | 05/28/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | 0.6 J | |
| | | | Kitchen Sink (Effluent) | 03/05/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | | 04/04/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | | 04/11/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | | 05/28/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | |
| | | | 450 | ~440 | Kitchen Sink | 03/10/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 |
| | | | 04/08/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | | 270 | 270 | Utility Sink in Garage | 02/22/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | 0.34 J |
| 04/07/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | | | |
| Unknown | Unknown | Pressure Tank | 02/19/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0095 | 0.017 J | | |
| | | Kitchen Sink | 03/10/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| | | | 04/16/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| 07/18/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | 2.9 | | | | | |
| ~100 | Unknown | Kitchen Sink | 02/20/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0094 | ND<0.12 | | | |
| 140 | 140 | Pressure Tank | 03/01/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| | | | 03/20/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| | | | 05/01/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| 128 | Unknown | Kitchen Sink (First Floor) | 03/06/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| 04/01/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | 0.4 J | | | | | |
| 185 | Unknown | Kitchen Sink | 03/15/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| ~30-50 | Unknown | Kitchen Sink (Effluent) | 03/18/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| 300 | Unknown | Pressure Tank | 02/19/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0095 | ND<0.12 | | |
| | | | 03/05/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| ~30 | Unknown | Spigot | 02/13/2025 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.20 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.10 | ND<0.0095 | 0.52 | | |
| | | | 03/07/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| | | | Influent | 04/07/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | | | 04/07/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| Midfluent | 04/07/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | | | |
| | 04/07/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | | | |
| 350 | 300 | Kitchen Sink | 03/01/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| Unknown | Unknown | Kitchen Sink | 03/01/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| 15 | Unknown | Kitchen Sink | 03/08/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| 200 | Unknown | 300 | Well 15 | 03/07/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| | | | Well 9 | 03/07/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | |
| Unknown | ~90 | Kitchen Sink | 04/09/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |
| Unknown | Unknown | Utility Sink (near Kitchen) | 04/08/2025 | ND<0.19 | ND<0.19 | ND<0.13 | ND<0.19 | ND<0.13 | ND<0.13 | ND<0.14 | ND<0.13 | ND<0.15 | ND<0.15 | ND<0.005 | ND<0.3 | | | |

Notes:
 DEP = Pennsylvania Department of Environmental Protection
 MSCs = Medium-Specific Concentrations per 25 Pa. Code Chapter 250
 µg/L = Micrograms/Liter
 ND=# = Not Detected (# is method detection limit)
 NA = Not Available or Not Analyzed
 MDL = Method Detection Limit
 RL = Reporting Limit
 PID = Photoionization Detector
 ppm = Parts Per Million
 J = Approximate value; result is < RL and ≥ MDL
 * = See laboratory report for qualifiers
Bold = Exceeds the DEP MSC for a Used, Residential Aquifer < 2,500 mg/L total dissolved solids
 Volatiles analyzed via EPA Method 524.2
 EDB analyzed via EPA Method 8011 through 2/28/2025; samples collected beginning 3/1/2025 analyzed via EPA Method 504
 Dissolved Lead analyzed via EPA Method 200.8