

## Attachment 1:

### Operations that Should Not Utilize Groundwater Discharge for Stormwater Management.

Operation
Facilities with NPDES Industrial Permits
Public Works Yards
Auto and metal recyclers / scrap yards/ junk yards
Petroleum and chemical storage facilities
Gas compressor station or Petroleum pump station; and other support facilities
Highway Maintenance Facilities
Wastewater, solid waste, composting facilities
Industrial machinery and equipment (exterior)
Trucks and trailers parking or maintenance areas
Aircraft deicing and maintenance areas
Fleet storage areas
Vehicle maintenance facilities
Parking lots (40 or more parking spaces)
Commercial loading areas
Fueling stations
Highways (ADT > 2500) and rest stops
Construction business (paving, heavy equipment storage and maintenance)
Retail/wholesale vehicle/ equipment dealers
Convenience stores/ fast food restaurants
Auto parts stores
Car washes (unless discharged to sanitary sewer)
Nurseries and garden centers
Golf courses
Brownfield site with existing soil or groundwater contamination

Note:

- 1.) Source: Adapted from Table B.4 of Tennessee Permanent SWM & Design Guidance Manual