

2011 Chapter 109 Index - March 16, 2011

(highlight = revised or new PN, Gen Update, DBP 2, LT2SWTR, LCR, and GWR citations)

This index provides many of the Chapter 109 citations.

Those highlighted in **blue** are new citations as a result of the following regulation:

Lead and Copper Rule Short Term Revisions - December 2010

Those highlighted in **yellow** are new citations as a result of the following regulations:

PN Revisions - May 2009

General Update Revisions - May 2009

Groundwater Rule - December 2009

Long-Term 2 Enhanced Surface Water Treatment Rule - December 2009

Stage 2 Disinfectants and Disinfection Byproducts Rule - December 2009

This is the hierarchy of names that are used in Chapter 109:

109 Chapter

A Subchapter

.1 Section

(a) Subsection

(1) Paragraph

(i) Subparagraph

(A) Clause

(V) Subclause

(-a-) Item

(-1-) Subitem

2011 Chapter 109 Index - March 16, 2011

(highlight = revised or new PN, Gen Update, DBP 2, LT2SWTR, LCR, and GWR citations)

A	GENERAL PROVISIONS	109-1
109.1	Definitions	109-2
	Bag filter	109-2
	Bank filtration.....	109-2
	Cartridge filter	109-3
	Combined distribution system	109-4
	Conventional filtration.....	109-4
	DBP.....	109-4
	Dual sample set	109-5
	Flowing stream.....	109-6
	GAC10	109-6
	GAC20	109-6
	Groundwater	109-6
	IDSE	109-7
	LRAA	109-7
	Lake/reservoir	109-7
	Log inactivation	109-7
	Log treatment.....	109-9
	Membrane filtration	109-10
	Microorganism	109-10
	Plant intake.....	109-10
	Presedimentation	109-11
	RAA.....	109-11
	Reliably and consistently below the MCL	109-11
	Significant deficiency	109-12
	Wholesale system	109-14
109.2	Purpose	109-15
109.3	Scope.....	109-15
109.4	General requirements	109-15
109.5	Organization of chapter	109-15
109.5(e)	Subchapter L (LT2ESWTR) applies to all PWSs using surface water or GUDI sources	109-16
109.5(f)	Subchapter M (additional requirements for GW sources) applies to all PWSs that use groundwater, excluding those systems that combine GW with SW or GUDI sources prior to treatment.....	109-16
109.6	Inspection authorization	109-16
B	MCLS, MRDLS, OR TREATMENT TECHNIQUE REQUIREMENTS	109-18
109.201	Authority	109-18
109.202	State MCLs, MRDLS and treatment technique requirements	109-19
109.202(a)	Primary MCLs	109-19
109.202(b)	Secondary MCLs	109-19
109.202(c)	Treatment technique requirements for pathogenic bacteria, viruses and protozoan cysts	109-19
109.202(c)(1)(i)(A)	Conventional or direct filtration	109-20
109.202(c)(1)(i)(B)	Slow sand or diatomaceous earth filtration	109-20
109.202(c)(1)(i)(C)	Other filtration technologies.....	109-20
109.202(c)(1)(ii)	Combined total disinfection processes for filtration plants	109-20
109.202(c)(1)(iii)	Unfiltered surface water treatment technique requirements.....	109-21
109.202(c)(1)(iv)	Unfiltered SW experiencing turbidity, microbial violations, contamination or outbreak feasibility study and permit requirements	109-22
109.202(c)(1)(v)	Subparagraph iv requirements do not impact compliance order requirements	109-23

2011 Chapter 109 Index - March 16, 2011

(highlight = revised or new PN, Gen Update, DBP 2, LT2SWTR, LCR, and GWR citations)

109.202(c)(1)(vi) Springs, infiltration galleries and GUDI source treatment technique requirements	109-23
109.202(c)(2) PWS using SW or GUDI sources comply with Subchapter L (LT2ESWTR)	109-23
109.202(c)(3) CWS shall provide continuous disinfection and comply with Subchapter M (GWR)	109-23
109.202(d) Fluoride	109-23
109.202(e) Treatment technique requirements for acrylamide and epichlorohydrin	109-23
109.202(f) MRDLs.....	109-23
109.202(g) Treatment technique requirements for disinfection byproduct precursors	109-24
109.202(h) Recycling of waste stream	109-24
109.203 Unregulated contaminants.....	109-24.1
109.204 Disinfection profiling and benchmarking	109-24.1
109.204(a) Disinfection profiling and benchmarking requirements are incorporated by reference.....	109-24.1
109.204(b) PWs that serve 10,000 or more before 1/1/05 shall comply with this section	109-24.1
109.204(c) PWSs shall conduct disinfection profiling using EPA's guidance manual.....	109-24.2
C MONITORING REQUIREMENTS	109-24.2
109.301 General monitoring requirement.....	109-24.2
109.301(1) Performance monitoring for filtration and disinfection	109-24.3
109.301(1)(i)(A) Shall determine and record the turbidity level as follows:	109-24.3
109.301(1)(i)(A)(I) For systems that operate continuously, at least once every 4 hours that the system is in operation except provided in clause (B)	109-24.3
109.301(1)(i)(A)(II) For systems that do not operate continuously, at start-up, at least once every 4 hours that the system is in operation and also prior to shutting down the plant, except as provided in clause (B).....	109-24.3
109.301(1)(i)(B) May substitute continuous turbidity monitoring and recording..At a minimum, calibration with an EPA-approved primary standard shall be conducted at least quarterly	109-24.3
109.301(2) Performance monitoring for unfiltered surface water and GUDI	109-25
109.301(3) Monitoring requirements for coliforms.....	109-27
109.301(3)(i) Frequency.....	109-27
109.301(3)(ii) Repeat Monitoring	109-29
109.301(3)(iii) Invalidation of total coliform samples	109-30
109.301(3)(iv) Compliance determinations	109-31
109.301(3)(v) Special purpose samples	109-32
109.301(4) Exception	109-32
109.301(5) Monitoring requirements for VOCs.....	109-32
109.301(5)(i) Vinyl chloride.....	109-32
109.301(5)(ii) Initial monitoring schedule.....	109-32
109.301(5)(iii) Repeat monitoring for entry points at which a VOC is detected	109-33
109.301(5)(iv) Repeat monitoring for entry points at which no VOC is detected	109-34
109.301(5)(v) Repeat monitoring for VOCS with MCL exceedances.....	109-34
109.301(5)(vi) Confirmation samples.....	109-34
109.301(5)(vii) Reduced monitoring	109-34
109.301(5)(viii) Waivers	109-35
109.301(5)(ix) Invalidation of VOC samples	109-35
109.301(5)(ix) Compliance determinations	109-35
109.301(6) Monitoring requirements for SOCs	109-36
109.301(6)(i) Initial monitoring schedule.....	109-36
109.301(6)(ii) Repeat monitoring for SOCs that are detected	109-36
109.301(6)(iii) Repeat monitoring for SOCs that are not detected	109-36
109.301(6)(iv) Repeat monitoring for SOCs with MCL exceedances	109-37
109.301(6)(v) Confirmation samples.....	109-37
109.301(6)(vi) Reduced monitoring	109-37
109.301(6)(vii) Waivers	109-38
109.301(6)(vii)(A) Vulnerability assessment area for SOCs except dioxin and PCBs.....	109-38
109.301(6)(vii)(B) Use waivers	109-38
109.301(6)(vii)(C) Susceptibility waivers	109-38

2011 Chapter 109 Index - March 16, 2011

(highlight = revised or new PN, Gen Update, DBP 2, LT2SWTR, LCR, and GWR citations)

109.301(6)(vii)(D)	Waiver requests and renewals	109-39
109.301(6)(vii)(E)	Waivers for dioxin and PCBs	109-39
109.301(6)(viii)	Invalidation of SOC samples	109-39
109.301(6)(ix)	Compliance determinations	109-39
109.301(7)	Monitoring requirements for IOCs	109-39
109.301(7)(i)	Monitoring requirements for asbestos	109-40
109.301(7)(i)(A)	Waivers for asbestos monitoring	109-40
109.301(7)(i)(B)	Initial monitoring schedule	109-40
109.301(7)(i)(C)	Monitoring of new entry points	109-40
109.301(7)(i)(D)	Repeat monitoring for systems that exceed the asbestos MCL	109-40
109.301(7)(i)(E)	Confirmation samples	109-40
109.301(7)(ii)	Monitoring requirements for nitrate and nitrite	109-40
109.301(7)(ii)(A)	Initial monitoring schedule	109-40
109.301(7)(ii)(B)	Monitoring of new entry points	109-41
109.301(7)(ii)(C)	Repeat monitoring for systems with nitrate or nitrite levels equal to or greater than 50% of the MCL	109-41
109.301(7)(ii)(D)	Repeat monitoring for systems with nitrate or nitrite levels less than 50% of the MCL	109-42
109.301(7)(iii)	Monitoring requirements for antimony, arsenic, barium beryllium, cadmium, cyanide, chromium, fluoride, mercury, nickel, selenium and thallium	109-42
109.301(7)(iii)(A)	Initial monitoring schedule	109-42
109.301(7)(iii)(B)	Monitoring of new entry points	109-42
109.301(7)(iii)(C)	Repeat monitoring for entry points at which an IOC MCL is exceeded	109-42
109.301(7)(iii)(D)	Waivers for IOC monitoring	109-42
109.301(7)(iii)(E)	Waivers for cyanide monitoring	109-43
109.301(7)(iii)(F)	Operational monitoring for fluoride	109-44
109.301(7)(iv)	Invalidation of IOC samples	109-44
109.301(7)(v)	Compliance determinations	109-44
109.301(8)	Monitoring requirements for public water systems that obtain finished water from another public water system	109-45
109.301(8)(iii)	Consecutive water supplies may be exempt from conducting monitoring for the MCLS for VOCS, SOCs, and IOCs and rads if the PWS from which finished water is obtained complies with monitoring and is in compliance with the MCLS.	109-45
109.301(9)	Monitoring requirements for POE devices	109-46
109.301(10)	Additional monitoring	109-46
109.301(11)	Monitoring requirements for entry points that do not provide water continuously	109-46
109.301(12)	Monitoring requirements for disinfection byproducts and disinfection byproduct precursors	109-46
109.301(12)(i)	TTHMs and HAA5 Stage 1 DBP Rule	109-46
109.301(12)(i)(A)	Routine monitoring	109-46
109.301(12)(i)(B)	Reduced monitoring Systems serving at least 500 persons and that use SW or GUDI sources shall monitor source water TOC for at least 1 year prior to qualifying for reduced TTHM and HAA5 monitoring	109-48
109.301(12)(ii)	TTHMs and HAA5 Stage 2 DBP Rule	109-49
109.301(12)(ii)(A)	Applicability and schedule	109-50
109.301(12)(ii)(B)	Routine monitoring	109-50
109.301(12)(ii)(C)	Reduced monitoring	109-52
109.301(12)(ii)(D)	Increased monitoring	109-55
109.301(12)(ii)(E)	General monitoring and compliance requirements	109-55
109.301(12)(iii)	Chlorite	109-56
109.301(12)(iii)(A)	Routine monitoring	109-56
109.301(12)(iii)(A)(I)	Daily monitoring	109-56
109.301(12)(iii)(A)(II)	Monthly monitoring	109-56
109.301(12)(iii)(A)(III)	Additional monitoring	109-57
109.301(12)(iii)(B)	Reduced monitoring	109-57

2011 Chapter 109 Index - March 16, 2011

(highlight = revised or new PN, Gen Update, DBP 2, LT2SWTR, LCR, and GWR citations)

109.301(12)(iv)	Bromate	109-57
109.301(12)(iv)(A)	Routine monitoring	109-57
109.301(12)(iv)(B)	Reduced monitoring	109-57
109.301(12)(iv)(B)(II)	Beginning April 1, 2009, a system required to analyze for bromate may reduce monitoring from monthly to quarterly, if the system's RAA bromate concentration computed quarterly is less than or equal to 0.0025 mg/l based on monthly measurements as prescribed in clause (A) for the most recent 4 quarters.	109-57
109.301(12)(v)	Disinfection byproduct precursors	109-58
109.301(12)(v)(A)	Routine monitoring	109-58
109.301(12)(v)(B)	Reduced monitoring	109-58
109.301(12)(v)(C)	Early monitoring	109-58
109.301(13)	Monitoring requirements for disinfectant residuals	109-58
109.301(13)(i)	Chlorine and chloramines	109-59
109.301(13)(ii)	Chlorine dioxide	109-59
109.301(13)(ii)(A)	Routine monitoring	109-59
109.301(13)(ii)(B)	Additional monitoring	109-59
109.301(14)	Monitoring requirements for radionuclides	109-59
109.301(14)(i)	Monitoring requirements for gross alpha particle activity, radium-226, radium-228 and uranium	109-60
109.301(14)(i)(A)	Initial monitoring schedule	109-60
109.301(14)(i)(A)(IV)	Systems that add new entry points shall conduct monitoring beginning the first full quarter the entry point begins serving the public.	109-60
109.301(14)(i)(A)(VI)	Quarterly monitoring is required when the average of initial monitoring > MCL.	109-60
109.301(14)(i)(B)	Repeat monitoring	109-60
109.301(14)(i)(C)	Gross alpha substitution	109-61
109.301(14)(i)(D)	Grandfathering	109-61
109.301(14)(ii)	Monitoring requirements for beta-particle and photon radioactivity	109-62
109.301(14)(iii)	General monitoring and compliance requirements	109-63
109.302	Special monitoring requirements	109-64
109.302(a)	Additional monitoring if PWS is not in compliance with MCL, MRDL or TT	109-64
109.302(b)	Additional monitoring where potential health hazard may exist	109-65
109.302(c)	Special monitoring of UCMR	109-65
109.302(d)	Schedule for sampling for special monitoring	109-65
109.302(e)	Special monitoring for experimental facilities	109-65
109.302(f)	GUDI sampling requirements	109-65
109.302(g)	DEP may reduce or eliminate GUDI sampling requirements	109-65
109.303	Sampling requirements	109-66
109.303(a)	Sampling locations identified in 109.301 or 109.302 or as follows:	109-66
109.303(a)(1)	turbidity MCL at EP	109-66
109.303(a)(2)	total coliform MCL within distribution system	109-66
109.303(a)(3)	fluoride MCL at EP	109-66
109.303(a)(4)	organics and inorganics MCLS and UCMR at EP	109-66
109.303(a)(5)	asbestos sampling points in distribution system with A/C pipe and EP	109-66
109.303(b)	TT performance monitoring locations	109-66
109.303(c)	PWSs assure that samples are properly collected and preserved	109-66
109.303(d)	Compliance monitoring for VOCs shall be collected by a trained person	109-67
109.303(e)	Samples may be composited	109-67
109.303(f)	POE free flowing tap location	109-67
109.303(g)	Rad samples may be composited	109-67
109.303(h)	Beta particle and photon radioactivity samples may be composited	109-67
109.304	Analytical requirements	109-68
109.304(a)	Analytical techniques adopted by EPA or methods approved by DEP	109-68
109.304(b)	Alternative analytical technique may be employed with the written approval from DEP	109-68

2011 Chapter 109 Index - March 16, 2011

(highlight = revised or new PN, Gen Update, DBP 2, LT2SWTR, LCR, and GWR citations)

109.304(c)	For the purpose of determining compliance with the monitoring and analytical requirements established under this subchapter and Subchapters K, L and M ...Turbidity, fluoridation operation, residual disinfectants, WQPs, daily chlorite may be performed by:	109-68
109.304(c)(1)	certified operator	109-68
109.304(c)(2)	person using SOPs	109-68
109.304(c)(3)	environmental lab	109-68
109.304(d)	<i>Cryptosporidium</i> samples analyzed by EPA-approved lab	109-69
109.305	Fees	109-69
109.305(a)	Data management fees	109-69
109.305(b)	Waivers	109-69
D	PUBLIC NOTIFICATION	109-70
109.407	General public notification requirements	109-72
109.407(a)	Violation categories and other situations requiring a public notice	109-72
109.407(a)(2)	Failure to comply with a prescribed treatment technique requirement in Subchapter B, G, K, L or M	109-72
109.407(b)	Definition of public notice tiers	109-72
109.407(b)(1)	Tier 1 public notice	109-73
109.407(b)(2)	Tier 2 public notice	109-73
109.407(b)(3)	Tier 3 public notice	109-73
109.407(c)	Public notice recipients	109-73
109.407(d)	Additional requirements	109-74
109.408	Tier 1 public notice - categories, timing and delivery of notice	109-74
109.408(a)	General violation categories and other situations requiring a Tier 1 public notice	109-74
109.408(a)(7)	Violation of a TT requirement for <i>Cryptosporidium</i> resulting from a failure to provide the bin level of treatment	109-75
109.408(a)(8)	Detection of <i>E. coli</i> in source water samples for triggered or assessment monitoring	109-75
109.408(a)(9)	A breakdown in treatment for GW sources as specified in 109.1307(a)(1)(ii)	109-75
109.408(a)(10)	Occurrence of a waterborne disease outbreak or other emergency situation as defined in 109.701(a)(3)(iii) that adversely affects the quality or quantity of the finished water and has a significant potential to have serious adverse effects on human health as a result of short-term exposure	109-75
109.408(b)	Timing for a Tier 1 public notice	109-75
109.408(b)(5)	Provide a "Problem Corrected" PN	109-76
109.408(c)	Form and manner of a Tier 1 public notice prior to May 10, 2010	109-76
109.408(d)	Delivery of a Tier 1 public notice beginning on May 10, 2010	109-76
109.409	Tier 2 public notice - categories, timing and delivery of notice	109-77
109.409(a)	General violation categories and other situations requiring a Tier 2 public notice	109-77
109.409(a)(1)	All violations and failure to take corrective action in Subchapters B, G, K, L, or M	109-77
109.409(a)(2)	Violations of monitoring requirements In Subchapter C, K or M, lead and copper and additional requirements for groundwater sources	109-77
109.409(b)	Timing for a Tier 2 public notice	109-78
109.409(c)	Form and manner of a Tier 2 public notice	109-78
109.410	Tier 3 public notice - categories, timing and delivery of notice	109-79
109.410(a)	General violation categories and other situations requiring a Tier 3 public notice	109-79
109.410(a)(1)	Monitoring violations under Subchapter C, K, L or M	109-79
109.410(a)(2)	Reporting and record maintenance violations under 109.701(h)	109-80
109.410(b)	Timing for a Tier 3 public notice	109-80
109.410(c)	Delivery of a Tier 3 public notice	109-80
109.410(d)	Use of a CCR to meet the Tier 3 public notice requirements	109-81

2011 Chapter 109 Index - March 16, 2011

(highlight = revised or new PN, Gen Update, DBP 2, LT2SWTR, LCR, and GWR citations)

109.411 Content of a public notice 109-81

109.411(a) Elements of a public notice 109-81

109.411(b) Abbreviated notice 109-82

109.411(c) Elements of a public notice for public water systems operating under a variance or exemption 109-82

109.411(d) Presentation of a public notice..... 109-83

109.411(e) Standard language for a public notice 109-83

109.411(e)(1) Standard health effects language for primary MCL or MRDL violations, treatment technique violations, and violations of the condition of a variance or exemption..... 109-83

109.411(e)(2) Standard language for violations of monitoring requirements 109-84

109.411(e)(3) Standard language to encourage the distribution of the public notice to all persons served 109-84

109.412 Special notice of the availability of unregulated contaminant monitoring results 109-85

109.412(a) Timing for a special notice..... 109-85

109.412(b) Delivery of a special notice 109-85

109.413 Special notice for nitrate exceedances above MCL by noncommunity water systems, where granted permission by the Department 109-85

109.413(a) Timing for a special notice..... 109-85

109.413(b) Delivery of a special notice 109-86

109.414 Notice to new billing units or new customers 109-86

109.414(a) Requirements for community water systems..... 109-86

109.414(b) Requirements for noncommunity water systems 109-86

109.415 Notice by the Department on behalf of the public water system 109-86

109.415(a) Failure to give public notice 109-86

109.415(b) System responsibilities when public notice is given by the Department 109-87

109.416 CCR requirements 109-87

109.416(1) EPA definitions of "customer" and "detected" are incorporated by reference 109-87

109.416(2) Each CWS shall deliver to its customers an annual CCR on the dates established by EPA 109-87

109.416(3) Report contains EPA language except health effects language for fluoride MCL violation 109-87

109.416(4) Report delivery and recordkeeping 109-88

109.417 Special notice for significant deficiencies by NCWS..... 109-89

109.417(a) NCWS shall inform the public of an uncorrected significant deficiency 109-89

109.417(b) If directed by DEP, NCWS with corrected significant deficiency shall inform its customers 109-90

109.418 Special notice for failure to conduct source water *Cryptosporidium* monitoring or failure to determine bin classification 109-90

109.418(a) Special notice for repeated failure to conduct monitoring of the source water for *Cryptosporidium* and for failure to determine bin classification or *Cryptosporidium* level..... 109-90

109.418(b) Delivery of the special notice for failure to determine bin classification or *Cryptosporidium* level. . 109-90

109.418(c) Form and manner of the special notice 109-91

E PERMIT REQUIREMENTS.....109-92

109.501 General permit requirements..... 109-92

109.502 Permitting of currently operating systems; compliance deadlines..... 109-93

109.503 Public water system construction permits 109-94

109.503(a) Permit application requirements 109-94

109.503(a)(1) General requirements..... 109-94

109.503(a)(1)(i) Permit application signatures..... 109-94

109.503(a)(1)(ii) Plans, specifications and engineer's report 109-95

109.503(a)(1)(iii) Information describing new sources 109-95

2011 Chapter 109 Index - March 16, 2011

(highlight = revised or new PN, Gen Update, DBP 2, LT2SWTR, LCR, and GWR citations)

109.503(a)(1)(iii)(B)(I)	VOCs for which MCLS have been established	109-95
109.503(a)(1)(iii)(B)(V)	Total coliform concentration and, if TC+, analyze for the presence of <i>E. coli</i>	109-96
109.503(a)(1)(iii)(B)(VI)(-a-)	Except for SOCs that have been granted a statewide waiver, SOCs.....	109-96
109.503(a)(1)(iii)(B)(VI)(-c-)	PCBs where there is a source of PCB contamination within 1000 feet.....	109-96
109.503(a)(1)(iii)(B)(XII)	For surface water or GUDI sources, <i>E. coli</i> or <i>Cryptosporidium</i> or both as specified in 109.1202	109-96
109.503(a)(1)(iv)	Chapter 102 requirements.....	109-97
109.503(a)(2)	Special requirements for public water suppliers proposing to use POE devices	109-97
109.503(a)(3)	Business plan requirements for new community water systems	109-97
109.503(a)(3)(i)	Facilities plan	109-98
109.503(a)(3)(ii)	Management plan	109-98
109.503(a)(3)(iii)	Financial plan	109-98
109.503(b)	Amendments.....	109-99
109.503(c)	Permit fees	109-99
109.503(d)	Department's review.....	109-100
109.503(e)	Issuance and conditions	109-100
109.504	Public water system operation permits	109-101
109.505	Requirements for noncommunity water systems	109-102
109.505(a)(3)(i)(B)	Total coliform concentration and, if TC+, analyze for the presence of <i>E. coli</i>	109-103
109.505(b)	A NCWS providing 4-log treatment shall obtain a NCWS 4-log treatment permit	109-103
109.506	Emergency permits.....	109-104
109.507	Permits for innovative technology	109-104
109.507	DEP may consider proposals for innovative water treatment processes...that the proposal will provide drinking water that complies with Subchapters B, L and M	109-104
F	DESIGN AND CONSTRUCTION STANDARDS.....	109-106
109.601	Application of standards	109-106
109.602	Acceptable design	109-106
109.602(a)	A PWS shall be designed to provide... and capable of providing water that complies with MCLs, MRDLs and TT established in Subchapters B, L and M.....	109-106
109.603	Source quality and quantity	109-107
109.604	Facilities siting	109-108
109.605	Minimum treatment design standards.....	109-109
109.605(2)	For surface water and GUDI sources, the minimum treatment design...except NCWs may propose and DEP may approve, an alternative to the <i>Giardia</i> design standard when 99.9% inactivation is not feasible	109-109
109.605(3)	For surface water and GUDI sources permitted after 12/26/09, that are determined to be bin 2 or higher, the minimum treatment design for filtration and disinfection must also meet requirements of 109.1203 and 109.1204.....	109-109
109.605(4)	For CWSs using groundwater, the minimum treatment design standard for disinfection is 99.99% treatment of viruses.	109-109
109.605(5)	For NCWs using groundwater with an <i>E. coli</i> positive groundwater source, the minimum treatment design standard for disinfection is 99.99% treatment of viruses.....	109-110
109.606	Chemicals, materials and equipment.....	109-110
109.607	Pressures	109-111

2011 Chapter 109 Index - March 16, 2011

(highlight = revised or new PN, Gen Update, DBP 2, LT2SWTR, LCR, and GWR citations)

109.608 Cross-connections 109-112

109.609 Reserved capacity and finished water storage 109-112

109.611 Disinfection 109-113

109.611 Disinfection facilities shall be designed to provide the dosage rate and contact time... to provide water that complies with the microbiological MCL, MRDL and TT requirements under 109.202 and 109.1302 ... 109-113

109.612 POE devices 109-113

G SYSTEM MANAGEMENT RESPONSIBILITIES.....109-114

109.701 Reporting and recordkeeping 109-114

109.701(a) Reporting requirements for public water systems 109-114

109.701(a)(1) General reporting requirements..... 109-114

109.701(a)(2) Monthly reporting requirements for performance monitoring..... 109-115

109.701(a)(2)(i)(B)(I) The date, time and lowest value each day the residual disinfectant remains equal to or greater than the required minimum..... 109-116

109.701(a)(2)(i)(B)(II) The initial date, time and value for each occurrence that the residual disinfectant concentration is less than the required minimum, and the subsequent date, time and value that the residual disinfect concentration is equal to or greater than the required minimum 109-116

109.701(a)(2)(i)(B)(III) The date the entry point is not in operation 109-116

109.701(a)(3) One-hour reporting requirements- 109-117

109.701(a)(3)(i) A primary MCL or MRDL has been exceeded or a treatment technique requirement has been violated under Subchapter B, K, L or M 109-117

109.701(a)(3)(iii)(F) An overfeed of a drinking water chemical that exceeds NSF maximum use value 109-117

109.701(a)(3)(iii)(G) A situation that causes a loss of positive water pressure in the distribution system where there is evidence of contamination or a water supplier suspects a high risk of contamination 109-117

109.701(a)(3)(iii)(H) A lack of resources that adversely affect operations, such as staff shortages, notification by the power utility of planned lengthy power outages or imminent depletion of treatment chemical inventory..... 109-117

109.701(a)(4) Notice..... 109-117

109.701(a)(5) Siting plan..... 109-118

109.701(a)(6) Records 109-118

109.701(a)(7) Form 109-118

109.701(a)(8) Reporting requirements for disinfectant residuals 109-118

109.701(a)(8)(i) Systems monitoring for chlorine dioxide shall report the number of days chlorine dioxide was used at each entry point during the last month..... 109-118

109.701(a)(8)(ii) Systems monitoring for either chlorine or chloramines shall report the following..... 109-118

109.701(a)(9) Noncompliance report Except where a different reporting period is specified in this chapter, the water supplier shall report to DEP within 48 hours the failure to comply with any NPDWR, including the failure to comply with any monitoring requirement set forth in this chapter. 109-119

109.701(b) Reporting requirements for community water systems 109-119

109.701(c) Reporting requirements for nontransient noncommunity water systems..... 109-119

109.701(d) Record maintenance 109-119

109.701(d)(2) Records of turbidity performance monitoring shall be kept for at least 5 years 109-120

109.701(e) Reporting requirements for public water systems required to perform individual filter monitoring under § 109.301(1)(iv) 109-120

109.701(f) Alternative individual filter turbidity exceedance levels 109-121

109.701(g)(2) Stage 2 DBP Rule..... 109-122

109.701(g)(2)(i) IDSE requirements 109-122

109.701(g)(2)(ii) Stage 2 DPB Rule monitoring plan..... 109-122

109.701(g)(2)(iii) Operational evaluation levels..... 109-123

109.701(g)(2)(iv) Reporting and recordkeeping requirements 109-124

109.701(h) Reporting and record maintenance requirements for systems recycling their waste streams 109-124

2011 Chapter 109 Index - March 16, 2011

(highlight = revised or new PN, Gen Update, DBP 2, LT2SWTR, LCR, and GWR citations)

109.701(i)	Accuracy of data.....	109-125
109.701(j)	Electronic reporting.....	109-125
109.701(k)	Monitoring plan to determine if a source is directly influenced by surface water.....	109-126
109.701(l)	Additional reporting and recordkeeping requirements for systems using surface water or GUDI sources.....	109-126
109.701(m)	Additional reporting and recordkeeping requirements for systems using groundwater sources.....	109-126
109.702	Operation and maintenance plan.....	109-127
109.702(a)(3)	Procedures for repairing and replacing water mains that conform to DEP and water industry standards.....	109-127
109.702(a)(14)	Date of last update.....	109-127
109.703	Facilities operation.....	109-128
109.704	Operator certification.....	109-129
109.704(a)	CWS and NCWS shall have personnel certified under Op Cert Act.....	109-129
109.704(b)	TNCWS shall have competent personnel qualified to operate and maintain.....	109-129
109.705	Sanitary surveys.....	109-130
109.705(c)(1)	A NCWS undergo sanitary survey every 5 years.....	109-130
109.705(c)(2)	Increase the number of routine coliform samples collected to at least 5 per month if DEP does not conduct a sanitary survey every 5 years.....	109-130
109.705(d)	The following apply to significant deficiencies identified at PWSs by a SW source and PWSs supplied by a GUDI source.....	109-131
109.705(e)	Significant deficiencies identified at DEP at a PWSs using groundwater shall comply with 109.1302(c).....	109-131
109.706	System distribution map.....	109-131
109.707	Emergency response plan.....	109-132
109.707(a)(2)(ii)	Key public officials.....	109-132
109.707(a)(2)(iv)	Facilities within a water supplier's service area, including, but not limited to, hospitals, schools, day-care facilities, nursing homes, social service agencies, industrial and commercial users.....	109-132
109.707(c)	The CWS shall review and update the plan at least annually and as necessary to reflect changes to communication procedures and contact information under subsection(a)(2).....	109-133
109.708	Planned service interruptions.....	109-133
109.709	Cross-connection control program.....	109-133
109.710	Disinfectant residual in the distribution system.....	109-134
109.711	Disinfection of facilities prior to placing them into service.....	109-135
109.712	Control of POE devices.....	109-135
109.713	Wellhead protection program.....	109-136
109.714	Filter profile, filter self-assessment and comprehensive performance evaluations.....	109-137
H	LABORATORY CERTIFICATION.....	109-138
109.801	Certification requirement.....	109-138
109.801	A laboratory shall be accredited...demonstrating compliance with monitoring requirements established.....	

2011 Chapter 109 Index - March 16, 2011

(highlight = revised or new PN, Gen Update, DBP 2, LT2SWTR, LCR, and GWR citations)

in Subchapters C, K, L and M 109-138

109.810 Reporting and notification requirements..... 109-140

109.810(a) Beginning November 13, 2009, a lab accredited shall electronically report..... 109-140

109.810(b) A lab accredited shall whenever an MCL, MRDL, TT or AL is exceeded or a sample requires a check
or confirmation sample or is *E. coli*-positive shall do the following..... 109-141

109.810(d) A lab accredited shall be responsible for the accurate reporting of data..... 109-142

I VARIANCES AND EXEMPTIONS ISSUED BY THE DEPARTMENT109-142

109.901 Requirements for a variance 109-143

109.901(a)(1) DEP may grant a variance from the MCL requirements if the PWS has installed and is using the
best treatment technology, treatment methods or other means available to reduce the level of
the contaminant, and has determined that alternate sources of water are not reasonably
available 109-143

109.901(b) The MCL for total coliforms is not eligible for a variance..... 109-143

109.901(c) The TT requirements under 109.202(c), 109.1102(b), 109.1203 and 109.1302 are not eligible
for a variance 109-143

109.902 Variance request..... 109-143

109.903 Requirements for an exemption..... 109-144

109.903(a)(1) PWS is unable to comply with the contaminant level or treatment technique requirement,
or to implement measures to develop an alternative source of water supply 109-144

109.903(a)(4) Management or restructuring changes or both cannot reasonably be made that will result in
compliance with the applicable MCL or TT or, if compliance cannot be achieved,
improve the quality of the drinking water..... 109-145

109.903(b) The MCL for total coliforms is not eligible for an exemption 109-145

109.903(c) The TT requirements under 109.202(c), 109.1102(b), 109.1203 and 109.1302 are not eligible for an
exemption 109-145

109.904 Exemption request 109-145

109.905 Public hearing on a variance or exemption 109-146

109.906 Consideration of a request for a variance or exemption..... 109-147

109.906(1) In its consideration of whether the PWS satisfies the requirements for a variance, DEP will ..., and
whether the system has evaluated that alternative sources of water are not reasonably available 109-147

109.906(3)(iii) The availability of an alternative source of water, including the feasibility of partnerships
with neighboring PWSs, as identified by the PWS or DEP 109-148

109.907 Disposition of a request for a variance or exemption..... 109-148

109.907(c) If DEP makes a determination to grant a variance or exemption request, it will document its
findings for granting a variance or exemption 109-148

109.908 Compliance schedules 109-148.1

109.908(e) In accordance with 40 CFR 142.20(b)(2), DEP may renew an exemption for a PWS that serves
fewer than 3,300 persons and which needs financial assistance for the necessary improvements 109-148.1

**J BOTTLED WATER AND VENDED WATER SYSTEMS, RETAIL WATER FACILITIES AND BULK WATER
HAULING SYSTEMS.....109-148.2**

109.1001 Scope 109-148.2

109.1002 MCLs, MRDLs or treatment techniques 109-148.2

109.1002(c) BRVB systems shall comply with TTs under Subchapter L..... 109-148.2

109.1002(d) BRVB systems shall comply with Subchapter M. BRVBs shall comply with standards

2011 Chapter 109 Index - March 16, 2011

(highlight = revised or new PN, Gen Update, DBP 2, LT2SWTR, LCR, and GWR citations)

109.1009(f)	Special operational requirements for bottled water systems and retail water facilities	109-148.26
109.1009(g)	Special operational requirements for water vending machine systems.....	109-148.26
109.1009(h)	Special operational requirements for bulk water hauling systems	109-148.26
K	LEAD AND COPPER	109-149
109.1101	Scope	109-149
109.1102	Action levels and treatment technique requirements	109-148.28
109.1102(a)	Action levels for lead and copper	109-150
109.1102(a)(4)	The 90 th percentile lead and copper action level computation	109-150
109.1102(b)	Treatment technique requirement for corrosion control	109-150
109.1102(b)(1)	Optimal corrosion control treatment	109-150
109.1102(b)(1)(ii)	A water system deemed to have optimized CCT demonstrates to DEP that for 2 consecutive 6-month monitoring periods that the system does not exceed a lead or copper action level and the difference between the 90th percentile tap water lead level and the highest source water lead level is less than 0.005 mg/L which is the PQL for lead	109-151
109.1102(b)(1)(ii)(A)	To make this demonstration, the system shall collect 1 sample for lead from each entry point during a monitoring period prior to initiation of construction or modification of CCT facilities.....	109-151
109.1102(b)(1)(ii)(B)	A water system deemed to have optimized CCT in accordance with this subparagraph shall continue monitoring for lead and copper at the tap no less frequently than once every 3-calendar years using the reduced number of sites specified in 109.1103(e) and collecting the samples at times and locations specified in 109.1103(e)(1)(iii)	109-151
109.1102(b)(2)	Corrosion control treatment compliance schedule.....	109-151
109.1102(b)(3)	Corrosion control treatment feasibility study.....	109-152
109.1102(b)(4)	Source water treatment	109-153
109.1102(b)(5)	Water quality parameter performance requirements	109-154
109.1103	Monitoring requirements.....	109-155
109.1103(a)	Initial monitoring	109-155
109.1103(a)(1)	Initial lead and copper tap monitoring.....	109-155
109.1103(a)(2)	Initial water quality parameter monitoring	109-156
109.1103(a)(3)	Initial source water monitoring A system which exceeds either the lead or copper action level shall collect one source water sample from each entry point within 6 months after the end of the monitoring period in which the action level was exceeded. Monitoring is required only for the parameter for which the action level was exceeded.	109-157
109.1103(b)	Special lead and copper tap monitoring	109-157
109.1103(c)	Follow-up monitoring after construction or modification of corrosion control treatment facilities.	109-157
109.1103(c)(1)	Lead and copper tap monitoring	109-157
109.1103(c)(2)	Water quality parameter monitoring	109-158
109.1103(c)(3)	Source water monitoring The source water monitoring begins within 6 months after the end of the monitoring period in which the action level was exceeded	109-159
109.1103(d)	Monitoring after performance requirements are established	109-159
109.1103(d)(1)	Lead and copper tap monitoring	109-159
109.1103(d)(2)	Water quality parameter performance monitoring.....	109-159
109.1103(d)(3)	Source water monitoring The source water monitoring begins within 6 months after the end of the monitoring period in which the action level was exceeded	109-160
109.1103(e)	Reduced monitoring.....	109-160
109.1103(e)(1)	Reduced lead and copper tap monitoring	109-161
109.1103(e)(1)(i)	Annual lead and copper tap monitoring.....	109-161
109.1103(e)(1)(i)(B)	A system that installed CCT may reduce lead and copper sample sites and reduce the frequency to once per year if the following conditions are met:	109-161
109.1103(e)(1)(i)(B)(I)	The system does not exceed the lead and copper action levels during each of 2 consecutive 6-month monitoring periods.	109-161
109.1103(e)(1)(i)(B)(II)	The system maintains the range of value for the WQP performance requirements during each of 2 consecutive 6-month monitoring periods in accordance with	

2011 Chapter 109 Index - March 16, 2011

(highlight = revised or new PN, Gen Update, DBP 2, LT2SWTR, LCR, and GWR citations)

	subsection (d)(2).	109-161
109.1103(e)(1)(i)(C)	Annual monitoring shall begin during the calendar year immediately following the end of the second consecutive 6-month monitoring period.	109-161
109.1103(e)(1)(ii)	Triennial lead and copper tap monitoring	109-161
109.1103(e)(1)(ii)(B)	A system that installed CCT may reduce the frequency of lead and copper tap monitoring from annual to once every 3 years if the following conditions are met:	109-161
109.1103(e)(1)(ii)(B)(I)	The system does not exceed the lead and copper action levels during 3 consecutive years of 6-month or annual monitoring.	109-161
109.1103(e)(1)(ii)(B)(II)	The system maintains the range of value for the WQP performance requirements during 3 consecutive years of monitoring.	109-161
109.1103(e)(1)(iii)	Sample sites and timing	109-162
109.1103(e)(2)	Reduced water quality parameter monitoring for large systems	109-162
109.1103(e)(2)(i)	Reduced sites	109-162
109.1103(e)(2)(ii)	Reduced water quality parameter monitoring	109-162
109.1103(e)(3)	Reduced monitoring revocation	109-163
109.1103(e)(3)(i)	Reduced monitoring revocation for large systems	109-163
109.1103(e)(3)(ii)	Reduced monitoring revocation for small or medium water systems	109-163
109.1103(e)(3)(ii)(A)	The water supplier shall conduct WQP monitoring during the monitoring period in which the action level is exceeded. The start of the 6-month monitoring period for WQP monitoring required must coincide with the start of the annual or triennial tap monitoring period in which the action level was exceeded.	109-164
109.1103(e)(3)(ii)(B)	The water supplier shall collect one source water sample from each entry point within 6 months of the end of the monitoring period for the which the action level was exceeded. Monitoring is required only for the parameter for which the action level was exceeded. For systems on annual or less frequent monitoring, the end of the monitoring period is September 30 of the calendar year in which sampling occurs, or, if DEP designated an alternative monitoring period, the end of the monitoring period is the last day of the 4-month period in which sampling occurs	109-164
109.1103(e)(3)(ii)(C)	If a system has installed CCT in compliance with 109.1102(b)(2), the water supplier shall resume lead and copper tap monitoring in accordance with subsection (d)(1)	109-164
109.1103(f)	Additional monitoring by systems	109-164
109.1103(g)	Sample site location plan	109-164
109.1103(g)(1)	Materials evaluation	109-165
109.1103(g)(2)	Lead and copper tap sample site selection	109-165
109.1103(g)(2)(i)	Site selection for community water systems	109-165
109.1103(g)(2)(ii)	Site selection for nontransient noncommunity water systems	109-165
109.1103(g)(2)(ii)	Site selection for nontransient noncommunity water systems	109-165
109.1103(g)(2)(iii)	Site selection for community and nontransient noncommunity water systems that have fewer than five taps	109-166
109.1103(g)(2)(iv)	Site selection for community and nontransient noncommunity water facilities that operate continuously	109-166
109.1103(g)(2)(v)	Sample sites with lead service lines	109-166
109.1103(g)(2)(vi)	Sample sites with point-of-use or point-of-entry devices	109-166
109.1103(g)(3)	Water quality parameter sample site selection	109-166
109.1103(g)(3)(i)	Water quality parameter distribution samples	109-166
109.1103(g)(3)(ii)	Water quality parameter entry point samples	109-167
109.1103(g)(4)	Sample procedure certification	109-167
109.1103(h)	Sample collection methods	109-167
109.1103(h)(1)	Lead and copper tap samples	109-167
109.1103(h)(2)	Water quality parameter distribution samples	109-168
109.1103(h)(3)	Water quality parameter entry point samples	109-168
109.1103(h)(4)	Source water samples	109-168
109.1103(h)(5)	Lead service line samples	109-168
109.1103(i)	Analytical methods	109-169
109.1103(j)	Invalidation of lead or copper tap water samples	109-169
109.1103(k)	Monitoring waivers for small systems	109-169
109.1103(k)(1)	Materials criteria	109-170

2011 Chapter 109 Index - March 16, 2011

(highlight = revised or new PN, Gen Update, DBP 2, LT2SWTR, LCR, and GWR citations)

109.1103(k)(1)(i)	Lead.....	109-170
109.1103(k)(1)(ii)	Copper.....	109-170
109.1103(k)(2)	Monitoring criteria for waiver issuance	109-170
109.1103(k)(2)(i)	Lead levels.....	109-170
109.1103(k)(2)(ii)	Copper levels.....	109-170
109.1103(k)(3)	Department approval of waiver application.....	109-170
109.1103(k)(4)	Monitoring frequency for systems with waivers	109-170
109.1103(k)(4)(i)	Monitoring shall be conducted during the last year of each 9-year compliance cycle- for example 2010, 2019, 2028 and so forth.....	109-170
109.1103(k)(5)	Continued eligibility.....	109-171
109.1103(k)(6)	Requirements following waiver revocation.....	109-171
109.1104	Public education and notification	109-171
109.1104(a)	Public education program	109-171
109.1104(a)(1)	Content.....	109-172
109.1104(a)(1)(i)	Content of written materials	109-172
109.1104(a)(1)(ii)	Information for non-English-speaking populations	109-172
109.1104(a)(1)(iii)	Submission of written materials.....	109-172
109.1104(a)(2)	Delivery	109-172
109.1104(a)(2)(i)	Community water system requirements	109-172
109.1104(a)(2)(ii)	Nontransient noncommunity water system requirements.....	109-174
109.1104(a)(2)(iii)	Extension of 60-day delivery deadline	109-175
109.1104(a)(3)	Discontinuation of public education program	109-175
109.1104(a)(4)	Notification of customer monitoring	109-175
109.1104(b)	Notification of customer monitoring	109-175
109.1104(b)(1)	Content.....	109-175
109.1104(b)(2)	Timing	109-175
109.1104(b)(3)	Delivery	109-175
109.1104(c)	Public notification requirements.....	109-175
109.1105	Permit requirements.....	109-176
109.1105(a)	General permit requirements.....	109-176
109.1105(b)	Construction permits and permit amendments.....	109-176
109.1105(b)(1)	Community water system minor permit amendments.....	109-176
109.1105(b)(2)	Nontransient noncommunity water system permits.....	109-176
109.1105(c)	Operation permits	109-177
109.1106	Design standards	109-177
109.1106(1)	A minimum pH in distribution samples of at least 7.0.....	109-177
109.1106(2)	For systems that are exempt from submitting a construction permit application, a minimum alkalinity measured in all distribution samples of 20 mg/L.....	109-177
109.1107	System management responsibilities	109-178
109.1107(a)	Reporting and recordkeeping	109-178
109.1107(a)(1)	Sample site location plan maintain on file and submit to DEP prior to initial lead and copper monitoring or upon request	109-178
109.1107(a)(2)	Reporting of monitoring results	109-178
109.1107(a)(2)(i)	Lead and copper tap monitoring results	109-178
109.1107(a)(2)(i)(I)	The sample location	109-178
109.1107(a)(2)(ii)	Water quality parameter monitoring results	109-178
109.1107(a)(2)(iii)	Source water monitoring results	109-179
109.1107(a)(3)	Corrosion control treatment reporting requirements.....	109-179
109.1107(a)(4)	Public education reporting requirements.....	109-180
109.1107(a)(5)	Consumer notice of lead tap monitoring results reporting requirements The water supplier shall submit to DEP within 3 months of the end of the monitoring period in which lead tap monitoring was conducted a sample copy of the consumer notice of lead tap monitoring	

2011 Chapter 109 Index - March 16, 2011

(highlight = revised or new PN, Gen Update, DBP 2, LT2SWTR, LCR, and GWR citations)

	results along with a certification that the notices were distributed in accordance with 109.1104(b)	109-180
109.1107(a)(6)	Lead service line replacement reporting	109-180
109.1107(a)(7)	Record maintenance	109-180
109.1107(b)	Operation and maintenance plan	109-181
109.1107(c)	Operator certification	109-182
109.1107(d)	Lead service line replacement	109-182
109.1107(d)(1)	Initiation of lead service line replacement The first year of LSL replacement begins on the first day following the end of the monitoring period in which the action level was exceeded. If monitoring is required annually or less frequently, the end of the monitoring period is September 30 of the calendar year in which sampling occurred.	109-182
109.1107(d)(2)	Replacement schedule	109-182
109.1107(d)(3)	Lead service line sampling	109-182
109.1107(d)(4)	Conditions of replacement	109-182
109.1107(d)(5)	Discontinuation of lead service line replacement	109-182.1
109.1107(d)(6)	Resumption of lead service line replacement Water systems that resume a LSL replacement program shall update their LSL inventory to include those sites that were previously excluded under paragraph (3). Systems shall divide the updated number of remaining LSLs by the number of remaining years in the replacement program to determine the number that must be replaced each year. If the system has completed a 15-year LSL replacement program, DEP will determine a schedule for replacing or retesting LSLs that were previously tested out under the replacement program	109-182.1
109.1108	Fees	109-182.1
109.1108(1)	Construction or permit amendment fee	109-181
109.1108(2)	System not paying construction fee	109-181
L	LONG-TERM 2 ENHANCED SURFACE WATER TREATMENT RULE	109-182.2
109.1201	Scope	109-182.3
109.1201(a)	Scope	109-182.3
109.1201(b)	Applicability	109-182.3
109.1202	Monitoring Requirements	109-183
109.1202(a)	Initial round of source water monitoring	109-183
109.1202(b)	Second round of source water monitoring	109-184
109.1202(c)	Source water monitoring schedule	109-184
109.1202(d)	Source water monitoring avoidance	109-185
109.1202(e)	Plants operating only part of the year	109-185
109.1202(f)	New sources	109-185
109.1202(g)	Monitoring violations	109-186
109.1202(h)	Source water sampling schedules	109-186
109.1202(i)	Source water sample collection period	109-186
109.1202(j)	Missed samples	109-187
109.1202(k)	Source water sampling location	109-187
109.1202(l)	Chemical treatment prior to sampling location	109-187
109.1202(m)	Source water sample location for plants that recycle	109-187
109.1202(n)	Bank filtration	109-187
109.1202(o)	Multiple sources	109-188
109.1202(p)	Additional requirements	109-188
109.1203	Bin classification and treatment technique requirements	109-189
109.1203(a)	Bin classification	109-189
109.1203(b)	Procedures for calculating bin classifications	109-189
109.1203(c)	<i>Cryptosporidium</i> bin concentration thresholds	109-189
109.1203(d)	<i>Cryptosporidium</i> bin concentration recalculation requirements	109-190
109.1203(e)	Filtered system additional <i>Cryptosporidium</i> treatment requirements	109-190

2011 Chapter 109 Index - March 16, 2011

(highlight = revised or new PN, Gen Update, DBP 2, LT2SWTR, LCR, and GWR citations)

109.1203(f)	Treatment and management options for filtered systems, microbial toolbox.....	109-191
109.1203(g)	Failure to meet treatment credit.....	109-191
109.1203(h)	Increased watershed contamination.....	109-191
109.1203(i)	Unfiltered systems determination of <i>Cryptosporidium</i> bin level, initial round.....	109-191
109.1203(j)	Unfiltered systems determination of <i>Cryptosporidium</i> bin level, second round.....	109-191
109.1203(k)	Schedule for compliance with <i>Cryptosporidium</i> treatment requirements.....	109-192
109.1203(l)	Treatment technique requirements for unfiltered systems.....	109-192
109.1203(m)	<i>Cryptosporidium</i> treatment compliance dates.....	109-192
109.1203(n)	Change in <i>Cryptosporidium</i> level for filtered system.....	109-192
109.1203(o)	Change in <i>Cryptosporidium</i> level for unfiltered system.....	109-192
109.1204	Requirements for microbial toolbox components.....	109-193
109.1204(a)	System will receive Treatment credits listed in Appendix B.....	109-193
109.1204(b)	Watershed control program.....	109-193
109.1204(c)	Alternative source.....	109-195
109.1204(d)	Presedimentation.....	109-195
109.1204(e)	2-stage lime softening.....	109-196
109.1204(f)	Bank filtration.....	109-196
109.1204(g)	Combined filter performance.....	109-197
109.1204(h)	Individual filter performance.....	109-197
109.1204(i)	Demonstration of performance.....	109-197
109.1204(j)	Bag and cartridge filters.....	109-198
109.1204(k)	Membrane filtration.....	109-199
109.1204(l)	Second stage filtration.....	109-203
109.1204(m)	Slow sand filtration (as secondary filter).....	109-203
109.1204(n)	Inactivation toolbox components.....	109-204
109.1204(o)	Chlorine dioxide.....	109-204
109.1204(p)	Ozone.....	109-204
109.1204(q)	Ultraviolet light.....	109-204
109.1205	Grandfathering previously collected data.....	109-206
109.1206	Reporting and recordkeeping requirements.....	109-206
109.1206(a)	Source water reporting time frame.....	109-206
109.1206(b)	Methods for reporting initial source water monitoring results to EPA.....	109-206
109.1206(c)	Methods for reporting initial source water monitoring results to DEP.....	109-206
109.1206(d)	Methods for reporting second round of source water monitoring results to DEP.....	109-206
109.1206(e)	Source water reporting data elements.....	109-206
109.1206(f)	Sampling schedule reporting.....	109-207
109.1206(g)	Bin classification reporting.....	109-207
109.1206(h)	Microbial toolbox reporting requirements.....	109-208
109.1206(i)	Reporting significant change in disinfection practices.....	109-208
109.1206(j)	Source water monitoring recordkeeping requirements.....	109-208
109.1206(k)	Notification retention.....	109-208
109.1206(l)	Results retention.....	109-208
M	ADDITIONAL REQUIREMENT FOR GROUNDWATER SOURCES.....	109-209
109.1301	Scope.....	109-209
109.1302	Treatment technique requirements.....	109-210
109.1302(a)	Community groundwater systems.....	109-210
109.1302(b)	Noncommunity groundwater systems including BVRBs.....	109-210
109.1302(c)	Groundwater systems with significant deficiencies or source water <i>E. coli</i> contamination.....	109-211
109.1303	Triggered monitoring requirements for groundwater sources.....	109-212
109.1303(a)	Source water sample for <i>E. coli</i> required within 24 hours of a TC+.....	109-212

2011 Chapter 109 Index - March 16, 2011

(highlight = revised or new PN, Gen Update, DBP 2, LT2SWTR, LCR, and GWR citations)

109.1303(b)	DEP may extend 24 hours to 72 hours for logical problem.....	109-213
109.1303(c)	Source water samples that are representative of multiple sources	109-213
109.1303(d)	Source water sample collected prior to any treatment	109-213
109.1303(e)	Purchased water system notifies selling system of TC+ within 24 hours	109-213
109.1303(f)	Source water monitoring waived if 2 conditions apply	109-213
109.1303(g)	Invalidation criteria of <i>E. coli</i> + source water sample	109-213
109.1303(h)	Requirements following a <i>E. coli</i> + source water sample	109-214
109.1303(i)	Selling systems must comply with triggered monitoring requirements under (a)	109-214
109.1304	Assessment source water monitoring	109-214
109.1304(a)	To determine if a noncommunity groundwater source contains fecal contamination.....	109-214
109.1304(b)	Invalidation criteria of <i>E. coli</i> TC+ source water sample.....	109-215
109.1305	Compliance monitoring	109-215
109.1305(a)	Chemical disinfection residual disinfection monitoring requirements	109-215
109.1305(b)	Alternative treatment compliance monitoring requirements	109-216
109.1306	Information describing 4-log treatment and compliance monitoring	109-217
109.1306(a)	CWS, BRVBs and NCWs with valid operations permits submit forms to evaluate treatment effectiveness	109-217
109.1306(b)	NCWs without permits demonstrating 4-log treatment submittal requirements	109-217
109.1306(c)	Plans, specifications and engineer report requirements	109-217
109.1307	System management responsibilities	109-218
109.1307(a)	Reporting.....	109-218
109.1307(b)	Recordkeeping	109-219
APPENDIX A TO SUBCHAPTER L (LT2ESWTR)		109-220
Table 1	CT Values for <i>Cryptosporidium</i> inactivation by chlorine dioxide	109-220
Table 2	CT Values for <i>Cryptosporidium</i> inactivation by ozone.....	109-220
Table 3	UV Dose for <i>Cryptosporidium</i> , <i>Giardia lamblia</i> and virus inactivation credit	109-221
APPENDIX B TO SUBCHAPTER L (LT2ESWTR)		109-222
Microbial Toolbox Summary Table: Options, Treatment Credits and Criteria		109-222
APPENDIX C TO SUBCHAPTER L (LT2ESWTR)		109-225
Microbial Toolbox Reporting Requirements		109-225