

ANALYTICAL LABORATORIES, INC.
P.O. BOX 319
CHALFONT, PA 18914
(215) 723-6466

SAMPLE ANALYSIS REPORT

Customer: Doylestown Twp. Municipal Authority
425 Wells Road
Doylestown, PA 18901

Attn: Scott 215-348-9915
FAX: 215-348-4985

Sample number: 6324-16
Date sampled : 5/23/16
Time sampled : 1245
Date received: 5/23/16
Sampled by : Customer
PWS ID # :

Sample source: 27 Cedar Wood Circle, Doylestown, PA
Kitchen sink

ANALYTICAL RESULTS

<u>Parameter</u>	<u>Result</u>	PHAL	QL	Analysis Method	Analysis Date
Perfluorobutanesulfonic Acid, ug/l	0.011	0.2	0.009	EPA 537	5/26/16
Perfluorheptanoic Acid (PFHPA), ug/l	0.009	0.4	0.001	EPA 537	5/26/16
Perfluorohexanesulfonic Acid(PFHXS), ug/l	0.007	0.2	0.003	EPA 537	5/26/16
Perfluorononanoic Acid (PFNA), ug/l	< 0.002	0.4	0.002	EPA 537	5/26/16
Perfluorooctanesulfonic Acid(PFOS), ug/l	0.038	0.2	0.070	EPA 537	5/26/16
Perfluorooctanoic Acid(PFOA), ug/l	0.034	0.4	0.070	EPA 537	5/26/16

All parameters were analyzed in accordance with EPA approved methods.
All Field Blank results were less than the detection limits.

Symbol key:
< - less than
QL - quantitation limit
ug/l - micrograms/liter
PHAL - Proposed Health Advisory Limit (Feb 2016)

Geo Kinka

PA DEP #09332
Analyzed by PH-0411

Geoff W. Kinka/Manager