

ANALYTICAL LABORATORIES, INC.
P.O. BOX 319
CHALFONT, PA 18914
(215) 723-6466

SAMPLE ANALYSIS REPORT

Customer: Doylestown Twp. Municipal Authority
425 Wells Road
Doylestown, PA 18901

Sample number: 6302-16
Date sampled : 5/20/16
Time sampled : 1120
Date received: 5/20/16
Sampled by : Customer
PWS ID # :

Attn: Scott 215-348-9915
FAX: 215-348-4985

Sample source: Cross Keys - Raw

ANALYTICAL RESULTS

<u>Parameter</u>	<u>Result</u>	PHAL	QL	Analysis Method	Analysis Date
Perfluorobutanesulfonic Acid, ug/l	< 0.009	0.2	0.009	EPA 537	5/31/16
Perfluoroheptanoic Acid (PFHPA), ug/l	0.097	0.4	0.001	EPA 537	5/31/16
Perfluorohexanesulfonic Acid(PFHXS), ug/l	< 0.003	0.2	0.003	EPA 537	5/31/16
Perfluorononanoic Acid (PFNA), ug/l	0.033	0.4	0.002	EPA 537	5/31/16
Perfluorooctanesulfonic Acid(PFOS), ug/l	0.012	x	0.004	EPA 537	5/31/16
Perfluorooctanoic Acid(PFOA), ug/l	0.255	x	0.002	EPA 537	5/31/16

All parameters were analyzed in accordance with EPA approved methods.
All Field Blank results were less than the detection limits.

Symbol key:

- < - less than
- QL - quantitation limit
- ug/l - micrograms/liter
- PHAL - Proposed Health Advisory Limit (Feb 2016)
- x - Proposed limit is 0.07 ug/l for Combination of PFOA and PFOS.

PA DEP #09332
Analyzed by PH-0411


Geoff W. Kinka/Manager

ANALYTICAL LABORATORIES, INC.
P.O. BOX 319
CHALFONT, PA 18914
(215) 723-6466
INVOICE # 630216

6/13/16

Doylestown Twp. Municipal Authority
425 Wells Road
Doylestown, PA 18901

Scott 215-348-9915

For professional services:	\$ 210.00
Chlorine residual filing fee	
Total due	210
Analytical services:	
Sample number: 6302-16	
Sample source: Cross Keys - Raw	
Date Sampled: 5/20/16	
P.O.# :	

VISA AND MASTERCARD ACCEPTED

Terms: Total balance due in 30 days. Balances remaining unpaid at due date are subject to a service charge of 1.5% per month until paid.