3850-PM-BCW0015d 3/2016 Permit



COMMONWEALTH OF PENNSYLVANIA DEPARTMENT OF ENVIRONMENTAL PROTECTION BUREAU OF CLEAN WATER

PERMIT NO. $\underline{4621412}$ AMENDMENT NO. $\underline{A-1}$

APS ID. <u>1050303</u>

AUTH. ID. <u>1373893</u>

WATER QUALITY MANAGEMENT PERMIT

well and valve box will be elevated 3' 6' higher than the existing system. In addition, the existing generator will be el submersible duplex pumps and controls will be added. The proposed pumps are rated for 252 gpm and 119 feet tot differences in capacity are due to manufacturer design difference. The discharge line will tie into the existing 6 inch in differences in capacity are due to manufacturer design difference. The discharge line will tie into the existing 6 inch in differences in capacity are due to manufacturer design difference. The discharge line will tie into the existing 6 inch in differences in capacity are due to manufacturer design difference. The discharge line will tie into the existing 6 inch in differences in capacity are due to manufacturer design difference. The discharge line will tie into the existing 6 inch in differences in capacity are due to the existing 6 inch in differences in capacity are due to the existing 6 inch in differences in capacity are due to the existing 6 inch in differences in capacity are due to the existing 6 inch in differences in capacity are due to the existing 6 inch in differences in capacity are due to the existing 6 inch in differences in capacity are due to the existing 6 inch in differences in capacity and an advantage Flow: Design Organic Capacity: Design Organic C	me):					
Green Lane, PA 18054-0045 C. LOCATION (Municipality, County): Green Lane Borough, Montgomery County D. This amendment approves the construction/modification/operation of sewage facilities consisting of: The new facility consists of a new manhole with watertight frame and cover, new 7' by 7' wet well, and a new 6' by 1 well and valve box will be elevated 3' 6' nigher than the existing system. In addition, the existing generator will be el submersible duplex pumps and controls will be added. The proposed pumps are rated for 252 gpm and 119 feet tot differences in capacity are due to manufacturer design difference. The discharge line will tie into the existing 6 inch 1 differences in capacity are due to manufacturer design difference. The discharge line will tie into the existing 6 inch 1 differences in capacity: Design Capacity: Design Capacity: E. APPROVAL GRANTED BY THIS PERMIT IS SUBJECT TO THE FOLLOWING: 1. New Permits: All construction, operations and procedures shall be in accordance with the Water Quality Manag September 2021, its supporting documentation and addendums dated, which are hereby made a part of this Amendments: All construction, operations and procedures shall be in accordance with the Water Quality Management Permit No dated shall remain in effect. Transfers: Water Quality Management Permit No dated shall remain in effect. Transfers: Water Quality Management Permit No dated and conditions, supporting documentation part of this transfer. 2. Permit Conditions Relating to Sewerage are attached and made part of this permit. F. THE AUTHORITY GRANTED BY THIS PERMIT IS SUBJECT TO THE FOLLOWING FURTHER QUALIFICATIONS. 1. If there is a conflict between the application or its supporting documents and amendments and the attached conditionshall apply. 2. Failure to comply with the rules and regulations of DEP or with the terms or conditions of this permit shall void the aby the issuance of this permit.	int Authority STP & Sewer					
C. LOCATION (Municipality, County): Green Lane Borough, Montgomery County D. This amendment approves the construction/modification/operation of sewage facilities consisting of: The new facility consists of a new manhole with watertight frame and cover, new 7' by 7' wet well, and a new 6' by 4 well and valve box will be elevated 3' 6' higher than the existing system. In addition, the existing generator will be el submersible duplex pumps and controls will be added. The proposed pumps are rated for 252 gpm and 119 feet tot differences in capacity are due to manufacturer design difference. The discharge line will tie into the existing 6 inch is understoomed to the existing 6 inch is submersible duplex pumps. Design Capacity: 252 GPM Wanure Storage: Not Applicable Volume:MG Freeboard:inches Design Hydraulic Capacity: Design Hydraulic Capacity: Design Organic Capacity: E. APPROVAL GRANTED BY THIS PERMIT IS SUBJECT TO THE FOLLOWING: New Permits: All construction, operations and procedures shall be in accordance with the Water Quality Managenether 2021; its supporting documentation and addendums dated, which are hereby made a part of this Amendments: All construction, operations and procedures shall be in accordance with the Water Quality Management Permit No dated shall remain in effect. Transfers: Water Quality Management Permit No dated shall remain in effect. Transfers: Water Quality Management Permit No dated and conditions, supporting documentation part of this transfer. 2. Permit Conditions Relating to Sewerage are attached and made part of this permit. F. THE AUTHORITY GRANTED BY THIS PERMIT IS SUBJECT TO THE FOLLOWING FURTHER QUALIFICATIONS. 1. If there is a conflict between the application or its supporting documents and amendments and the attached conditionshall apply. 2. Failure to comply with the rules and regulations of DEP or with the terms or conditions of this permit shall void the aby the issuance of this permit.	tion					
D. This amendment approves the construction/modification/operation of sewage facilities consisting of: The new facility consists of a new manhole with watertight frame and cover, new 7' by 7' wet well, and a new 6' by 1 well and valve box will be elevated 3' 6' higher than the existing system. In addition, the existing generator will be el submersible duplex pumps and controls will be added. The proposed pumps are rated for 252 gpm and 119 feet tot differences in capacity are due to manufacturer design difference. The discharge line will tie into the existing 6 inch 1 differences in capacity: Pump Stations: 1 with duplex pumps Design Capacity: 252 GPM Wolume: MG Freeboard: inches Freeboard: inches Freeboard: inches Pesign Organic Capacity: Design Organic Capacity: E. APPROVAL GRANTED BY THIS PERMIT IS SUBJECT TO THE FOLLOWING: 1. New Permits: All construction, operations and procedures shall be in accordance with the Water Quality Manag September 2021, its supporting documentation and addendums dated, which are hereby made a part of this Amendments: All construction, operations and procedures shall be in accordance with the Water Quality Manag application dated and its supporting documentation and addendums dated, which are hereby made a Except for any herein approved modifications, all terms, conditions, supporting documentation and addendums dated and its supporting documentation and addendums dated shall remain in effect. Transfers: Water Quality Management Permit No dated and conditions, supporting documentation part of this transfer. Permit Conditions Relating to Sewerage are attached and made part of this permit. F. THE AUTHORITY GRANTED BY THIS PERMIT IS SUBJECT TO THE FOLLOWING FURTHER QUALIFICATIONS in the result of this permit. F. THE AUTHORITY GRANTED BY THIS PERMIT IS SUBJECT TO THE FOLLOWING FURTHER QUALIFICATIONS in the permit.						
D. This amendment approves the construction/modification/operation of sewage facilities consisting of: The new facility consists of a new manhole with watertight frame and cover, new 7' by 7' wet well, and a new 6' by 1 well and valve box will be elevated 3' 6" higher than the existing system. In addition, the existing generator will be el submersible duplex pumps and controls will be added. The proposed pumps are rated for 252 gpm and 119 feet but differences in capacity are due to manufacturer design difference. The discharge line will tie into the existing 6 inch is differences in capacity: Pump Stations: 1 with duplex pumps Design Capacity: 252 GPM Manure Storage: Not Applicable Volume:MG Freeboard:inches Design Hydraulic Capacity: Design Organic Capacity: E. APPROVAL GRANTED BY THIS PERMIT IS SUBJECT TO THE FOLLOWING: 1. New Permits: All construction, operations and procedures shall be in accordance with the Water Quality Manag September 2021, its supporting documentation and addendums dated, which are hereby made a part of this Amendments: All construction, operations and procedures shall be in accordance with the Water Quality Mapplication dated and its supporting documentation and addendums dated, which are hereby made a Except for any herein approved modifications, all terms, conditions, supporting documentation and addendums dated, which are hereby made a Except for any herein approved modifications, all terms, conditions, supporting documentation and addendums dated, and conditions Relating to Sewerage are attached and made part of this permit. Transfers: Water Quality Management Permit No dated and conditions, supporting documentation part of this transfer. Permit Conditions Relating to Sewerage are attached and made part of this permit. F. THE AUTHORITY GRANTED BY THIS PERMIT IS SUBJECT TO THE FOLLOWING FURTHER QUALIFICATIONS If there is a conflict between the application or its supporting documents and amendments and the attached c						
The new facility consists of a new manhole with watertight frame and cover, new 7' by 7' wet well, and a new 6' by 1 well and valve box will be elevated 3' 6' higher than the existing system. In addition, the existing generator will be el submersible duplex pumps and controls will be added. The proposed pumps are rated 7252 gpm and 119 feet tot differences in capacity are due to manufacturer design difference. The discharge line will tie into the existing 6 inch is differences in capacity are due to manufacturer design difference. The discharge line will tie into the existing 6 inch is differences. The discharge line will tie into the existing 6 inch is differences. The discharge line will tie into the existing 6 inch is differences. The discharge line will tie into the existing 6 inch is differences. The discharge line will tie into the existing 6 inch is differences. The discharge line will tie into the existing 6 inch is differences. The discharge line will tie into the existing 6 inch is differences. The discharge line will tie into the existing 6 inch is differences. The discharge line will tie into the existing 6 inch is differences. The discharge line will tie into the existing 6 inch is differences. The discharge line will tie into the existing 6 inch is discharge line will tie into the existing 6 inch is discharge line will tie into the existing 6 inch is discharge line will tie into the existing 6 inch is discharge line will tie into the existing 6 inch is discharge line will tie into the existing 6 inch is discharge line will tie into the existing 6 inch is discharge line will tie into the existing 6 inch is discharge line will tie into the existing 6 inch is discharge line will tie into the existing 6 inch is discharge line will tie into the existing 6 inch is discharge line will tie into the existing 6 inch is discharge line will tie into the existing 6 inch is discharge line will tie into the existing 6 inch is discharge line will tie into the existing 6 inch is discharge line will tie into the ex						
well and valve box will be elevated 3' 6' higher than the existing system. In addition, the existing generator will be el submersible duplex pumps and controls will be added. The proposed pumps are rated for 252 gpm and 119 feet tot differences in capacity are due to manufacturer design difference. The discharge line will tie into the existing 6 inch in differences in capacity are due to manufacturer design difference. The discharge line will tie into the existing 6 inch in differences in capacity are due to manufacturer design difference. The discharge line will tie into the existing 6 inch in differences in capacity are due to manufacturer design difference. The discharge line will tie into the existing 6 inch in differences in capacity are due to manufacturer design difference. The discharge line will tie into the existing 6 inch in differences in capacity are due to the existing 6 inch in differences in capacity are due to the existing 6 inch in differences in capacity are due to the existing 6 inch in differences in capacity are due to the existing 6 inch in differences in capacity are due to the existing 6 inch in differences in capacity are due to the existing 6 inch in differences in capacity are due to the existing 6 inch in differences in capacity and an advantage Flow: Design Organic Capacity: Design Organic C						
Design Capacity: 252 GPM Volume:MG Freeboard:inches Design Hydraulic Capacity: Design Organic Capacity: E. APPROVAL GRANTED BY THIS PERMIT IS SUBJECT TO THE FOLLOWING: New Permits: All construction, operations and procedures shall be in accordance with the Water Quality Managements: All construction, operations and procedures shall be in accordance with the Water Quality Mapplication dated and its supporting documentation and addendums dated, which are hereby made a Except for any herein approved modifications, all terms, conditions, supporting documentation and addendums Management Permit No dated shall remain in effect. Transfers: Water Quality Management Permit No dated and conditions, supporting documentation part of this transfer. Permit Conditions Relating to Sewerage are attached and made part of this permit. F. THE AUTHORITY GRANTED BY THIS PERMIT IS SUBJECT TO THE FOLLOWING FURTHER QUALIFICATIONS shall apply. If there is a conflict between the application or its supporting documents and amendments and the attached conditions shall apply. Failure to comply with the rules and regulations of DEP or with the terms or conditions of this permit shall void the arby the issuance of this permit.	The new facility consists of a new manhole with watertight frame and cover, new 7' by 7' wet well, and a new 6' by 10' valve box. The manhole, wet well and valve box will be elevated 3' 6" higher than the existing system. In addition, the existing generator will be elevated by 1.5'. New submersible duplex pumps and controls will be added. The proposed pumps are rated for 252 gpm and 119 feet total dynamic head (TDH). The differences in capacity are due to manufacturer design difference. The discharge line will tie into the existing 6 inch forcemain.					
E. APPROVAL GRANTED BY THIS PERMIT IS SUBJECT TO THE FOLLOWING: 1. New Permits: All construction, operations and procedures shall be in accordance with the Water Quality Managements: All construction, operations and procedures shall be in accordance with the Water Quality Managements: All construction, operations and procedures shall be in accordance with the Water Quality Managements: All construction, operations and procedures shall be in accordance with the Water Quality Manaplication dated and its supporting documentation and addendums dated, which are hereby made a Except for any herein approved modifications, all terms, conditions, supporting documentation and addendums Management Permit No dated shall remain in effect. Transfers: Water Quality Management Permit No dated and conditions, supporting documentation part of this transfer. 2. Permit Conditions Relating to Sewerage are attached and made part of this permit. 5. THE AUTHORITY GRANTED BY THIS PERMIT IS SUBJECT TO THE FOLLOWING FURTHER QUALIFICATIONS and It has a conflict between the application or its supporting documents and amendments and the attached conditions shall apply. 2. Failure to comply with the rules and regulations of DEP or with the terms or conditions of this permit shall void the aby the issuance of this permit.	t Applicable					
E. APPROVAL GRANTED BY THIS PERMIT IS SUBJECT TO THE FOLLOWING: 1. New Permits: All construction, operations and procedures shall be in accordance with the Water Quality Managements: All construction, operations and procedures shall be in accordance with the Water Quality Managements: All construction, operations and procedures shall be in accordance with the Water Quality Managements: All construction, operations and procedures shall be in accordance with the Water Quality Manaplication dated and its supporting documentation and addendums dated, which are hereby made a Except for any herein approved modifications, all terms, conditions, supporting documentation and addendums Management Permit No dated shall remain in effect. Transfers: Water Quality Management Permit No dated and conditions, supporting documentation part of this transfer. 2. Permit Conditions Relating to Sewerage are attached and made part of this permit. 5. THE AUTHORITY GRANTED BY THIS PERMIT IS SUBJECT TO THE FOLLOWING FURTHER QUALIFICATIONS and It has a conflict between the application or its supporting documents and amendments and the attached conditions shall apply. 2. Failure to comply with the rules and regulations of DEP or with the terms or conditions of this permit shall void the aby the issuance of this permit.	MGD					
E. APPROVAL GRANTED BY THIS PERMIT IS SUBJECT TO THE FOLLOWING: 1. New Permits: All construction, operations and procedures shall be in accordance with the Water Quality Managements: All construction, operations and procedures shall be in accordance with the Water Quality Mapplication dated, which are hereby made a part of this Amendments: All construction, operations and procedures shall be in accordance with the Water Quality Mapplication dated and its supporting documentation and addendums dated, which are hereby made a Except for any herein approved modifications, all terms, conditions, supporting documentation and addendums Management Permit No dated shall remain in effect. 1. Transfers: Water Quality Management Permit No dated and conditions, supporting documentation part of this transfer. 2. Permit Conditions Relating to Sewerage are attached and made part of this permit. 3. Special Conditions are attached and made part of this permit. F. THE AUTHORITY GRANTED BY THIS PERMIT IS SUBJECT TO THE FOLLOWING FURTHER QUALIFICATIONS. 1. If there is a conflict between the application or its supporting documents and amendments and the attached conditions shall apply. 2. Failure to comply with the rules and regulations of DEP or with the terms or conditions of this permit shall void the accordance with the data accordance with the Water Quality Management Permit shall void the accordance with the value of this permit.	MGD					
 New Permits: All construction, operations and procedures shall be in accordance with the Water Quality Management 2021, its supporting documentation and addendums dated, which are hereby made a part of this Amendments: All construction, operations and procedures shall be in accordance with the Water Quality M application dated and its supporting documentation and addendums dated, which are hereby made a Except for any herein approved modifications, all terms, conditions, supporting documentation and addendums Management Permit No dated and conditions, supporting documentation part of this transfer. Permit Conditions Relating to Sewerage are attached and made part of this permit. Special Conditions are attached and made part of this permit. THE AUTHORITY GRANTED BY THIS PERMIT IS SUBJECT TO THE FOLLOWING FURTHER QUALIFICATIONS. If there is a conflict between the application or its supporting documents and amendments and the attached conditions shall apply. Failure to comply with the rules and regulations of DEP or with the terms or conditions of this permit shall void the aby the issuance of this permit. 	lb/day					
 New Permits: All construction, operations and procedures shall be in accordance with the Water Quality Management 2021, its supporting documentation and addendums dated, which are hereby made a part of this Amendments: All construction, operations and procedures shall be in accordance with the Water Quality M application dated and its supporting documentation and addendums dated, which are hereby made a Except for any herein approved modifications, all terms, conditions, supporting documentation and addendums Management Permit No dated and conditions, supporting documentation part of this transfer. Permit Conditions Relating to Sewerage are attached and made part of this permit. Special Conditions are attached and made part of this permit. THE AUTHORITY GRANTED BY THIS PERMIT IS SUBJECT TO THE FOLLOWING FURTHER QUALIFICATIONS. If there is a conflict between the application or its supporting documents and amendments and the attached conditions shall apply. Failure to comply with the rules and regulations of DEP or with the terms or conditions of this permit shall void the aby the issuance of this permit. 	_					
application dated and its supporting documentation and addendums dated, which are hereby made a Except for any herein approved modifications, all terms, conditions, supporting documentation and addendums Management Permit No dated shall remain in effect. Transfers: Water Quality Management Permit No dated and conditions, supporting documentation part of this transfer. 2. Permit Conditions Relating to Sewerage are attached and made part of this permit. 3. Special Conditions are attached and made part of this permit. F. THE AUTHORITY GRANTED BY THIS PERMIT IS SUBJECT TO THE FOLLOWING FURTHER QUALIFICATIONS 1. If there is a conflict between the application or its supporting documents and amendments and the attached conditions shall apply. 2. Failure to comply with the rules and regulations of DEP or with the terms or conditions of this permit shall void the arby the issuance of this permit.						
Management Permit No dated shall remain in effect. Transfers: Water Quality Management Permit No dated and conditions, supporting documentation part of this transfer. 2. Permit Conditions Relating to Sewerage are attached and made part of this permit. 3. Special Conditions are attached and made part of this permit. F. THE AUTHORITY GRANTED BY THIS PERMIT IS SUBJECT TO THE FOLLOWING FURTHER QUALIFICATIONS 1. If there is a conflict between the application or its supporting documents and amendments and the attached condition shall apply. 2. Failure to comply with the rules and regulations of DEP or with the terms or conditions of this permit shall void the arby the issuance of this permit.	Amendments: All construction, operations and procedures shall be in accordance with the Water Quality Management Permit Amendment application dated and its supporting documentation and addendums dated, which are hereby made a part of this amendment.					
 Permit Conditions Relating to Sewerage are attached and made part of this permit. Special Conditions are attached and made part of this permit. THE AUTHORITY GRANTED BY THIS PERMIT IS SUBJECT TO THE FOLLOWING FURTHER QUALIFICATIONS. If there is a conflict between the application or its supporting documents and amendments and the attached conditions shall apply. Failure to comply with the rules and regulations of DEP or with the terms or conditions of this permit shall void the arby the issuance of this permit. 	Except for any herein approved modifications, all terms, conditions, supporting documentation and addendums approved under Water Quality Management Permit No dated shall remain in effect.					
 Special Conditions are attached and made part of this permit. THE AUTHORITY GRANTED BY THIS PERMIT IS SUBJECT TO THE FOLLOWING FURTHER QUALIFICATIONS If there is a conflict between the application or its supporting documents and amendments and the attached condition shall apply. Failure to comply with the rules and regulations of DEP or with the terms or conditions of this permit shall void the arby the issuance of this permit. 	Transfers: Water Quality Management Permit No dated and conditions, supporting documentation and addendums are also made part of this transfer.					
 F. THE AUTHORITY GRANTED BY THIS PERMIT IS SUBJECT TO THE FOLLOWING FURTHER QUALIFICATIONS 1. If there is a conflict between the application or its supporting documents and amendments and the attached conditions shall apply. 2. Failure to comply with the rules and regulations of DEP or with the terms or conditions of this permit shall void the arby the issuance of this permit. 	. Permit Conditions Relating to Sewerage are attached and made part of this permit.					
 If there is a conflict between the application or its supporting documents and amendments and the attached conditions shall apply. Failure to comply with the rules and regulations of DEP or with the terms or conditions of this permit shall void the aby the issuance of this permit. 	. Special Conditions are attached and made part of this permit.					
shall apply.Failure to comply with the rules and regulations of DEP or with the terms or conditions of this permit shall void the aby the issuance of this permit.	. THE AUTHORITY GRANTED BY THIS PERMIT IS SUBJECT TO THE FOLLOWING FURTHER QUALIFICATIONS:					
by the issuance of this permit.	shall apply.					
3. This permit is issued pursuant to the Clean Streams Law Act of June 22, 1937, P.L. 1987, as amended 35 P.S.	by the issuance of this permit.					
3. This permit is issued pursuant to the Clean Streams Law Act of June 22, 1937, P.L. 1987, as amended 35 P.S. §691.1 <i>et seq.</i> Issuance of this permit shall not relieve the permittee of any responsibility under any other law.						
PERMIT ISSUED: BY: /s/						
December 16, 2021 Thomas L. Magge Thomas L. Magge Clean Water Program Manage Southeast Regional Office	•					



COMMONWEALTH OF PENNSYLVANIA DEPARTMENT OF ENVIRONMENTAL PROTECTION BUREAU OF POINT AND NON-POINT SOURCE MANAGEMENT

PERMIT CONDITIONS RELATING TO SEWERAGE

For use in Water Quality Management Permits

The Department of Environmental Protection (DEP) considers the licensed Professional Engineer whose seal

(Check boxes that apply)

General

1.

		is affixed to the design documents to be fully responsible for the adequacy of all aspects of the facility design.
	2.	The permittee shall adopt and enforce an ordinance requiring the abandonment of privies, cesspools or similar receptacles for human waste and onlot sewage disposal systems on the premises of occupied structures accessible to public sewers. All such structures must be connected to the public sewers.
	3.	The outfall sewer or drain shall be extended to the low water mark of the receiving body of water. Where necessary to ensure proper mixing and waste assimilation, an outfall sewer or drain may be extended with appurtenances below the low water mark and into the bed of a navigable stream provided that the permittee has secured an easement, right-of-way, license or lease from DEP in accordance with Section 15 of the Dam Safety and Encroachments Act, the Act of November 26, 1978, P.L. 1375, as amended.
	4.	The approval is specifically made contingent on the permittee acquiring all necessary property rights, by easement or otherwise, providing for the satisfactory construction, operation, maintenance and replacement of all sewers or sewerage structures in, along or across private property with full rights of ingress, egress and regress.
	5.	When construction of the approved sewerage facilities is completed and before they are placed in operation, the permittee shall notify DEP in writing so that a DEP representative may inspect the facilities.
	6.	The approval of the plans, and the authority granted in this permit, if not specifically extended, shall cease and be null and void 5 years from the issuance date of this permit unless construction or modification of the facilities covered by this permit has begun on or before the fifth anniversary of the permit date.
	7.	If, at any time, the sewerage facilities covered by this permit create a public nuisance, including but not limited to, causing malodors or causing environmental harm to waters of the Commonwealth, DEP may require the permittee to adopt appropriate remedial measures to abate the nuisance or harm.
	8.	If, after the issuance of this permit, DEP approves a municipal sewage facilities official plan or an amendment to an official plan under Act 537 (Pennsylvania Sewage Facilities Act, the Act of January 24, 1966, P.L. 1535 as amended) in which sewage from the herein approved facilities will be treated and disposed of at other planned facilities, the permittee shall, upon notification from the municipality or DEP, provide for the conveyance of its sewage to the planned facilities, abandon use and decommission the herein approved facilities including the proper disposal of solids, and notify DEP accordingly. The permittee shall adhere to schedules in the approved official plan, amendments to the plan, or other agreements between the permittee and municipality. This permit shall then, upon notice from DEP, terminate and become null and void and shall be relinquished to DEP.
\boxtimes	9.	This permit does not relieve the permittee of its obligations to comply with all federal, interstate, state or local laws, ordinances and regulations applicable to the sewerage facilities.
\boxtimes	10.	This permit does not give any real or personal property rights or grant any exclusive privileges, nor shall it be construed to grant or confirm any right, easement or interest in, on, to or over any lands which belong to the

Construction

Commonwealth.

12. This permit is issued under the authorization of The Clean Streams Law and 25 Pa. Code Chapter 91. The permittee shall obtain all necessary permits, approvals and/or registrations under 25 Pa. Code Chapters 102, 105 and 106 prior to commencing construction of the facilities authorized by this permit, as applicable. The permittee should contact the DEP office that issued this permit if there are any questions concerning the applicability of additional permits.

authorized from these facilities unless approved by an NPDES Permit.

11. The authority granted by this permit is subject to all effluent requirements, monitoring requirements and other conditions as set forth in the NPDES Permit and all subsequent amendments and renewals. No discharge is

- 14. A Pennsylvania licensed Professional Engineer shall certify that construction of the permitted facilities was completed in accordance with the application and design plans submitted to DEP, using the "Post Construction Certification" form (3800-PM-WSFR0179a). It is the permittee's responsibility to ensure that a Professional Engineer is on-site to provide the necessary oversight and/or inspections to certify the facilities. The certification must be submitted to DEP before the facility is placed in operation. As-built drawings, photographs (if available) and a description of all deviations from the application and design plans must be submitted to DEP within 30 days of certification.
- Manhole inverts shall be formed to facilitate the flow of the sewage and to prevent the stranding of sewage solids. The manhole structure shall be built to prevent undue infiltration, entrance of street wash or grit and provide safe access to facilitate manhole maintenance activities.
- 16. The local Waterways Conservation Officer of the Pennsylvania Fish and Boat Commission (PFBC) shall be notified when the construction of any stream crossing and/or outfall is started and completed. A written permit must be secured from the PFBC if the use of explosives in any waterways is required and the permittee shall notify the local Waterways Conservation Officer when explosives are to be used.

Operation and Maintenance

- 17. The permittee shall maintain records of "as-built" plans showing all the treatment facilities as actually constructed together with facility operation and maintenance (O&M) manuals and any other relevant information that may be required. Upon request, the "as-built" plans and O&M manuals shall be filed with DEP.
- 18. The sewers shall have adequate foundation support as soil conditions require. Trenches shall be back-filled to ensure that sewers will have proper structural stability, with minimum settling and adequate protection against breakage. Concrete used in connection with these sewers shall be protected from damage by water, freezing, drying or other harmful conditions until cured.
- 19. Stormwater from roofs, foundation drains, basement drains or other sources shall not be admitted directly to the sanitary sewers.
- 20. The approved sewers shall be maintained in good condition, kept free of deposits by flushing or other cleaning methods and repaired when necessary.
- oxtimes 21. The sewerage facilities shall be properly operated and maintained to perform as designed.
- 22. The attention of the permittee is called to the highly explosive nature of certain gases generated by the digestion of sewage solids when these gases are mixed in proper proportions with air and to the highly toxic character of certain gases arising from such digestion or from sewage in poorly ventilated compartments or sewers. Therefore, at all places throughout the sewerage facilities where hazard of fire, explosion or danger from toxic gases may occur, the permittee shall post conspicuous permanent and legible warnings. The permittee shall instruct all employees concerning the aforesaid hazards, first aid and emergency methods of meeting such hazards and shall make all necessary equipment and material accessible.
- 23. An operator certified in accordance with the Water and Wastewater Systems Operator Certification Act of February 21, 2002, 63 P.S. §§1001, et seq. shall operate the sewage treatment plant.
- 24. The permittee shall properly control any industrial waste discharged into its sewerage system by regulating the rate and quality of such discharge, requiring necessary pretreatment and excluding industrial waste, if necessary, to protect the integrity or operation of the permittee's sewerage system.
- 25. There shall be no physical connection between a public water supply system and a sewer or appurtenance to it which would permit the passage of any sewage or polluted water into the potable water supply. No water pipe shall pass through or come in contact with any part of a sewer manhole.
- 26. All connections to the approved sanitary sewers must be in accordance with the official Act 537 Plan and, if applicable, a corrective action plan as contained in the approved Title 25 Pa. Code Chapter 94 Municipal Wasteload Management Annual Report.
- 27. Collected screenings, slurries, sludge and other solids shall be handled and disposed of in compliance with Title 25 Pa. Code Chapters 271, 273, 275, 283 and 285 (related to permits and requirements for land filling, land application, incineration and storage of sewage sludge), Federal Regulations 40 CFR 257 and the Federal Clean Water Act and its amendments.



COMMONWEALTH OF PENNSYLVANIA DEPARTMENT OF ENVIRONMENTAL PROTECTION BUREAU OF CLEAN WATER

WATER QUALITY MANAGEMENT POST CONSTRUCTION CERTIFICATION

PERMITTEE IDENTIFIER			
Permittee	Green Lane Borough & Marlborough Township Joint Authority Montgomery County		
Municipality	Green Lane Borough		
County	Montgomery		
WQM Permit No.	<u>4621412</u>		
Facility Type	Sewage		

All of the above information should be taken directly from the Water Quality Management Permit.

CERTIFICATION

This certification must be completed and returned to the permits section of the DEP's regional office issuing the WQM permit within 30 days of completion of the project and received by DEP prior to operation, and if requested, as-built drawings, photographs (if available) and a discussion of any DEP-approved deviations from the design plans during construction.

I, being a Registered Professional Engineer in Pennsylvania, do hereby certify to the best of my knowledge and belief, based upon personal observation and interviews, that the above facility approved under the Water Quality Management Permit has been constructed in accordance with the plans, specifications and modifications approved by DEP.

Construction Completion Date (MM/DD/YYYY):				
	Professional Engineer			
	Name(Please Print or Type)			
	Signature			
	Date			
	License Expiration Date			
	Firm or Agency			
	Telephone			
	Permittee or Authorized Representative			
	Name			
	(Please Print or Type)			
T	Signature			
Engineer's Seal	Title			
Seal	Telephone			