

WATER QUALITY MANAGEMENT PERMIT

A. PERMITTEE (Name and Address): Pennsylvania Transformer Technology, LLC 30 Curry Avenue Canonsburg, PA 15317-1786	CLIENT ID#: 84104	B. PROJECT/FACILITY (Name): 006 Treatment System Collection System Expansion for Guardhouse Discharge and Former Tank Farm Area Groundwater Permit Transfer (Name Change)
C. LOCATION (Municipality, County): Cecil Township and Canonsburg Borough, Washington County		SITE ID#: 241871
<p>D. This amendment approves the modification of industrial wastewater facilities consisting of:</p> <ul style="list-style-type: none"> • Four (4) 10-gpm groundwater depression pumps (2.5" dia. submersible well pumps) with VFD controls—one for each existing recovery well AP-6, AP-20, AP-22, and OW-2 • Four (4) 2-inch SPG AutoGenie product recovery pump (or equivalent)—one for each existing recovery well AP-6, AP-20, AP-22, and OW-2—with selective LNAPL removal systems • Three (3) 55-gallon drums to store product recovered from AP-6, AP-20, and AP-22 (one drum per well) • One (1) new 500-gallon aboveground batch tank to store groundwater pumped from well OW-2 • One (1) vertical multistage centrifugal pump (30 gpm, 5-hp, 290 TDH) to transfer water from the 500-gallon tank to the 006 Treatment System • Approximately 1,050 linear feet of two-inch diameter PVC conveyance pipe in a four-inch diameter PVC casing pipe to convey groundwater from the 500-gallon aboveground batch tank for OW-2 to the 006 Treatment System • Accompanying support facilities and units including a new shed to house controls for the Guardhouse Discharge system, 55-gallon product collection drums, and small pipe/hose runs to transfer groundwater and recovered product. <p>Existing treatment units for this treatment system, consisting of the following, remain unchanged:</p> <ul style="list-style-type: none"> • Wet well lift station (design flow rate of 100 gpm) • Manhole 916.19 lift station (design flow rate of 100 gpm) • 4,500-gallon flow equalization / settling tank • Multi-bag pre-filter (5-microns) located before the granular activated carbon units • UV disinfection unit • Two 10,000-pound granular activated carbon units • Multi-bag post-filter (0.5 to 1.0 microns) located after the granular activated carbon units • 2,400-gallon, prefabricated, non-pressurized, polyethylene effluent surge tank <p>The permittee's name is changed from "Pennsylvania Transformer Technology, Inc." to "Pennsylvania Transformer Technology, LLC."</p>		
Pump Stations: _____	Manure Storage:	Industrial Wastewater Treatment Facility:
Design Capacity: _____ GPM	Volume: _____ MG	Annual Average Flow: _____ MGD
	Freeboard: _____ inches	Design Hydraulic Capacity: 0.288 MGD
		Design Organic Capacity: _____ lb/day
<p>E. APPROVAL GRANTED BY THIS PERMIT IS SUBJECT TO THE FOLLOWING:</p> <ol style="list-style-type: none"> 1. Amendments: All construction, operations and procedures shall be in accordance with the Water Quality Management Permit Amendment application dated <u>May 22, 2023</u> and its supporting documentation and addendums dated <u>June 14, 2024</u>, which are hereby made a part of this amendment. Except for any herein approved modifications, all terms, conditions, supporting documentation and addendums approved under Water Quality Management Permit No. <u>6308202</u> dated <u>May 16, 2012</u> shall remain in effect. 2. Permit Conditions Relating to Industrial Wastewater are attached and made part of this permit. 3. Special Conditions numbered A and B are attached and made part of this permit. 		
<p>F. THE AUTHORITY GRANTED BY THIS PERMIT IS SUBJECT TO THE FOLLOWING FURTHER QUALIFICATIONS:</p> <ol style="list-style-type: none"> 1. If there is a conflict between the application or its supporting documents and amendments and the attached conditions, the attached conditions shall apply. 2. Failure to comply with the rules and regulations of DEP or with the terms or conditions of this permit shall void the authority given to the permittee by the issuance of this permit. 3. This permit is issued pursuant to the Clean Streams Law Act of June 22, 1937, P.L. 1987, as amended 35 P.S. §691.1 et seq. Issuance of this permit shall not relieve the permittee of any responsibility under any other law. 		
<p>PERMIT ISSUED:</p> <p><u>JUNE 28, 2024</u> <u>Christopher Kriley, P.E.</u> Christopher Kriley, P.E. Clean Water Program Manager Southwest Regional Office</p>		

COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
BUREAU OF POINT AND NON-POINT SOURCE MANAGEMENT

PERMIT CONDITIONS RELATING TO INDUSTRIAL WASTEWATER
For use in Water Quality Management Permits

(Check boxes that apply)

General

- 1. The Department of Environmental Protection (DEP) considers the licensed Professional Engineer whose seal is affixed to the design documents to be fully responsible for the adequacy of all aspects of the facility design.
- 2. All relevant and non-superseded conditions of any prior Water Quality Management Permits, decrees or orders issued to the permittee or his predecessor shall be continued in full force and effect and together with the provisions of this permit shall apply to his successors, lessees, heirs and assigns.
- 3. The responsibility for implementing the conditions of this permit shall rest upon the owner, lessee, assignee or other party in responsible managerial charge of the operation producing the wastewaters and waste treatment facilities. Transfer of a permit to a new owner shall not be effective until said transfer has been executed and filed on forms provided by DEP and DEP approved the transfer.
- 4. The permittee shall secure any necessary permission from the proper federal authority for any outfall or industrial waste treatment structure which discharges into or enters navigable waters and shall obtain a separate permit for any stream crossing, encroachment or change of natural stream conditions within the jurisdiction of DEP.
- 5. When construction of the approved facilities is completed and before they are placed in operation, the permittee shall notify DEP in writing so that a DEP representative may inspect the facilities.
- 6. The approval of the plans, and the authority granted in this permit, if not specifically extended, shall cease and be null and void 5 years from the issuance date of this permit unless construction or modification of the facilities covered by this permit has begun on or before the fifth anniversary of the permit date.
- 7. The authority granted by this permit is subject to all effluent requirements, monitoring requirements and other conditions as set forth in the NPDES Permit and all subsequent amendments and renewals. No discharge is authorized from these facilities unless approved by an NPDES Permit.
- 8. Nothing herein shall be construed to be an intent on the part of DEP to approve any present or future act by the permittee, inconsistent with the permittee's lawful powers or with existing laws of this Commonwealth regulating industrial wastes and the practice of professional engineering. This permit shall not be construed to sanction any act otherwise forbidden by any of the laws of the Commonwealth of Pennsylvania or of the United States.

Construction

- 9. This permit is issued under the authorization of The Clean Streams Law and 25 Pa. Code Chapter 91. The permittee shall obtain all necessary permits, approvals and/or registrations under 25 Pa. Code Chapters 102, 105 and 106 prior to commencing construction of the facilities authorized by this permit, as applicable. The permittee should contact the DEP office that issued this permit if there are any questions concerning the applicability of additional permits.
- 10. The facilities shall be constructed under expert engineering supervision and competent inspection, in accordance with plans, designs and other data as herein approved or amended and with the conditions of this permit.
- 11. A Pennsylvania licensed Professional Engineer shall certify that construction of the permitted facilities was completed in accordance with the application and design plans submitted to DEP, using the "Post Construction Certification" form (3800-PM-WSFR0179a). It is the permittee's responsibility to ensure that a Professional Engineer is on-site to provide the necessary oversight and/or inspections to certify the facilities. The certification must be submitted to DEP before the facility is placed in operation. As-built drawings, photographs (if available) and a description of all deviations from the application and design plans must be submitted to DEP within 30 days of certification.

- 12. The DEP office that issued this permit must be contacted during construction if significant changes are proposed to the approved facilities. Significant changes include, but are not limited to changes to the type(s) of process(es) used for treatment and changes to the design capacities of tanks, impoundments, and conveyance structures or equipment by more than 5% of the original design. For projects involving PENNVEST funding, all changes should be discussed with the DEP project manager prior to implementation. DEP may require the submission of an application to amend this permit. All changes shall be documented in an attachment to the Post Construction Certification form.
- 13. The local Waterways Conservation Officer of the Pennsylvania Fish and Boat Commission (PFBC) shall be notified when the construction of any stream crossing and/or outfall is started and completed. A written permit must be secured from the PFBC if the use of explosives in any waterways is required and the local Waterways Conservation Officer must be notified when explosives are to be used.

Operation and Maintenance

- 14. If at any time the industrial waste treatment facility, or the discharge of the effluent creates a public nuisance, or such discharge is causing or contributing to pollution of the waters of this Commonwealth, the permittee shall immediately adopt remedial measures acceptable to DEP.
- 15. The permittee shall maintain records of "as-built" plans showing all the treatment facilities as actually constructed together with facility operation and maintenance (O&M) manuals and any other relevant information that may be required. Upon request, the "as-built" plans and O&M manuals shall be filed with DEP.
- 16. To ensure operational efficiency and protect the waters of this Commonwealth, the permittee shall maintain skilled operators at all times.
- 17. No stormwater, sewage or other industrial wastes not specifically approved herein shall be admitted to the facilities for which this permit is issued.
- 18. These industrial waste treatment facilities shall be operated and maintained to perform as designed. In order to ensure the efficiency and proper maintenance of the treatment facilities, the permittee shall make periodic inspections to detect any impairment of structural stability, adequate capacity or other requisites which might impair the effectiveness of the approved facilities.
- 19. Collected screenings, slurries, sludge and other solids shall be handled and disposed of in compliance with Title 25 Pa. Code Chapters 287, 288, 291, 297 and 299 (related to permits and requirements for land filling, land application, incineration and storage of industrial sludge), Federal Regulations 40 CFR 257 and the Federal Clean Water Act and its amendments.



COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
WATER MANAGEMENT PROGRAM
SPECIAL CONDITIONS

- A. Once the pumping rates from the abandoned sanitary sewer system have reached equilibrium with the inflow and groundwater infiltration rates to the abandoned sanitary sewer system, the treatment facilities approved herein shall be operated in a manner that ensures that the abandoned sanitary sewer system remains evacuated of all fluids.
- B. Once the guardhouse seep extraction system is constructed and connected to the treatment facilities approved herein, the system shall be operated in a manner that maintains a groundwater flow gradient away from Chartiers Creek.

**WATER QUALITY MANAGEMENT
POST CONSTRUCTION CERTIFICATION**

PERMITTEE IDENTIFIER

Permittee	Pennsylvania Transformer Technology, Inc.
Municipality	Cecil Township Canonsburg Borough
County	Washington
WQM Permit No.	6308202, Amendment No. 1
Facility Type	Industrial Waste

All of the above information should be taken directly from the Water Quality Management Permit.

CERTIFICATION

This certification must be completed and returned to the permits section of the DEP's regional office issuing the WQM permit within 30 days of completion of the project and received by DEP prior to operation, and if requested, as-built drawings, photographs (if available) and a discussion of any DEP-approved deviations from the design plans during construction.

I, being a Registered Professional Engineer in Pennsylvania, do hereby certify to the best of my knowledge and belief, based upon personal observation and interviews, that the above facility approved under the Water Quality Management Permit has been constructed in accordance with the plans, specifications and modifications approved by DEP.

Construction Completion Date (MM/DD/YYYY): _____

<p>Engineer's Seal</p>	Professional Engineer
	Name _____ (Please Print or Type)
	Signature
	Date
	License Expiration Date
	Firm or Agency
	Telephone
	Permittee or Authorized Representative
	Name _____ (Please Print or Type)
	Signature
Title	
Telephone	