



Application Type
Facility Type
Major / Minor

Renewal
Industrial
Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL INDUSTRIAL WASTE (IW)
AND IW STORMWATER**

Application No. **PA0000302**
APS ID **1079181**
Authorization ID **1423833**

Applicant and Facility Information

Applicant Name	<u>Pennsylvania American Water Company - Indiana</u>	Facility Name	<u>Pennsylvania American Water – Two Lick Creek Plant - Indiana</u>
Applicant Address	<u>852 Wesley Drive</u> <u>Mechanicsburg, PA 17055-4436</u>	Facility Address	<u>1034 Waterworks Road</u> <u>Indiana, PA 15701-6119</u>
Applicant Contact	<u>James Runzer</u>	Facility Contact	<u>Sammi Medivitz</u>
Applicant Phone	<u>(717) 550-1540</u>	Facility Phone	<u>724-415-7823</u>
Client ID	<u>87712</u>	Site ID	<u>262074</u>
SIC Code	<u>4941</u>	Municipality	<u>White Township</u>
SIC Description	<u>Trans. & Utilities - Water Supply</u>	County	<u>Indiana</u>
Date Application Received	<u>January 9, 2023</u>	EPA Waived?	<u>No</u>
Date Application Accepted		If No, Reason	<u>TMDL</u>
Purpose of Application	<u>Renewal of NPDES Permit PA0000302.</u>		

Summary of Review

The Two Lick Creek Plant is a potable public water treatment plant (WTP). The WTP purifies water withdrawn from the Two Lick Creek for public consumption. The raw water is treated with lime, caustic soda, carbon, ferric chloride, and polymer, and then passes through an in-line static mixer. The water is then routed to the Aldrich Purification Units for clarification, sedimentation, and filtration. Finished water is treated with chlorine, fluoride, lime, and caustic soda. Finished water is routed to the two in-line clearwells prior to being pumped into the distribution system to Indiana Borough, White Township, and surrounding areas.

There are three discharges from the facility; 001, 002, and 003. 001 consists of treated filter backwash, sludge blanket wasting, and laboratory waste from sample taps and on-line analyzers located within the treatment plant. The wastewater from the treatment process flows to Lagoon No.1, where settling occurs. The decant flows to Outfall 001. If Lagoon No.1 is out of service, the wastewater flows to Lagoon No.2 and the same process occurs, with the decant flowing to Outfall 002. Outfalls 001 and 002 never simultaneously discharge. Drying beds 3A and 3B have not been utilized in the past 15+ years, but any discharge from these drying beds would flow to Outfall 003. It will be retained in the permit for emergency purposes. All three outfalls process the same wastewater load and flow, and will have the same effluent limits.

Changes to the permit: Total Mercury monitoring has been added to the permit.

There are open violations for this Applicant, but only in SERO and NERO. There are no open violations for the NWRO.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-

Approve	Deny	Signatures	Date
X		Benjamin R. Lockwood Benjamin R. Lockwood / Environmental Engineering Specialist	March 27, 2025
		Adam Olesnanik, P.E. / Environmental Engineer Manager	Okay to Draft JCD 4/4/2025

Summary of Review

day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	.353
Latitude	40° 35' 47"	Longitude	-79° 7' 8"
Quad Name		Quad Code	
Wastewater Description:	Treated backwash water, clarifier supernatant, and miscellaneous wastewater		
Receiving Waters	Two Lick Creek (TSF)	Stream Code	44073
NHD Com ID	123716309	RMI	13.1
Drainage Area	79.1 mi ²	Yield (cfs/mi ²)	0.074
Q ₇₋₁₀ Flow (cfs)	5.83	Q ₇₋₁₀ Basis	USGS PA StreamStats
Elevation (ft)	1511	Slope (ft/ft)	
Watershed No.	18-D	Chapter 93 Class.	TSF
Existing Use	N/A	Existing Use Qualifier	N/A
Exceptions to Use	N/A	Exceptions to Criteria	N/A
Assessment Status	Impaired		
Cause(s) of Impairment	Metals, pH, Pathogens, Pathogens		
Source(s) of Impairment	Acid Mine Drainage, Acid Mine Drainage, Agriculture, Urban Runoff/Storm Sewers		
TMDL Status	Final	Name	Kiskiminetas-Conemaugh River Watersheds TMDL
Nearest Downstream Public Water Supply Intake	Saltsburg Municipal Works		
PWS Waters	Conemaugh River	Flow at Intake (cfs)	
PWS RMI		Distance from Outfall (mi)	37

Changes Since Last Permit Issuance: None

Other Comments: None

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	002	Design Flow (MGD)	.353
Latitude	40° 35' 48"	Longitude	-79° 7' 9"
Quad Name		Quad Code	
Wastewater Description:	Treated backwash water, clarifier supernatant, and miscellaneous wastewater		
Receiving Waters	Two Lick Creek (TSF)	Stream Code	44073
NHD Com ID	123716309	RMI	13.1
Drainage Area	79.1 mi ²	Yield (cfs/mi ²)	0.074
Q ₇₋₁₀ Flow (cfs)	5.83	Q ₇₋₁₀ Basis	USGS PA StreamStats
Elevation (ft)	1511	Slope (ft/ft)	
Watershed No.	18-D	Chapter 93 Class.	TSF
Existing Use	N/A	Existing Use Qualifier	N/A
Exceptions to Use	N/A	Exceptions to Criteria	N/A
Assessment Status	Impaired		
Cause(s) of Impairment	Metals, pH, Pathogens, Pathogens		
Source(s) of Impairment	Acid Mine Drainage, Acid Mine Drainage, Agriculture, Urban Runoff/Storm Sewers		
TMDL Status	Final	Name	Kiskiminetas-Conemaugh River Watersheds TMDL
Nearest Downstream Public Water Supply Intake	Saltsburg Municipal Works		
PWS Waters	Conemaugh River	Flow at Intake (cfs)	
PWS RMI		Distance from Outfall (mi)	37

Changes Since Last Permit Issuance: None

Other Comments: None

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	003	Design Flow (MGD)	.353
Latitude	40° 35' 49"	Longitude	-79° 7' 12"
Quad Name		Quad Code	
Wastewater Description:	Treated backwash water, clarifier supernatant, and miscellaneous wastewater		
Receiving Waters	Two Lick Creek (TSF)	Stream Code	44073
NHD Com ID	123716309	RMI	13.1
Drainage Area	79.1 mi ²	Yield (cfs/mi ²)	0.074
Q ₇₋₁₀ Flow (cfs)	5.83	Q ₇₋₁₀ Basis	USGS PA StreamStats
Elevation (ft)	1511	Slope (ft/ft)	
Watershed No.	18-D	Chapter 93 Class.	TSF
Existing Use	N/A	Existing Use Qualifier	N/A
Exceptions to Use	N/A	Exceptions to Criteria	N/A
Assessment Status	Impaired		
Cause(s) of Impairment	Metals, pH, Pathogens, Pathogens		
Source(s) of Impairment	Acid Mine Drainage, Acid Mine Drainage, Agriculture, Urban Runoff/Storm Sewers		
TMDL Status	Final	Name	Kiskiminetas-Conemaugh River Watersheds TMDL
Nearest Downstream Public Water Supply Intake	Saltsburg Municipal Works		
PWS Waters	Conemaugh River	Flow at Intake (cfs)	
PWS RMI		Distance from Outfall (mi)	37

Changes Since Last Permit Issuance: None

Other Comments: None

Compliance History	
Summary of DMRs:	There were no effluent violations reported in the last year of eDMR data.
Summary of Inspections:	5/13/2019: An inspection was conducted, and no violations were noted. 5/17/2024: An inspection was conducted, and no violations were noted.

Other Comments: None

Compliance History

DMR Data for Outfall 001 (from February 1, 2024 to January 31, 2025)

Parameter	JAN-25	DEC-24	NOV-24	OCT-24	SEP-24	AUG-24	JUL-24	JUN-24	MAY-24	APR-24	MAR-24	FEB-24
Flow (MGD) Average Monthly	0.146	0.14	0.144	0.148	0.153	0.151	0.163	0.155	0.122	0.137	0.153	0.112
Flow (MGD) Daily Maximum	0.319	0.335	0.322	0.317	0.32	0.327	0.334	0.318	0.329	0.314	0.213	0.304
pH (S.U.) Minimum	6.5	6.7	6.8	6.6	6.7	6.8	6.7	6.8	6.9	6.7	6.7	6.5
pH (S.U.) Maximum	7.1	7.5	7.4	7.4	7.3	7.2	7.6	7.5	7.6	7.5	7.4	7.0
TRC (mg/L) Average Monthly	0.19	0.18	0.16	0.19	0.14	0.10	0.12	0.12	0.12	0.16	0.18	0.16
TRC (mg/L) Instantaneous Maximum	0.31	0.39	0.29	0.39	0.19	0.17	0.3	0.34	0.19	0.35	0.36	0.32
TSS (mg/L) Average Monthly	< 2.0	< 2.0	< 2	< 2.0	< 2	< 4.0	< 2.0	2.0	< 2.0	< 2.0	< 3.0	< 2.0
TSS (mg/L) Instantaneous Maximum	< 2.0	< 2	< 2	< 2.0	< 2	6.0	< 2	2	2.0	2	4	< 2.0
Total Aluminum (mg/L) Average Monthly	< 0.10	< 0.10	< 0.10	< 0.10	< 0.10	< 0.10	< 0.10	< 0.10	< 0.10	< 0.10	< 0.10	< 0.10
Total Aluminum (mg/L) Instantaneous Maximum	< 0.10	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.10	< 0.10	< 0.10	< 0.1	< 0.10
Total Iron (mg/L) Average Monthly	0.19	0.32	0.29	0.41	0.23	0.87	0.36	0.19	0.29	0.20	0.59	0.34
Total Iron (mg/L) Instantaneous Maximum	0.20	0.36	0.36	0.46	0.29	1.49	0.36	0.2	0.37	0.22	0.76	0.40
Total Manganese (mg/L) Average Monthly	0.12	0.13	0.09	0.21	0.23	0.27	0.40	0.52	0.84	0.18	0.21	0.18
Total Manganese (mg/L) Instantaneous Maximum	0.12	0.13	0.09	0.24	0.27	0.34	0.51	0.58	0.94	0.22	0.22	0.18

DMR Data for Outfall 002 (from February 1, 2024 to January 31, 2025)

Parameter	JAN-25	DEC-24	NOV-24	OCT-24	SEP-24	AUG-24	JUL-24	JUN-24	MAY-24	APR-24	MAR-24	FEB-24
Flow (MGD) Average Monthly									0.122			
Flow (MGD) Daily Maximum									0.329			
pH (S.U.) Minimum									7.2			
pH (S.U.) Maximum									7.6			
TRC (mg/L) Average Monthly									0.07			
TRC (mg/L) Instantaneous Maximum									0.09			
TSS (mg/L) Average Monthly									< 2.0			
TSS (mg/L) Instantaneous Maximum									2.0			
Total Aluminum (mg/L) Average Monthly									< 0.10			
Total Aluminum (mg/L) Instantaneous Maximum									< 0.10			
Total Iron (mg/L) Average Monthly									0.11			
Total Iron (mg/L) Instantaneous Maximum									0.14			
Total Manganese (mg/L) Average Monthly									0.25			
Total Manganese (mg/L) Instantaneous Maximum									0.27			

Development of Effluent Limitations

Outfall No.	001	Design Flow (MGD)	.353
Latitude	40° 35' 47"	Longitude	-79° 7' 8"
Wastewater Description: IW Process Effluent without ELG			

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Parameter	Limit (mg/l)	SBC	Federal Regulation	State Regulation
Total Suspended Solids	30	Average Monthly		362-2183-003
Total Suspended Solids	40	Daily Maximum		362-2183-003
Aluminum	4.0	Average Monthly		362-2183-003
Aluminum	8.0	Daily Maximum		362-2183-003
Manganese	1.0	Average Monthly		362-2183-003
Manganese	2.0	Daily Maximum		362-2183-003
Total Iron	2.0	Average Monthly		362-2183-003
Total Iron	4.0	Daily Maximum		362-2183-003
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)
Total Residual Chlorine	1.0	Daily Maximum		362-2183-003
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)

Comments: The DEP Guidance "Technology-based Control Requirements for Water Treatment Plant Wastes" (362-2183-001) provides these limits that are based on Best Practical Control Technology (BPT). The Two Lick Creek Plant is not subject to Federal Effluent Limitation Guidelines (ELGs) as the SIC code is not listed under 40 CFR parts 405 through 471.

Water Quality-Based Limitations

The following limitations were determined through water quality modeling (output files attached):

Parameter	Limit (mg/l)	SBC	Model
Total Mercury	Report	Daily Max	Toxics Management Spreadsheet

Comments: The Toxics Management Spreadsheet recommended a monitoring requirement for Total Mercury since the discharge concentration reported on the application was greater than 10% of the calculated WQBEL. Output files are attached to the fact sheet.

Best Professional Judgment (BPJ) Limitations

Comments: See "Technology-Based Limitations" section above for BPT limits.

Kiskiminetas-Conemaugh River Watershed TMDL

A TMDL was finalized on January 29, 2010 for the Kiskiminetas-Conemaugh River Watersheds. The TMDL established waste load allocations for the discharge of aluminum, iron, and manganese within the watershed. This facility is included in the TMDL in Appendix G, which required the load allocations shown in the table below. These load allocations are imposed as effluent limitations in the NPDES permit. These limits are included in the existing permit, so no changes will be made to these in the renewal.

Region	SWS	PERMIT	PIPE	Metal	Baseline Load (lbs/yr)	Baseline Concentration (mg/L)	Allocated Load (lbs/yr)	Allocated Concentration (mg/L)	% Reduction
4	4410	PA0000302	1	Aluminum	1,694	4.00	318	0.75	81
4	4410	PA0000302	1	Iron	847	2.00	635	1.50	25
4	4410	PA0000302	1	Manganese	423	1.00	423	1.00	0
4	4410	PA0000302	2	Aluminum	1,694	4.00	318	0.75	81
4	4410	PA0000302	2	Iron	847	2.00	635	1.50	25
4	4410	PA0000302	2	Manganese	423	1.00	423	1.00	0

Additional Considerations

Monitoring for PFAS parameters – PFOA, PFOS, PFBS, and HFPO-DA –will not be required at this time because the facility does not currently have treatment to remove PFAS.

Anti-Backsliding

Pursuant to 40 CFR § 122.44(l)(1), all proposed permit requirements addressed in this fact sheet are at least as stringent as the requirements implemented in the existing NPDES permit.

Development of Effluent Limitations

Outfall No. 002

Latitude 40° 35' 48"

Wastewater Description: IW Process Effluent without ELG

Design Flow (MGD) .353

Longitude -79° 7' 9"

Outfall 002 processes the same wastewater load and flow as Outfall 001; therefore, this outfall will be analyzed using the same methodology and will have the same effluent limitations.

Refer to Outfall 001 Development of Effluent Limitations for methodology of effluent limits.

Development of Effluent Limitations

Outfall No. 003
Latitude 40° 35' 49"

Design Flow (MGD) 0.353
Longitude -79° 7' 12"

Wastewater Description: IW Process Effluent without ELG

Outfall 003 processes the same wastewater load and flow as Outfall 001; therefore, this outfall will be analyzed using the same methodology and will have the same effluent limitations.

Refer to Outfall 001 Development of Effluent Limitations for methodology of effluent limits.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Daily Maximum	Instant. Maximum		
Flow (MGD)	Report	Daily Max	XXX	XXX	XXX	XXX	2/month	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	2/month	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.0	2/month	Grab
TSS	XXX	XXX	XXX	30	XXX	60	2/month	Grab
Total Aluminum	XXX	XXX	XXX	0.75	XXX	1.5	2/month	Grab
Total Iron	XXX	XXX	XXX	1.5	XXX	3.0	2/month	Grab
Total Manganese	XXX	XXX	XXX	1.0	XXX	2.0	2/month	Grab
Total Mercury	XXX	XXX	XXX	XXX	Report	XXX	1/month	Grab

Compliance Sampling Location: Outfall 001

Other Comments: None

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 002, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	2/month	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	2/month	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.0	2/month	Grab
TSS	XXX	XXX	XXX	30	XXX	60	2/month	Grab
Total Aluminum	XXX	XXX	XXX	0.75	XXX	1.5	2/month	Grab
Total Iron	XXX	XXX	XXX	1.5	XXX	3.0	2/month	Grab
Total Manganese	XXX	XXX	XXX	1.0	XXX	2.0	2/month	Grab
Total Mercury	XXX	XXX	XXX	XXX	Report	XXX	1/month	Grab

Compliance Sampling Location: Outfall 002

Other Comments: None

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 003, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	2/month	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	2/month	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.0	2/month	Grab
TSS	XXX	XXX	XXX	30	XXX	60	2/month	Grab
Total Aluminum	XXX	XXX	XXX	0.75	XXX	1.5	2/month	Grab
Total Iron	XXX	XXX	XXX	1.5	XXX	3.0	2/month	Grab
Total Manganese	XXX	XXX	XXX	1.0	XXX	2.0	2/month	Grab
Total Mercury	XXX	XXX	XXX	XXX	Report	XXX	1/month	Grab

Compliance Sampling Location: Outfall 003

Other Comments: None


PA American Water Company PA0000302 Outfall 001

Region ID: PA

Workspace ID: PA20250325001550782000

Clicked Point (Latitude, Longitude): 40.59629, -79.11972

Time: 2025-03-24 20:16:15 -0400



[Collapse All](#)

➤ Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	79.1	square miles
ELEV	Mean Basin Elevation	1511	feet
PRECIP	Mean Annual Precipitation	47	inches

➤ Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 3]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	79.1	square miles	2.33	1720
ELEV	Mean Basin Elevation	1511	feet	898	2700
PRECIP	Mean Annual Precipitation	47	inches	38.7	47.9

Low-Flow Statistics Flow Report [Low Flow Region 3]

PIL: Lower 90% Prediction Interval, PIU: Upper 90% Prediction Interval, ASEp: Average Standard Error of Prediction, SE: Standard Error, PC: Percent Correct, RMSE: Root Mean Squared Error, PseudoR²: Pseudo R Squared (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	10.5	ft ³ /s	43	43
30 Day 2 Year Low Flow	14.8	ft ³ /s	38	38
7 Day 10 Year Low Flow	5.82	ft ³ /s	54	54
30 Day 10 Year Low Flow	7.61	ft ³ /s	49	49
90 Day 10 Year Low Flow	10.7	ft ³ /s	41	41

Low-Flow Statistics Citations

Stuckey, M.H.,2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.28.0
StreamStats Services Version: 1.2.22
NSS Services Version: 2.2.1


PA American Water Company PA0000302 RMI = 11.9

Region ID: PA

Workspace ID: PA20250325002803496000

Clicked Point (Latitude, Longitude): 40.59131, -79.13806

Time: 2025-03-24 20:28:26 -0400



 [Collapse All](#)

➤ Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	80.9	square miles
ELEV	Mean Basin Elevation	1507	feet
PRECIP	Mean Annual Precipitation	47	inches

➤ Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 3]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	79.1	square miles	2.33	1720
ELEV	Mean Basin Elevation	1511	feet	898	2700
PRECIP	Mean Annual Precipitation	47	inches	38.7	47.9

Low-Flow Statistics Flow Report [Low Flow Region 3]

PIL: Lower 90% Prediction Interval, PIU: Upper 90% Prediction Interval, ASEp: Average Standard Error of Prediction, SE: Standard Error, PC: Percent Correct, RMSE: Root Mean Squared Error, PseudoR²: Pseudo R Squared (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	10.5	ft ³ /s	43	43
30 Day 2 Year Low Flow	14.8	ft ³ /s	38	38
7 Day 10 Year Low Flow	5.82	ft ³ /s	54	54
30 Day 10 Year Low Flow	7.61	ft ³ /s	49	49
90 Day 10 Year Low Flow	10.7	ft ³ /s	41	41

Low-Flow Statistics Citations

Stuckey, M.H.,2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.28.0
StreamStats Services Version: 1.2.22
NSS Services Version: 2.2.1

TRC_CALC

1A	B	C	D	E	F	G
2 TRC EVALUATION						
3 Input appropriate values in B4:B8 and E4:E7						
4	5.83	= Q stream (cfs)		0.5	= CV Daily	
5	0.353	= Q discharge (MGD)		0.5	= CV Hourly	
6	30	= no. samples		1	= AFC_Partial Mix Factor	
7	0.3	= Chlorine Demand of Stream		1	= CFC_Partial Mix Factor	
8	0	= Chlorine Demand of Discharge		15	= AFC_Criteria Compliance Time (min)	
9	0.5	= BAT/BPJ Value		720	= CFC_Criteria Compliance Time (min)	
	0	= % Factor of Safety (FOS)			= Decay Coefficient (K)	
10	Source	Reference	AFC Calculations	Reference	CFC Calculations	
11	TRC	1.3.2.III	WLA_afc = 3.425	1.3.2.III	WLA_cfc = 3.331	
12	PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373	5.1c	LTAMULT_cfc = 0.581	
13	PENTOXSD TRG	5.1b	LTA_afc = 1.276	5.1d	LTA_cfc = 1.937	
14						
15	Source	Effluent Limit Calculations				
16	PENTOXSD TRG	5.1f	AML MULT = 1.231			
17	PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.500	BAT/BPJ		
18			INST MAX LIMIT (mg/l) = 1.635			
19						
20	WLA_afc	$(.019/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k*AFC_tc))...\\...+ Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$				
21	LTAMULT_afc	$\text{EXP}((0.5*\text{LN}(cvh^2+1))-2.326*\text{LN}(cvh^2+1)^0.5)$				
22	LTA_afc	wla_afc*LTAMULT_afc				
23	WLA_cfc	$(.011/e(-k*CFC_tc)) + [(CFC_Yc*Qs*.011/Qd*e(-k*CFC_tc))...\\...+ Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$				
24	LTAMULT_cfc	$\text{EXP}((0.5*\text{LN}(cvd^2/no_samples+1))-2.326*\text{LN}(cvd^2/no_samples+1)^0.5)$				
25	LTA_cfc	wla_cfc*LTAMULT_cfc				
26	AML MULT	$\text{EXP}(2.326*\text{LN}((cvd^2/no_samples+1)^0.5)-0.5*\text{LN}(cvd^2/no_samples+1))$				
27	AVG MON LIMIT	$\text{MIN}(\text{BAT_BPJ},\text{MIN}(\text{LTA_afc},\text{LTA_cfc})*\text{AML_MULT})$				
28	INST MAX LIMIT	$1.5*((\text{av_mon_limit}/\text{AML_MULT})/\text{LTAMULT_afc})$				



Discharge Information

Instructions **Discharge** Stream

Facility: **PA American Water Company - Indiana** NPDES Permit No.: **PA0000302** Outfall No.: **001**

Evaluation Type: **Major Sewage / Industrial Waste** Wastewater Description: **Treated backwash water**

Discharge Characteristics								
Design Flow (MGD)*	Hardness (mg/l)*	pH (SU)*	Partial Mix Factors (PMFs)			Complete Mix Times (min)		
			AFC	CFC	THH	CRL	Q ₇₋₁₀	Q _h
0.353	127	7.7						

			0 if left blank		0.5 if left blank		0 if left blank		1 if left blank		
			Trib Conc	Stream Conc	Daily CV	Hourly CV	Strea m CV	Fate Coeff	FOS	Criteri a Mod	Chem Transl
Group 1	Total Dissolved Solids (PWS)	mg/L	235								
	Chloride (PWS)	mg/L	43.6								
	Bromide	mg/L	0.1								
	Sulfate (PWS)	mg/L	102								
	Fluoride (PWS)	mg/L	0.08								
Group 2	Total Aluminum	µg/L	16.2								
	Total Antimony	µg/L	0.5								
	Total Arsenic	µg/L	0.5								
	Total Barium	µg/L	37.5								
	Total Beryllium	µg/L	0.5								
	Total Boron	µg/L	24								
	Total Cadmium	µg/L	0.1								
	Total Chromium (III)	µg/L	2.1								
	Hexavalent Chromium	µg/L	0.0015								
	Total Cobalt	µg/L	0.2								
	Total Copper	µg/L	1.7								
	Free Cyanide	µg/L									
	Total Cyanide	µg/L	0.01								
	Dissolved Iron	µg/L	20								
	Total Iron	µg/L	410								
	Total Lead	µg/L	0.2								
	Total Manganese	µg/L	406								
	Total Mercury	µg/L	0.1								
	Total Nickel	µg/L	2.7								
	Total Phenols (Phenolics) (PWS)	µg/L	5								
	Total Selenium	µg/L	0.5								
	Total Silver	µg/L	0.1								
	Total Thallium	µg/L	0.1								
	Total Zinc	µg/L	4.7								
	Total Molybdenum	µg/L	1.2								
	Acrolein	µg/L	<								
	Acrylamide	µg/L	<								
	Acrylonitrile	µg/L	<								
	Benzene	µg/L	<								
	Bromoform	µg/L	<								



Stream / Surface Water Information

Instructions Discharge Stream

PA American Water Company - Indiana, NPDES Permit No. PA0000302, Outfall 001

Toxics Management Spreadsheet
Version 1.4, May 2023

Receiving Surface Water Name: **Two Lick Creek**

No. Reaches to Model: 1

- Statewide Criteria
- Great Lakes Criteria
- ORSANC0 Criteria

Location	Stream Code*	RMI*	Elevation (ft)*	DA (mi ²)*	Slope (ft/ft)	PWS Withdrawal (MGD)	Apply Fish Criteria*
Point of Discharge	044073	13.1	1511	79.1			Yes
End of Reach 1	044073	11.9	1507	80.9			Yes

Q₇₋₁₀

Location	RMI	LFY (cfs/mi ²)*	Flow (cfs)	W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary	Stream	Analysis
Point of Discharge	13.1	0.1	5.83						Hardness	pH*	Hardness
End of Reach 1	11.9	0.1	5.95						100	7	100

Q_h

Location	RMI	LFY (cfs/mi ²)*	Flow (cfs)	W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary	Stream	Analysis
Point of Discharge	13.1								Hardness	pH	Hardness
End of Reach 1	11.9								100	7	100



Model Results

PA American Water Company - Indiana, NPDES Permit No. PA0000302, Outfall 001

[Instructions](#) [Results](#) [RETURN TO INPUTS](#) [SAVE AS PDF](#) [PRINT](#) [All](#) [Inputs](#) [Results](#) [Limits](#)

[Hydrodynamics](#)

[Wasteload Allocations](#)

AFC CCT (min): PMF: Analysis Hardness (mg/L): Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0	0	0	N/A	N/A	
Chloride (PWS)	0	0	0	0	N/A	N/A	
Sulfate (PWS)	0	0	0	0	N/A	N/A	
Fluoride (PWS)	0	0	0	0	N/A	N/A	
Total Aluminum	0	0	0	0	750	750	3,424
Total Antimony	0	0	0	0	1,100	1,100	5,022
Total Arsenic	0	0	0	0	340	340	1,552
Total Barium	0	0	0	0	21,000	21,000	95,880
Total Boron	0	0	0	0	8,100	8,100	36,982
Total Cadmium	0	0	0	0	2,129	2,26	10.3
Total Chromium (III)	0	0	0	0	597.214	1,890	8,629
Hexavalent Chromium	0	0	0	0	16	16.3	74.4
Total Cobalt	0	0	0	0	95	95.0	434
Total Copper	0	0	0	0	14,187	14.8	67.5
Dissolved Iron	0	0	0	0	N/A	N/A	
Total Iron	0	0	0	0	N/A	N/A	
Total Lead	0	0	0	0	68.746	87.8	401
Total Manganese	0	0	0	0	N/A	N/A	
Total Mercury	0	0	0	0	1,400	1,65	7.52
Total Nickel	0	0	0	0	491.557	493	2,249
Total Phenols (Phenolics) (PWS)	0	0	0	0	N/A	N/A	
Total Selenium	0	0	0	0	N/A	N/A	
Total Silver	0	0	0	0	3.551	4.18	19.1
Total Thallium	0	0	0	0	65	65.0	297
Total Zinc	0	0	0	0	123,026	126	574

CFC CCT (min): ##### PMF: 1 Analysis Hardness (mg/l): 102.31 Analysis pH: 7.03

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQA Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0	0	0	N/A	N/A	N/A	
Chloride (PWS)	0	0	0	0	N/A	N/A	N/A	
Sulfate (PWS)	0	0	0	0	N/A	N/A	N/A	
Fluoride (PWS)	0	0	0	0	N/A	N/A	N/A	
Total Aluminum	0	0	0	0	N/A	N/A	N/A	
Total Antimony	0	0	0	0	220	220	2,569	
Total Arsenic	0	0	0	0	150	150	1,751	Chem Translator of 1 applied
Total Barium	0	0	0	0	4,100	4,100	47,871	
Total Boron	0	0	0	0	1,600	1,600	18,681	
Total Cadmium	0	0	0	0	0.250	0.288	3.21	Chem Translator of 0.908 applied
Total Chromium (III)	0	0	0	0	75.515	87.8	1,025	Chem Translator of 0.86 applied
Hexavalent Chromium	0	0	0	0	10	10.4	121	Chem Translator of 0.962 applied
Total Cobalt	0	0	0	0	19	19.0	222	Chem Translator of 0.96 applied
Total Copper	0	0	0	0	9,132	9.51	111	Chem Translator of 0.96 applied
Dissolved Iron	0	0	0	0	N/A	N/A	N/A	
Total Iron	0	0	0	0	1,500	1,500	17,514	WQC = 30 day average; PMF = 1
Total Lead	0	0	0	0	2,580	3,28	38.2	Chem Translator of 0.788 applied
Total Manganese	0	0	0	0	N/A	N/A	N/A	
Total Mercury	0	0	0	0	0.770	0.91	10.6	Chem Translator of 0.85 applied
Total Nickel	0	0	0	0	53.022	53.2	621	Chem Translator of 0.997 applied
Total Phenols (Phenolics) (PWS)	0	0	0	0	N/A	N/A	N/A	
Total Selenium	0	0	0	0	4,600	4,99	58.3	Chem Translator of 0.922 applied
Total Silver	0	0	0	0	N/A	N/A	N/A	Chem Translator of 1 applied
Total Thallium	0	0	0	0	13	13.0	152	
Total Zinc	0	0	0	0	120,450	122	1,426	Chem Translator of 0.986 applied

THH CCT (min): ##### PMF: 1 Analysis Hardness (mg/l): N/A Analysis pH: N/A

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQA Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0	0	0	500,000	500,000	N/A	
Chloride (PWS)	0	0	0	0	250,000	250,000	N/A	
Sulfate (PWS)	0	0	0	0	250,000	250,000	N/A	
Fluoride (PWS)	0	0	0	0	2,000	2,000	N/A	
Total Aluminum	0	0	0	0	N/A	N/A	N/A	
Total Antimony	0	0	0	0	5.6	5.6	65.4	
Total Arsenic	0	0	0	0	10	10.0	117	
Total Barium	0	0	0	0	2,400	2,400	28,022	
Total Boron	0	0	0	0	3,100	3,100	36,195	
Total Cadmium	0	0	0	0	N/A	N/A	N/A	
Total Chromium (III)	0	0	0	0	N/A	N/A	N/A	

Hexavalent Chromium	0	0	0	0	N/A	N/A	N/A
Total Cobalt	0	0	0	0	N/A	N/A	N/A
Total Copper	0	0	0	0	N/A	N/A	N/A
Dissolved Iron	0	0	0	0	300	300	3,503
Total Iron	0	0	0	0	N/A	N/A	N/A
Total Lead	0	0	0	0	N/A	N/A	N/A
Total Manganese	0	0	0	0	1,000	1,000	11,676
Total Mercury	0	0	0	0	0.050	0.05	0.58
Total Nickel	0	0	0	0	610	610	7,122
Total Phenols (Phenolics) (PWS)	0	0	0	0	5	5.0	N/A
Total Selenium	0	0	0	0	N/A	N/A	N/A
Total Silver	0	0	0	0	N/A	N/A	N/A
Total Thallium	0	0	0	0	0.24	0.24	2.8
Total Zinc	0	0	0	0	N/A	N/A	N/A

CRL CCT (min): 50,444

PMF: 1

Analysis Hardness (mg/l): N/A

Analysis pH: N/A

Pollutants	Stream	Conc ($\mu\text{g/L}$)	Stream CV	Trib Conc ($\mu\text{g/L}$)	Fate Coef	WQC ($\mu\text{g/L}$)	WQA Obj ($\mu\text{g/L}$)	Comments	
								WLA (mg/L)	
Total Dissolved Solids (PWS)	0	0	0	0	N/A	N/A	N/A	N/A	
Chloride (PWS)	0	0	0	0	N/A	N/A	N/A	N/A	
Sulfate (PWS)	0	0	0	0	N/A	N/A	N/A	N/A	
Fluoride (PWS)	0	0	0	0	N/A	N/A	N/A	N/A	
Total Aluminum	0	0	0	0	N/A	N/A	N/A	N/A	
Total Antimony	0	0	0	0	N/A	N/A	N/A	N/A	
Total Arsenic	0	0	0	0	N/A	N/A	N/A	N/A	
Total Barium	0	0	0	0	N/A	N/A	N/A	N/A	
Total Boron	0	0	0	0	N/A	N/A	N/A	N/A	
Total Cadmium	0	0	0	0	N/A	N/A	N/A	N/A	
Total Chromium (III)	0	0	0	0	N/A	N/A	N/A	N/A	
Hexavalent Chromium	0	0	0	0	N/A	N/A	N/A	N/A	
Total Cobalt	0	0	0	0	N/A	N/A	N/A	N/A	
Total Copper	0	0	0	0	N/A	N/A	N/A	N/A	
Dissolved Iron	0	0	0	0	N/A	N/A	N/A	N/A	
Total Iron	0	0	0	0	N/A	N/A	N/A	N/A	
Total Lead	0	0	0	0	N/A	N/A	N/A	N/A	
Total Manganese	0	0	0	0	N/A	N/A	N/A	N/A	
Total Mercury	0	0	0	0	N/A	N/A	N/A	N/A	
Total Nickel	0	0	0	0	N/A	N/A	N/A	N/A	
Total Phenols (Phenolics) (PWS)	0	0	0	0	N/A	N/A	N/A	N/A	
Total Selenium	0	0	0	0	N/A	N/A	N/A	N/A	
Total Silver	0	0	0	0	N/A	N/A	N/A	N/A	
Total Thallium	0	0	0	0	N/A	N/A	N/A	N/A	
Total Zinc	0	0	0	0	N/A	N/A	N/A	N/A	

Recommended WQBELs & Monitoring Requirements

No. Samples/Month: 4

Pollutants	Mass Limits			Concentration Limits			Governing WQBEL Basis	Comments
	AML (lbs/day)	MDL (lbs/day)	AML Report	MDL Report	IMAX Report	Units µg/L		
Total Mercury							0.58	THH Discharge Conc > 10% WQBEL (no RP)

Other Pollutants without Limits or Monitoring

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., <= Target QL).

Pollutants	Governing WQBEL	Units	Comments
Total Dissolved Solids (PWS)	N/A	N/A	PWS Not Applicable
Chloride (PWS)	N/A	N/A	PWS Not Applicable
Bromide	N/A	N/A	No WQS
Sulfate (PWS)	N/A	N/A	PWS Not Applicable
Fluoride (PWS)	N/A	N/A	PWS Not Applicable
Total Aluminum	2,195	µg/L	Discharge Conc ≤ 10% WQBEL
Total Antimony	65.4	µg/L	Discharge Conc ≤ 10% WQBEL
Total Arsenic	117	µg/L	Discharge Conc ≤ 10% WQBEL
Total Barium	28,022	µg/L	Discharge Conc ≤ 10% WQBEL
Total Beryllium	N/A	N/A	No WQS
Total Boron	18,681	µg/L	Discharge Conc ≤ 10% WQBEL
Total Cadmium	3.21	µg/L	Discharge Conc ≤ 10% WQBEL
Total Chromium (III)	1,025	µg/L	Discharge Conc ≤ 10% WQBEL
Hexavalent Chromium	47.7	µg/L	Discharge Conc ≤ 10% WQBEL
Total Cobalt	222	µg/L	Discharge Conc ≤ 10% WQBEL
Total Copper	43.2	µg/L	Discharge Conc ≤ 10% WQBEL
Total Cyanide	N/A	N/A	No WQS
Dissolved Iron	3,503	µg/L	Discharge Conc ≤ 10% WQBEL
Total Iron	17,514	µg/L	Discharge Conc ≤ 10% WQBEL
Total Lead	38.2	µg/L	Discharge Conc ≤ 10% WQBEL
Total Manganese	11,676	µg/L	Discharge Conc ≤ 10% WQBEL
Total Nickel	621	µg/L	Discharge Conc ≤ 10% WQBEL
Total Phenols (Phenolics) (PWS)		µg/L	PWS Not Applicable
Total Selenium	58.3	µg/L	Discharge Conc ≤ 10% WQBEL
Total Silver	12.2	µg/L	Discharge Conc ≤ 10% WQBEL
Total Thallium	2.8	µg/L	Discharge Conc ≤ 10% WQBEL
Total Zinc	368	µg/L	Discharge Conc ≤ 10% WQBEL
Total Molybdenum	N/A	N/A	No WQS

