

Application Type Amendment, Major
 Facility Type Industrial
 Major / Minor Minor

**NPDES PERMIT FACT SHEET
 INDIVIDUAL INDUSTRIAL WASTE (IW)
 AND IW STORMWATER**

Application No. PA0001228 A-1
 APS ID 1006168
 Authorization ID 1296200

Applicant and Facility Information



Applicant Name	<u>Curtiss Wright Corp</u>	Facility Name	<u>Curtiss Wright Electro Mechanical Corp</u>
Applicant Address	<u>1000 Wright Way</u> <u>Cheswick, PA 15024-1008</u>	Facility Address	<u>1000 Wright Way</u> <u>Cheswick, PA 15024-1008</u>
Applicant Contact	<u>Brian Eckels</u>	Facility Contact	<u>Heather List</u>
Applicant Phone	<u>724-275-5000</u>	Facility Phone	<u>724-275-5755</u>
Client ID	<u>208140</u>	Site ID	<u>241874</u>
SIC Code	<u>3621</u>	Municipality	<u>Harmar Township</u>
SIC Description	<u>Manufacturing - Motors And Generators</u>	County	<u>Allegheny</u>
Date Application Received	<u>November 14, 2019</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>November 20, 2019</u>	If No, Reason	<u></u>
Purpose of Application	<u>Permit Amendment to include an additional Internal Monitoring Point</u>		

Summary of Review

The Department received an NPDES amendment application from Curtiss Wright Electro-Mechanical Corporation on November 14, 2019. The site operations consist of manufacturing and testing of mechanical equipment with SIC codes of 3561 (Pumps and Pumping Engineering), 3621 (Motors and Generators), and 3559 (Nuclear Control Rod Drive Mechanisms).

Curtiss-Wright Electro-Mechanical Corporation manufactures pumps, motors, generators and other components for both nuclear and non-nuclear applications. Activities include machining, cutting, grinding, welding and assembly of stainless-steel parts to fine tolerance. The facility refurbishes and repairs equipment used at existing nuclear power facilities. Repair and manufactured pumps are tested in "test loops". When testing occurs, water is continuously recirculated throughout the test loop so the pumps can be evaluated under various conditions. Test runs can last from a few days to multiple months. Discharges of test loop water occurs when a pump is inserted or removed from the test loop. This results in batch discharges. The amendment is to amend the August 24, 2018 NPDES permit to include a new IMP (IMP 133) that will discharge non-contact cooling water from a new test loop, Test Loop Y-2.

Test Loop Y-2 will consist of a submersible pump that is submerged during the test. The test will be conducted in an open-top tank, filled with approximately 20,000 gallons of cooling water. Well water will be used as the cooling water, which will be continuously flowed into and out of the tank at a rate of approximately 0.0288 MGD. The flow rate may vary depending on testing needs but will be between 0.0144 MGD and 0.0432 MGD. No chemical additives will be used. The well water used as cooling water will contact the exterior of the pump. The cooling water from the tank will discharge to Outfall 003 and will be monitored at IMP 133. A closed loop piping system of primary test water will be flowed through the pump. Water from the cooling tower will be used as the primary water, which will be discharge to the sanitary sewer. The first prototype test is anticipated to begin as early as August of 2020. The first test of the prototype will take approximately three months, or 180 hours of run time. There are currently no orders for products after the prototype. This means that the prototype test may be the only one. However, if additional orders are received after the prototype testing is complete, subsequent tests will be

Approve	Deny	Signatures	Date
X		 Adam Olesnanik / Environmental Engineering Specialist	11-21-19
✓		 Michael E. Fifth / P.E. / Environmental Engineer Manager	11/22/19

Summary of Review

completed at an estimated frequency of 2 to 4 test per year, beginning approximately one-year after the order is received. Each product after the prototype is estimated to only require 1 month of testing, compared to the 3 months required for the prototype test.

The site has six outfalls (001 through 006), seven existing internal monitoring points (113, 123, 303, 403, 603, 901, and 903), and is proposing to add an additional internal monitoring point (IMP 133). Outfalls 002, 004, 005, and 006 received only stormwater. Outfall 001 received stormwater, non-contact cooling water, and discharges from IMP 901. IMP 901 receives discharge water from test loops using DI water. Outfall 003 received stormwater, non-contact cooling water, and discharges from IMPs 113, 123, 303, 403, 603, 903, and the proposed IMP 133. IMP 403 and 603 receive discharge water from test loops using DI water. IMP 113, 123, 303, and 903 receive discharge water from test loops that have lithium hydroxide as a chemical additive. The proposed IMP 133 received discharge water from a test loop using filtered well water. The purpose of having internal monitoring points is to monitor the discharge from the individual test loops that feed to Outfall 001 or Outfall 003. Outfalls 002, 003, 004, 005, and 006 discharge to an unnamed tributary to the Allegheny River designated in 25 PA Code, Chapter 93 as a Warm Water Fishery and Outfall 001 discharges to a drainage swale to the Allegheny River. No changes are being proposed for all of the existing outfalls and IMPs, and the limitations imposed on these points will not be discussed in this fact sheet.

The permittee has no open violations.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Discharge, Receiving Waters and Water Supply Information

Outfall No.	<u>003 (IMP 113, 123, 303, 403, 603, 903, & 133)</u>	Design Flow (MGD)	<u>0.277</u>
Latitude	<u>40° 33' 10"</u>	Longitude	<u>-79° 48' 50"</u>
Quad Name	<u>New Kensington West</u>	Quad Code	<u>1407</u>
Wastewater Description: <u>IW Process Effluent without ELG</u>			
Receiving Waters	<u>Unnamed Tributary to Allegheny River</u>	Stream Code	<u>42368</u>
NHD Com ID	<u>123972662</u>	RMI	<u>0.80</u>
Drainage Area	<u>0.0679</u>	Yield (cfs/mi ²)	<u>0.006</u>
Q ₇₋₁₀ Flow (cfs)	<u>0.000268</u>	Q ₇₋₁₀ Basis	<u>USGS Streamstats</u>
Elevation (ft)	<u>900</u>	Slope (ft/ft)	<u>0.0001</u>
Watershed No.	<u>18-A</u>	Chapter 93 Class.	<u>WWF</u>
Existing Use	<u></u>	Existing Use Qualifier	<u></u>
Exceptions to Use	<u></u>	Exceptions to Criteria	<u></u>
Assessment Status	<u>Attaining Use(s)</u>		
Cause(s) of Impairment	<u></u>		
Source(s) of Impairment	<u></u>		
TMDL Status	<u>Name</u>		
Nearest Downstream Public Water Supply Intake	<u>Oakmont Borough Municipal Authority</u>		
PWS Waters	<u>Allegheny River</u>	Flow at Intake (cfs)	<u>2,390</u>
PWS RMI	<u>13.3</u>	Distance from Outfall (mi)	<u>2.24</u>

Development of Effluent Limitations

IMP No. 133 Design Flow (MGD) 0.0288
Wastewater Description: Non-contact cooling water from Test Loop Y-2

Technology Based Effluent limits

Flow monitoring is required pursuant to 25 Pa. Code § 92a.61(d)(1) as indicated in Table 1.

Effluent standards for pH are also imposed on industrial wastes by 25 Pa. Code §§ 95.2(1) as indicated in Table 1.

Dissolved iron limitations are imposed pursuant to 25 Pa. Code §§ 95.2(4).

Table 1: TBELs for IMP 133

Parameter	Monthly Average	Daily Maximum	Units
Flow	Monitor and Report		MGD
Iron, dissolved	Report	7.0	mg/L
pH	Not less than 6.0 nor greater than 9.0		S.U.

As non-contact cooling water, temperature limitations are required; however, the temperature limitations will not be imposed at the internal monitoring point and are imposed at the discharge point, Outfall 003. The Temperature is limited at the discharge point because the waste streams from the other IMPs can combine and influence the temperature of the discharge.

The discharge is similar to the other test loop discharges at the site; therefore, the limits imposed on the other IMPs for the Test Loop discharges will be imposed at IMP 133. These limitations were originally imposed on a BPJ basis using limitations that are imposed on hydrostatic testing discharges.

Table 2: Proposed BPJ Limits at IMP 133

Parameter	Monthly Average	Daily Maximum	Monitor Frequency	Sample Type
Flow (MGD)	Monitor and Report		2/month	Estimate
Total Suspended Solids (mg/L)	30	60	2/month	Grab
Dissolved Oxygen (mg/L)	-	5.0 minimum	2/month	Grab
Iron, dissolved (mg/L)	Report	7.0	2/month	Grab
pH (S.U.)	Not less than 6.0 nor greater than 9.0		2/month	Grab

Water Quality Based Effluent Limits

Due to the facilities location there is no upland flow contribution at the point of discharge. The receiving stream has a Q₇₋₁₀ of zero. For this reason, water quality-based temperature limits are not proposed at IMP 113. Whenever industrial facilities discharge wastewater to an intermittent or zero-flow stream, the discharges must meet the water quality criteria published in PA Code Chapter 93.8.

Anti-Backsliding

The previous permit limitations imposed at IMP 133 can be used pursuant to EPA's anti-backsliding regulation, 40 CFR 122.44(l); however, IMP 133 is new to the permit and does not have existing limitations imposed in the current permit.

Proposed Final Effluent Limitations for IMP 133

The proposed final effluent limitation and monitoring frequency for IMP 133 is displayed below in Table 3.

Table 3: Proposed Final Limits at IMP 133

Parameter	Monthly Average	Daily Maximum	Monitor Frequency	Sample Type
Flow (MGD)	Monitor and Report		2/month	Estimate
Total Suspended Solids (mg/L)	30	60	2/month	Grab
Dissolved Oxygen (mg/L)	-	5.0 minimum	2/month	Grab
Iron, dissolved (mg/L)	Report	7.0	2/month	Grab
pH (S.U.)	Not less than 6.0 nor greater than 9.0		2/month	Grab

Tools and References Used to Develop Permit	
<input type="checkbox"/>	WQM for Windows Model (see Attachment [redacted])
<input type="checkbox"/>	PENTOXSD for Windows Model (see Attachment [redacted])
<input type="checkbox"/>	TRC Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Toxics Screening Analysis Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 385-2000-011, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 391-2000-006, 9/97.
<input type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 391-2000-023, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97.
<input type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input type="checkbox"/>	SOP: [redacted]
<input type="checkbox"/>	Other: [redacted]