

Application Type Renewal  
 Facility Type Non-Municipal  
 Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0001350  
 APS ID 1028193  
 Authorization ID 1335718

**Applicant and Facility Information**

Applicant Name	<u>The Washington County Coal Company</u>	Facility Name	<u>Somerset Portal STP</u>
Applicant Address	<u>46226 National Road</u> <u>Saint Clairsville, OH 43950-8742</u>	Facility Address	<u>860 Vanceville Road</u> <u>Eighty Four, PA 15330</u>
Applicant Contact	<u>Jon Nagel</u>	Facility Contact	<u></u>
Applicant Phone	<u>(724) 338-3100</u>	Facility Phone	<u></u>
Client ID	<u>310093</u>	Site ID	<u>257787</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Somerset Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Washington</u>
Date Application Received	<u>December 4, 2020</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>December 8, 2020</u>	If No, Reason	<u></u>

Purpose of Application Renewal of an NPDES Permit for an existing discharge of treated sewage.

**Summary of Review**

This is a privately owned sewage treatment plant serving an industrial facility engaged in coal mining activities.

No changes to discharge quantity or quality were proposed as part of this permit renewal.

The facility is currently using the eDMR system for reporting.

There are currently no open violations listed in EFACTS for this permittee (5/25/2021).

A WQM Permit amendment application must be submitted for a dechlorination unit that has been installed.

Sludge use and disposal description and location(s): Sludge is hauled offsite by a septic hauler for disposal at Liquid Asset Disposal in Wheeling, WV.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		Adam Pesek Adam J. Pesek, E.I.T. / Environmental Engineering Specialist	May 25, 2021
X		Justin C. Dickey Justin C. Dickey, P.E. / Environmental Engineer Manager	May 27, 2021

**Discharge, Receiving Waters and Water Supply Information**

Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.00972</u>
Latitude	<u>40° 7' 38.0"</u>	Longitude	<u>-80° 3' 37"</u>
Quad Name	<u>Hackett</u>	Quad Code	<u>01705</u>
Wastewater Description: <u>Treated Sewage Effluent</u>			

Receiving Waters	<u>Center Branch Pigeon Creek</u>	Stream Code	<u>39723</u>
NHD Com ID	<u>99410260</u>	RMI	<u>1.85</u>
Drainage Area	<u>4.37</u>	Yield (cfs/mi <sup>2</sup> )	<u>0.01137</u>
Q <sub>7-10</sub> Flow (cfs)	<u>.0497</u>	Q <sub>7-10</sub> Basis	<u>USGS Streamstats Regression Analysis</u>
Elevation (ft)	<u>993</u>	Slope (ft/ft)	<u></u>
Watershed No.	<u>19-C</u>	Chapter 93 Class.	<u>WWF</u>
Existing Use	<u></u>	Existing Use Qualifier	<u></u>
Exceptions to Use	<u></u>	Exceptions to Criteria	<u></u>
Assessment Status	<u>Attaining Use(s)</u>		

Cause(s) of Impairment

Source(s) of Impairment

TMDL Status  Name

Background/Ambient Data		Data Source	
pH (SU)	<u>8.0</u>	3/12/2020 Stream Sample directly above Mine No. 60	<u>Reservoir</u>
Temperature (°C)	<u>25</u>	Default (WWF)	<u></u>
Hardness (mg/L)	<u>443</u>	3/12/2020 Stream Sample directly above Mine No. 60	<u>Reservoir</u>
Other: NH <sub>3</sub> -N	<u>&lt; 0.02</u>	3/12/2020 Stream Sample directly above Mine No. 60	<u>Reservoir</u>

Nearest Downstream Public Water Supply Intake	<u>PA American Water Company - Aldrich Station</u>		
PWS Waters	<u>Monongahela River</u>	Flow at Intake (cfs)	<u>550</u>
PWS RMI	<u>23.5</u>	Distance from Outfall (mi)	<u></u>

Changes Since Last Permit Issuance:

Other Comments:

Treatment Facility Summary				
<b>Treatment Facility Name:</b> Somerset Portal STP				
<b>WQM Permit No.</b>		<b>Issuance Date</b>		
467S050 T-2		9/8/2016		
467S050 T-1		10/27/1993		
467S050		1/15/1968		
<b>Waste Type</b>	<b>Degree of Treatment</b>	<b>Process Type</b>	<b>Disinfection</b>	<b>Avg Annual Flow (MGD)</b>
Sewage	Secondary with NH3-N removal	Septic Tank Sand Filter W/Sol Removal	Hypochlorite	0.00972
<b>Hydraulic Capacity (MGD)</b>	<b>Organic Capacity (lbs/day)</b>	<b>Load Status</b>	<b>Biosolids Treatment</b>	<b>Biosolids Use/Disposal</b>
0.00972	16.2	Not Overloaded	Septic Tank	Hauled offsite by septic hauler

Changes Since Last Permit Issuance: the application indicated that the permittee had installed a dechlorination unit without a WQM Permit Amendment. To come into compliance, the permittee must apply for and receive a WQM Permit Amendment. A WQM Permit application has not been submitted to date (4/30/2021).

Other Comments: Organic capacity was previously calculated using the following equation:

$$0.0097 \text{ mgd} \times 8.345 \times 200 \text{ mg/l} = 16.2 \text{ lbs/day}$$

<b>Compliance History</b>	
<b>Summary of DMRs:</b>	A DMR review done during the 2/2/2021 inspection did not find any effluent violations at that time.
<b>Summary of Inspections:</b>	<p>The last site inspection was conducted on 2/2/21. The inspection report found the plant to be well maintained and in good working order. Sludge records were not available onsite at the inspection.</p> <p>Recommendations included:</p> <ul style="list-style-type: none"> <li>• Calibration records need to be maintained for pH, DO, and TRC.</li> <li>• Daily log, repair log, and routine maintenance logs need to be maintained.</li> <li>• Please add visual observations, any process adjustments, or any problems or concerns to the daily log.</li> <li>• Sludge removal records need to be kept on-site and retained for at least five years.</li> </ul> <p>The report also requested that the on-site lab needs registered with DEP Bureau of Labs and make sure Standard Laboratories is also registered with PA DEP. I will need both PA DEP Lab ID numbers.</p>

Other Comments:

Compliance History

DMR Data for Outfall 001 (from March 1, 2020 to February 28, 2021)

Parameter	FEB-21	JAN-21	DEC-20	NOV-20	OCT-20	SEP-20	AUG-20	JUL-20	JUN-20	MAY-20	APR-20	MAR-20
Flow (MGD) Average Monthly		0.00070	0.00060	0.00080 0	0.00080 0		0.00180		0.00010	0.00200	0.00480	0.00500
pH (S.U.) Minimum		7.5	8.0	7.9	7.26		7.38		7.85	6.98	6.86	6.81
pH (S.U.) Maximum		7.7	8.0	7.9	7.26		7.38		8.85	8.33	8.53	8.47
DO (mg/L) Minimum		9.4	9.0	8.1	8.4		8.1		8.6	6.7	7.5	8.8
TRC (mg/L) Average Monthly		0.048	0.0225	0.02	0.05		0.02		0.02	0.02	0.01	0.04
TRC (mg/L) Instantaneous Maximum		0.08	0.025	0.02	0.05		0.02		0.03	0.06	0.09	0.32
CBOD5 (mg/L) Average Monthly		1.19	1.39	1.24	2.48		E		5.3	< 2.0	< 4.4	< 2.0
CBOD5 (mg/L) Instantaneous Maximum		1.19	1.39	1.24	2.48		E		5.3	< 2.0	< 6.8	< 2.0
TSS (mg/L) Average Monthly		< 3.0	< 3.0	< 3.0	< 3.0		E		10.0	< 3.0	< 3.0	< 3.0
TSS (mg/L) Instantaneous Maximum		< 3.0	< 3.0	< 3.0	< 3.0		E		10.0	< 3.0	< 3.0	< 3.0
Fecal Coliform (No./100 ml) Average Monthly		< 1.0	< 1.0	< 1.0	< 1.0		E		< 1	< 1.0	< 1	< 1.0
Fecal Coliform (No./100 ml) Instantaneous Maximum		< 1.0	< 1.0	< 1.0	< 1.0		E		< 1	< 1.0	< 1	< 1.0
Total Nitrogen (mg/L) Daily Maximum			< 3.87									
Ammonia (mg/L) Average Monthly		< 0.15	0.21	< 0.15	< 0.15		E		< 0.15	< 0.15	< 0.15	< 1.415
Ammonia (mg/L) Instantaneous Maximum		< 0.15	0.21	< 0.15	< 0.15		E		< 0.15	< 0.15	< 0.15	2.66
Total Phosphorus (mg/L) Daily Maximum			0.240									

**Development of Effluent Limitations**

<b>Outfall No.</b>	001	<b>Design Flow (MGD)</b>	0.00972
<b>Latitude</b>	40° 7' 38.00"	<b>Longitude</b>	-80° 3' 37.00"
<b>Wastewater Description:</b> Sewage Effluent			

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

**Water Quality-Based Limitations**

The following limitations were determined through water quality modeling (output files attached):

Parameter	Limit (mg/l)	SBC	Model
Ammonia Nitrogen	3.0	Average Monthly	WQM 7.0 Ver. 1.1
Total Residual Chlorine	0.49	Average Monthly	TRC Calc Spreadsheet
Total Residual Chlorine	1.6	IMAX	TRC Calc Spreadsheet

Comments: A seasonal multiplier of “3” is applied to ammonia nitrogen limits in accordance with the Department’s SOP entitled “Establishing Effluent Limitations for Individual Sewage Permits.”

The calculated ammonia nitrogen WQBELs are significantly more stringent than the previously calculated limits, mainly due to the revised stream flow, calculated discharge and stream pH, and new water quality criteria. Based on a review of eDMRs, the permittee should be able to meet the new limits consistently when the permit is renewed.

**Best Professional Judgment (BPJ) Limitations**

N/A

**Additional Considerations**

Monitoring for E. Coli, total nitrogen, and total phosphorus will be placed in the permit in accordance with the Department’s SOP entitled “Establishing Effluent Limitations for Individual Sewage Permits.”

Monitoring for D.O. will be placed in the permit instead of a limit of a minimum of 4.0 mg/l due to the type of treatment used (septic tank/sand filter).

**Anti-Backsliding**

N/A

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	XXX	XXX	XXX	XXX	XXX	2/month	Measured
pH (S.U.)	XXX	XXX	6.0 Daily Min	XXX	9.0 Daily Max	XXX	1/day	Grab
DO	XXX	XXX	Report Daily Min	XXX	XXX	XXX	2/month	Grab
TRC	XXX	XXX	XXX	0.49	XXX	1.6	1/day	Grab
CBOD5	XXX	XXX	XXX	25.0	XXX	50	2/month	Grab
TSS	XXX	XXX	XXX	30.0	XXX	60	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Total Nitrogen	XXX	XXX	XXX	Report Daily Max	XXX	XXX	1/year	Grab
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	9.0	XXX	18.0	2/month	Grab
Ammonia May 1 - Oct 31	XXX	XXX	XXX	3.0	XXX	6.0	2/month	Grab
Total Phosphorus	XXX	XXX	XXX	Report Daily Max	XXX	XXX	1/year	Grab

Compliance Sampling Location: Outfall 001 (after disinfection)

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
19C	39723	CENTER BRANCH PIGEON CREEK	1.850	993.00	4.37	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.011	0.00	0.05	0.000	0.000	0.0	0.00	0.00	25.00	8.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Somerset Portal	PA0001350	0.0097	0.0000	0.0000	0.000	20.00	8.10

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	4.00	7.54	0.00	0.00
NH3-N	25.00	0.02	0.00	0.70



**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
19C	39723	CENTER BRANCH PIGEON CREEK	0.001	966.00	6.84	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.011	0.00	0.09	0.000	0.000	0.0	0.00	0.00	25.00	8.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data							
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00
Parameter Data							
Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)			
CBOD5	25.00	2.00	0.00	1.50			
Dissolved Oxygen	3.00	8.24	0.00	0.00			
NH3-N	25.00	0.00	0.00	0.70			

**WQM 7.0 Hydrodynamic Outputs**

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
19C		39723				CENTER BRANCH PIGEON CREEK						
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
<b>Q7-10 Flow</b>												
1.850	0.05	0.00	0.05	.015	0.00277	.343	6.05	17.68	0.03	3.619	23.84	8.02
<b>Q1-10 Flow</b>												
1.850	0.03	0.00	0.03	.015	0.00277	NA	NA	NA	0.03	4.338	23.40	8.03
<b>Q30-10 Flow</b>												
1.850	0.07	0.00	0.07	.015	0.00277	NA	NA	NA	0.04	3.157	24.09	8.02

**WQM 7.0 Modeling Specifications**

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

**WQM 7.0 Wasteload Allocations**

**SWP Basin**      **Stream Code**      **Stream Name**  
19C                      39723                      CENTER BRANCH PIGEON CREEK

**NH3-N Acute Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
1.850	Somerset Portal	2.79	8.64	2.79	8.64	0	0

**NH3-N Chronic Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
1.850	Somerset Portal	.58	3.11	.58	3.11	0	0

**Dissolved Oxygen Allocations**

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
1.85	Somerset Portal	25	25	3.11	3.11	4	4	0	0

**WQM 7.0 D.O.Simulation**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
19C	39723	CENTER BRANCH PIGEON CREEK		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
1.850	0.010	23.839	8.021	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
6.054	0.343	17.676	0.031	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
7.34	0.301	0.74	0.941	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
6.718	16.908	Owens	5	
<u>Reach Travel Time (days)</u>	<b>Subreach Results</b>			
3.619	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.362	6.45	0.53	7.54
	0.724	5.66	0.37	7.54
	1.086	4.97	0.27	7.54
	1.448	4.36	0.19	7.54
	1.810	3.83	0.13	7.54
	2.172	3.36	0.10	7.54
	2.534	2.95	0.07	7.54
	2.896	2.59	0.05	7.54
	3.258	2.28	0.03	7.54
	3.619	2.00	0.02	7.54

**WQM 7.0 Effluent Limits**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>					
19C	39723	CENTER BRANCH PIGEON CREEK					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
1.850	Somerset Portal	PA0001350	0.010	CBOD5	25		
				NH3-N	3.11	6.22	
				Dissolved Oxygen			4

1A	B	C	D	E	F	G
2	<b>TRC EVALUATION</b>		<b>Somerset Portal STP</b>			
3	Input appropriate values in B4:B8 and E4:E7					
4	0.0497	= Q stream (cfs)		0.5	= CV Daily	
5	0.00972	= Q discharge (MGD)		0.5	= CV Hourly	
6	30	= no. samples		1	= AFC_Partial Mix Factor	
7	0.3	= Chlorine Demand of Stream		1	= CFC_Partial Mix Factor	
8	0	= Chlorine Demand of Discharge		15	= AFC_Criteria Compliance Time (min)	
9	0.5	= BAT/BPJ Value		720	= CFC_Criteria Compliance Time (min)	
	0	= % Factor of Safety (FOS)		0	=Decay Coefficient (K)	
10	Source	Reference	AFC Calculations		Reference	CFC Calculations
11	TRC	1.3.2.iii	WLA_afc = 1.073		1.3.2.iii	WLA_cfc = 1.039
12	PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373		5.1c	LTAMULT_cfc = 0.581
13	PENTOXSD TRG	5.1b	LTA_afc = 0.400		5.1d	LTA_cfc = 0.604
14						
15	Source	Effluent Limit Calculations				
16	PENTOXSD TRG	5.1f	AML_MULT = 1.231			
17	PENTOXSD TRG	5.1g	AVG_MON_LIMIT (mg/l) = 0.492		AFC	
18			INST_MAX_LIMIT (mg/l) = 1.610			
	WLA_afc	$(.019/e^{-k \cdot AFC\_tc}) + [(AFC\_Yc \cdot Qs \cdot .019 / Qd \cdot e^{-k \cdot AFC\_tc}) \dots + Xd + (AFC\_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$				
	LTAMULT_afc	$EXP((0.5 \cdot LN(cvh^2 + 1)) - 2.326 \cdot LN(cvh^2 + 1)^{0.5})$				
	LTA_afc	wla_afc * LTAMULT_afc				
	WLA_cfc	$(.011/e^{-k \cdot CFC\_tc}) + [(CFC\_Yc \cdot Qs \cdot .011 / Qd \cdot e^{-k \cdot CFC\_tc}) \dots + Xd + (CFC\_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$				
	LTAMULT_cfc	$EXP((0.5 \cdot LN(cvd^2 / no\_samples + 1)) - 2.326 \cdot LN(cvd^2 / no\_samples + 1)^{0.5})$				
	LTA_cfc	wla_cfc * LTAMULT_cfc				
	AML_MULT	$EXP(2.326 \cdot LN((cvd^2 / no\_samples + 1)^{0.5}) - 0.5 \cdot LN(cvd^2 / no\_samples + 1))$				
	AVG_MON_LIMIT	MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc) * AML_MULT)				
	INST_MAX_LIMIT	1.5 * ((av_mon_limit / AML_MULT) / LTAMULT_afc)				