

Application Type
Facility Type
Major / Minor

Renewal
Industrial
Major

**NPDES PERMIT FACT SHEET
INDIVIDUAL INDUSTRIAL WASTE (IW)
AND IW STORMWATER**

Application No. PA0004073
APS ID 715650
Authorization ID 827245

Applicant and Facility Information

| | | | |
|---------------------------|---|------------------|--|
| Applicant Name | <u>United States Steel Corporation</u> | Facility Name | <u>Mon Valley Works - Irvin Plant</u> |
| Applicant Address | 1 Camp Hollow Road West Mifflin, PA 15112 | Facility Address | Camp Hollow Road West Mifflin, PA 15122 |
| Applicant Contact | <u>Jonelle Scheetz</u> | Facility Contact | <u>Same as Applicant</u> |
| Applicant Phone | <u>412-675-7382</u> | Facility Phone | <u>Same as Applicant</u> |
| Applicant email | <u>JSScheetz@uss.com</u> | Facility email | <u>Same as Applicant</u> |
| Client ID | <u>80062</u> | Site ID | <u>194251</u> |
| SIC Code | <u>3312</u> | Municipality | <u>West Mifflin Borough</u> |
| SIC Description | <u>Manufacturing - Blast Furnaces and Steel Mills</u> | County | <u>Allegheny</u> |
| Date Application Received | <u>January 28, 2010</u> | EPA Waived? | <u>No</u> |
| Date Application Accepted | <u>March 16, 2010</u> | If No, Reason | <u>Major Facility</u> |
| Purpose of Application | <u>Renewal NPDES Permit coverage</u> | | |

Summary of Review



The Department received an NPDES Permit renewal application from United States Steel Corporation for its Mon Valley Works Irvin Plant (Irvin) on January 28, 2010. The site is a steel mill with a SIC code of 3312, Steel Works, Blast Furnaces and Rolling Mills. The site is a steel finishing facility with operations consisting of a hot strip mill, acid pickling, cold forming and galvanizing.

The site has five outfalls that discharge to the Monongahela River, designated in 25 Pa Code Chapter 93 as a Warm Water Fishery. The site also has five internal monitoring points.

Outfall 001 discharges the wastewater from IMP 101, 201, 301, 601, and 701, blowdown from the NCCW recycle system, back-up strainer backwash, emergency overflow, NCCW, Boiler Blowdown, and Stormwater. Outfall 001 previously discharged wastewater via MP 401, which collected and treated the Nickel Terne Line process wastewater. The Nickel Terne Line (Electrolytic Plating Line) has been permanently shut down, therefore, IMP 401 will be removed in this renewal permit. IMP 501 has also been eliminated. IMP 501 was the discharge from the Hot Strip Mill Cooling Pond Emergency Overflow but has since been rerouted to the South WWTP. However, the cooling pond has not been used for several years. IMP 501 will be removed from this renewal permit.

IMP 101 collects and treats sanitary sewage. The treatment system at IMP 101 (Sanitary WWTP) consist of solids setting (2 Imhoff Tanks in parallel), trickling filter, and disinfection with sodium hypochlorite.

IMP 201 collects and treats wastewater from various production lines subject to Federal Effluent Limitation Guidelines (ELGs), miscellaneous contact water, non-contact cooling water, boiler blowdown, boiler condensate, boiler feedwater

| Approve | Deny | Signatures | Date |
|---------|------|--|---------------------|
| X | |  Adam Olesnak, P.E. / Environmental Engineer | September 26, 2024, |
| X | |  Michael E. Fifth, P.E. / Environmental Engineer Manager | September 26, 2024 |

Summary of Review

treatment wastewater, waste oil wastewater, groundwater, stormwater, acid seep collection system wastewater, and the discharge from the South Taylor Environmental Park (STEP). The discharges from STEP are untreated residual waste landfill leachate, treated hazardous landfill leachate, and acid mine drainage. STEP is a captive landfill USS used for the disposal of various steel manufacturing wastes streams (i.e. combustion residuals, metallurgical process residuals, sludges and scales, etc.). The various production lines that are routed to the treatment system that discharge via IMP 201 are:

- The 64-inch Continuous Pickle Production line (Hydrochloric Acid Pickling Rinse water and one fume scrubber), which is subject to 40 CFR 420.94(b)(2) and 420.94(b)(4).
- The 84-inch Continuous Pickle Production line (Hydrochloric Acid Pickling Rinse water and one fume scrubber), which is subject to 40 CFR 420.92(b)(2) and 420.92(b)(4).
- The Continuous Annealing Line (Alkaline Cleaning of Strip), which is subject to 40 CFR 420.112(b) and 420.113(b).
- The Cold Reduction Mill (Cold Rolling of Steel in a five-stand recirculating mill), which is subject to 40 CFR 420.102(a)(2) and 420.103(a)(2).
- The No. 1 Galvanize Line (Hot Coating of Steel Strip), which is subject to 40 CFR 420.122(a)(1) and 420.123(a)(1).
- The No. 2 Galvanize Line (Alkaline Cleaning of Steel Strip, Hot Coating of Steel Strip and one fume scrubber), which is subject to 40 CFR 420.112(b), 420.113(b), 420.122(a)(1), 420.122(c), 420.123(a)(1), and 420.123(c).
- The Temper Mill (Cold Rolling of Steel in Single-stand Direct Application Mill), which is subject to 40 CFR 420.102(a)(4) and 420.103(a)(4).

The treatment system at IMP 201 (South WWTP) consists of a waste oil treatment system (phase separation, oil skimmers, and re-use of reclaimed oil), equalization, neutralization, chemical precipitation, flocculation, and clarification (3 clarifiers in parallel).

As described above, IMP 201 is the monitoring point for the South WWTP, which collects and treats various wastewater streams including wastewater subject to ELGs, contact and non-contact cooling water, waste oil wastewater, untreated residual landfill leachate, treated hazardous landfill leachate, and various other non-process wastewater. The limitations that apply to wastewaters that are subject to ELGs should apply to those wastewaters before comingling with other wastewaters. In other words, dilution shouldn't be used to treat or meet the limitations from the ELGs. However, all of the wastewater at the South WWTP are combined and treated together. The Department can use the flow rates of each waste stream, prior to commingling, to adjust the loading limits and concentration limits to consider dilution. Additionally, some of the other waste streams may contain parameters that have limitations from the ELG that add to the discharge load but were not considered in the total loading limit. Therefore, the Department can increase the loading for a parameter present in a non-process waste stream by using the flow rate of the waste stream and the concentration in the waste stream or an applicable concentration limit for that wastewater. However, at this point in time, the Department does not have the flow data of each individual waste stream that is collected and treated at the South WWTP; therefore, the Department is requesting that this information be collected during this permit term and submitted with the next renewal application. The Department has included in Part C of the Draft Permit a requirement to conduct a Wastewater Source Flow Study. As part of the flow study, the permittee shall monitor the influent flow of the various waste streams separately before comingling together for treatment. The study should contain at least two years' worth of flow data; noting the estimated average flow rate of each waste stream that is treated in the South WWTP on a monthly basis to determine a long-term average flow rate of each waste stream. The flow study shall be submitted to the Department, with the renewal application, at least 180 days prior to the expiration date of this permit.

IMP 301 collects and treats the Carbon Plate Mill hot forming operations wastewater, miscellaneous contact water, filter backwash. The 80" Hot Strip Mill (Carbon Plate Mill Hot Forming Operations) is subject to 40 CFR 420.72(c)(1). The treatment system at IMP 301 (North WWTP) consists of sedimentation (2 scale pits with oil skimmers), flocculation, clarification (2 clarifiers in parallel) and sand filtration. Solids handling consist of clarifier, thickening and solids dewatering via centrifuge or vacuum filter. Skimmed oil is collected and directed to the waste oil treatment system at IMP 201.

IMP 601 is the discharge from the Hot Strip Mill North Scale Pit Emergency Overflow and miscellaneous contact water.

IMP 701 is the discharge from the Hot Strip Mill South Scale Pit Emergency Overflow and miscellaneous contact water.

Summary of Review

Outfall 002 discharges the Travel Screen Backwash.

Outfall 003 discharges NCCW, Boiler Blowdown, and Stormwater.

Outfall 004 discharges Stormwater.

Outfall 005 discharges Stormwater.

Clean Water Act § 316(b) – Cooling Water Intake Structures

On August 15, 2014, EPA promulgated Clean Water Act Section 316(b) regulations applicable to cooling water intake structures. The regulations established best technology available (“BTA”) standards to reduce impingement mortality and entrainment of all life stages of fish and shellfish at existing power generating and manufacturing facilities. The Final Rule took effect on October 14, 2014. Regulations implementing the 2014 Final Rule (and the previously promulgated Phase I Rule) are provided in 40 CFR Part 125, Subparts I and J for new facilities and existing facilities, respectively. Associated NPDES permit application requirements for facilities with cooling water intake structures are provided in 40 CFR Part 122, Subpart B – Permit Application and Special NPDES Program Requirements (§ 122.21(r)).

The Irvin Plant is an “existing facility” as defined in 40 CFR § 125.92(k). As an existing facility, Irvin is subject to 40 CFR Part 125, Subpart J – Requirements Applicable to Cooling Water Intake Structures for Existing Facilities Under Section 316(b) of the Clean Water Act (§§ 125.90 – 125.99) if the facility meets the rule’s applicability criteria. Pursuant to the applicability criteria given by § 125.91(a), Irvin is subject to the requirements of §§ 125.94 – 125.99 if:

- (1) The facility is a point source;
- (2) The facility uses or proposes to use one or more cooling water intake structures with a cumulative design intake flow (DIF) of greater than 2 million gallons per day (mgd) to withdraw water from waters of the United States; and
- (3) Twenty-five percent or more of the water the facility withdraws on an actual intake flow basis is used exclusively for cooling purposes.

Irvin is a point source as defined in 40 CFR § 122.2. Irvin uses one cooling water intake structure with a cumulative Design Intake Flow greater than 2 MGD (86.40 MGD). And Irvin uses more than 25% of the water it withdraws for cooling purposes, thus exceeding the 25% applicability threshold. Thus, Irvin is subject to the requirements of §§ 125.94 – 125.99.

Water is withdrawn from the Monongahela River for the Irvin Pant through a shoreline intake structure located on the western bank of the Monongahela River between river mile 17 and 18, known as the Irvin River Pump House (RPH). The RPH provides process and cooling water for once-through cooling for the facility. Water is withdrawn and discharged into the Monongahela River 365 days per year. The invert elevation of the RPH is 713 ft. The normal water elevation is 718.8 feet, which is also reported as the low water elevation. The RPH consists of a concrete structure approximately 127 ft in length and 30 ft wide that houses the intake pumps. A 28-ft section of the structure is flushed with the river and contains the trash bars and traveling screens. Water is withdrawn through a series of three separate openings that are protected by trash bars and a floating skimmer. The trash bars are constructed of 0.5 in. thick steel bars with 2.5-inch openings between the bars. Each of the three trash bars is approximately 8 feet wide. Water withdrawn through the trash bars is directed through intake openings that are each 4 feet wide by 5 feet high that lead to a screen chamber equipped with a traveling water screen, three in total. The traveling screens are through-flow with 0.375-inch wire mesh openings. Each screen panel is approximately 6 feet wide by 2 feet high, with an overall channel depth of 46 feet from the CWIS intake elevation of 713 feet to the deck/operating floor elevation of 759 feet. Each screen chamber then discharges through another 4-foot wide by 5-foot high opening into a common suction tunnel that feed the pumps. There are 5 pump systems or stations that pump water to the facility for use. Each pump station consists of two pumps in series, one low stage and one high stage. Each pump is rated for 12,000 gpm. Two pump stations are in operation continuously under normal conditions. Occasionally a third pump station may be used depending on flow demand. Flow from the pumps are regulated via cone valves and bypass valves. Excess water from the two pumps is bypassed back to the suction tunnel.

No physical studies were performed to determine the intake area of influence (AOI) within the waterbody. A desktop analysis was performed to calculate the approximate AOI within the 0.5 feet per second velocity contour. EPA considers a velocity of 0.5 fps to be a de minimis value relative to impingement concerns because fish have the swimming ability to overcome this

Summary of Review

velocity and avoid impingement. Based on the physical dimensions of the CWIS, the DIF, 5-year minimum AIF, and assuming the water is at low level, velocities have been computed at the face of the CWIS. At DIF flow of 86.40 MGD, the water velocity at the face of the intake is approximately 0.89 fps and the AOI extends approximately 4.5 feet into the water body past the face of the intake. At the 5-year maximum daily AIF of 51.84, the velocity at the face if the CWIS is approximately 0.53 fps and the AOI extends less than 0.5 feet into the waterbody. During typical operations with two pumps operating at a daily AIF of 34.6 MGD, the velocity at the face of the CWIS is approximately 0.36 fps and the AOI does not extend past the face of the intake. The design through-screen velocity was calculated to be 2.14 fps, the max daily actual intake velocity was calculated to be 1.28 fps, and the typical actual intake velocity was calculated to be 0.85 fps.

No impingement or entrainment data have been collected at the Irvin Plant intake. However, fisheries information is available from Braddock Pool of the Monongahela River and impingement and entrainment data are available from other facilities withdrawing from the Monongahela River nearby. These sources were used to identify taxa in the vicinity of the CWIS and those most susceptible to impingement and entrainment. USS Irvin and USS Clairton both withdraw from the Braddock Pool and have a shoreline CWIS, trash racks/bars, and traveling water screens. Elrama Generating Station and Mitchell Power Station historically withdrew from the Elizabeth Pool, directly upstream of the Braddock Pool. The results of the impingement and entrainment studies at these facilities reflect the species abundant in the Monongahela River that are susceptible to impingement or entrainment. However, design and actual intake flows differ among the facilities and the raw numbers are not necessarily representative of the magnitude of impingement or entrainment at Irvin.

USS requests that the Department, in accordance with 40 CFR 125.95(a)(2) establish an alternate schedule for the submission of the information required in 40 CFR 122.21(r) when USS applies for a subsequent permit. USS believes that the Irvin permit falls under this provision of the Federal Regulations and it is not possible for USS to develop the required information prior to the current renewal.

The following modified cooling water intake structure requirements will be included in Part C of the Draft permit:

COOLING WATER INTAKE STRUCTURE – Clean Water Act § 316(b)

- A. Based upon information provided by the permittee, the Department has made a determination that the permittee operates interim Best Technology Available (BTA) to comply with the impingement and entrainment mortality standard based upon available information at the time of permit issuance. This interim BTA determination may be revised upon submission of additional information by the permittee with the NPDES permit renewal application. Revisions to the BTA determination shall be effective only through amendment or renewal of the NPDES permit.

To comply with the interim BTA determination, U.S. Steel shall under normal operating conditions Operate the Irvin River Pump House (RPH) with a maximum actual through screen velocity of 1.5 fps. To document compliance with the interim BTA determination for this permit term, cooling water intake flow and through screen velocity (if applicable) will be calculated in the Cooling Water Intake Monitoring Supplemental Report (3800-FM-BCW0010) by U.S. Steel once per month and submitted to the Department along with the monthly eEDMR. If U.S. Steel reports an interim BTA through screen velocity greater than 1.5 fps for RPH, and contends that such through screen velocity occurred under non-normal operating conditions, then U.S. Steel shall provide the Department, along with the monthly eEDMR, with an explanation as to why the through screen velocity was greater than the identified interim BTA stated above, what the non-normal operating condition was, why that condition is non-normal, how frequently that condition is expected to reoccur, and why that condition caused such a velocity.

- B. Nothing in this permit authorizes a take of endangered or threatened species under the Endangered Species Act.
- C. Technology and operational measures currently employed at the cooling water intake structures must be operated in a way that minimizes impingement mortality and entrainment to the fullest extent practicable.
- D. The location, design, construction or capacity of the intake structure(s) may not be altered without prior approval of DEP.
- E. In accordance with 40 CFR § 125.95(a)(2), an alternate schedule is provided for the permittee to submit the information required by 40 CFR § 122.21(r). The permittee shall submit the information specified below with its permit renewal application due 180 days prior to the permit expiration date of the permit.

Summary of Review

1. Source water physical data.
2. Cooling water intake structure data.
3. Source water biological baseline characterization data.
4. Cooling water system data.
5. Chosen method(s) of compliance with impingement mortality standard from 40 CFR § 125.94(c).
6. Entrainment performance studies.
7. Operational status.

F. If the facility covered by this permit withdraws greater than 125 MGD on an Actual Intake Flow basis as defined in 40 CFR § 125.92, the permittee must submit the applicable information in 40 CFR §122.21(r)(9) – (r)(13) with the subsequent permit renewal application, as follows:

1. Entrainment Characterization Study.
2. Comprehensive Technical Feasibility and Cost Evaluation Study (including, but not limited to, evaluations of closed-cycle recirculating cooling, fine mesh screens with a mesh size of 2 mm or less, alternate sources of cooling water, water reuse, variable speed pumps, variable frequency drives, and seasonal flow reductions).
3. Benefits Valuation Study.
4. Non-Water Quality Environmental and Other Impacts Study.
5. Peer Review, completed by peer reviewer(s) approved by DEP.

G. If the facility covered by this permit withdraws less than or equal to 125 MGD on an Actual Intake Flow basis as defined in 40 CFR § 125.92, the permittee must submit an entrainment reduction technology evaluation with the subsequent permit renewal application, which must include at a minimum, an evaluation of the feasibility, cost estimates, and environmental impacts of reducing intake flow using alternate sources of cooling water, water reuse, closed-cycle recirculating cooling; and fine mesh screens.

H. If DEP requests additional information to make a BTA determination, the permittee shall submit information within 30 days unless a different time frame is approved by DEP.

I. If DEP determines the methods to meet impingement and entrainment BTA requirements are not sufficient, the permittee shall employ additional controls to reduce adverse impacts from impingement and entrainment.

J. The permittee shall, on an annual basis, submit a report describing any modifications to the operation of any unit at the facility that impacts cooling water withdrawals or operation of the cooling water intake structure(s) during a calendar year. If not applicable, the permittee shall submit a statement certifying that no modifications have occurred in lieu of a report. The annual report or statement is due by January 28 of each year.

K. The permittee shall retain data and other records for any information developed pursuant to Section 316(b) of the Clean Water Act for a minimum of ten years.

L. New Units - The permittee must submit applicable information in 40 CFR §122.21(r) at least 180 days prior to the planned commencement of cooling water withdrawals associated with the operation of a new unit (as defined in 40 CFR §125.92(u)).

Summary of Review

The permittee has three open violations. All three violations are with the Southwest Regional Office Tanks Program.

The site was last inspected on February 20, 2024; one violation was noted, but has since been resolved.

Draft Permit Issuance is recommended.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Discharge, Receiving Waters and Water Supply Information

| | | | |
|---|---|------------------------------|---------------------------|
| Outfall No. | 001 (IMP 101, 201, 301, 601, and 701) | Design Flow (MGD) | 23.6 |
| Latitude | 40° 20' 14.3" | Longitude | -79° 53' 41.3" |
| Quad Name | Glassport | Quad Code | 1606 |
| Wastewater Description: | IW Process Effluent with ELG, Treated Sewage, Treated Hazardous Waste Leachate, Residual Waste Leachate, Acid Seep Collection, AMD, Waste Oil Wastewater, NCCW, Cooling Tower Blowdown, Boiler Blowdown, Emergency Overflow, and Stormwater | | |
| Receiving Waters | Monongahela River (WWF) | Stream Code | 37185 |
| NHD Com ID | 99408282 | RMI | 17.53 |
| Drainage Area | 5410 | Yield (cfs/mi ²) | 0.102 |
| Q ₇₋₁₀ Flow (cfs) | 550 | Q ₇₋₁₀ Basis | US Army Corp of Engineers |
| Elevation (ft) | 712 | Slope (ft/ft) | 0.0001 |
| Watershed No. | 19-C | Chapter 93 Class. | WWF |
| Existing Use | | Existing Use Qualifier | |
| Exceptions to Use | | Exceptions to Criteria | |
| Assessment Status | Impaired | | |
| Cause(s) of Impairment | Polychlorinated Biphenyls (PCBS) | | |
| Source(s) of Impairment | Source Unknown | | |
| TMDL Status | Final | Name | Monongahela River TMDL |
| Nearest Downstream Public Water Supply Intake | PA American Water Company - Pittsburgh | | |
| PWS Waters | Monongahela River | Flow at Intake (cfs) | 1,230 |
| PWS RMI | 4.6 | Distance from Outfall (mi) | 12.77 |

Discharge, Receiving Waters and Water Supply Information

| | | | |
|--|----------------------------------|--|---------------------------|
| Outfall No. | 002 | Design Flow (MGD) | Varies |
| Latitude | 40° 20' 2.5" | Longitude | -79° 53' 48.2" |
| Quad Name | Glassport | Quad Code | 1606 |
| Wastewater Description: Travel Screen Backwash | | | |
| Receiving Waters | Monongahela River (WWF) | Stream Code | 37185 |
| NHD Com ID | 99408282 | RMI | 17.75 |
| Drainage Area | 5410 | Yield (cfs/mi ²) | 0.102 |
| Q ₇₋₁₀ Flow (cfs) | 550 | Q ₇₋₁₀ Basis | US Army Corp of Engineers |
| Elevation (ft) | 712 | Slope (ft/ft) | 0.0001 |
| Watershed No. | 19-C | Chapter 93 Class. | WWF |
| Existing Use | | Existing Use Qualifier | |
| Exceptions to Use | | Exceptions to Criteria | |
| Assessment Status | Impaired | | |
| Cause(s) of Impairment | Polychlorinated Biphenyls (PCBS) | | |
| Source(s) of Impairment | Source Unknown | | |
| TMDL Status | Final | Name | Monongahela River TMDL |
| Nearest Downstream Public Water Supply Intake | | PA American Water Company - Pittsburgh | |
| PWS Waters | Monongahela River | Flow at Intake (cfs) | 1,230 |
| PWS RMI | 4.6 | Distance from Outfall (mi) | 12.77 |

Discharge, Receiving Waters and Water Supply Information

| | | | |
|---|----------------------------------|--|---------------------------|
| Outfall No. | 003 | Design Flow (MGD) | 1.72 |
| Latitude | 40° 19' 44.2" | Longitude | -79° 53' 59.9" |
| Quad Name | Glassport | Quad Code | 1606 |
| Wastewater Description: NCCW, Boiler Blowdown, and Stormwater | | | |
| Receiving Waters | Monongahela River (WWF) | Stream Code | 37185 |
| NHD Com ID | 99408282 | RMI | 18.1 |
| Drainage Area | 5410 | Yield (cfs/mi ²) | 0.102 |
| Q ₇₋₁₀ Flow (cfs) | 550 | Q ₇₋₁₀ Basis | US Army Corp of Engineers |
| Elevation (ft) | 712 | Slope (ft/ft) | 0.0001 |
| Watershed No. | 19-C | Chapter 93 Class. | WWF |
| Existing Use | | Existing Use Qualifier | |
| Exceptions to Use | | Exceptions to Criteria | |
| Assessment Status | Impaired | | |
| Cause(s) of Impairment | Polychlorinated Biphenyls (PCBS) | | |
| Source(s) of Impairment | Source Unknown | | |
| TMDL Status | Final | Name | Monongahela River TMDL |
| Nearest Downstream Public Water Supply Intake | | PA American Water Company - Pittsburgh | |
| PWS Waters | Monongahela River | Flow at Intake (cfs) | 1,230 |
| PWS RMI | 4.6 | Distance from Outfall (mi) | 12.77 |

Discharge, Receiving Waters and Water Supply Information

| | | | |
|---|--|------------------------------|---------------------------|
| Outfall No. | 004 | Design Flow (MGD) | Varies |
| Latitude | 40° 19' 51.5" | Longitude | -79° 53' 52.4" |
| Quad Name | Glassport | Quad Code | 1606 |
| Wastewater Description: | Stormwater | | |
| Receiving Waters | Monongahela River (WWF) | Stream Code | 37185 |
| NHD Com ID | 99408282 | RMI | 17.9 |
| Drainage Area | 5410 | Yield (cfs/mi ²) | 0.102 |
| Q ₇₋₁₀ Flow (cfs) | 550 | Q ₇₋₁₀ Basis | US Army Corp of Engineers |
| Elevation (ft) | 712 | Slope (ft/ft) | 0.0001 |
| Watershed No. | 19-C | Chapter 93 Class. | WWF |
| Existing Use | | Existing Use Qualifier | |
| Exceptions to Use | | Exceptions to Criteria | |
| Assessment Status | Impaired | | |
| Cause(s) of Impairment | Polychlorinated Biphenyls (PCBs) | | |
| Source(s) of Impairment | Source Unknown | | |
| TMDL Status | Final | Name | Monongahela River TMDL |
| Nearest Downstream Public Water Supply Intake | PA American Water Company - Pittsburgh | | |
| PWS Waters | Monongahela River | Flow at Intake (cfs) | 1,230 |
| PWS RMI | 4.6 | Distance from Outfall (mi) | 12.77 |

Discharge, Receiving Waters and Water Supply Information

| | | | |
|---|--|------------------------------|---------------------------|
| Outfall No. | 005 | Design Flow (MGD) | Varies |
| Latitude | 40° 20' 27.3" | Longitude | -79° 54' 5.9" |
| Quad Name | Glassport | Quad Code | 1606 |
| Wastewater Description: | Stormwater | | |
| Receiving Waters | Monongahela River (WWF) | Stream Code | 37185 |
| NHD Com ID | 99408282 | RMI | 17.37 |
| Drainage Area | 5410 | Yield (cfs/mi ²) | 0.102 |
| Q ₇₋₁₀ Flow (cfs) | 550 | Q ₇₋₁₀ Basis | US Army Corp of Engineers |
| Elevation (ft) | 712 | Slope (ft/ft) | 0.0001 |
| Watershed No. | 19-C | Chapter 93 Class. | WWF |
| Existing Use | | Existing Use Qualifier | |
| Exceptions to Use | | Exceptions to Criteria | |
| Assessment Status | Impaired | | |
| Cause(s) of Impairment | Polychlorinated Biphenyls (PCBS) | | |
| Source(s) of Impairment | Source Unknown | | |
| TMDL Status | Final | Name | Monongahela River TMDL |
| Nearest Downstream Public Water Supply Intake | PA American Water Company - Pittsburgh | | |
| PWS Waters | Monongahela River | Flow at Intake (cfs) | 1,230 |
| PWS RMI | 4.6 | Distance from Outfall (mi) | 12.77 |

Development of Effluent Limitations

| | | | |
|--|---------------|--------------------------|----------------|
| Outfall No. | 001 | Design Flow (MGD) | 23.6 |
| Latitude | 40° 20' 14.3" | Longitude | -79° 53' 41.3" |
| Wastewater Description: IW Process Effluent with ELG, Treated Sewage, Treated Hazardous Waste Leachate, Residual Waste Leachate, Acid Seep Collection, AMD, Waste Oil Wastewater, NCCW, Cooling Tower Blowdown, Boiler Blowdown, Emergency Overflow, and Stormwater | | | |

Technology-Based Limitations

Sewage Minimum Technology and BPJ Standards:

The sewage limitations will be evaluated and imposed at the Internal Monitoring Point, IMP 101.

Federal Effluent Limitation Guidelines (ELGs)

The ELG limitations will be evaluated and imposed at the Internal Monitoring Points (IMP 201 and 301).

Regulatory Effluent Standards and Monitoring Requirements

Flow monitoring is required pursuant to 25 Pa. Code § 92a.61(d)(1).

As oil-bearing wastewaters, discharges from Outfall 001 are subject to effluent standards for oil and grease from 25 Pa. Code § 95.2(2).

Pennsylvania regulations at 25 Pa. Code § 92a.48(b) require the imposition of technology-based TRC limits for facilities that use chlorination and that are not already subject to TRC limits based on applicable federal ELGs or a facility-specific BPJ evaluation.

Effluent standards for pH are also imposed on industrial wastes by 25 Pa. Code § 95.2(1).

Temperature limits will be imposed per the Department's "*Implementation Guidance for Temperature Criteria*." As a policy, DEP normally imposes a maximum temperature limit of 110°F on discharges that contain residual heat. The limit is intended as a safety measure to protect sampling personnel or anyone who may come into contact with the heated discharge where it enters the receiving water.

Table 1: Regulatory Effluent Standards and Monitoring Requirements for Outfall 001

| Parameter | Monthly Average | Daily Maximum | IMAX | Units |
|-------------------------|--|---------------|------|-------|
| Flow | Monitor and Report | | XXX | MGD |
| Oil & Grease | 15 | 30 | XXX | mg/L |
| Total Residual Chlorine | 0.5 | 1.0 | XXX | mg/L |
| Temperature | XXX | XXX | 110 | °F |
| pH | Not less than 6.0 nor greater than 9.0 | | | S.U. |

Per- and Polyfluoroalkyl Substances (PFAS)

In February 2024, DEP implemented a new monitoring initiative for PFAS consistent with an EPA memorandum that provides guidance to states for addressing PFAS discharges. PFAS are a family of thousands of synthetic organic chemicals that contain a chain of strong carbon-fluorine bonds. Many PFAS are highly stable, water- and oil-resistant, and exhibit other properties that make them useful in a variety of consumer products and industrial processes. PFAS are resistant to biodegradation, photooxidation, direct photolysis, and hydrolysis and do not readily degrade naturally; thus, many PFAS accumulate over time. According to the United States Department of Health and Human Services, Agency for Toxic Substances and Disease Registry (ATSDR), the environmental persistence and mobility of some PFAS, combined with decades of widespread use, have resulted in their presence in surface water, groundwater, drinking water, rainwater, soil, sediment, ice caps, outdoor and indoor air, plants, animal tissue, and human blood serum across the globe. ATSDR also reported that exposure to certain PFAS can lead to adverse human health impacts. Due to their durability, toxicity, persistence, and pervasiveness, PFAS have emerged as potentially significant pollutants of concern.

In accordance with Section II.I of DEP's "Standard Operating Procedure (SOP) for Clean Water Program – Establishing Effluent Limitations for Individual Industrial Permits" [SOP No. BCW-PMT-032] and under the authority of 25 Pa. Code §

92a.61(b), DEP has determined that monitoring for a subset of common/well-studied PFAS including Perfluorooctanoic acid (PFOA), Perfluorooctanesulfonic acid (PFOS), Perfluorobutanesulfonic acid (PFBS), and Hexafluoropropylene oxide dimer acid (HFPO-DA) is necessary to help understand the extent of environmental contamination by PFAS in the Commonwealth and the extent to which point source dischargers are contributors. SOP BCW-PMT-032 directs permit writers to consider special monitoring requirements for PFOA, PFOS, PFBS, and HFPO-DA in the following instances:

- a. If sampling that is completed as part of the permit renewal application reveals a detection of PFOA, PFOS, HFPO-DA or PFBS (any of these compounds), the application manager will establish a quarterly monitoring requirement for PFOA, PFOS, HFPO-DA and PFBS (all of these compounds) in the permit.
- b. If sampling that is completed as part of the permit renewal application demonstrates non-detect values at or below the Target QLs for PFOA, PFOS, HFPO-DA and PFBS (all of these compounds in a minimum of 3 samples), the application manager will establish an annual monitoring requirement for PFOA, PFOS, HFPO-DA and PFBS in the permit.
- c. In all cases the application manager will include a condition in the permit that the permittee may cease monitoring for PFOA, PFOS, HFPO-DA and PFBS when the permittee reports non-detect values at or below the Target QL for four consecutive monitoring periods for each PFAS parameter that is analyzed. Use the following language: The permittee may discontinue monitoring for PFOA, PFOS, HFPO-DA, and PFBS if the results in 4 consecutive monitoring periods indicate non-detects at or below Quantitation Limits of 4.0 ng/L for PFOA, 3.7 ng/L for PFOS, 3.5 ng/L for PFBS and 6.4 ng/L for HFPO-DA. When monitoring is discontinued, permittees should enter a No Discharge Indicator (NODI) Code of "GG" on DMRs.

Irvin's application was submitted before the NPDES permit application forms were updated to require sampling for PFOA, PFOS, PFBS, and HFPO-DA. Also, according to EPA's guidance, Irvin does not operate in one of the industries EPA expects to be a source for PFAS. Therefore, annual reporting of PFOA, PFOS, PFBS, and HFPO-DA will be required consistent with Section II.I.b of SOP BCW-PMT-032. Even though Irvin did not report results for PFOA, PFOS, PFBS, and HFPO-DA on the permit application, as a facility operating in a suspected non-source industry, it is reasonable to conclude that if Irvin did report results for PFOA, PFOS, PFBS, and HFPO-DA on the application, the results may have been non-detect values, which would subject Irvin to the annual monitoring requirements described in Section II.I.b of the SOP.

As stated in Section II.I.c of the SOP, if non-detect values at or below DEP's Target QLs are reported for four consecutive monitoring periods (i.e., four consecutive annual results in Irvin's case), then the monitoring may be discontinued.

Water Quality-Based Limitations

Toxics Management Spread Sheet

The Department of Environmental Protection (DEP) has developed the DEP Toxics Management Spreadsheet ("TMS") to facilitate calculations necessary for completing a reasonable potential (RP) analysis and determining water quality-based effluent limitations for discharges of toxic pollutants. The Toxics Management Spreadsheet is a macro-enabled Excel binary file that combines the functions of the PENTOXSD model and the Toxics Screening Analysis spreadsheet to evaluate the reasonable potential for discharges to cause excursions above water quality standards and to determine WQBELs. The Toxics Management Spread Sheet is a single discharge, mass-balance water quality calculation spread sheet that includes consideration for mixing, first-order decay and other factors to determine recommended WQBELs for toxic substances and several non-toxic substances. Required input data including stream code, river mile index, elevation, drainage area, discharge name, NPDES permit number, discharge flow rate and the discharge concentrations for parameters in the permit application or in DMRs, which are entered into the spread sheet to establish site-specific discharge conditions. Other data such as low flow yield, reach dimensions and partial mix factors may also be entered to further characterize the conditions of the discharge and receiving water. Discharge concentrations for the parameters are chosen to represent the "worst case" quality of the discharge (i.e., maximum reported discharge concentrations). The spread sheet then evaluates each parameter by computing a Waste Load Allocation for each applicable criterion, determining a recommended maximum WQBEL and comparing that recommended WQBEL with the input discharge concentration to determine which is more stringent. Based on this evaluation, the Toxics Management Spread sheet recommends average monthly and maximum daily WQBELs.

Reasonable Potential Analysis and WQBEL Development for Outfall 001

Discharges from Outfall 001 are evaluated based on concentrations reported on the application and on DMRs; data from those sources are entered into the Toxics Management Spread Sheet. The maximum reported value of the parameters

from the application form or from previous DMRs is used as the input concentration in the Toxics Management Spread Sheet. All toxic pollutants whose maximum concentrations, as reported in the permit application or on DMRs, are greater than the most stringent applicable water quality criterion are considered to be pollutants of concern. [This includes pollutants reported as "Not Detectable" or as "<MDL" where the method detection limit for the analytical method used by the applicant is greater than the most stringent water quality criterion]. The Toxics Management Spread Sheet is run with the discharge and receiving stream characteristics shown in Table 2. For IW discharges, the design flow used in modeling is the average flow during production or operation taken from the permit application. Pollutants for which water quality standards have not been promulgated (e.g., TSS, oil and grease) are excluded from the analysis. All the parameters are evaluated using the model to determine the water quality-based effluent limits applicable to the discharge and the receiving stream. The spreadsheet then compares the reported discharge concentrations to the calculated water quality-based effluent limitations to determine if a reasonable potential exists to exceed the calculated WQBELs. Effluent limitations are established in the draft permit where a pollutant's maximum reported discharge concentration equals or exceeds 50% of the WQBEL. For non-conservative pollutants, monitoring requirements are established where the maximum reported concentration is between 25% - 50% of the WQBEL. For conservative pollutants, monitoring requirements are established where the maximum reported concentration is between 10% - 50% of the WQBEL. The information described above including the maximum reported discharge concentrations, the most stringent water quality criteria, the pollutant-of-concern (reasonable potential) determinations, the calculated WQBELs, and the WQBEL/monitoring recommendations are displayed in the Toxics Management Spread Sheet in Attachment B of this Fact Sheet. The water quality-based effluent limitations and monitoring requirements that are recommended by the Toxics Management Spread Sheet are displayed below in Table 3.

Table 2: TMS Inputs for Outfall 001

| Parameter | Value |
|---------------------------------------|--------|
| River Mile Index | 17.53 |
| Discharge Flow (MGD) | 23.6 |
| Basin/Stream Characteristics | |
| Parameter | Value |
| Area in Square Miles | 5,410 |
| Q ₇₋₁₀ (cfs) | 550 |
| Low-flow yield (cfs/mi ²) | 0.102 |
| Elevation (ft) | 712 |
| Slope | 0.0001 |

Table 3: Water Quality Based Effluent Limitations at Outfall 001

| Parameters | Average Monthly | Daily Maximum | Discharge Concentration |
|----------------------------|-----------------|---------------|-------------------------|
| Total Aluminum (mg/L) | 1.25 | 1.95 | 1.75 |
| Hexavalent Chromium (µg/L) | Report | Report | 3.9 |
| Total Copper (µg/L) | Report | Report | 5.27 |
| Total Iron (mg/L) | Report | Report | 4.29 |
| Total Zinc (µg/L) | Report | Report | 43.6 |

Total Residual Chlorine

To determine if WQBELs are required for discharges containing total residual chlorine (TRC), a discharge evaluation is performed using a DEP program called TRC_CALC created with Microsoft Excel for Windows. TRC_CALC calculates TRC Waste Load Allocations (WLAs) through the application of a mass balance model which considers TRC losses due to stream and discharge chlorine demands and first-order chlorine decay. Input values for the program include flow rates and chlorine demands for the receiving stream and the discharge, the number of samples taken per month, coefficients of TRC variability, partial mix factors, and an optional factor of safety. The mass balance model calculates WLAs for acute and chronic criteria

that are then converted to long term averages using calculated multipliers. The multipliers are functions of the number of samples taken per month and the TRC variability coefficients (normally kept at default values unless site specific information is available). The most stringent limitation between the acute and chronic long-term averages is converted to an average monthly limit for comparison to the BAT average monthly limit of 0.5 mg/l from 25 Pa. Code § 92a.48(b)(2). The more stringent of these average monthly TRC limitations is imposed in the permit. The results of the modeling, included in Attachment C, indicate that no WQBELs are required for TRC.

WQM 7.0 Water Quality Modeling Program

WQM 7.0 is a water quality modeling program for Windows that determines waste load allocations and effluent limitations for carbonaceous biochemical oxygen demand (CBOD5), ammonia nitrogen (NH3-N), and dissolved oxygen (DO) for single and multiple point-source discharge scenarios. To accomplish this, the model simulates two basic processes. In the NH3-N module, the model simulates the mixing and degradation of NH3-N in the stream and compares calculated instream NH3-N concentrations to NH3-N water quality criteria. In the DO module the model simulates the mixing and consumption of DO in the stream due to the degradation of CBOD5 and NH3-N and compares calculated instream DO concentrations to DO water quality criteria. WQM 7.0 then determines the highest pollutant loadings that the stream can assimilate while still meeting water quality criteria under design conditions. WQM 7.0 was run for Outfall 001 because the outfall discharge treated sewage wastewater. The WQM-7 model was run using the discharge and receiving stream characteristics shown in Table X above. The modeling results, which are included in Attachment D, indicate that WQBELs are required for CBOD5 and NH3-N during the summer; but no WQBELs are required for CBOD5 or NH3-H in the winter. The proposed summer limitations for CBOD5 are, 16.6 mg/L average monthly and 33.2 mg/L daily maximum. The proposed summer limitations for NH3-N are, 5.3 mg/L average monthly and 10.6 mg/L daily maximum. No WQBELs are required for dissolved oxygen. The summer limitations for CBOD5 and NH3-N will be imposed from May through September and a monitor and report requirement will be imposed from October through April.

Thermal WQBELs for Heated Discharges

Thermal WQBELs are evaluated using DEP's "Thermal Discharge Limit Calculation Spreadsheet" created with Microsoft Excel for Windows. The program calculates temperature WLAs through the application of a heat transfer equation, which takes two forms in the program depending on the source of the facility's cooling water. In Case 1, intake water to a facility is from the receiving stream. In Case 2, intake water is from a source other than the receiving stream (e.g., municipal water supply). The determination of which case applies to a given discharge is determined by the input data which include the receiving stream flow rate (Q_{7-10} or the minimum regulated flow for large rivers), the stream intake flow rate, external source intake flow rates, consumptive flow rates and site-specific ambient stream temperatures. Case 1 limits are generally expressed as heat rejection rates while Case 2 limits are usually expressed as temperatures.

Since the temperature criteria from 25 Pa. Code Chapter 93.7(a) are expressed on monthly and semi-monthly bases for three different aquatic life-uses—cold water fishes, warm water fishes and trout stocking—the program generates monthly and semi-monthly limits for each use. DEP selects the output that corresponds to the aquatic life-use of the receiving stream and consequently which limits apply to the discharge. Temperature WLAs are bounded by an upper limit of 110°F for the safety of sampling personnel and anyone who may come into contact with the heated discharge where it enters the receiving water. If no WLAs below 110°F are calculated, an instantaneous maximum limit of 110°F is recommended by the program.

Due to the nature of the discharges and their relative locations on the receiving stream, all heated discharges will be evaluated as one discharge to ensure the temperature criteria is met instream from all of the heated discharges and a combined flow of 25.32 MGD was used in the model. Discharges from Outfall 001 and Outfall 003 are classified under Case 1 because water is obtained via an intake structure owned by the permittee on the Monongahela River. The results of the thermal analysis, included in Attachment E, indicate that no WQBELs for temperature are required at Outfall 001. Therefore, the 110°F daily maximum temperature limit will be imposed at Outfall 001

Anti-backsliding:

Previous effluent limits and monitoring requirements can be used pursuant to EPA's anti-backsliding regulation, 40 CFR 122.44(l) and are displayed below in Table 4.

Table 4: Existing Effluent Limitation for Outfall 001

| Parameters | Mass (lb/day) | | Concentration (mg/L) | | | | Monitoring Requirements | |
|------------|-----------------|---------------|----------------------|-----------------|---------------|------------------|-------------------------|-------------|
| | Average Monthly | Daily Maximum | Minimum | Average Monthly | Daily Maximum | Instant. Maximum | Frequency | Sample Type |
| Flow (MGD) | Report | Report | XXX | XXX | XXX | XXX | 1/Week | Measure |

Table 4: Existing Effluent Limitation for Outfall 001

| Parameters | Mass (lb/day) | | Concentration (mg/L) | | | Monitoring Requirements | | |
|--------------------|-----------------|---------------|----------------------|-----------------|---------------|-------------------------|-----------|-------------|
| | Average Monthly | Daily Maximum | Minimum | Average Monthly | Daily Maximum | Instant. Maximum | Frequency | Sample Type |
| Temperature (°F) * | XXX | XXX | XXX | XXX | 110 | XXX | 1/Week | I-S |
| Oil and Grease | XXX | XXX | XXX | 15.0 | XXX | 30.0 | 1/Week | Grab |
| pH (S.U.) | XXX | XXX | 6.0 | XXX | 9.0 | XXX | 1/Week | Grab |

* There shall be no net addition of pollutants to non-contact cooling water over intake values except for heart and water conditioning additivities for which complete information was submitted in the appellation of is required to be submitted as a condition of this permit.

*For the purpose of determining compliance with any maximum daily temperature limitations in apart A of this permit and notwithstanding A.2.o of this permit, the temperature value shall consist of the average of three (30 individual immersion stabilization temperature measurements over a twenty-four hour period. The individual temperate measurement shall be taken at equal internals over the period as is practical and in no case shall any two individual temperature measurements be taken at less than a one (1) hour interval.

Proposed Effluent Limitations

The proposed effluent limitations for Outfall 001 are displayed in Table 5 below, they are the most stringent values from the above effluent limitation development.

Table 5: Proposed Effluent Limitation for Outfall 001

| Parameters | Mass (lb/day) | | Concentration (mg/L) | | | Monitoring Requirements | | |
|-------------------------------|-----------------|---------------|----------------------|-----------------|---------------|-------------------------|-----------|-------------|
| | Average Monthly | Daily Maximum | Minimum | Average Monthly | Daily Maximum | Instant. Maximum | Frequency | Sample Type |
| Flow (MGD) | Report | Report | XXX | XXX | XXX | XXX | 1/Week | Measure |
| Temperature (°F) | XXX | XXX | XXX | XXX | XXX | 110 | 1/Week | I-S |
| Total Residual Chlorine (TRC) | XXX | XXX | XXX | 0.5 | 1.0 | XXX | 1/Week | Grab |
| Oil and Grease | XXX | XXX | XXX | 15.0 | 30.0 | XXX | 1/Week | Grab |
| CBOD5 | | | | | | | 1/Week | Grab |
| May 1 – Sept 30 | XXX | XXX | XXX | 16.6 | 32.2 | XXX | | |
| Oct 1 – April 30 | XXX | XXX | XXX | Report | Report | XXX | | |
| NH3-N | | | | | | | 1/Week | Grab |
| May 1 – Sept 30 | XXX | XXX | XXX | 5.3 | 10.6 | XXX | | |
| Oct 1 – April 30 | XXX | XXX | XXX | Report | Report | XXX | | |
| Total Aluminum | XXX | XXX | XXX | 1.25 | 1.95 | XXX | 1/Week | Grab |
| Hexavalent Chromium | XXX | XXX | XXX | Report | Report | XXX | 1/Week | Grab |
| Total Copper | XXX | XXX | XXX | Report | Report | XXX | 1/Week | Grab |
| Total Iron | XXX | XXX | XXX | Report | Report | XXX | 1/Week | Grab |
| Total Zinc | XXX | XXX | XXX | Report | Report | XXX | 1/Week | Grab |
| PFOA (ng/L) | XXX | XXX | XXX | XXX | Monitor | XXX | 1/year | Grab |
| PFOS (ng/L) | XXX | XXX | XXX | XXX | Monitor | XXX | 1/year | Grab |
| PFBS (ng/L) | XXX | XXX | XXX | XXX | Monitor | XXX | 1/year | Grab |
| HFPO-DA (ng/L) | XXX | XXX | XXX | XXX | Monitor | XXX | 1/year | Grab |
| pH (S.U.) | XXX | XXX | 6.0 | XXX | XXX | 9.0 | 1/Week | Grab |

Final WQBEL Compliance Report and Interim Monitoring

The WQBELs listed in Table 5 above for Total Aluminum are new to Outfall 001. US Steel may not have the necessary controls in place to ensure compliance with the WQBELs upon permit issuance. Therefore, in accordance with 25 Pa. Code § 92a.51(a) of DEP's regulations, US Steel will be granted three years to come into compliance with the WQBELs. Because the new WQBELs will not be effective upon permit issuance, the permit will be tiered to have interim and final effluent limitations. For the first three years, Total Aluminum will have monitor and report requirements, and after three years, the WQBELs will take effect. Additionally, because the WQBELs were developed using the default or model-derived estimates, the permittee shall collect site-specific data and conduct a Toxics Reduction Evaluation (TRE). The site-specific data and TRE will be submitted to the Department as part of a Final WQBEL Compliance Report.

Development of Effluent Limitations

IMP No. 101
Latitude 40° 20' 15"
Wastewater Description: Treated Sewage

Design Flow (MGD) 0.048
Longitude -79° 53' 46"

Technology-Based Limitations - Sewage Minimum Technology and BPJ Standards:

The following are minimum technology based and BPJ standards for sewage discharges.

Table 6. Standard Sewage Tech Limits

| Parameter | Minimum | Average Monthly | Average Weekly | IMAX | Basis |
|---|---------|-----------------|------------------|--------|----------------|
| Flow (MGD) | XXX | Report | Report Max Daily | XXX | 92a.27, 92a.61 |
| CBOD5 (mg/L) | XXX | 25 | 40* | 50 | 92a.47 |
| TSS (mg/L) | XXX | 30 | 45* | 60 | 92a.47 |
| TRC (mg/L) | XXX | 0.5 | XXX | 1.6 | 92a.47 & 48 |
| NH3-N (mg/L) | XXX | 25 | XXX | 50 | BPJ |
| D.O. (mg/L) | 4.0 | XXX | XXX | XXX | BPJ |
| pH (SU) | 6.0 | XXX | XXX | 9.0 | 92a.47, 95.2 |
| Total N (mg/L) | XXX | Report | XXX | XXX | 92a.61 |
| Total P (mg/L) | XXX | Report | XXX | XXX | 92a.61 |
| Fecal Coliform May-Sept (no./100 ml) | XXX | 200 Geo Mean | XXX | 1,000 | 92a.47 |
| Fecal Coliform Oct-April (no./100 ml) | XXX | 2,000 Geo Mean | XXX | 10,000 | 92a.47 |

*Weekly average limits for CBOD5 and TSS will not be imposed where the sampling frequency is less than 1/week.

Water Quality-Based Limitations

A water quality analysis was not conducted at the internal monitoring point because water quality was evaluated at the discharge point, Outfall 001.

Anti-backsliding:

Previous effluent limits and monitoring requirements can be used pursuant to EPA's anti-backsliding regulation, 40 CFR 122.44(l) and are displayed below in Table 7.

Table 7: Existing Effluent Limitation for IMP 101

| Parameters | Mass (lb/day) | | Concentration (mg/L) | | | Monitoring Requirements | | |
|----------------------------|-----------------|---------------|----------------------|-----------------------------------|---------------|-------------------------|-----------|------------------|
| | Average Monthly | Daily Maximum | Minimum | Average Monthly | Daily Maximum | Instant. Maximum | Frequency | Sample Type |
| Flow (MGD) | Report | Report | XXX | XXX | XXX | XXX | 1/Week | Measure |
| CBOD 5-Day | XXX | XXX | XXX | 25.0 | 50.0 | 62.5*** | 1/Week | 8-hour Composite |
| Total Suspended Solids | XXX | XXX | XXX | 30.0 | 60.0 | 75.0*** | 1/Week | 8-hour Composite |
| Fecal Coliform | XXX | XXX | XXX | Refer to Condition No.2 in Part C | | | 1/Week | Grab |
| Total Residual Chlorine ** | XXX | XXX | XXX | 1.4 | XXX | 3.3 | 1/Week | Grab |
| pH (S.U.) | XXX | XXX | 6.0 | XXX | 9.0 | XXX | 1/Week | Grab |

*Refer to Condition No.7 in Part C

**Refer to Condition No.8 in Part C

***Refer to Condition No.9 in Part C

Condition C.7.

Collected screenings, slurries, sludges, and other solids shall be handled and disposed of in compliance with 25 Pa. Code, Chapters 271, 273, 275, 283, and 285 (related to permits and requirements for landfilling, land application, incineration and storage of sewage sludge) Federal Regulations 40 CFR 257, and the Federal Clean Water Act and its amendments.

Sludges and other solids shall be handled and disposed of in compliance with the Solids Waste Management Act of 1980 (Act 97) and with 25 Pa. Code Chapter 261, 262, 263 and 264 (related to permits and requirements for landfilling and storage of sewage sludge) Federal Regulations, the Federal Clean Water Act, RCRA and their amendments.

Sludges and other solids shall be handled and disposed of in compliance with the Solid Waste Management Act of 1980 (Act 97) and with 25 Pa. Code Chapters 287, 291, and 299 (related to residual waste generators) and 288 and 289 (related to residual waste landfills and impoundments) and the Federal Clean Water Act and its amendments.

Condition C.8.

The permittee will ensure that applied chlorine dosages, used for disinfection or other purposes, are optimized to the degree necessary such that the total residual chlorine in the discharge does not cause an adverse stream impact. In doing so, the permittee shall consider relevant factors affecting chlorine dosage, such as wastewater characteristics, mixing and contact times, desired result of chlorination, and expected impact on the receiving water body.

To reduce or eliminate the amount of chlorine discharged into water bodies, the permittee must: (1) improve/adjust process controls and (2) improve operation/maintenance practices.

If the Department determines or receives documented evidence levels of TRC in the permittee's effluent are causing adverse impacts in the receiving water, the permittee shall institute necessary additional steps to reduce or eliminate such impact.

Condition C.9.

Instantaneous maximum limitations are imposed to allow for a grab to be collected by the appropriate regulatory agency to determine compliance. The permittee is not required to monitor for the instantaneous maximum limitations. However, if grab samples are collected by the permittee, the results must be reported except for the results of individual grab collected by the permittee to comply with a sample type specified as 3/grabs/24 hours. These limits serve as a screening tool to assist field staff in enforcement decision-making. These limits are to be used as indicators to help determine the need for follow-up compliance inspections.

Proposed Effluent Limitations

The proposed effluent limitations for IMP 101 are displayed in Table 8 below, they are the most stringent values from the above effluent limitation development.

Table 8: Existing Effluent Limitation for IMP 101

| Parameters | Concentration (mg/L) | | | | | Monitoring Requirements | |
|---|----------------------|-------------------|----------------|---------------|--------|-------------------------|------------------|
| | Minimum | Average Monthly | Average Weekly | Daily Maximum | IMAX | Frequency | Sample Type |
| Flow (MGD) | XXX | Report | XXX | Report | XXX | 1/Week | Measure |
| CBOD5 (mg/L) | XXX | 25 | 40 | 50 | 62.5* | 1/Week | 8-hour Composite |
| TSS (mg/L) | XXX | 30 | 45 | 60 | 75.0* | 1/Week | 8-hour Composite |
| TRC (mg/L) | XXX | 0.5 | XXX | XXX | 1.6 | 1/Week | Grab |
| NH3-N (mg/L) | XXX | 25 | XXX | XXX | 50 | 1/Week | Grab |
| D.O. (mg/L) | 4.0 | XXX | XXX | XXX | XXX | 1/Week | Grab |
| pH (SU) | 6.0 | XXX | XXX | XXX | 9.0 | 1/Week | Grab |
| Total N (mg/L) | XXX | Report | XXX | XXX | XXX | 1/Week | Grab |
| Total P (mg/L) | XXX | Report | XXX | XXX | XXX | 1/Week | Grab |
| Fecal Coliform May-Sept (no./100 ml) | XXX | 200 Geo Mean | XXX | XXX | 1,000 | 1/Week | Grab |
| Fecal Coliform Oct-April (no./100 ml) | XXX | 2,000 Geo Mean | XXX | XXX | 10,000 | 1/Week | Grab |

*Instantaneous maximum limitations are imposed to allow for a grab sample to be collected by the appropriate regulatory agency to determine compliance. The permittee is not required to monitor for the instantaneous maximum limitations. However, if grab samples are collected by the permittee, the results must be reported.

Development of Effluent Limitations

IMP No. 201
Latitude 40° 20' 13"

Design Flow (MGD) 2.19
Longitude -79° 53' 50"

Wastewater Description: IW Process Effluent with ELG, Treated Hazardous Waste Leachate, Residual Waste Leachate, Acid Seep Collection, AMD, Waste Oil Wastewater, NCCW, and Stormwater

Technology-Based Limitations

Federal Effluent Limitation Guidelines (ELGs)

IMP 201 is subject to Federal Effluent Limitation Guidelines (ELGs) under 40 CFR 420 Iron and Steel Manufacturing.

- The 64-inch Continuous Pickle Production line (Hydrochloric Acid Pickling Rinse water and one fume scrubber), which is subject to 40 CFR 420.94(b)(2) and 420.94(b)(4).
- The 84-inch Continuous Pickle Production line (Hydrochloric Acid Pickling Rinse water and one fume scrubber), which is subject to 40 CFR 420.92(b)(2) and 420.92(b)(4).
- The Continuous Annealing Line (Alkaline Cleaning of Strip), which is subject to 40 CFR 420.112(b) and 420.113(b).
- The Cold Reduction Mill (Cold Rolling of Steel in a five-stand recirculating mill), which is subject to 40 CFR 420.102(a)(2) and 420.103(a)(2).
- The No. 1 Galvanize Line (Hot Coating of Steel Strip), which is subject to 40 CFR 420.122(a)(1) and 420.123(a)(1).
- The No. 2 Galvanize Line (Alkaline Cleaning of Steel Strip, Hot Coating of Steel Strip and one fume scrubber), which is subject to 40 CFR 420.112(b), 420.113(b), 420.122(a)(1), 420.122(c), 420.123(a)(1), and 420.123(c).
- The Temper Mill (Cold Rolling of Steel in Single-stand Direct Application Mill), which is subject to 40 CFR 420.102(a)(4) and 420.103(a)(4).

Each subcategory of each production line is broken down in detail in Attachment F. The maximum monthly average production rates from the past five years was used to calculate the mass-based limitations. The mass-based limitations from the ELGs are displayed below in Table 9. The limits are the summation of all of the above subparts for each of the production lines. To ensure that the mass-based limitations are met, the concentration limits that EPA used to develop the ELGs will be imposed as well. These concentration values are from Tables I-1, I-3, and I-5 from the Iron and Steel Development Document. Because the wastewater that is discharged via IMP 201 is a combination of multiple subcategories, the most stringent concentration for a pollutant of all the subcategory is imposed. The concentrations are also displayed below in Table 9.

Table 9: ELG Limitations – IMP 201

| Parameter | Average Monthly (lbs/day) | Daily Maximum (lbs/day) | Average Monthly (mg/L) | Daily Maximum (mg/L) | Instantaneous Maximum (mg/L) |
|------------------------|---------------------------|-------------------------|--|----------------------|------------------------------|
| Total Suspended Solids | 870 | 1990 | 30.0 | 60.0 | 75.0 |
| Oil and Grease | 291 | 849 | 10.0 | 25.0 | 31.3 |
| Total Lead | 3.62 | 10.9 | 0.15 | 0.45 | 0.56 |
| Total Zinc | 4.38 | 13.1 | 0.1 | 0.3 | 0.38 |
| Naphthalene | XXX | 0.45 | XXX | 0.1 | 0.13 |
| Tetrachloroethylene | XXX | 0.67 | XXX | 0.15 | 0.19 |
| pH (S.U.) | | | Not less than 6.0 nor greater than 9.0 | | |

Water Quality-Based Limitations

Water quality-based effluent limitations will be evaluated and imposed at the receiving outfall, Outfall 001.

Anti-backsliding:

Previous effluent limits and monitoring requirements can be used pursuant to EPA's anti-backsliding regulation, 40 CFR 122.44(l) and are displayed below in Table 10. The Mass-Based limitations will be replaced with new limits based on the current production and operation. The concentration limits are from the previous permit and were developed by converting the mass-based limits at that time to concentrations by using a conversion factor of 8.34 and a flow of 2.06 MGD. The Oil and Grease concentration limits were from 25 PA Code Chapter 95.2. The pH limits were adjusted in the previous permit to be between 6.0 and 10.0 S.U. to accommodate the removal of metallic waste from the water. The pH limitations of between 6.0 and 9.0 S.U. at Outfall 001 comply with the effluent limitation guidelines for discharges from IMP 201.

Table 10: Existing Effluent Limitation for IMP 201

| Parameters | Mass (lb/day) | | Concentration (mg/L) | | | Monitoring Requirements | | |
|------------------------|-----------------|---------------|-----------------------------------|-----------------|---------------|-------------------------|-----------|-------------------|
| | Average Monthly | Daily Maximum | Minimum | Average Monthly | Daily Maximum | Instant. Maximum* | Frequency | Sample Type |
| Flow (MGD) | Report | Report | XXX | XXX | XXX | XXX | 1/Week | Measure |
| Total Suspended Solids | 1007 | 2314 | XXX | 58.0 | 132.0 | 165 | 1/Week | 24-hour Composite |
| Oil and Grease | 337 | 989 | XXX | 15.0 | 30.0 | 30.0 | 1/Week | 3 grabs/24 hours |
| Lead | 3.85 | 11.57 | XXX | 0.22 | 0.68 | 0.84 | 1/Week | 24-hour Composite |
| Zinc | 4.78 | 14.33 | XXX | 0.28 | 0.83 | 1.04 | 1/Week | 24-hour Composite |
| Naphthalene | XXX | 0.358 | XXX | XXX | 0.022 | 0.028 | 1/Quarter | 24-hour Composite |
| Tetrachloroethylene | XXX | 0.536 | XXX | XXX | 0.032 | 0.04 | 1/Quarter | 3 grabs/24 hours |
| Total Iron | XXX | XXX | XXX | 3.5 | 7.0 | 8.75 | 1/Week | 24-hour Composite |
| pH (S.U.) | XXX | XXX | Between 6.0 and 10.0 at all times | | | | 1/Week | Grab |

*Instantaneous maximum limitations are imposed to allow for a grab to be collected by the appropriate regulatory agency to determine compliance. The permittee is not required to monitor for the instantaneous maximum limitations. However, if grab samples are collected by the permittee, the results must be reported except for the results of individual grab collected by the permittee to comply with a sample type specified as 3/grabs/24 hours. These limits serve as a screening tool to assist field staff in enforcement decision-making. These limits are to be used as indicators to help determine the need for follow-up compliance inspections.

Proposed Effluent Limitations

The proposed effluent limitations for IMP 201 are displayed in Table 11 below. They are the most stringent values from the above effluent limitation development. The Mass-Based limitations have been replaced with new limits based on the current production and operation. The concentration limits for TSS, Oil and Grease, Lead, and Zinc have been replaced with the concentration limits from the Iron and Steel Development document. The concentration limits for Naphthalene and Tetrachloroethylene will be carried over to the new permit from the previous permit.

Table 11: Proposed Effluent Limitation for IMP 201

| Parameters | Mass (lb/day) | | Concentration (mg/L) | | | Monitoring Requirements | | |
|------------------------|-----------------|---------------|----------------------|-----------------|---------------|-------------------------|-----------|-------------------|
| | Average Monthly | Daily Maximum | Minimum | Average Monthly | Daily Maximum | Instant. Maximum* | Frequency | Sample Type |
| Flow (MGD) | Report | Report | XXX | XXX | XXX | XXX | 1/Week | Measure |
| Total Suspended Solids | 870 | 1990 | XXX | 30.0 | 60.0 | 75.0 | 1/Week | 24-hour Composite |
| Oil and Grease | 291 | 849 | XXX | 10.0 | 25.0 | 30.0 | 1/Week | 3 grabs/24 hours |
| Lead | 3.62 | 10.9 | XXX | 0.15 | 0.45 | 0.56 | 1/Week | 24-hour Composite |
| Zinc | 4.38 | 13.1 | XXX | 0.1 | 0.3 | 0.38 | 1/Week | 24-hour Composite |
| Naphthalene | XXX | 0.45 | XXX | XXX | 0.022 | 0.028 | 1/Quarter | 24-hour Composite |
| Tetrachloroethylene | XXX | 0.67 | XXX | XXX | 0.032 | 0.04 | 1/Quarter | 3 grabs/24 hours |
| Total Iron | XXX | XXX | XXX | 3.5 | 7.0 | 8.75 | 1/Week | 24-hour Composite |
| pH (S.U.) | XXX | XXX | 6.0 | XXX | XXX | 10.0 | 1/Week | Grab |

*Instantaneous maximum limitations are imposed to allow for a grab sample to be collected by the appropriate regulatory agency to determine compliance. The permittee is not required to monitor for the instantaneous maximum limitations. However, if grab samples are collected by the permittee, the results must be reported.

Development of Effluent Limitations

| | | | |
|---|-------------|-------------------|--------------|
| IMP No. | 301 | Design Flow (MGD) | 0.952 |
| Latitude | 40° 20' 15" | Longitude | -79° 54' 18" |
| Wastewater Description: IW Process Effluent with ELG | | | |

Technology-Based Limitations

Federal Effluent Limitation Guidelines (ELGs)

IMP 301 is subject to Federal Effluent Limitation Guidelines (ELGs) under 40 CFR 420 Iron and Steel Manufacturing. The 80" Hot Strip Mill (Carbon Plate Mill Hot Forming Operations) is subject to 40 CFR 420.72(c)(1).

The production limitation calculations are broken down in detail in Attachment F. The maximum monthly average production rate from the past five years was used to calculate the mass-based limitations. The mass-based limitations from the ELGs are displayed below in Table 12. To ensure that the mass-based limitations are met, the concentration limits that EPA used to develop the ELGs will be imposed as well. These concentration values are from Table I-1 from the Iron and Steel Development Document and are also displayed below in Table 12.

Table 12: ELG Limitations

| Parameter | Average Monthly (lbs/day) | Daily Maximum (lbs/day) | Average Monthly (mg/L) | Daily Maximum (mg/L) | Instantaneous Maximum (mg/L) |
|------------------------|--|-------------------------|------------------------|----------------------|------------------------------|
| Total Suspended Solids | 3200 | 8530 | 30.0 | 70.0 | 87.5 |
| Oil and Grease | XXX | 2140 | 10.0 | 30.0 | 37.5 |
| pH (S.U.) | Not less than 6.0 nor greater than 9.0 | | | | |

Regulatory Effluent Standards and Monitoring Requirements

Flow monitoring is required pursuant to 25 Pa. Code § 92a.61(d)(1).

As oil-bearing wastewaters, discharges from IMP 301 are subject to effluent standards for oil and grease from 25 Pa. Code § 95.2(2).

Effluent standards for pH are also imposed on industrial wastes by 25 Pa. Code § 95.2(1).

Table 13: Regulatory Effluent Standards and Monitoring Requirements for IMP 301

| Parameter | Monthly Average | Daily Maximum | IMAX | Units |
|--------------|--|---------------|------|-------|
| Flow | Monitor and Report | | XXX | MGD |
| Oil & Grease | 15 | 30 | XXX | mg/L |
| pH | Not less than 6.0 nor greater than 9.0 | | | S.U. |

Water Quality-Based Limitations

Water quality-based effluent limitations will be evaluated and imposed at the receiving outfall, Outfall 001.

Anti-backsliding:

Previous effluent limits and monitoring requirements can be used pursuant to EPA's anti-backsliding regulation, 40 CFR 122.44(l) and are displayed below in Table 14. The Mass-Based limitations will be replaced with new limits based on the current production and operation. The TSS concentrations were developed in a previous permit per Best Professional Judgment. The BPJ approach, considered the average discharge concentration and compared the percent recycling of the BAT technology from the ELG Development document to the percent recycling of the treatment system at the site. The Oil and Grease concentration limits were adopted from 25 PA Code Chapter 95.2.

Table 14: Existing Effluent Limitation for IMP 301

| Parameters | Mass (lb/day) | | Concentration (mg/L) | | | Monitoring Requirements | | |
|------------------------|-----------------|---------------|----------------------|-----------------|---------------|-------------------------|------------|-------------------|
| | Average Monthly | Daily Maximum | Minimum | Average Monthly | Daily Maximum | Instant. Maximum* | Frequency | Sample Type |
| Flow (MGD) | Report | Report | XXX | XXX | XXX | XXX | Continuous | Measure |
| Total Suspended Solids | 2818 | 7522 | XXX | 24.0 | 48.0 | 60.0 | 1/Week | 24-hour Composite |
| Oil and Grease | XXX | 1885 | XXX | 15.0 | XXX | 30.0 | 1/Week | 3 grabs/24 hours |
| pH (S.U.) | XXX | XXX | 6.0 | XXX | XXX | 9.0 | 1/Week | Grab |

*Instantaneous maximum limitations are imposed to allow for a grab to be collected by the appropriate regulatory agency to determine compliance. The permittee is not required to monitor for the instantaneous maximum limitations. However, if grab samples are collected by the permittee, the results must be reported except for the results of individual grab collected by the permittee to comply with a sample type specified as 3/grabs/24 hours. These limits serve as a screening tool to assist field staff in enforcement decision-making. These limits are to be used as indicators to help determine the need for follow-up compliance inspections.

See Part C Condition No.14

Condition C.14.

The total mass load being discharged from Outfalls 301, 601, and 701 shall not exceed the following limits

Monthly Average Total Suspended Solids = 2818 ppd;
Daily Maximum Total Suspended Solids = 7522 ppd;
Daily Maximum Oil and Grease = 1885 ppd.

Proposed Effluent Limitations

The proposed effluent limitations for IMP 301 are displayed in Table 15 below. They are the most stringent values from the above effluent limitation development. The Mass-Based limitations have been replaced with new limits based on the current production and operation. The concentration limits for TSS will be carried over to the new permit from the previous permit. The concentration limits for Oil and Grease have been replaced with the concentration limits from the Iron and Steel Development document. Part C condition 14 of the current permit has been changed to Footnote number 4 in the Draft permit and has been updated to reflect the changes to the loading limitation.

Table 15: Proposed Effluent Limitation for IMP 301

| Parameters | Mass (lb/day) | | Concentration (mg/L) | | | Monitoring Requirements | | |
|------------------------|-----------------|---------------|----------------------|-----------------|---------------|-------------------------|------------|-------------------|
| | Average Monthly | Daily Maximum | Instant. Minimum | Average Monthly | Daily Maximum | Instant. Maximum* | Frequency | Sample Type |
| Flow (MGD) | Report | Report | XXX | XXX | XXX | XXX | Continuous | Measure |
| Total Suspended Solids | 3200 | 8530 | XXX | 24.0 | 48.0 | 60.0 | 1/Week | 24-hour Composite |
| Oil and Grease | XXX | 2140 | XXX | 10.0 | 30.0 | 30.0 | 1/Week | 3 grabs/24 hours |
| pH (S.U.) | XXX | XXX | 6.0 | XXX | XXX | 9.0 | 1/Week | Grab |

*Instantaneous maximum limitations are imposed to allow for a grab sample to be collected by the appropriate regulatory agency to determine compliance. The permittee is not required to monitor for the instantaneous maximum limitations. However, if grab samples are collected by the permittee, the results must be reported

Development of Effluent Limitations

IMP No. 601
Latitude 40° 20' 17"

Design Flow (MGD) Emergency Overflow
Longitude -79° 54' 08"

Wastewater Description: IW Process Effluent with ELG Overflow

IMP 601 is the emergency overflow of the wastewater that would typically discharge via IMP 301, therefore the same limitations from IMP 301 will be imposed at IMP 601.

Table 16: Effluent Limitation proposed for IMP 301

| Parameters | Mass (lb/day) | | Concentration (mg/L) | | | | Monitoring Requirements | |
|------------------------|-----------------|---------------|----------------------|-----------------|---------------|-------------------|-------------------------|-------------|
| | Average Monthly | Daily Maximum | Instant. Minimum | Average Monthly | Daily Maximum | Instant. Maximum* | Frequency | Sample Type |
| Flow (MGD) | Report | Report | XXX | XXX | XXX | XXX | 1/Discharge | Measure |
| Total Suspended Solids | 3200 | 8530 | XXX | 24.0 | 48.0 | 60.0 | 1/Discharge | Grab |
| Oil and Grease | XXX | 2140 | XXX | 10.0 | 30.0 | 37.5 | 1/Discharge | Grab |
| pH (S.U.) | XXX | XXX | 6.0 | XXX | XXX | 9.0 | 1/Discharge | Grab |

Anti-backsliding:

Previous effluent limits and monitoring requirements can be used pursuant to EPA's anti-backsliding regulation, 40 CFR 122.44(l) and are displayed below in Table 17.

Table 17: Existing Effluent Limitation for IMP 601

| Parameters | Mass (lb/day) | | Concentration (mg/L) | | | | Monitoring Requirements | |
|------------------------|-----------------|---------------|----------------------|-----------------|---------------|------------------|-------------------------|-------------|
| | Average Monthly | Daily Maximum | Minimum | Average Monthly | Daily Maximum | Instant. Maximum | Frequency | Sample Type |
| Flow (MGD) | Report | Report | XXX | XXX | XXX | XXX | 1/Discharge | Estimate |
| Total Suspended Solids | 2818 | 7522 | XXX | 24.0 | 48.0 | 60.0 | 1/Discharge | Grab |
| Oil and Grease | XXX | 1885 | XXX | 15.0 | XXX | 30.0 | 1/Discharge | Grab |
| pH (S.U.) | XXX | XXX | 6.0 | XXX | XXX | 9.0 | 1/Discharge | Grab |

See Part C Condition No.14

Condition C.14.

The total mass load being discharged from Outfalls 301, 601, and 701 shall not exceed the following limits

Monthly Average Total Suspended Solids = 2818 ppd;

Daily Maximum Total Suspended Solids = 7522 ppd;

Daily Maximum Oil and Grease = 1885 ppd.

Proposed Effluent Limitations

The proposed effluent limitations for IMP 601 are displayed in Table 18 below, they are the most stringent values from the above effluent limitation development. Part C condition 14 of the current permit has been changed to Footnote number 4 in the Draft permit and has been updated to reflect the changes to the loading limitation.

Table 18: Proposed Effluent Limitation for IMP 601

| Parameters | Mass (lb/day) | | Concentration (mg/L) | | | | Monitoring Requirements | |
|------------------------|-----------------|---------------|----------------------|-----------------|---------------|-------------------|-------------------------|-------------|
| | Average Monthly | Daily Maximum | Minimum | Average Monthly | Daily Maximum | Instant. Maximum* | Frequency | Sample Type |
| Flow (MGD) | Report | Report | XXX | XXX | XXX | XXX | 1/Discharge | Estimate |
| Total Suspended Solids | 3200 | 8530 | XXX | 24.0 | 48.0 | 60.0 | 1/Discharge | Grab |
| Oil and Grease | XXX | 2140 | XXX | 10.0 | 30.0 | 30.0 | 1/Discharge | Grab |
| pH (S.U.) | XXX | XXX | 6.0 | XXX | XXX | 9.0 | 1/Discharge | Grab |

Development of Effluent Limitations

IMP No. 701
Latitude 40° 20' 11"

Design Flow (MGD) _____
Longitude _____
Emergency Overflow
-79° 54' 09"

Wastewater Description: IW Process Effluent with ELG Overflow

IMP 701 is the emergency overflow of wastewater that would typically discharge via IMP 301, therefore the limitations from IMP 301 will be imposed at IMP 701.

Table 19: Effluent Limitation proposed for IMP 301

| Parameters | Mass (lb/day) | | Concentration (mg/L) | | | Monitoring Requirements | | |
|------------------------|-----------------|---------------|----------------------|-----------------|---------------|-------------------------|-------------|-------------|
| | Average Monthly | Daily Maximum | Minimum | Average Monthly | Daily Maximum | Instant. Maximum* | Frequency | Sample Type |
| Flow (MGD) | Report | Report | XXX | XXX | XXX | XXX | 1/Discharge | Measure |
| Total Suspended Solids | 3200 | 8530 | XXX | 24.0 | 48.0 | 60.0 | 1/Discharge | Grab |
| Oil and Grease | XXX | 2140 | XXX | 10.0 | 30.0 | 37.5 | 1/Discharge | Grab |
| pH (S.U.) | XXX | XXX | 6.0 | XXX | XXX | 9.0 | 1/Discharge | Grab |

Anti-backsliding:

Previous effluent limits and monitoring requirements can be used pursuant to EPA's anti-backsliding regulation, 40 CFR 122.44(l) and are displayed below in Table 20.

Table 20: Existing Effluent Limitation for IMP 701

| Parameters | Mass (lb/day) | | Concentration (mg/L) | | | Monitoring Requirements | | |
|------------------------|-----------------|---------------|----------------------|-----------------|---------------|-------------------------|-------------|-------------|
| | Average Monthly | Daily Maximum | Minimum | Average Monthly | Daily Maximum | Instant. Maximum | Frequency | Sample Type |
| Flow (MGD) | Report | Report | XXX | XXX | XXX | XXX | 1/Discharge | Estimate |
| Total Suspended Solids | 2818 | 7522 | XXX | 24.0 | 48.0 | 60.0 | 1/Discharge | Grab |
| Oil and Grease | XXX | 1885 | XXX | 15.0 | XXX | 30.0 | 1/Discharge | Grab |
| pH (S.U.) | XXX | XXX | 6.0 | XXX | XXX | 9.0 | 1/Discharge | Grab |

See Part C Condition No.14

Condition C.14.

The total mass load being discharged from Outfalls 301, 601, and 701 shall not exceed the following limits

Monthly Average Total Suspended Solids = 2818 ppd;

Daily Maximum Total Suspended Solids = 7522 ppd;

Daily Maximum Oil and Grease = 1885 ppd.

Proposed Effluent Limitations

The proposed effluent limitations for IMP 701 are displayed in Table 21 below, they are the most stringent values from the above effluent limitation development. Part C condition 14 of the current permit has been changed to Footnote number 4 in the Draft permit and has been updated to reflect the changes to the loading limitation.

Table 21: Proposed Effluent Limitation for IMP 701

| Parameters | Mass (lb/day) | | Concentration (mg/L) | | | Monitoring Requirements | | |
|------------------------|-----------------|---------------|----------------------|-----------------|---------------|-------------------------|-------------|-------------|
| | Average Monthly | Daily Maximum | Instant. Minimum | Average Monthly | Daily Maximum | Instant. Maximum* | Frequency | Sample Type |
| Flow (MGD) | Report | Report | XXX | XXX | XXX | XXX | 1/Discharge | Estimate |
| Total Suspended Solids | 3200 | 8530 | XXX | 24.0 | 48.0 | 60.0 | 1/Discharge | Grab |
| Oil and Grease | XXX | 2140 | XXX | 10.0 | 30.0 | 30.0 | 1/Discharge | Grab |
| pH (S.U.) | XXX | XXX | 6.0 | XXX | XXX | 9.0 | 1/Discharge | Grab |

Development of Effluent Limitations

Outfall No. 002
Latitude 40° 20' 2.5"
Wastewater Description: Travel Screen Backwash

Design Flow (MGD) Varies
Longitude -79° 53' 48.2"

The following statement from the current permit will remain in Part A of the new permit:

The material (solids and other debris) physically or mechanically removed by USS in the backwash operation shall not be returned to surface waters. The disposal of this material shall prevent any discharge of removed substance to surface waters.

Development of Effluent Limitations

| | | | |
|-------------------------|---------------|---------------------------------------|----------------|
| Outfall No. | 003 | Design Flow (MGD) | 1.72 |
| Latitude | 40° 19' 44.2" | Longitude | -79° 53' 59.9" |
| Wastewater Description: | | NCCW, Boiler Blowdown, and Stormwater | |

Technology-Based Limitations

Regulatory Effluent Standards and Monitoring Requirements

25 PA Code Chapter 92 requires pH to be a minimum of 6.0 and a maximum of 9.0 S.U. for all industrial waste process and non-process discharges.

Flow reporting requirements are in accordance with the 25 PA Code Chapter 92 regulations.

Pennsylvania regulations at 25 Pa. Code § 92a.48(b) require the imposition of technology-based TRC limits for facilities that use chlorination and that are not already subject to TRC limits based on applicable federal ELGs or a facility-specific BPJ evaluation.

Although the sample results in the updated permit application indicate that the oil and grease concentrations from the discharge of Outfall 003 are non-detect, there have been multiple instances where the Department has noted an oily sheen from the discharge of Outfall 003. Therefore, the effluent standards for oil and grease from 25 Pa. Code § 95.2(2) will be imposed at Outfall 003.

Temperature limits will be imposed per the Department's *"Implementation Guidance for Temperature Criteria."* As a policy, DEP normally imposes a maximum temperature limit of 110°F on discharges that contain residual heat. The limit is intended as a safety measure to protect sampling personnel or anyone who may come into contact with the heated discharge where it enters the receiving water.

Table 22: Regulatory Effluent Standards and Monitoring Requirements for Outfall 003

| Parameter | Monthly Average | Daily Maximum | Instantaneous Maximum | Units |
|-------------------------|---------------------|---------------|-----------------------|-------|
| Flow | Monitor and Report | | - | MGD |
| Total Residual Chlorine | 0.5 | 1.0 | - | mg/L |
| Oil and Grease | 15.0 | 30.0 | - | mg/L |
| Temperature | - | - | 110 | °F |
| pH | Between 6.0 and 9.0 | | | S.U. |

Water Quality-Based Limitations

Toxics Management Spread Sheet

The Department of Environmental Protection (DEP) has developed the DEP Toxics Management Spreadsheet ("TMS") to facilitate calculations necessary for completing a reasonable potential (RP) analysis and determining water quality-based effluent limitations for discharges of toxic pollutants. The Toxics Management Spreadsheet is a macro-enabled Excel binary file that combines the functions of the PENTOXSD model and the Toxics Screening Analysis spreadsheet to evaluate the reasonable potential for discharges to cause excursions above water quality standards and to determine WQBELs. The Toxics Management Spread Sheet is a single discharge, mass-balance water quality calculation spread sheet that includes consideration for mixing, first-order decay and other factors to determine recommended WQBELs for toxic substances and several non-toxic substances. Required input data including stream code, river mile index, elevation, drainage area, discharge name, NPDES permit number, discharge flow rate and the discharge concentrations for parameters in the permit application or in DMRs, which are entered into the spread sheet to establish site-specific discharge conditions. Other data such as low flow yield, reach dimensions and partial mix factors may also be entered to further characterize the conditions of the discharge and receiving water. Discharge concentrations for the parameters are chosen to represent the "worst case" quality of the discharge (i.e., maximum reported discharge concentrations). The spread sheet then evaluates each parameter by computing a Waste Load Allocation for each applicable criterion, determining a recommended maximum WQBEL and comparing that recommended WQBEL with the input discharge concentration to determine which is more stringent. Based on this evaluation, the Toxics Management Spread sheet recommends average monthly and maximum daily WQBELs.

Reasonable Potential Analysis and WQBEL Development for Outfall 003

Discharges from Outfall 003 are evaluated based on concentrations reported on the application and on DMRs; data from those sources are entered into the Toxics Management Spread Sheet. The maximum reported value of the parameters from the application form or from previous DMRs is used as the input concentration in the Toxics Management Spread Sheet. All toxic pollutants whose maximum concentrations, as reported in the permit application or on DMRs, are greater than the most stringent applicable water quality criterion are considered to be pollutants of concern. [This includes pollutants reported as "Not Detectable" or as "<MDL" where the method detection limit for the analytical method used by the applicant is greater than the most stringent water quality criterion]. The Toxics Management Spread Sheet is run with the discharge and receiving stream characteristics shown in Table 23. For IW discharges, the design flow used in modeling is the average flow during production or operation taken from the permit application. Pollutants for which water quality standards have not been promulgated (e.g., TSS, oil and grease) are excluded from the analysis. All the parameters are evaluated using the model to determine the water quality-based effluent limits applicable to the discharge and the receiving stream. The spreadsheet then compares the reported discharge concentrations to the calculated water quality-based effluent limitations to determine if a reasonable potential exists to exceed the calculated WQBELs. Effluent limitations are established in the draft permit where a pollutant's maximum reported discharge concentration equals or exceeds 50% of the WQBEL. For non-conservative pollutants, monitoring requirements are established where the maximum reported concentration is between 25% - 50% of the WQBEL. For conservative pollutants, monitoring requirements are established where the maximum reported concentration is between 10% - 50% of the WQBEL. The information described above including the maximum reported discharge concentrations, the most stringent water quality criteria, the pollutant-of-concern (reasonable potential) determinations, the calculated WQBELs, and the WQBEL/monitoring recommendations are displayed in the Toxics Management Spread Sheet in Attachment G of this Fact Sheet. The water quality-based effluent limitations and monitoring requirements that are recommended by the Toxics Management Spread Sheet are displayed below in Table 24.

Table 23: TMS Inputs for Outfall 003

| Parameter | Value |
|---------------------------------------|--------|
| River Mile Index | 18.1 |
| Discharge Flow (MGD) | 1.72 |
| | |
| Parameter | Value |
| Area in Square Miles | 5,410 |
| Q ₇₋₁₀ (cfs) | 550 |
| Low-flow yield (cfs/mi ²) | 0.102 |
| Elevation (ft) | 712 |
| Slope | 0.0001 |

Table 24: Water Quality Based Effluent Limitations at Outfall 003

| Parameters | Average Monthly | Daily Maximum | Discharge Concentration |
|-------------------------------|-----------------|---------------|-------------------------|
| Butyl Benzyl Phthalate (µg/L) | Report | Report | 4.3 |

Thermal WQBELs for Heated Discharges

Thermal WQBELs are evaluated using DEP's "Thermal Discharge Limit Calculation Spreadsheet" created with Microsoft Excel for Windows. The program calculates temperature WLs through the application of a heat transfer equation, which takes two forms in the program depending on the source of the facility's cooling water. In Case 1, intake water to a facility is from the receiving stream. In Case 2, intake water is from a source other than the receiving stream (e.g., municipal water supply). The determination of which case applies to a given discharge is determined by the input data which include the

receiving stream flow rate (Q_{7-10} or the minimum regulated flow for large rivers), the stream intake flow rate, external source intake flow rates, consumptive flow rates and site-specific ambient stream temperatures. Case 1 limits are generally expressed as heat rejection rates while Case 2 limits are usually expressed as temperatures.

Since the temperature criteria from 25 Pa. Code Chapter 93.7(a) are expressed on monthly and semi-monthly bases for three different aquatic life-uses—cold water fishes, warm water fishes and trout stocking—the program generates monthly and semi-monthly limits for each use. DEP selects the output that corresponds to the aquatic life-use of the receiving stream and consequently which limits apply to the discharge. Temperature WLAs are bounded by an upper limit of 110°F for the safety of sampling personnel and anyone who may come into contact with the heated discharge where it enters the receiving water. If no WLAs below 110°F are calculated, an instantaneous maximum limit of 110°F is recommended by the program.

Due to the nature of the discharges and their relative locations on the receiving stream, all heated discharges will be evaluated as one discharge to ensure the temperature criteria is met instream from all of the heated discharges and a combined flow of 25.32 MGD was used in the model. Discharges from Outfall 001 and Outfall 003 are classified under Case 1 because water is obtained via an intake structure owned by the permittee on the Monongahela River. The results of the thermal analysis, included in Attachment E, indicate that no WQBELs for temperature are required at Outfall 003. Therefore, the 110°F daily maximum temperature limit will be imposed at Outfall 003.

Total Residual Chlorine

To determine if WQBELs are required for discharges containing total residual chlorine (TRC), a discharge evaluation is performed using a DEP program called TRC_CALC created with Microsoft Excel for Windows. TRC_CALC calculates TRC Waste Load Allocations (WLAs) through the application of a mass balance model which considers TRC losses due to stream and discharge chlorine demands and first-order chlorine decay. Input values for the program include flow rates and chlorine demands for the receiving stream and the discharge, the number of samples taken per month, coefficients of TRC variability, partial mix factors, and an optional factor of safety. The mass balance model calculates WLAs for acute and chronic criteria that are then converted to long term averages using calculated multipliers. The multipliers are functions of the number of samples taken per month and the TRC variability coefficients (normally kept at default values unless site specific information is available). The most stringent limitation between the acute and chronic long-term averages is converted to an average monthly limit for comparison to the BAT average monthly limit of 0.5 mg/l from 25 Pa. Code § 92a.48(b)(2). The more stringent of these average monthly TRC limitations is imposed in the permit. The results of the modeling, included in Attachment H, indicate that no WQBELs are required for TRC.

Anti-backsliding:

Previous effluent limits and monitoring requirements can be used pursuant to EPA's anti-backsliding regulation, 40 CFR 122.44(l) and are displayed below in Table 25.

Table 25: Existing Effluent Limitation for Outfall 003

| Parameters | Mass (lb/day) | | Concentration (mg/L) | | | | Monitoring Requirements | |
|-------------------|-----------------|---------------|----------------------|-----------------|---------------|------------------|-------------------------|-------------|
| | Average Monthly | Daily Maximum | Minimum | Average Monthly | Daily Maximum | Instant. Maximum | Frequency | Sample Type |
| Flow (MGD) | Report | Report | XXX | XXX | XXX | XXX | 1/Week | Estimate |
| Temperature (°F)* | XXX | XXX | XXX | XXX | 110 | XXX | 1/Week | I-S |
| pH (S.U.) | XXX | XXX | 6.0 | XXX | 9.0 | XXX | 1/Week | Grab |

* There shall be no net addition of pollutants to non-contact cooling water over intake values except for heat and water conditioning additivities for which complete information was submitted in the appellation of is required to be submitted as a condition of this permit.

For the purpose of determining compliance with any maximum daily temperature limitations in apart A of this permit and notwithstanding A.2.o of this permit, the temperature value shall consist of the average of three (30 individual immersion stabilization temperature measurements over a twenty-four hour period. The individual temperate measurement shall be taken at equal internals over the period as is practical and in no case shall any two individual temperature measurements be taken at less than a one (1) hour interval.

Proposed Effluent Limitations

The proposed effluent limitations for Outfall 003 are displayed in Table 26, they are the most stringent values from the above effluent limitation development.

Table 26: Proposed Final Effluent Limitations for Outfall 003

| Parameter | Instantaneous Minimum | Average Monthly | Daily Maximum | Instantaneous Maximum | Sample Frequency | Sample Type |
|--------------------------------|-----------------------|-----------------|---------------|-----------------------|------------------|-------------|
| Flow (MGD) | XXX | Report | Report | XXX | 1/Week | Estimate |
| Temperature (°F) | XXX | XXX | XXX | 110 | 1/Week | I-S |
| Total Residual Chlorine (mg/l) | XXX | 0.5 | 1.0 | 1.25 | 1/Week | Grab |
| Oil and Grease | XXX | 15.0 | 30.0 | XXX | 1/Week | Grab |
| Butyl Benzyl Phthalate | XXX | Report | Report | XXX | 1/Week | Grab |
| pH (S.U.) | 6.0 | XXX | XXX | 9.0 | 1/Week | Grab |

Development of Effluent Limitations

Outfall No. 004
Latitude 40° 19' 51.5"
Wastewater Description: Stormwater

Design Flow (MGD) Varies
Longitude -79° 53' 52.4"

Stormwater Technology Limits

Outfall 004 will be subject to PAG-03 General Stormwater Permit conditions as a minimum requirement because the outfall discharges stormwater associated with industrial activity. The SIC code for the site is 3312 and the corresponding appendix of the PAG-03 that would apply to the facility is Appendix B. The reporting requirements applicable to stormwater discharges are shown in Table 27 below.

Table 27: PAG-03 Appendix (B) Monitoring Requirements

| Parameter | Max Daily Concentration | Measurement Frequency | Sample Type |
|------------------------------|-------------------------|-----------------------|-------------|
| Total Nitrogen* | Monitor and Report | 1/6 Months | Grab |
| Total Phosphorus | Monitor and Report | 1/6 Months | Grab |
| Total Suspended Solids (TSS) | Monitor and Report | 1/6 Months | Grab |
| Oil and Grease | Monitor and Report | 1/6 Months | Grab |
| Total Aluminum | Monitor and Report | 1/6 Months | Grab |
| Total Zinc | Monitor and Report | 1/6 Months | Grab |
| Total Copper | Monitor and Report | 1/6 Months | Grab |
| Total Iron | Monitor and Report | 1/6 Months | Grab |
| Total Lead | Monitor and Report | 1/6 Months | Grab |

*Total Nitrogen is the sum of Total Kjeldahl-N (TKN) plus Nitrite-Nitrate as N (NO₂+NO₃-N), where TKN and NO₂+NO₃-N are measured in the same sample.

Water Quality-Based Limitations

Stormwater WQBELs

Water quality analyses are typically performed under low-flow (Q7-10) conditions. Stormwater discharges occur at variable rates and frequencies but not however during Q7-10 conditions. Since the discharges from Outfall 004 are composed entirely of stormwater, a formal water quality analysis cannot be accurately conducted. Accordingly, water quality-based effluent limitations based on water quality analyses are not proposed.

Anti-backsliding:

No limits were imposed on Outfall 004 in the previous permit.

Proposed Effluent Limitations and Monitoring Requirements

The proposed effluent monitoring requirements for Outfall 004 are displayed in Table 28 below, they are the most stringent values from the above effluent limitation development. The Draft Permit requires a Corrective Action Plan when there are two consecutive exceedances of the benchmark values, which are also included in the Part C condition. The benchmark values are displayed below in Table 28. These values are not effluent limitations, an exceedance of the benchmark value is not a violation. As described above, if there are two consecutive exceedances of the benchmark value, a corrective action plan must be conducted to evaluate site stormwater controls and BMPs. Benchmark monitoring is a feedback tool, along with routine inspections and visual assessments, for assessing the effectiveness of stormwater controls and BMPs. An exceedance of the benchmark provides permittees with an indication that the facility's controls may not be sufficiently controlling pollutants in stormwater.

Table 28: Proposed Effluent Monitoring Requirements – Outfall 004

| Parameter | Max Daily Concentration | Benchmark Values (mg/L) | Measurement Frequency | Sample Type |
|------------------------------|-------------------------|-------------------------|-----------------------|-------------|
| Total Nitrogen | Report | XXX | 1/6 Months | Calculation |
| Total Phosphorus | Report | XXX | 1/6 Months | Grab |
| Total Suspended Solids (TSS) | Report | 100 | 1/6 Months | Grab |
| Oil and Grease | Report | 30 | 1/6 Months | Grab |
| Total Aluminum | Report | XXX | 1/6 Months | Grab |
| Total Zinc | Report | XXX | 1/6 Months | Grab |
| Total Copper | Report | XXX | 1/6 Months | Grab |
| Total Iron | Report | XXX | 1/6 Months | Grab |
| Total Lead | Report | XXX | 1/6 Months | Grab |

Development of Effluent Limitations

Outfall No. 005
Latitude 40° 20' 27.3"
Wastewater Description: Stormwater

Design Flow (MGD) Varies
Longitude -79° 54' 5.9"

Stormwater Technology Limits

Outfall 005 will be subject to PAG-03 General Stormwater Permit conditions as a minimum requirement because the outfall discharges stormwater associated with industrial activity. The SIC code for the site is 3312 and the corresponding appendix of the PAG-03 that would apply to the facility is Appendix B. The reporting requirements applicable to stormwater discharges are shown in Table 29 below.

Table 29: PAG-03 Appendix (B) Monitoring Requirements

| Parameter | Max Daily Concentration | Measurement Frequency | Sample Type |
|------------------------------|-------------------------|-----------------------|-------------|
| Total Nitrogen* | Monitor and Report | 1/6 Months | Grab |
| Total Phosphorus | Monitor and Report | 1/6 Months | Grab |
| Total Suspended Solids (TSS) | Monitor and Report | 1/6 Months | Grab |
| Oil and Grease | Monitor and Report | 1/6 Months | Grab |
| Total Aluminum | Monitor and Report | 1/6 Months | Grab |
| Total Zinc | Monitor and Report | 1/6 Months | Grab |
| Total Copper | Monitor and Report | 1/6 Months | Grab |
| Total Iron | Monitor and Report | 1/6 Months | Grab |
| Total Lead | Monitor and Report | 1/6 Months | Grab |

*Total Nitrogen is the sum of Total Kjeldahl-N (TKN) plus Nitrite-Nitrate as N (NO₂+NO₃-N), where TKN and NO₂+NO₃-N are measured in the same sample.

Water Quality-Based Limitations

Stormwater WQBELs

Water quality analyses are typically performed under low-flow (Q7-10) conditions. Stormwater discharges occur at variable rates and frequencies but not however during Q7-10 conditions. Since the discharges from Outfall 005 are composed entirely of stormwater, a formal water quality analysis cannot be accurately conducted. Accordingly, water quality-based effluent limitations based on water quality analyses are not proposed.

Anti-backsliding:

No limits were imposed on Outfall 005 in the previous permit.

Proposed Effluent Limitations and Monitoring Requirements

The proposed effluent monitoring requirements for Outfall 005 are displayed in Table 30 below, they are the most stringent values from the above effluent limitation development. The Draft Permit requires a Corrective Action Plan when there are two consecutive exceedances of the benchmark values, which are also included in the Part C condition. The benchmark values are displayed below in Table 30. These values are not effluent limitations, an exceedance of the benchmark value is not a violation. As described above, if there are two consecutive exceedances of the benchmark value, a Corrective Action Plan must be conducted to evaluate site stormwater controls and BMPs. Benchmark monitoring is a feedback tool, along with routine inspections and visual assessments, for assessing the effectiveness of stormwater controls and BMPs. An exceedance of the benchmark provides permittees with an indication that the facility's controls may not be sufficiently controlling pollutants in stormwater.

Table 30: Proposed Effluent Monitoring Requirements – Outfall 005

| Parameter | Max Daily Concentration | Benchmark Values (mg/L) | Measurement Frequency | Sample Type |
|------------------------------|-------------------------|-------------------------|-----------------------|-------------|
| Total Nitrogen | Report | XXX | 1/6 Months | Calculation |
| Total Phosphorus | Report | XXX | 1/6 Months | Grab |
| Total Suspended Solids (TSS) | Report | 100 | 1/6 Months | Grab |
| Oil and Grease | Report | 30 | 1/6 Months | Grab |
| Total Aluminum | Report | XXX | 1/6 Months | Grab |
| Total Zinc | Report | XXX | 1/6 Months | Grab |
| Total Copper | Report | XXX | 1/6 Months | Grab |
| Total Iron | Report | XXX | 1/6 Months | Grab |
| Total Lead | Report | XXX | 1/6 Months | Grab |

| Tools and References Used to Develop Permit | |
|---|--|
| <input checked="" type="checkbox"/> | WQM for Windows Model (see Attachment D) |
| <input checked="" type="checkbox"/> | Toxics Management Spreadsheet (see Attachment B and G) |
| <input checked="" type="checkbox"/> | TRC Model Spreadsheet (see Attachment C and H) |
| <input checked="" type="checkbox"/> | Temperature Model Spreadsheet (see Attachment E) |
| <input type="checkbox"/> | Water Quality Toxics Management Strategy, 361-0100-003, 4/06. |
| <input type="checkbox"/> | Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97. |
| <input type="checkbox"/> | Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98. |
| <input type="checkbox"/> | Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96. |
| <input type="checkbox"/> | Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97. |
| <input type="checkbox"/> | Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97. |
| <input type="checkbox"/> | Pennsylvania CSO Policy, 385-2000-011, 9/08. |
| <input type="checkbox"/> | Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03. |
| <input type="checkbox"/> | Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97. |
| <input type="checkbox"/> | Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97. |
| <input type="checkbox"/> | Implementation Guidance Design Conditions, 391-2000-006, 9/97. |
| <input type="checkbox"/> | Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004. |
| <input type="checkbox"/> | Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997. |
| <input type="checkbox"/> | Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99. |
| <input type="checkbox"/> | Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004. |
| <input type="checkbox"/> | Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97. |
| <input type="checkbox"/> | Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008. |
| <input type="checkbox"/> | Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994. |
| <input type="checkbox"/> | Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09. |
| <input type="checkbox"/> | Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97. |
| <input type="checkbox"/> | Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97. |
| <input type="checkbox"/> | Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99. |
| <input type="checkbox"/> | Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999. |
| <input type="checkbox"/> | Design Stream Flows, 391-2000-023, 9/98. |
| <input type="checkbox"/> | Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98. |
| <input type="checkbox"/> | Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97. |
| <input type="checkbox"/> | Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07. |
| <input type="checkbox"/> | SOP: [REDACTED] |
| <input type="checkbox"/> | Other: [REDACTED] |

Attachments

Attachment A: StreamStats Report

Attachment B: Outfall 001 Toxics Management Spreadsheet Evaluation

Attachment C: Outfall 001 TRC Spreadsheet Evaluation

Attachment D: Outfall 001 WQM7.0 Model Run

Attachment E: Site Temperature Model Spreadsheet Evaluation

Attachment F: Effluent Limitation Guidelines Calculations

Attachment G: Outfall 003 Toxics Management Spreadsheet Evaluation

Attachment H: Outfall 003 TRC Spreadsheet Evaluation

Attachment I: Site Flow Diagrams

Attachment A:
StreamStats Report

StreamStats Report

Region ID: PA

Workspace ID: PA20220302192820361000

Clicked Point (Latitude, Longitude): 40.33691, -79.89389

Time: 2022-03-02 14:28:46 -0500



Basin Characteristics

| Parameter Code | Parameter Description | Value | Unit |
|----------------|--|--------|--------------|
| DRNAREA | Area that drains to a point on a stream | 5410 | square miles |
| ELEV | Mean Basin Elevation | 1814 | feet |
| PRECIP | Mean Annual Precipitation | 47 | inches |
| FOREST | Percentage of area covered by forest | 75.749 | percent |
| URBAN | Percentage of basin with urban development | 3.1205 | percent |

Annual Flow Statistics Parameters [99.9 Percent (5410 square miles) Statewide Mean and Base Flow]

| Parameter Code | Parameter Name | Value | Units | Min Limit | Max Limit |
|----------------|---------------------------|--------|--------------|-----------|-----------|
| DRNAREA | Drainage Area | 5410 | square miles | 2.26 | 1720 |
| ELEV | Mean Basin Elevation | 1814 | feet | 130 | 2700 |
| PRECIP | Mean Annual Precipitation | 47 | inches | 33.1 | 50.4 |
| FOREST | Percent Forest | 75.749 | percent | 5.1 | 100 |
| URBAN | Percent Urban | 3.1205 | percent | 0 | 89 |

Annual Flow Statistics Disclaimers [99.9 Percent (5410 square miles) Statewide Mean and Base Flow]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors

Annual Flow Statistics Flow Report [99.9 Percent (5410 square miles) Statewide Mean and Base Flow]

| Statistic | Value | Unit |
|------------------|-------|--------|
| Mean Annual Flow | 11300 | ft^3/s |

Annual Flow Statistics Citations

Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)

Attachment B:

Outfall 001 Toxics Management Spreadsheet Evaluation



Discharge Information

Instructions Discharge Stream

Facility: USS Mon Valley Irvin Plant NPDES Permit No.: PA0004073 Outfall No.: 001
Evaluation Type: Major Sewage / Industrial Waste Wastewater Description: IW ELG, Sewage, NCCW, Boiler Blowdown

| Discharge Characteristics | | | | | | |
|---------------------------|------------------|----------|----------------------------|-----|-----|--------------------------|
| Design Flow (MGD)* | Hardness (mg/l)* | pH (SU)* | Partial Mix Factors (PMFs) | | | Complete Mix Times (min) |
| | | | AFC | CFC | THH | |
| 23.6 | 160 | 7 | | | | |

| | Discharge Pollutant | Units | Max Discharge Conc | 0 if left blank | | 0.5 if left blank | | 0 if left blank | | 1 if left blank | |
|----------------|---------------------------------|-------|--------------------|-----------------|-------------|-------------------|-----------|-----------------|------------|-----------------|---------------|
| | | | | Trib Conc | Stream Conc | Daily CV | Hourly CV | Stream CV | Fate Coeff | FOS | Criteri a Mod |
| Group 1 | Total Dissolved Solids (PWS) | mg/L | 340 | | | | | | | | |
| | Chloride (PWS) | mg/L | 70.8 | | | | | | | | |
| | Bromide | mg/L | 1.3 | | | | | | | | |
| | Sulfate (PWS) | mg/L | 75.6 | | | | | | | | |
| | Fluoride (PWS) | mg/L | < 0.22 | | | | | | | | |
| | Total Aluminum | µg/L | 1750 | | | | | | | | |
| | Total Antimony | µg/L | 0.42 | | | | | | | | |
| | Total Arsenic | µg/L | < 1 | | | | | | | | |
| | Total Barium | µg/L | 49 | | | | | | | | |
| | Total Beryllium | µg/L | < 1 | | | | | | | | |
| | Total Boron | µg/L | 48 | | | | | | | | |
| | Total Cadmium | µg/L | < 0.16 | | | | | | | | |
| | Total Chromium (III) | µg/L | 3.9 | | | | | | | | |
| | Hexavalent Chromium | µg/L | 3.9 | | | | | | | | |
| | Total Cobalt | µg/L | 3.71 | | | | | | | | |
| | Total Copper | µg/L | 5.27 | | | | | | | | |
| | Free Cyanide | µg/L | | | | | | | | | |
| | Total Cyanide | µg/L | < 10 | | | | | | | | |
| | Dissolved Iron | µg/L | 116 | | | | | | | | |
| | Total Iron | µg/L | 4290 | | | | | | | | |
| | Total Lead | µg/L | 3.7 | | | | | | | | |
| | Total Manganese | µg/L | 242 | | | | | | | | |
| | Total Mercury | µg/L | < 0.2 | | | | | | | | |
| | Total Nickel | µg/L | 9.1 | | | | | | | | |
| | Total Phenols (Phenolics) (PWS) | µg/L | 13 | | | | | | | | |
| | Total Selenium | µg/L | < 2 | | | | | | | | |
| | Total Silver | µg/L | < 0.144 | | | | | | | | |
| | Total Thallium | µg/L | < 1 | | | | | | | | |
| | Total Zinc | µg/L | 43.6 | | | | | | | | |
| | Total Molybdenum | µg/L | < 2.37 | | | | | | | | |
| Group 2 | Acrolein | µg/L | < 1.3 | | | | | | | | |
| | Acrylamide | µg/L | < 0.011 | | | | | | | | |
| | Acrylonitrile | µg/L | < 2 | | | | | | | | |
| | Benzene | µg/L | < 0.12 | | | | | | | | |
| | Bromoform | µg/L | < 0.37 | | | | | | | | |

| | | | | | | | | | | | | | | | | | | | | |
|---------|-----------------------------|------|---|------|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|
| Group 3 | Carbon Tetrachloride | µg/L | < | 0.23 | | | | | | | | | | | | | | | | |
| | Chlorobenzene | µg/L | | 0.25 | | | | | | | | | | | | | | | | |
| | Chlorodibromomethane | µg/L | < | 0.6 | | | | | | | | | | | | | | | | |
| | Chloroethane | µg/L | < | 0.27 | | | | | | | | | | | | | | | | |
| | 2-Chloroethyl Vinyl Ether | µg/L | < | 3.1 | | | | | | | | | | | | | | | | |
| | Chloroform | µg/L | | 3.4 | | | | | | | | | | | | | | | | |
| | Dichlorobromomethane | µg/L | | 1.7 | | | | | | | | | | | | | | | | |
| | 1,1-Dichloroethane | µg/L | < | 0.05 | | | | | | | | | | | | | | | | |
| | 1,2-Dichloroethane | µg/L | < | 0.12 | | | | | | | | | | | | | | | | |
| | 1,1-Dichloroethylene | µg/L | < | 0.13 | | | | | | | | | | | | | | | | |
| | 1,2-Dichloropropane | µg/L | < | 0.26 | | | | | | | | | | | | | | | | |
| | 1,3-Dichloropropylene | µg/L | < | 0.47 | | | | | | | | | | | | | | | | |
| | 1,4-Dioxane | µg/L | | 0.4 | | | | | | | | | | | | | | | | |
| | Ethylbenzene | µg/L | < | 0.2 | | | | | | | | | | | | | | | | |
| | Methyl Bromide | µg/L | < | 0.42 | | | | | | | | | | | | | | | | |
| | Methyl Chloride | µg/L | < | 0.33 | | | | | | | | | | | | | | | | |
| | Methylene Chloride | µg/L | < | 0.14 | | | | | | | | | | | | | | | | |
| | 1,1,2,2-Tetrachloroethane | µg/L | < | 0.38 | | | | | | | | | | | | | | | | |
| | Tetrachloroethylene | µg/L | < | 0.27 | | | | | | | | | | | | | | | | |
| | Toluene | µg/L | < | 0.24 | | | | | | | | | | | | | | | | |
| | 1,2-trans-Dichloroethylene | µg/L | < | 0.08 | | | | | | | | | | | | | | | | |
| | 1,1,1-Trichloroethane | µg/L | < | 0.12 | | | | | | | | | | | | | | | | |
| | 1,1,2-Trichloroethane | µg/L | < | 0.13 | | | | | | | | | | | | | | | | |
| | Trichloroethylene | µg/L | < | 0.29 | | | | | | | | | | | | | | | | |
| | Vinyl Chloride | µg/L | < | 0.33 | | | | | | | | | | | | | | | | |
| Group 4 | 2-Chlorophenol | µg/L | < | 0.38 | | | | | | | | | | | | | | | | |
| | 2,4-Dichlorophenol | µg/L | < | 0.43 | | | | | | | | | | | | | | | | |
| | 2,4-Dimethylphenol | µg/L | < | 0.46 | | | | | | | | | | | | | | | | |
| | 4,6-Dinitro-o-Cresol | µg/L | < | 0.97 | | | | | | | | | | | | | | | | |
| | 2,4-Dinitrophenol | µg/L | < | 0.97 | | | | | | | | | | | | | | | | |
| | 2-Nitrophenol | µg/L | < | 0.38 | | | | | | | | | | | | | | | | |
| | 4-Nitrophenol | µg/L | < | 0.97 | | | | | | | | | | | | | | | | |
| | p-Chloro-m-Cresol | µg/L | < | 0.38 | | | | | | | | | | | | | | | | |
| | Pentachlorophenol | µg/L | < | 1.7 | | | | | | | | | | | | | | | | |
| | Phenol | µg/L | | 5 | | | | | | | | | | | | | | | | |
| Group 5 | 2,4,6-Trichlorophenol | µg/L | < | 0.46 | | | | | | | | | | | | | | | | |
| | Acenaphthene | µg/L | < | 0.39 | | | | | | | | | | | | | | | | |
| | Acenaphthylene | µg/L | < | 0.38 | | | | | | | | | | | | | | | | |
| | Anthracene | µg/L | < | 0.39 | | | | | | | | | | | | | | | | |
| | Benzidine | µg/L | < | 2.5 | | | | | | | | | | | | | | | | |
| | Benzo(a)Anthracene | µg/L | < | 0.4 | | | | | | | | | | | | | | | | |
| | Benzo(a)Pyrene | µg/L | < | 0.35 | | | | | | | | | | | | | | | | |
| | 3,4-Benzofluoranthene | µg/L | < | 0.39 | | | | | | | | | | | | | | | | |
| | Benzo(ghi)Perylene | µg/L | < | 0.41 | | | | | | | | | | | | | | | | |
| | Benzo(k)Fluoranthene | µg/L | < | 0.38 | | | | | | | | | | | | | | | | |
| | Bis(2-Chloroethoxy)Methane | µg/L | < | 0.43 | | | | | | | | | | | | | | | | |
| | Bis(2-Chloroethyl)Ether | µg/L | < | 0.37 | | | | | | | | | | | | | | | | |
| | Bis(2-Chloroisopropyl)Ether | µg/L | < | 0.43 | | | | | | | | | | | | | | | | |
| | Bis(2-Ethylhexyl)Phthalate | µg/L | | 2.6 | | | | | | | | | | | | | | | | |
| | 4-Bromophenyl Phenyl Ether | µg/L | < | 0.44 | | | | | | | | | | | | | | | | |
| | Butyl Benzyl Phthalate | µg/L | < | 0.57 | | | | | | | | | | | | | | | | |
| | 2-Chloronaphthalene | µg/L | < | 0.39 | | | | | | | | | | | | | | | | |
| | 4-Chlorophenyl Phenyl Ether | µg/L | < | 0.39 | | | | | | | | | | | | | | | | |
| | Chrysene | µg/L | < | 0.41 | | | | | | | | | | | | | | | | |
| | Dibenzo(a,h)Anthracene | µg/L | < | 0.42 | | | | | | | | | | | | | | | | |
| | 1,2-Dichlorobenzene | µg/L | < | 0.37 | | | | | | | | | | | | | | | | |
| | 1,3-Dichlorobenzene | µg/L | < | 0.43 | | | | | | | | | | | | | | | | |
| | 1,4-Dichlorobenzene | µg/L | < | 0.43 | | | | | | | | | | | | | | | | |
| | 3,3-Dichlorobenzidine | µg/L | < | 1 | | | | | | | | | | | | | | | | |
| | Diethyl Phthalate | µg/L | | 2 | | | | | | | | | | | | | | | | |
| | Dimethyl Phthalate | µg/L | < | 0.41 | | | | | | | | | | | | | | | | |
| | Di-n-Butyl Phthalate | µg/L | < | 0.56 | | | | | | | | | | | | | | | | |
| | 2,4-Dinitrotoluene | µg/L | < | 0.44 | | | | | | | | | | | | | | | | |

| | | | | | | | | | | | |
|---------------------------|------|---|------|--|--|--|--|--|--|--|--|
| 2,6-Dinitrotoluene | µg/L | < | 0.4 | | | | | | | | |
| Di-n-Octyl Phthalate | µg/L | < | 0.86 | | | | | | | | |
| 1,2-Diphenylhydrazine | µg/L | < | 0.37 | | | | | | | | |
| Fluoranthene | µg/L | < | 0.42 | | | | | | | | |
| Fluorene | µg/L | < | 0.37 | | | | | | | | |
| Hexachlorobenzene | µg/L | < | 0.42 | | | | | | | | |
| Hexachlorobutadiene | µg/L | < | 0.48 | | | | | | | | |
| Hexachlorocyclopentadiene | µg/L | < | 0.72 | | | | | | | | |
| Hexachloroethane | µg/L | < | 0.36 | | | | | | | | |
| Indeno(1,2,3-cd)Pyrene | µg/L | < | 0.39 | | | | | | | | |
| Isophorone | µg/L | < | 0.42 | | | | | | | | |
| Naphthalene | µg/L | < | 0.39 | | | | | | | | |
| Nitrobenzene | µg/L | < | 0.51 | | | | | | | | |
| n-Nitrosodimethylamine | µg/L | < | 1.1 | | | | | | | | |
| n-Nitrosodi-n-Propylamine | µg/L | < | 0.41 | | | | | | | | |
| n-Nitrosodiphenylamine | µg/L | < | 0.48 | | | | | | | | |
| Phenanthrene | µg/L | < | 0.38 | | | | | | | | |
| Pyrene | µg/L | < | 0.41 | | | | | | | | |
| 1,2,4-Trichlorobenzene | µg/L | < | 0.41 | | | | | | | | |



Stream / Surface Water Information

USS Mon Valley Irvin Plant, NPDES Permit No. PA0004073, Outfall 001

Instructions Discharge Stream

Receiving Surface Water Name: Monongahela

No. Reaches to Model: 1

Statewide Criteria
 Great Lakes Criteria
 ORSANCO Criteria

| Location | Stream Code* | RMI* | Elevation (ft)* | DA (mi ²)* | Slope (ft/ft) | PWS Withdrawal (MGD) | Apply Fish Criteria* |
|--------------------|--------------|-------|-----------------|------------------------|---------------|----------------------|----------------------|
| Point of Discharge | 037185 | 17.53 | 712 | 5410 | | | Yes |
| End of Reach 1 | 037185 | 16 | 710 | 5411 | | | Yes |

*Q*₇₋₁₀

| Location | RMI | LFY (cfs/mi ²)* | Flow (cfs) | | W/D Ratio | Width (ft) | Depth (ft) | Velocity (fps) | Travel Time (days) | Tributary | | Stream | | Analysis | |
|--------------------|-------|-----------------------------|------------|-----------|-----------|------------|------------|----------------|--------------------|-----------|----|-----------|-----|----------|----|
| | | | Stream | Tributary | | | | | | Hardness | pH | Hardness* | pH* | Hardness | pH |
| Point of Discharge | 17.53 | 0.1 | 550 | | | 850 | 12 | | | | | 100 | 7 | | |
| End of Reach 1 | 16 | 0.1 | 550 | | | 850 | 12 | | | | | | | | |

*Q*_h

| Location | RMI | LFY (cfs/mi ²)* | Flow (cfs) | | W/D Ratio | Width (ft) | Depth (ft) | Velocity (fps) | Travel Time (days) | Tributary | | Stream | | Analysis | |
|--------------------|-------|-----------------------------|------------|-----------|-----------|------------|------------|----------------|--------------------|-----------|----|-----------|-----|----------|----|
| | | | Stream | Tributary | | | | | | Hardness | pH | Hardness* | pH* | Hardness | pH |
| Point of Discharge | 17.53 | | | | | | | | | | | | | | |
| End of Reach 1 | 16 | | | | | | | | | | | | | | |



Model Results

USS Mon Valley Irvin Plant, NPDES Permit No. PA0004073, Outfall 001

All Inputs Results Limits

Hydrodynamics

Wasteload Allocations

AFC CCT (min): PMF: Analysis Hardness (mg/l): Analysis pH:

| Pollutants | Stream Conc (mg/L) | Stream CV | Trib Conc (µg/L) | Fate Coef | WQC (µg/L) | WQ Obj (µg/L) | WLA (µg/L) | Comments |
|---------------------------------|--------------------|-----------|------------------|-----------|------------|---------------|------------|----------------------------------|
| Total Dissolved Solids (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Chloride (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Sulfate (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Fluoride (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Aluminum | 0 | 0 | | 0 | 750 | 750 | 1,949 | |
| Total Antimony | 0 | 0 | | 0 | 1,100 | 1,100 | 2,859 | |
| Total Arsenic | 0 | 0 | | 0 | 340 | 340 | 884 | Chem Translator of 1 applied |
| Total Barium | 0 | 0 | | 0 | 21,000 | 21,000 | 54,579 | |
| Total Boron | 0 | 0 | | 0 | 8,100 | 8,100 | 21,052 | |
| Total Cadmium | 0 | 0 | | 0 | 2.464 | 2.63 | 6.85 | Chem Translator of 0.935 applied |
| Total Chromium (III) | 0 | 0 | | 0 | 675.422 | 2,137 | 5,555 | Chem Translator of 0.318 applied |
| Hexavalent Chromium | 0 | 0 | | 0 | 16 | 16.3 | 42.3 | Chem Translator of 0.982 applied |
| Total Cobalt | 0 | 0 | | 0 | 95 | 95.0 | 247 | |
| Total Copper | 0 | 0 | | 0 | 16.344 | 17.0 | 44.2 | Chem Translator of 0.96 applied |
| Dissolved Iron | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Iron | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Lead | 0 | 0 | | 0 | 80.909 | 106 | 276 | Chem Translator of 0.781 applied |
| Total Manganese | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Mercury | 0 | 0 | | 0 | 1.400 | 1.85 | 4.28 | Chem Translator of 0.85 applied |
| Total Nickel | 0 | 0 | | 0 | 558.188 | 550 | 1,454 | Chem Translator of 0.998 applied |
| Total Phenols (Phenolics) (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Selenium | 0 | 0 | | 0 | N/A | N/A | N/A | Chem Translator of 0.922 applied |
| Total Silver | 0 | 0 | | 0 | 4.598 | 5.41 | 14.1 | Chem Translator of 0.85 applied |
| Total Thallium | 0 | 0 | | 0 | 65 | 65.0 | 169 | |
| Total Zinc | 0 | 0 | | 0 | 139.730 | 143 | 371 | Chem Translator of 0.978 applied |
| Acrolein | 0 | 0 | | 0 | 3 | 3.0 | 7.8 | |

| | | | | | | | | |
|-----------------------------|---|---|--|---|--------|--------|--------|--|
| Acrylamide | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Acrylonitrile | 0 | 0 | | 0 | 650 | 650 | 1,689 | |
| Benzene | 0 | 0 | | 0 | 640 | 640 | 1,663 | |
| Bromoform | 0 | 0 | | 0 | 1,800 | 1,800 | 4,678 | |
| Carbon Tetrachloride | 0 | 0 | | 0 | 2,800 | 2,800 | 7,277 | |
| Chlorobenzene | 0 | 0 | | 0 | 1,200 | 1,200 | 3,119 | |
| Chlorodibromomethane | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 2-Chloroethyl Vinyl Ether | 0 | 0 | | 0 | 18,000 | 18,000 | 46,782 | |
| Chloroform | 0 | 0 | | 0 | 1,900 | 1,900 | 4,938 | |
| Dichlorobromomethane | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 1,2-Dichloroethane | 0 | 0 | | 0 | 15,000 | 15,000 | 38,985 | |
| 1,1-Dichloroethylene | 0 | 0 | | 0 | 7,500 | 7,500 | 19,492 | |
| 1,2-Dichloropropane | 0 | 0 | | 0 | 11,000 | 11,000 | 28,589 | |
| 1,3-Dichloropropylene | 0 | 0 | | 0 | 310 | 310 | 806 | |
| Ethylbenzene | 0 | 0 | | 0 | 2,900 | 2,900 | 7,537 | |
| Methyl Bromide | 0 | 0 | | 0 | 550 | 550 | 1,429 | |
| Methyl Chloride | 0 | 0 | | 0 | 28,000 | 28,000 | 72,772 | |
| Methylene Chloride | 0 | 0 | | 0 | 12,000 | 12,000 | 31,188 | |
| 1,1,2,2-Tetrachloroethane | 0 | 0 | | 0 | 1,000 | 1,000 | 2,599 | |
| Tetrachloroethylene | 0 | 0 | | 0 | 700 | 700 | 1,819 | |
| Toluene | 0 | 0 | | 0 | 1,700 | 1,700 | 4,418 | |
| 1,2-trans-Dichloroethylene | 0 | 0 | | 0 | 6,800 | 6,800 | 17,673 | |
| 1,1,1-Trichloroethane | 0 | 0 | | 0 | 3,000 | 3,000 | 7,797 | |
| 1,1,2-Trichloroethane | 0 | 0 | | 0 | 3,400 | 3,400 | 8,837 | |
| Trichloroethylene | 0 | 0 | | 0 | 2,300 | 2,300 | 5,978 | |
| Vinyl Chloride | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 2-Chlorophenol | 0 | 0 | | 0 | 560 | 560 | 1,455 | |
| 2,4-Dichlorophenol | 0 | 0 | | 0 | 1,700 | 1,700 | 4,418 | |
| 2,4-Dimethylphenol | 0 | 0 | | 0 | 660 | 660 | 1,715 | |
| 4,6-Dinitro-o-Cresol | 0 | 0 | | 0 | 80 | 80.0 | 208 | |
| 2,4-Dinitrophenol | 0 | 0 | | 0 | 660 | 660 | 1,715 | |
| 2-Nitrophenol | 0 | 0 | | 0 | 8,000 | 8,000 | 20,792 | |
| 4-Nitrophenol | 0 | 0 | | 0 | 2,300 | 2,300 | 5,978 | |
| p-Chloro-m-Cresol | 0 | 0 | | 0 | 160 | 160 | 416 | |
| Pentachlorophenol | 0 | 0 | | 0 | 8,723 | 8.72 | 22.7 | |
| Phenol | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 2,4,6-Trichlorophenol | 0 | 0 | | 0 | 460 | 460 | 1,196 | |
| Acenaphthene | 0 | 0 | | 0 | 83 | 83.0 | 216 | |
| Anthracene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Benzidine | 0 | 0 | | 0 | 300 | 300 | 780 | |
| Benzo(a)Anthracene | 0 | 0 | | 0 | 0.5 | 0.5 | 1.3 | |
| Benzo(a)Pyrene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 3,4-Benzofluoranthene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Benzo(k)Fluoranthene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Bis(2-Chloroethyl)Ether | 0 | 0 | | 0 | 30,000 | 30,000 | 77,970 | |
| Bis(2-Chloroisopropyl)Ether | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Bis(2-Ethylhexyl)Phthalate | 0 | 0 | | 0 | 4,500 | 4,500 | 11,695 | |
| 4-Bromophenyl Phenyl Ether | 0 | 0 | | 0 | 270 | 270 | 702 | |

| | | | | | | | | |
|---------------------------|---|---|--|---|--------|--------|--------|--|
| Butyl Benzyl Phthalate | 0 | 0 | | 0 | 140 | 140 | 364 | |
| 2-Chloronaphthalene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Chrysene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Dibenzo(a,h)Anthracene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 1,2-Dichlorobenzene | 0 | 0 | | 0 | 820 | 820 | 2,131 | |
| 1,3-Dichlorobenzene | 0 | 0 | | 0 | 350 | 350 | 910 | |
| 1,4-Dichlorobenzene | 0 | 0 | | 0 | 730 | 730 | 1,897 | |
| 3,3-Dichlorobenzidine | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Diethyl Phthalate | 0 | 0 | | 0 | 4,000 | 4,000 | 10,396 | |
| Dimethyl Phthalate | 0 | 0 | | 0 | 2,500 | 2,500 | 6,497 | |
| Di-n-Butyl Phthalate | 0 | 0 | | 0 | 110 | 110 | 286 | |
| 2,4-Dinitrotoluene | 0 | 0 | | 0 | 1,600 | 1,600 | 4,158 | |
| 2,6-Dinitrotoluene | 0 | 0 | | 0 | 990 | 990 | 2,573 | |
| 1,2-Diphenylhydrazine | 0 | 0 | | 0 | 15 | 15.0 | 39.0 | |
| Fluoranthene | 0 | 0 | | 0 | 200 | 200 | 520 | |
| Fluorene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Hexachlorobenzene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Hexachlorobutadiene | 0 | 0 | | 0 | 10 | 10.0 | 26.0 | |
| Hexachlorocyclopentadiene | 0 | 0 | | 0 | 5 | 5.0 | 13.0 | |
| Hexachloroethane | 0 | 0 | | 0 | 60 | 60.0 | 156 | |
| Indeno(1,2,3-cd)Pyrene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Isophorone | 0 | 0 | | 0 | 10,000 | 10,000 | 25,990 | |
| Naphthalene | 0 | 0 | | 0 | 140 | 140 | 364 | |
| Nitrobenzene | 0 | 0 | | 0 | 4,000 | 4,000 | 10,396 | |
| n-Nitrosodimethylamine | 0 | 0 | | 0 | 17,000 | 17,000 | 44,183 | |
| n-Nitrosodi-n-Propylamine | 0 | 0 | | 0 | N/A | N/A | N/A | |
| n-Nitrosodiphenylamine | 0 | 0 | | 0 | 300 | 300 | 780 | |
| Phenanthrene | 0 | 0 | | 0 | 5 | 5.0 | 13.0 | |
| Pyrene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 1,2,4-Trichlorobenzene | 0 | 0 | | 0 | 130 | 130 | 338 | |

CFC CCT (min): 720 PMF: 0.735 Analysis Hardness (mg/l): 104.97 Analysis pH: 7.00

| Pollutants | Stream Conc (μg/L) | Stream CV | Trib Conc (μg/L) | Fate Coef | WQC (μg/L) | WQ Obj (μg/L) | WLA (μg/L) | Comments |
|------------------------------|--------------------|-----------|------------------|-----------|------------|---------------|------------|----------------------------------|
| Total Dissolved Solids (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Chloride (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Sulfate (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Fluoride (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Aluminum | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Antimony | 0 | 0 | | 0 | 220 | 220 | 2,657 | |
| Total Arsenic | 0 | 0 | | 0 | 150 | 150 | 1,812 | Chem Translator of 1 applied |
| Total Barium | 0 | 0 | | 0 | 4,100 | 4,100 | 49,521 | |
| Total Boron | 0 | 0 | | 0 | 1,600 | 1,600 | 19,325 | |
| Total Cadmium | 0 | 0 | | 0 | 0.254 | 0.28 | 3.39 | Chem Translator of 0.907 applied |
| Total Chromium (III) | 0 | 0 | | 0 | 77.117 | 89.7 | 1,083 | Chem Translator of 0.86 applied |
| Hexavalent Chromium | 0 | 0 | | 0 | 10 | 10.4 | 126 | Chem Translator of 0.962 applied |

| | | | | | | | | |
|---------------------------------|---|---|--|---|---------|-------|--------|----------------------------------|
| Total Cobalt | 0 | 0 | | 0 | 19 | 19.0 | 229 | |
| Total Copper | 0 | 0 | | 0 | 9.335 | 9.72 | 117 | Chem Translator of 0.98 applied |
| Dissolved Iron | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Iron | 0 | 0 | | 0 | 1,500 | 1,500 | 24,097 | WQC = 30 day average; PMF = 1 |
| Total Lead | 0 | 0 | | 0 | 2.653 | 3.38 | 40.9 | Chem Translator of 0.784 applied |
| Total Manganese | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Mercury | 0 | 0 | | 0 | 0.770 | 0.91 | 10.9 | Chem Translator of 0.85 applied |
| Total Nickel | 0 | 0 | | 0 | 54.184 | 54.3 | 656 | Chem Translator of 0.997 applied |
| Total Phenols (Phenolics) (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Selenium | 0 | 0 | | 0 | 4.800 | 4.99 | 60.3 | Chem Translator of 0.922 applied |
| Total Silver | 0 | 0 | | 0 | N/A | N/A | N/A | Chem Translator of 1 applied |
| Total Thallium | 0 | 0 | | 0 | 13 | 13.0 | 157 | |
| Total Zinc | 0 | 0 | | 0 | 123.093 | 125 | 1,508 | Chem Translator of 0.986 applied |
| Acrolein | 0 | 0 | | 0 | 3 | 3.0 | 36.2 | |
| Acrylamide | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Acrylonitrile | 0 | 0 | | 0 | 130 | 130 | 1,570 | |
| Benzene | 0 | 0 | | 0 | 130 | 130 | 1,570 | |
| Bromoform | 0 | 0 | | 0 | 370 | 370 | 4,469 | |
| Carbon Tetrachloride | 0 | 0 | | 0 | 560 | 560 | 6,764 | |
| Chlorobenzene | 0 | 0 | | 0 | 240 | 240 | 2,899 | |
| Chlorodibromomethane | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 2-Chloroethyl Vinyl Ether | 0 | 0 | | 0 | 3,500 | 3,500 | 42,274 | |
| Chloroform | 0 | 0 | | 0 | 390 | 390 | 4,710 | |
| Dichlorobromomethane | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 1,2-Dichloroethane | 0 | 0 | | 0 | 3,100 | 3,100 | 37,442 | |
| 1,1-Dichloroethylene | 0 | 0 | | 0 | 1,500 | 1,500 | 18,117 | |
| 1,2-Dichloropropane | 0 | 0 | | 0 | 2,200 | 2,200 | 26,572 | |
| 1,3-Dichloropropylene | 0 | 0 | | 0 | 61 | 61.0 | 737 | |
| Ethylbenzene | 0 | 0 | | 0 | 580 | 580 | 7,005 | |
| Methyl Bromide | 0 | 0 | | 0 | 110 | 110 | 1,329 | |
| Methyl Chloride | 0 | 0 | | 0 | 5,500 | 5,500 | 66,430 | |
| Methylene Chloride | 0 | 0 | | 0 | 2,400 | 2,400 | 28,988 | |
| 1,1,2,2-Tetrachloroethane | 0 | 0 | | 0 | 210 | 210 | 2,536 | |
| Tetrachloroethylene | 0 | 0 | | 0 | 140 | 140 | 1,691 | |
| Toluene | 0 | 0 | | 0 | 330 | 330 | 3,986 | |
| 1,2-trans-Dichloroethylene | 0 | 0 | | 0 | 1,400 | 1,400 | 16,909 | |
| 1,1,1-Trichloroethane | 0 | 0 | | 0 | 610 | 610 | 7,368 | |
| 1,1,2-Trichloroethane | 0 | 0 | | 0 | 680 | 680 | 8,213 | |
| Trichloroethylene | 0 | 0 | | 0 | 450 | 450 | 5,435 | |
| Vinyl Chloride | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 2-Chlorophenol | 0 | 0 | | 0 | 110 | 110 | 1,329 | |
| 2,4-Dichlorophenol | 0 | 0 | | 0 | 340 | 340 | 4,107 | |
| 2,4-Dimethylphenol | 0 | 0 | | 0 | 130 | 130 | 1,570 | |
| 4,6-Dinitro-o-Cresol | 0 | 0 | | 0 | 18 | 18.0 | 193 | |
| 2,4-Dinitrophenol | 0 | 0 | | 0 | 130 | 130 | 1,570 | |

| | | | | | | | | |
|-----------------------------|---|---|--|---|-------|-------|--------|--|
| 2-Nitrophenol | 0 | 0 | | 0 | 1,600 | 1,600 | 19,325 | |
| 4-Nitrophenol | 0 | 0 | | 0 | 470 | 470 | 5,677 | |
| p-Chloro-m-Cresol | 0 | 0 | | 0 | 500 | 500 | 6,039 | |
| Pentachlorophenol | 0 | 0 | | 0 | 6,693 | 6.69 | 80.8 | |
| Phenol | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 2,4,6-Trichlorophenol | 0 | 0 | | 0 | 91 | 91.0 | 1,099 | |
| Acenaphthene | 0 | 0 | | 0 | 17 | 17.0 | 205 | |
| Anthracene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Benzidine | 0 | 0 | | 0 | 59 | 59.0 | 713 | |
| Benzo(a)Anthracene | 0 | 0 | | 0 | 0.1 | 0.1 | 1.21 | |
| Benzo(a)Pyrene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 3,4-Benzofluoranthene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Benzo(k)Fluoranthene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Bis(2-Chloroethyl)Ether | 0 | 0 | | 0 | 6,000 | 6,000 | 72,489 | |
| Bis(2-Chloroisopropyl)Ether | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Bis(2-Ethylhexyl)Phthalate | 0 | 0 | | 0 | 910 | 910 | 10,991 | |
| 4-Bromophenyl Phenyl Ether | 0 | 0 | | 0 | 54 | 54.0 | 652 | |
| Butyl Benzyl Phthalate | 0 | 0 | | 0 | 35 | 35.0 | 423 | |
| 2-Chloronaphthalene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Chrysene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Dibenzo(a,h)Anthracene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 1,2-Dichlorobenzene | 0 | 0 | | 0 | 180 | 180 | 1,933 | |
| 1,3-Dichlorobenzene | 0 | 0 | | 0 | 69 | 69.0 | 833 | |
| 1,4-Dichlorobenzene | 0 | 0 | | 0 | 150 | 150 | 1,812 | |
| 3,3-Dichlorobenzidine | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Diethyl Phthalate | 0 | 0 | | 0 | 800 | 800 | 9,663 | |
| Dimethyl Phthalate | 0 | 0 | | 0 | 500 | 500 | 6,039 | |
| Di-n-Butyl Phthalate | 0 | 0 | | 0 | 21 | 21.0 | 254 | |
| 2,4-Dinitrotoluene | 0 | 0 | | 0 | 320 | 320 | 3,865 | |
| 2,6-Dinitrotoluene | 0 | 0 | | 0 | 200 | 200 | 2,416 | |
| 1,2-Diphenylhydrazine | 0 | 0 | | 0 | 3 | 3.0 | 36.2 | |
| Fluoranthene | 0 | 0 | | 0 | 40 | 40.0 | 483 | |
| Fluorene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Hexachlorobenzene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Hexachlorobutadiene | 0 | 0 | | 0 | 2 | 2.0 | 24.2 | |
| Hexachlorocyclopentadiene | 0 | 0 | | 0 | 1 | 1.0 | 12.1 | |
| Hexachloroethane | 0 | 0 | | 0 | 12 | 12.0 | 145 | |
| Indeno(1,2,3-cd)Pyrene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Isophorone | 0 | 0 | | 0 | 2,100 | 2,100 | 25,364 | |
| Naphthalene | 0 | 0 | | 0 | 43 | 43.0 | 519 | |
| Nitrobenzene | 0 | 0 | | 0 | 810 | 810 | 9,783 | |
| n-Nitrosodimethylamine | 0 | 0 | | 0 | 3,400 | 3,400 | 41,066 | |
| n-Nitrosodi-n-Propylamine | 0 | 0 | | 0 | N/A | N/A | N/A | |
| n-Nitrosodiphenylamine | 0 | 0 | | 0 | 59 | 59.0 | 713 | |
| Phenanthrene | 0 | 0 | | 0 | 1 | 1.0 | 12.1 | |

| | | | | | | | | |
|------------------------|---|---|--|---|-----|------|-----|--|
| Pyrene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 1,2,4-Trichlorobenzene | 0 | 0 | | 0 | 26 | 26.0 | 314 | |

THH CCT (min): 720 PMF: 0.735 Analysis Hardness (mg/l): N/A Analysis pH: N/A

| Pollutants | Stream Conc (µg/L) | Stream CV | Trb Conc (µg/L) | Fate Coef | WQC (µg/L) | WQ Obj (µg/L) | WLA (µg/L) | Comments |
|---------------------------------|--------------------|-----------|-----------------|-----------|------------|---------------|------------|----------|
| Total Dissolved Solids (PWS) | 0 | 0 | | 0 | 500,000 | 500,000 | N/A | |
| Chloride (PWS) | 0 | 0 | | 0 | 250,000 | 250,000 | N/A | |
| Sulfate (PWS) | 0 | 0 | | 0 | 250,000 | 250,000 | N/A | |
| Fluoride (PWS) | 0 | 0 | | 0 | 2,000 | 2,000 | N/A | |
| Total Aluminum | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Antimony | 0 | 0 | | 0 | 5.6 | 5.6 | 67.6 | |
| Total Arsenic | 0 | 0 | | 0 | 10 | 10.0 | 121 | |
| Total Barium | 0 | 0 | | 0 | 2,400 | 2,400 | 28,988 | |
| Total Boron | 0 | 0 | | 0 | 3,100 | 3,100 | 37,442 | |
| Total Cadmium | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Chromium (III) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Hexavalent Chromium | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Cobalt | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Copper | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Dissolved Iron | 0 | 0 | | 0 | 300 | 300 | 3,623 | |
| Total Iron | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Lead | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Manganese | 0 | 0 | | 0 | 1,000 | 1,000 | 12,078 | |
| Total Mercury | 0 | 0 | | 0 | 0.050 | 0.05 | 0.6 | |
| Total Nickel | 0 | 0 | | 0 | 610 | 610 | 7,368 | |
| Total Phenols (Phenolics) (PWS) | 0 | 0 | | 0 | 5 | 5.0 | N/A | |
| Total Selenium | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Silver | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Thallium | 0 | 0 | | 0 | 0.24 | 0.24 | 2.9 | |
| Total Zinc | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Acrolein | 0 | 0 | | 0 | 3 | 3.0 | 36.2 | |
| Acrylamide | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Acrylonitrile | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Benzene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Bromoform | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Carbon Tetrachloride | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Chlorobenzene | 0 | 0 | | 0 | 100 | 100.0 | 1,208 | |
| Chlorodibromomethane | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 2-Chloroethyl Vinyl Ether | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Chloroform | 0 | 0 | | 0 | 5.7 | 5.7 | 68.8 | |
| Dichlorobromomethane | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 1,2-Dichloroethane | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 1,1-Dichloroethylene | 0 | 0 | | 0 | 33 | 33.0 | 399 | |

| | | | | | | | |
|-----------------------------|---|---|--|---|--------|--------|---------|
| 1,2-Dichloropropane | 0 | 0 | | 0 | N/A | N/A | N/A |
| 1,3-Dichloropropylene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Ethylbenzene | 0 | 0 | | 0 | 68 | 68.0 | 821 |
| Methyl Bromide | 0 | 0 | | 0 | 100 | 100.0 | 1,208 |
| Methyl Chloride | 0 | 0 | | 0 | N/A | N/A | N/A |
| Methylene Chloride | 0 | 0 | | 0 | N/A | N/A | N/A |
| 1,1,2,2-Tetrachloroethane | 0 | 0 | | 0 | N/A | N/A | N/A |
| Tetrachloroethylene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Toluene | 0 | 0 | | 0 | 57 | 57.0 | 688 |
| 1,2-trans-Dichloroethylene | 0 | 0 | | 0 | 100 | 100.0 | 1,208 |
| 1,1,1-Trichloroethane | 0 | 0 | | 0 | 10,000 | 10,000 | 120,782 |
| 1,1,2-Trichloroethane | 0 | 0 | | 0 | N/A | N/A | N/A |
| Trichloroethylene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Vinyl Chloride | 0 | 0 | | 0 | N/A | N/A | N/A |
| 2-Chlorophenol | 0 | 0 | | 0 | 30 | 30.0 | 362 |
| 2,4-Dichlorophenol | 0 | 0 | | 0 | 10 | 10.0 | 121 |
| 2,4-Dimethylphenol | 0 | 0 | | 0 | 100 | 100.0 | 1,208 |
| 4,6-Dinitro-o-Cresol | 0 | 0 | | 0 | 2 | 2.0 | 24.2 |
| 2,4-Dinitrophenol | 0 | 0 | | 0 | 10 | 10.0 | 121 |
| 2-Nitrophenol | 0 | 0 | | 0 | N/A | N/A | N/A |
| 4-Nitrophenol | 0 | 0 | | 0 | N/A | N/A | N/A |
| p-Chloro-m-Cresol | 0 | 0 | | 0 | N/A | N/A | N/A |
| Pentachlorophenol | 0 | 0 | | 0 | N/A | N/A | N/A |
| Phenol | 0 | 0 | | 0 | 4,000 | 4,000 | 48,313 |
| 2,4,6-Trichlorophenol | 0 | 0 | | 0 | N/A | N/A | N/A |
| Acenaphthene | 0 | 0 | | 0 | 70 | 70.0 | 845 |
| Anthracene | 0 | 0 | | 0 | 300 | 300 | 3,623 |
| Benzidine | 0 | 0 | | 0 | N/A | N/A | N/A |
| Benzo(a)Anthracene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Benzo(a)Pyrene | 0 | 0 | | 0 | N/A | N/A | N/A |
| 3,4-Benzo fluoranthene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Benzo(k)Fluoranthene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Bis(2-Chloroethyl)Ether | 0 | 0 | | 0 | N/A | N/A | N/A |
| Bis(2-Chloroisopropyl)Ether | 0 | 0 | | 0 | 200 | 200 | 2,416 |
| Bis(2-Ethylhexyl)Phthalate | 0 | 0 | | 0 | N/A | N/A | N/A |
| 4-Bromophenyl Phenyl Ether | 0 | 0 | | 0 | N/A | N/A | N/A |
| Butyl Benzyl Phthalate | 0 | 0 | | 0 | 0.1 | 0.1 | 1.21 |
| 2-Chloronaphthalene | 0 | 0 | | 0 | 800 | 800 | 9,663 |
| Chrysene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Dibenzo(a,h)Anthracene | 0 | 0 | | 0 | N/A | N/A | N/A |
| 1,2-Dichlorobenzene | 0 | 0 | | 0 | 1,000 | 1,000 | 12,078 |
| 1,3-Dichlorobenzene | 0 | 0 | | 0 | 7 | 7.0 | 84.5 |
| 1,4-Dichlorobenzene | 0 | 0 | | 0 | 300 | 300 | 3,623 |
| 3,3-Dichlorobenzidine | 0 | 0 | | 0 | N/A | N/A | N/A |
| Diethyl Phthalate | 0 | 0 | | 0 | 600 | 600 | 7,247 |

| | | | | | | | | |
|---------------------------|---|---|--|---|-------|-------|--------|--|
| Dimethyl Phthalate | 0 | 0 | | 0 | 2,000 | 2,000 | 24,156 | |
| Di-n-Butyl Phthalate | 0 | 0 | | 0 | 20 | 20.0 | 242 | |
| 2,4-Dinitrotoluene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 2,6-Dinitrotoluene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 1,2-Diphenylhydrazine | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Fluoranthene | 0 | 0 | | 0 | 20 | 20.0 | 242 | |
| Fluorene | 0 | 0 | | 0 | 50 | 50.0 | 604 | |
| Hexachlorobenzene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Hexachlorobutadiene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Hexachlorocyclopentadiene | 0 | 0 | | 0 | 4 | 4.0 | 48.3 | |
| Hexachloroethane | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Indeno(1,2,3-cd)Pyrene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Isophorone | 0 | 0 | | 0 | 34 | 34.0 | 411 | |
| Naphthalene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Nitrobenzene | 0 | 0 | | 0 | 10 | 10.0 | 121 | |
| n-Nitrosodimethylamine | 0 | 0 | | 0 | N/A | N/A | N/A | |
| n-Nitrosodi-n-Propylamine | 0 | 0 | | 0 | N/A | N/A | N/A | |
| n-Nitrosodiphenylamine | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Phenanthrene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Pyrene | 0 | 0 | | 0 | 20 | 20.0 | 242 | |
| 1,2,4-Trichlorobenzene | 0 | 0 | | 0 | 0.07 | 0.07 | 0.85 | |

CRL

CCT (min): #####

PMF: 1

Analysis Hardness (mg/l):

N/A

Analysis pH: N/A

| Pollutants | Stream Conc (µg/L) | Stream CV | Trb Conc (µg/L) | Fate Coef | WQC (µg/L) | WQ Obj (µg/L) | WLA (µg/L) | Comments |
|------------------------------|--------------------|-----------|-----------------|-----------|------------|---------------|------------|----------|
| Total Dissolved Solids (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Chloride (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Sulfate (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Fluoride (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Aluminum | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Antimony | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Arsenic | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Barium | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Boron | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Cadmium | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Chromium (III) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Hexavalent Chromium | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Cobalt | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Copper | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Dissolved Iron | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Iron | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Lead | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Manganese | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Mercury | 0 | 0 | | 0 | N/A | N/A | N/A | |

| | | | | | | | |
|---------------------------------|---|---|--|---|-------|------|-------|
| Total Nickel | 0 | 0 | | 0 | N/A | N/A | N/A |
| Total Phenols (Phenolics) (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A |
| Total Selenium | 0 | 0 | | 0 | N/A | N/A | N/A |
| Total Silver | 0 | 0 | | 0 | N/A | N/A | N/A |
| Total Thallium | 0 | 0 | | 0 | N/A | N/A | N/A |
| Total Zinc | 0 | 0 | | 0 | N/A | N/A | N/A |
| Acrolein | 0 | 0 | | 0 | N/A | N/A | N/A |
| Acrylamide | 0 | 0 | | 0 | 0.07 | 0.07 | 3.61 |
| Acrylonitrile | 0 | 0 | | 0 | 0.08 | 0.08 | 3.09 |
| Benzene | 0 | 0 | | 0 | 0.58 | 0.58 | 29.9 |
| Bromoform | 0 | 0 | | 0 | 7 | 7.0 | 361 |
| Carbon Tetrachloride | 0 | 0 | | 0 | 0.4 | 0.4 | 20.6 |
| Chlorobenzene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Chlorodibromomethane | 0 | 0 | | 0 | 0.8 | 0.8 | 41.2 |
| 2-Chloroethyl Vinyl Ether | 0 | 0 | | 0 | N/A | N/A | N/A |
| Chloroform | 0 | 0 | | 0 | N/A | N/A | N/A |
| Dichlorobromomethane | 0 | 0 | | 0 | 0.95 | 0.95 | 49.0 |
| 1,2-Dichloroethane | 0 | 0 | | 0 | 9.9 | 9.9 | 510 |
| 1,1-Dichloroethylene | 0 | 0 | | 0 | N/A | N/A | N/A |
| 1,2-Dichloropropane | 0 | 0 | | 0 | 0.9 | 0.9 | 46.4 |
| 1,3-Dichloropropylene | 0 | 0 | | 0 | 0.27 | 0.27 | 13.9 |
| Ethylbenzene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Methyl Bromide | 0 | 0 | | 0 | N/A | N/A | N/A |
| Methyl Chloride | 0 | 0 | | 0 | N/A | N/A | N/A |
| Methylene Chloride | 0 | 0 | | 0 | 20 | 20.0 | 1,031 |
| 1,1,2,2-Tetrachloroethane | 0 | 0 | | 0 | 0.2 | 0.2 | 10.3 |
| Tetrachloroethylene | 0 | 0 | | 0 | 10 | 10.0 | 515 |
| Toluene | 0 | 0 | | 0 | N/A | N/A | N/A |
| 1,2-trans-Dichloroethylene | 0 | 0 | | 0 | N/A | N/A | N/A |
| 1,1,1-Trichloroethane | 0 | 0 | | 0 | N/A | N/A | N/A |
| 1,1,2-Trichloroethane | 0 | 0 | | 0 | 0.55 | 0.55 | 28.3 |
| Trichloroethylene | 0 | 0 | | 0 | 0.6 | 0.6 | 30.9 |
| Vinyl Chloride | 0 | 0 | | 0 | 0.02 | 0.02 | 1.03 |
| 2-Chlorophenol | 0 | 0 | | 0 | N/A | N/A | N/A |
| 2,4-Dichlorophenol | 0 | 0 | | 0 | N/A | N/A | N/A |
| 2,4-Dimethylphenol | 0 | 0 | | 0 | N/A | N/A | N/A |
| 4,6-Dinitro- <i>o</i> -Cresol | 0 | 0 | | 0 | N/A | N/A | N/A |
| 2,4-Dinitrophenol | 0 | 0 | | 0 | N/A | N/A | N/A |
| 2-Nitrophenol | 0 | 0 | | 0 | N/A | N/A | N/A |
| 4-Nitrophenol | 0 | 0 | | 0 | N/A | N/A | N/A |
| p-Chloro- <i>m</i> -Cresol | 0 | 0 | | 0 | N/A | N/A | N/A |
| Pentachlorophenol | 0 | 0 | | 0 | 0.030 | 0.03 | 1.55 |
| Phenol | 0 | 0 | | 0 | N/A | N/A | N/A |
| 2,4,6-Trichlorophenol | 0 | 0 | | 0 | 1.5 | 1.5 | 77.3 |
| Acenaphthene | 0 | 0 | | 0 | N/A | N/A | N/A |

| | | | | | | | | |
|-----------------------------|---|---|--|---|---------|---------|-------|--|
| Anthracene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Benzidine | 0 | 0 | | 0 | 0.0001 | 0.0001 | 0.005 | |
| Benzo(a)Anthracene | 0 | 0 | | 0 | 0.001 | 0.001 | 0.052 | |
| Benzo(a)Pyrene | 0 | 0 | | 0 | 0.0001 | 0.0001 | 0.005 | |
| 3,4-Benzofluoranthene | 0 | 0 | | 0 | 0.001 | 0.001 | 0.052 | |
| Benzo(k)Fluoranthene | 0 | 0 | | 0 | 0.01 | 0.01 | 0.52 | |
| Bis(2-Chloroethyl)Ether | 0 | 0 | | 0 | 0.03 | 0.03 | 1.55 | |
| Bis(2-Chloroisopropyl)Ether | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Bis(2-Ethylhexyl)Phthalate | 0 | 0 | | 0 | 0.32 | 0.32 | 18.5 | |
| 4-Bromophenyl Phenyl Ether | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Butyl Benzyl Phthalate | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 2-Chloronaphthalene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Chrysene | 0 | 0 | | 0 | 0.12 | 0.12 | 6.19 | |
| Dibenzo(a,h)Anthracene | 0 | 0 | | 0 | 0.0001 | 0.0001 | 0.005 | |
| 1,2-Dichlorobenzene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 1,3-Dichlorobenzene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 1,4-Dichlorobenzene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 3,3-Dichlorobenzidine | 0 | 0 | | 0 | 0.05 | 0.05 | 2.58 | |
| Diethyl Phthalate | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Dimethyl Phthalate | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Di-n-Butyl Phthalate | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 2,4-Dinitrotoluene | 0 | 0 | | 0 | 0.05 | 0.05 | 2.58 | |
| 2,6-Dinitrotoluene | 0 | 0 | | 0 | 0.05 | 0.05 | 2.58 | |
| 1,2-Diphenylhydrazine | 0 | 0 | | 0 | 0.03 | 0.03 | 1.55 | |
| Fluoranthene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Fluorene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Hexachlorobenzene | 0 | 0 | | 0 | 0.00008 | 0.00008 | 0.004 | |
| Hexachlorobutadiene | 0 | 0 | | 0 | 0.01 | 0.01 | 0.52 | |
| Hexachlorocyclopentadiene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Hexachloroethane | 0 | 0 | | 0 | 0.1 | 0.1 | 5.15 | |
| Indeno(1,2,3-cd)Pyrene | 0 | 0 | | 0 | 0.001 | 0.001 | 0.052 | |
| Isophorone | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Naphthalene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Nitrobenzene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| n-Nitrosodimethylamine | 0 | 0 | | 0 | 0.0007 | 0.0007 | 0.036 | |
| n-Nitrosodi-n-Propylamine | 0 | 0 | | 0 | 0.005 | 0.005 | 0.26 | |
| n-Nitrosodiphenylamine | 0 | 0 | | 0 | 3.3 | 3.3 | 170 | |
| Phenanthrene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Pyrene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 1,2,4-Trichlorobenzene | 0 | 0 | | 0 | N/A | N/A | N/A | |

Recommended WQBELs & Monitoring Requirements

No. Samples/Month: 4

| Pollutants | Mass Limits | | Concentration Limits | | | | Governing WQBEL | WQBEL Basis | Comments |
|---------------------|---------------|---------------|----------------------|--------|--------|-------|-----------------|-------------|------------------------------------|
| | AML (lbs/day) | MDL (lbs/day) | AML | MDL | IMAX | Units | | | |
| Total Aluminum | 246 | 384 | 1,249 | 1,949 | 3,123 | µg/L | 1,249 | AFC | Discharge Conc ≥ 50% WQBEL (RP) |
| Hexavalent Chromium | Report | Report | Report | Report | Report | µg/L | 27.1 | AFC | Discharge Conc > 10% WQBEL (no RP) |
| Total Copper | Report | Report | Report | Report | Report | µg/L | 28.4 | AFC | Discharge Conc > 10% WQBEL (no RP) |
| Total Iron | Report | Report | Report | Report | Report | µg/L | 24,097 | CFC | Discharge Conc > 10% WQBEL (no RP) |
| Total Zinc | Report | Report | Report | Report | Report | µg/L | 238 | AFC | Discharge Conc > 10% WQBEL (no RP) |

Other Pollutants without Limits or Monitoring

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., <= Target QL).

| Pollutants | Governing WQBEL | Units | Comments |
|---------------------------------|-----------------|-------|----------------------------|
| Total Dissolved Solids (PWS) | N/A | N/A | PWS Not Applicable |
| Chloride (PWS) | N/A | N/A | PWS Not Applicable |
| Bromide | N/A | N/A | No WQS |
| Sulfate (PWS) | N/A | N/A | PWS Not Applicable |
| Fluoride (PWS) | N/A | N/A | PWS Not Applicable |
| Total Antimony | 67.6 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Arsenic | N/A | N/A | Discharge Conc < TQL |
| Total Barium | 28,988 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Beryllium | N/A | N/A | No WQS |
| Total Boron | 13,493 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Cadmium | 3.39 | µg/L | Discharge Conc < TQL |
| Total Chromium (III) | 1,083 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Cobalt | 158 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Cyanide | N/A | N/A | No WQS |
| Dissolved Iron | 3,623 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Lead | 40.9 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Manganese | 12,078 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Mercury | 0.6 | µg/L | Discharge Conc < TQL |
| Total Nickel | 656 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Phenols (Phenolics) (PWS) | | µg/L | PWS Not Applicable |
| Total Selenium | 60.3 | µg/L | Discharge Conc < TQL |
| Total Silver | 9.01 | µg/L | Discharge Conc < TQL |
| Total Thallium | 2.9 | µg/L | Discharge Conc < TQL |
| Total Molybdenum | N/A | N/A | No WQS |
| Acrolein | 5.0 | µg/L | Discharge Conc < TQL |
| Acrylamide | 3.81 | µg/L | Discharge Conc < TQL |
| Acrylonitrile | 3.09 | µg/L | Discharge Conc < TQL |
| Benzene | 29.9 | µg/L | Discharge Conc < TQL |
| Bromoform | 361 | µg/L | Discharge Conc < TQL |
| Carbon Tetrachloride | 20.6 | µg/L | Discharge Conc < TQL |

| | | | |
|----------------------------|--------|------|----------------------------|
| Chlorobenzene | 1,208 | µg/L | Discharge Conc ≤ 25% WQBEL |
| Chlorodibromomethane | 41.2 | µg/L | Discharge Conc ≤ 25% WQBEL |
| Chloroethane | N/A | N/A | No WQS |
| 2-Chloroethyl Vinyl Ether | 29,985 | µg/L | Discharge Conc < TQL |
| Chloroform | 68.8 | µg/L | Discharge Conc ≤ 25% WQBEL |
| Dichlorobromomethane | 49.0 | µg/L | Discharge Conc ≤ 25% WQBEL |
| 1,1-Dichloroethane | N/A | N/A | No WQS |
| 1,2-Dichloroethane | 510 | µg/L | Discharge Conc < TQL |
| 1,1-Dichloroethylene | 399 | µg/L | Discharge Conc < TQL |
| 1,2-Dichloropropane | 46.4 | µg/L | Discharge Conc < TQL |
| 1,3-Dichloropropylene | 13.9 | µg/L | Discharge Conc < TQL |
| 1,4-Dioxane | N/A | N/A | No WQS |
| Ethylbenzene | 821 | µg/L | Discharge Conc < TQL |
| Methyl Bromide | 916 | µg/L | Discharge Conc < TQL |
| Methyl Chloride | 46,644 | µg/L | Discharge Conc < TQL |
| Methylene Chloride | 1,031 | µg/L | Discharge Conc < TQL |
| 1,1,2,2-Tetrachloroethane | 10.3 | µg/L | Discharge Conc < TQL |
| Tetrachloroethylene | 515 | µg/L | Discharge Conc < TQL |
| Toluene | 688 | µg/L | Discharge Conc < TQL |
| 1,2-trans-Dichloroethylene | 1,208 | µg/L | Discharge Conc < TQL |
| 1,1,1-Trichloroethane | 4,998 | µg/L | Discharge Conc < TQL |
| 1,1,2-Trichloroethane | 28.3 | µg/L | Discharge Conc < TQL |
| Trichloroethylene | 30.9 | µg/L | Discharge Conc < TQL |
| Vinyl Chloride | 1.03 | µg/L | Discharge Conc < TQL |
| 2-Chlorophenol | 362 | µg/L | Discharge Conc < TQL |
| 2,4-Dichlorophenol | 121 | µg/L | Discharge Conc < TQL |
| 2,4-Dimethylphenol | 1,099 | µg/L | Discharge Conc < TQL |
| 4,6-Dinitro-o-Cresol | 24.2 | µg/L | Discharge Conc < TQL |
| 2,4-Dinitrophenol | 121 | µg/L | Discharge Conc < TQL |
| 2-Nitrophenol | 13,327 | µg/L | Discharge Conc < TQL |
| 4-Nitrophenol | 3,831 | µg/L | Discharge Conc < TQL |
| p-Chloro-m-Cresol | 267 | µg/L | Discharge Conc < TQL |
| Pentachlorophenol | 1.55 | µg/L | Discharge Conc < TQL |
| Phenol | 48,313 | µg/L | Discharge Conc ≤ 25% WQBEL |
| 2,4,6-Trichlorophenol | 77.3 | µg/L | Discharge Conc < TQL |
| Acenaphthene | 138 | µg/L | Discharge Conc < TQL |
| Acenaphthylene | N/A | N/A | No WQS |
| Anthracene | 3,623 | µg/L | Discharge Conc < TQL |
| Benzidine | 0.005 | µg/L | Discharge Conc < TQL |
| Benzo(a)Anthracene | 0.052 | µg/L | Discharge Conc < TQL |
| Benzo(a)Pyrene | 0.005 | µg/L | Discharge Conc < TQL |
| 3,4-Benzo fluoranthene | 0.052 | µg/L | Discharge Conc < TQL |
| Benzo(ghi)Perylene | N/A | N/A | No WQS |
| Benzo(k)Fluoranthene | 0.52 | µg/L | Discharge Conc < TQL |
| Bis(2-Chloroethoxy)Methane | N/A | N/A | No WQS |

| | | | |
|-----------------------------|-------|------|----------------------------|
| Bis(2-Chloroethyl)Ether | 1.55 | µg/L | Discharge Conc < TQL |
| Bis(2-Chloroisopropyl)Ether | 2,416 | µg/L | Discharge Conc < TQL |
| Bis(2-Ethylhexyl)Phthalate | 16.5 | µg/L | Discharge Conc ≤ 25% WQBEL |
| 4-Bromophenyl Phenyl Ether | 450 | µg/L | Discharge Conc < TQL |
| Butyl Benzyl Phthalate | 1.21 | µg/L | Discharge Conc < TQL |
| 2-Chloronaphthalene | 9,663 | µg/L | Discharge Conc < TQL |
| 4-Chlorophenyl Phenyl Ether | N/A | N/A | No WQS |
| Chrysene | 6.19 | µg/L | Discharge Conc < TQL |
| Dibenz(a,h)Anthracene | 0.005 | µg/L | Discharge Conc < TQL |
| 1,2-Dichlorobenzene | 1,366 | µg/L | Discharge Conc < TQL |
| 1,3-Dichlorobenzene | 84.5 | µg/L | Discharge Conc < TQL |
| 1,4-Dichlorobenzene | 1,216 | µg/L | Discharge Conc < TQL |
| 3,3-Dichlorobenzidine | 2.58 | µg/L | Discharge Conc < TQL |
| Diethyl Phthalate | 6,663 | µg/L | Discharge Conc ≤ 25% WQBEL |
| Dimethyl Phthalate | 4,165 | µg/L | Discharge Conc < TQL |
| Di-n-Butyl Phthalate | 183 | µg/L | Discharge Conc < TQL |
| 2,4-Dinitrotoluene | 2.58 | µg/L | Discharge Conc < TQL |
| 2,6-Dinitrotoluene | 2.58 | µg/L | Discharge Conc < TQL |
| Di-n-Octyl Phthalate | N/A | N/A | No WQS |
| 1,2-Diphenylhydrazine | 1.55 | µg/L | Discharge Conc < TQL |
| Fluoranthene | 242 | µg/L | Discharge Conc < TQL |
| Fluorene | 804 | µg/L | Discharge Conc < TQL |
| Hexachlorobenzene | 0.004 | µg/L | Discharge Conc < TQL |
| Hexachlorobutadiene | 0.52 | µg/L | Discharge Conc < TQL |
| Hexachlorocyclopentadiene | 8.33 | µg/L | Discharge Conc < TQL |
| Hexachloroethane | 5.15 | µg/L | Discharge Conc < TQL |
| Indeno(1,2,3-cd)Pyrene | 0.052 | µg/L | Discharge Conc < TQL |
| Isophorone | 411 | µg/L | Discharge Conc < TQL |
| Naphthalene | 233 | µg/L | Discharge Conc < TQL |
| Nitrobenzene | 121 | µg/L | Discharge Conc < TQL |
| n-Nitrosodimethylamine | 0.036 | µg/L | Discharge Conc < TQL |
| n-Nitrosodi-n-Propylamine | 0.26 | µg/L | Discharge Conc < TQL |
| n-Nitrosodiphenylamine | 170 | µg/L | Discharge Conc < TQL |
| Phenanthrene | 8.33 | µg/L | Discharge Conc < TQL |
| Pyrene | 242 | µg/L | Discharge Conc < TQL |
| 1,2,4-Trichlorobenzene | 0.85 | µg/L | Discharge Conc < TQL |

Attachment C:
Outfall 001 TRC Spreadsheet Evaluation

TRC EVALUATION

| 550 | = Q stream (cfs) | 0.5 | = CV Daily |
|----------------|---|--------------------------------------|--------------------------------------|
| 23.6 | = Q discharge (MGD) | 0.5 | = CV Hourly |
| 4 | = no. samples | 0.5 | = AFC_Partial Mix Factor |
| 0.3 | = Chlorine Demand of Stream | 0.5 | = CFC_Partial Mix Factor |
| 0 | = Chlorine Demand of Discharge | 15 | = AFC_Criteria Compliance Time (min) |
| 0.5 | = BAT/BPJ Value | 720 | = CFC_Criteria Compliance Time (min) |
| | = %Factor of Safety (FOS) | | = Decay Coefficient (K) |
| Source | Reference | AFC Calculations | Reference |
| TRC | 1.3.2.iii | WLA_afc = 2.422 | 1.3.2.iii |
| PENTOXSD TRG | 5.1a | LTAMULT_afc = 0.373 | 5.1c |
| PENTOXSD TRG | 5.1b | LTA_afc= 0.902 | 5.1d |
| | | | WLA_cfc = 2.354 |
| | | | LTAMULT_cfc = 0.581 |
| | | | LTA_cfc = 1.368 |
| Source | Effluent Limit Calculations | | |
| PENTOXSD TRG | 5.1f | AML MULT = 1.720 | |
| PENTOXSD TRG | 5.1g | AVG MON LIMIT (mg/l) = 0.500 | BAT/BPJ |
| | | INST MAX LIMIT (mg/l) = 1.170 | |
| WLA_afc | $(.019/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k*AFC_tc))...\\ ...+ Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$ | | |
| LTAMULT_afc | $\text{EXP}((0.5*\text{LN}(cvh^2+1))-2.326*\text{LN}(cvh^2+1)^0.5)$ | | |
| LTA_afc | wla_afc*LTAMULT_afc | | |
| WLA_cfc | $(.011/e(-k*CFC_tc)) + [(CFC_Yc*Qs*.011/Qd*e(-k*CFC_tc))...\\ ...+ Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$ | | |
| LTAMULT_cfc | $\text{EXP}((0.5*\text{LN}(cvd^2/no_samples+1))-2.326*\text{LN}(cvd^2/no_samples+1)^0.5)$ | | |
| LTA_cfc | wla_cfc*LTAMULT_cfc | | |
| AML MULT | $\text{EXP}(2.326*\text{LN}((cvd^2/no_samples+1)^0.5)-0.5*\text{LN}(cvd^2/no_samples+1))$ | | |
| AVG MON LIMIT | MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT) | | |
| INST MAX LIMIT | $1.5*((av_mon_limit/AML_MULT)/LTAMULT_afc)$ | | |

Attachment D:
Outfall 001 WQM7.0 Model Run

Input Data WQM 7.0

| SWP Basin | Stream Code | Stream Name | RMI | Elevation | | Drainage Area (sq mi) | Slope (ft/ft) | PWS Withdrawal (mgd) | Apply FC |
|-----------|-------------|-------------------|-----|-----------|--------|-----------------------|---------------|----------------------|-------------------------------------|
| | | | | (ft) | (ft) | | | | |
| 19A | 37185 | MONONGAHELA RIVER | | 17.530 | 712.00 | 5410.00 | 0.00010 | 0.00 | <input checked="" type="checkbox"/> |

Stream Data

| Design Cond. | LFY | Trib Flow | Stream Flow | Rch Trav Time (days) | Rch Velocity (fps) | WD Ratio | Rch Width (ft) | Rch Depth (ft) | Tributary Temp (°C) | pH | Stream Temp (°C) | pH |
|--------------|--------|-----------|-------------|----------------------|--------------------|----------|----------------|----------------|---------------------|------|------------------|------|
| | (cfsm) | (cfs) | (cfs) | | | | | | | | | |
| Q7-10 | 0.100 | 550.00 | 0.00 | 0.000 | 0.000 | 0.0 | 730.00 | 15.00 | 25.00 | 7.00 | 0.00 | 0.00 |
| Q1-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |
| Q30-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |

| Discharge Data | | | | | | | |
|------------------|---------------|--------------------------|---------------------------|------------------------|--------------------|----------------|---------|
| Name | Permit Number | Existing Disc Flow (mgd) | Permitted Disc Flow (mgd) | Design Disc Flow (mgd) | Reserve Factor | Disc Temp (°C) | Disc pH |
| Irvin Works | PA0004073 | 23.6000 | 0.0000 | 0.0000 | 0.000 | 20.00 | 7.00 |
| Parameter Data | | | | | | | |
| Parameter Name | | Disc Conc (mg/L) | Trib Conc (mg/L) | Stream Conc (mg/L) | Fate Coef (1/days) | | |
| CBOD5 | | 25.00 | 2.00 | 0.00 | 1.50 | | |
| Dissolved Oxygen | | 5.00 | 8.38 | 0.00 | 0.00 | | |
| NH3-N | | 25.00 | 0.00 | 0.00 | 0.70 | | |

Input Data WQM 7.0

| SWP Basin | Stream Code | Stream Name | | RMI | Elevation | Drainage Area | Slope | PWS Withdrawal | Apply FC | | | |
|-----------------------|-------------|------------------|-------------------|--------------------------|---------------------------|------------------------|--------------------|----------------|-------------------------------------|------|------------------|------|
| | | | | (ft) | (sq mi) | (ft/ft) | (mgd) | | | | | |
| 19A | | 37185 | MONONGAHELA RIVER | 16.500 | 711.00 | 5411.00 | 0.00010 | 0.00 | <input checked="" type="checkbox"/> | | | |
| Stream Data | | | | | | | | | | | | |
| Design Cond. | LFY | Trib Flow | Stream Flow | Rch Trav Time (days) | Rch Velocity (fps) | WD Ratio | Rch Width (ft) | Rch Depth (ft) | Tributary Temp (°C) | pH | Stream Temp (°C) | pH |
| | (cfsm) | (cfs) | (cfs) | | | | | | | | | |
| Q7-10 | 0.100 | 550.00 | 0.00 | 0.000 | 0.000 | 0.0 | 730.00 | 15.00 | 25.00 | 7.00 | 0.00 | 0.00 |
| Q1-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |
| Q30-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |
| Discharge Data | | | | | | | | | | | | |
| | | Name | Permit Number | Existing Disc Flow (mgd) | Permitted Disc Flow (mgd) | Design Disc Flow (mgd) | Reserve Factor | Disc Temp (°C) | Disc pH | | | |
| | | | | 0.0000 | 0.0000 | 0.0000 | 0.000 | 0.00 | 7.00 | | | |
| Parameter Data | | | | | | | | | | | | |
| | | Parameter Name | | Disc Conc (mg/L) | Trib Conc (mg/L) | Stream Conc (mg/L) | Fate Coef (1/days) | | | | | |
| | | | | | | | | | | | | |
| | | CBOD5 | | 25.00 | 2.00 | 0.00 | 1.50 | | | | | |
| | | Dissolved Oxygen | | 3.00 | 8.24 | 0.00 | 0.00 | | | | | |
| | | NH3-N | | 25.00 | 0.00 | 0.00 | 0.70 | | | | | |

Input Data WQM 7.0

| SWP Basin | Stream Code | Stream Name | RMI | Elevation (ft) | Drainage Area (sq mi) | Slope (ft/ft) | PWS Withdrawal (mgd) | Apply FC |
|-----------|-------------|-------------------|--------|-------------------|--------------------------|------------------|-------------------------|-------------------------------------|
| 19A | 37185 | MONONGAHELA RIVER | 15.500 | 710.00 | 5412.00 | 0.00010 | 0.00 | <input checked="" type="checkbox"/> |

Stream Data

| Design Cond. | LFY | Trib Flow | Stream Flow | Rch Trav Time | Rch Velocity | WD Ratio | Rch Width | Rch Depth | Tributary Temp | pH | Stream Temp | pH |
|--------------|---------|-----------|-------------|---------------|--------------|----------|-----------|-----------|----------------|------|-------------|------|
| | (cfs/m) | (cfs) | (cfs) | (days) | (fps) | | (ft) | (ft) | (°C) | | (°C) | |
| Q7-10 | 0.100 | 550.00 | 0.00 | 0.000 | 0.000 | 0.0 | 730.00 | 15.00 | 25.00 | 7.00 | 0.00 | 0.00 |
| Q1-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |
| Q30-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |

| Discharge Data | | | | | | | |
|------------------|---------------|--------------------------|---------------------------|------------------------|--------------------|----------------|---------|
| Name | Permit Number | Existing Disc Flow (mgd) | Permitted Disc Flow (mgd) | Design Disc Flow (mgd) | Reserve Factor | Disc Temp (°C) | Disc pH |
| | | 0.0000 | 0.0000 | 0.0000 | 0.000 | 25.00 | 7.00 |
| Parameter Data | | | | | | | |
| Parameter Name | | Disc Conc (mg/L) | Trib Conc (mg/L) | Stream Conc (mg/L) | Fate Coef (1/days) | | |
| CBOD5 | | 25.00 | 2.00 | 0.00 | 1.50 | | |
| Dissolved Oxygen | | 3.00 | 8.24 | 0.00 | 0.00 | | |
| NH3-N | | 25.00 | 0.00 | 0.00 | 0.70 | | |

WQM 7.0 Hydrodynamic Outputs

| <u>SWP Basin</u> | | | <u>Stream Code</u> | | <u>Stream Name</u> | | | | | | | |
|--------------------|-------------|----------|--------------------|--------------------|--------------------|-------|-------|-----------|----------|-----------------|---------------|-------------|
| 19A | | | 37185 | | MONONGAHELA RIVER | | | | | | | |
| RMI | Stream Flow | PWS With | Net Stream Flow | Disc Analysis Flow | Reach Slope | Depth | Width | W/D Ratio | Velocity | Reach Trav Time | Analysis Temp | Analysis pH |
| | (cfs) | | (cfs) | (cfs) | (ft/ft) | (ft) | (ft) | | (fps) | (days) | (°C) | |
| Q7-10 Flow | | | | | | | | | | | | |
| 17.530 | 550.00 | 0.00 | 550.00 | 36.5092 | 0.00010 | 15 | 730 | 48.67 | 0.05 | 1.175 | 24.69 | 7.00 |
| 16.500 | 1100.00 | 0.00 | 1100.00 | 36.5092 | 0.00010 | 15 | 730 | 48.67 | 0.10 | 0.589 | 24.84 | 7.00 |
| Q1-10 Flow | | | | | | | | | | | | |
| 17.530 | 352.00 | 0.00 | 352.00 | 36.5092 | 0.00010 | NA | NA | NA | 0.04 | 1.774 | 24.53 | 7.00 |
| 16.500 | 704.00 | 0.00 | 704.00 | 36.5092 | 0.00010 | NA | NA | NA | 0.07 | 0.904 | 24.75 | 7.00 |
| Q30-10 Flow | | | | | | | | | | | | |
| 17.530 | 748.00 | 0.00 | 748.00 | 36.5092 | 0.00010 | NA | NA | NA | 0.07 | 0.879 | 24.77 | 7.00 |
| 16.500 | 1496.00 | 0.00 | 1496.00 | 36.5092 | 0.00010 | NA | NA | NA | 0.14 | 0.437 | 24.88 | 7.00 |

WQM 7.0 Modeling Specifications

| | | | |
|--------------------|--------|-------------------------------------|-------------------------------------|
| Parameters | Both | Use Inputted Q1-10 and Q30-10 Flows | <input checked="" type="checkbox"/> |
| WLA Method | EMPR | Use Inputted W/D Ratio | <input type="checkbox"/> |
| Q1-10/Q7-10 Ratio | 0.64 | Use Inputted Reach Travel Times | <input type="checkbox"/> |
| Q30-10/Q7-10 Ratio | 1.36 | Temperature Adjust Kr | <input checked="" type="checkbox"/> |
| D.O. Saturation | 90.00% | Use Balanced Technology | <input checked="" type="checkbox"/> |
| D.O. Goal | 6 | | |

WQM 7.0 Wasteload Allocations

| SWP Basin | Stream Code | Stream Name |
|-----------|-------------|-------------------|
| 19A | 37185 | MONONGAHELA RIVER |

NH3-N Acute Allocations

| RMI | Discharge Name | Baseline Criterion (mg/L) | Baseline WLA (mg/L) | Multiple Criterion (mg/L) | Multiple WLA (mg/L) | Critical Reach | Percent Reduction |
|--------|----------------|---------------------------|---------------------|---------------------------|---------------------|----------------|-------------------|
| 17.530 | Irvin Works | 11.51 | 50 | 11.51 | 50 | 0 | 0 |
| 16.500 | | NA | NA | 11.3 | NA | NA | NA |

NH3-N Chronic Allocations

| RMI | Discharge Name | Baseline Criterion (mg/L) | Baseline WLA (mg/L) | Multiple Criterion (mg/L) | Multiple WLA (mg/L) | Critical Reach | Percent Reduction |
|--------|----------------|---------------------------|---------------------|---------------------------|---------------------|----------------|-------------------|
| 17.530 | Irvin Works | 1.39 | 25 | 1.39 | 25 | 0 | 0 |
| 16.500 | | NA | NA | 1.38 | NA | NA | NA |

Dissolved Oxygen Allocations

| RMI | Discharge Name | CBOD5 | | NH3-N | | Dissolved Oxygen | | Critical Reach | Percent Reduction |
|-------|----------------|-----------------|-----------------|-----------------|-----------------|------------------|-----------------|----------------|-------------------|
| | | Baseline (mg/L) | Multiple (mg/L) | Baseline (mg/L) | Multiple (mg/L) | Baseline (mg/L) | Multiple (mg/L) | | |
| 17.53 | Irvin Works | 16.62 | 16.62 | 5.29 | 5.29 | 5 | 5 | 0 | 0 |
| 16.50 | | NA | NA | NA | NA | NA | NA | NA | NA |

WQM 7.0 D.O. Simulation

| SWP Basin | Stream Code | Stream Name | | |
|---------------------------------|-----------------------------------|----------------------------------|-----------------------------|-------------|
| 19A | 37185 | MONONGAHELA RIVER | | |
| <u>RMI</u> | <u>Total Discharge Flow (mgd)</u> | <u>Analysis Temperature (°C)</u> | <u>Analysis pH</u> | |
| 17.530 | 23.600 | 24.689 | 7.000 | |
| <u>Reach Width (ft)</u> | <u>Reach Depth (ft)</u> | <u>Reach WDRatio</u> | <u>Reach Velocity (fps)</u> | |
| 730.000 | 15.000 | 48.667 | 0.054 | |
| <u>Reach CBOD5 (mg/L)</u> | <u>Reach Kc (1/days)</u> | <u>Reach NH3-N (mg/L)</u> | <u>Reach Kn (1/days)</u> | |
| 2.91 | 0.218 | 0.33 | 1.004 | |
| <u>Reach DO (mg/L)</u> | <u>Reach Kr (1/days)</u> | <u>Kr Equation</u> | <u>Reach DO Goal (mg/L)</u> | |
| 8.170 | 0.057 | O'Connor | 6 | |
| <u>Reach Travel Time (days)</u> | | <u>Subreach Results</u> | | |
| 1.175 | TravTime (days) | CBOD5 (mg/L) | NH3-N (mg/L) | D.O. (mg/L) |
| | | 0.118 | 2.82 | 0.29 |
| | | 0.235 | 2.73 | 0.26 |
| | | 0.353 | 2.65 | 0.23 |
| | | 0.470 | 2.58 | 0.21 |
| | | 0.588 | 2.48 | 0.18 |
| | | 0.705 | 2.40 | 0.16 |
| | | 0.823 | 2.33 | 0.14 |
| | | 0.940 | 2.26 | 0.13 |
| | | 1.058 | 2.19 | 0.11 |
| | | 1.175 | 2.12 | 0.10 |
| | | | | 6.04 |
| <u>RMI</u> | <u>Total Discharge Flow (mgd)</u> | <u>Analysis Temperature (°C)</u> | <u>Analysis pH</u> | |
| 16.500 | 23.600 | 24.839 | 7.000 | |
| <u>Reach Width (ft)</u> | <u>Reach Depth (ft)</u> | <u>Reach WDRatio</u> | <u>Reach Velocity (fps)</u> | |
| 730.000 | 15.000 | 48.667 | 0.104 | |
| <u>Reach CBOD5 (mg/L)</u> | <u>Reach Kc (1/days)</u> | <u>Reach NH3-N (mg/L)</u> | <u>Reach Kn (1/days)</u> | |
| 2.06 | 0.041 | 0.05 | 1.016 | |
| <u>Reach DO (mg/L)</u> | <u>Reach Kr (1/days)</u> | <u>Kr Equation</u> | <u>Reach DO Goal (mg/L)</u> | |
| 7.105 | 0.080 | O'Connor | 6 | |
| <u>Reach Travel Time (days)</u> | | <u>Subreach Results</u> | | |
| 0.589 | TravTime (days) | CBOD5 (mg/L) | NH3-N (mg/L) | D.O. (mg/L) |
| | | 0.059 | 2.05 | 0.05 |
| | | 0.118 | 2.05 | 0.05 |
| | | 0.177 | 2.04 | 0.04 |
| | | 0.236 | 2.04 | 0.04 |
| | | 0.294 | 2.03 | 0.04 |
| | | 0.353 | 2.02 | 0.04 |
| | | 0.412 | 2.02 | 0.03 |
| | | 0.471 | 2.01 | 0.03 |
| | | 0.530 | 2.01 | 0.03 |
| | | 0.589 | 2.00 | 0.03 |
| | | | | 6.97 |

WQM 7.0 Effluent Limits

| SWP Basin | Stream Code | Stream Name | | | | | |
|-----------|-------------|---------------|-----------------|-------------------|--------------------------------|----------------------------|----------------------------|
| | | 19A | 37185 | MONONGAHELA RIVER | | | |
| RMI | Name | Permit Number | Disc Flow (mgd) | Parameter | Effl. Limit 30-day Ave. (mg/L) | Effl. Limit Maximum (mg/L) | Effl. Limit Minimum (mg/L) |
| 17.530 | Irvin Works | PA0004073 | 23.600 | CBOD5 | 16.62 | | |
| | | | | NH3-N | 5.29 | 10.58 | |
| | | | | Dissolved Oxygen | | | 5 |

Input Data WQM 7.0

| SWP Basin | Stream Code | Stream Name | RMI | Elevation (ft) | Drainage Area (sq mi) | Slope (ft/ft) | PWS Withdrawal (mgd) | Apply FC |
|-----------|-------------|-------------------|--------|----------------|-----------------------|---------------|----------------------|-------------------------------------|
| 19A | 37185 | MONONGAHELA RIVER | 17.530 | 712.00 | 5410.00 | 0.00010 | 0.00 | <input checked="" type="checkbox"/> |

| Design Cond. | Stream Data | | | | | | | | | |
|--------------|-------------|-----------|-------------|----------------------|--------------------|----------|----------------|----------------|---------------------|-----------|
| | LFY | Trib Flow | Stream Flow | Rch Trav Time (days) | Rch Velocity (fps) | WD Ratio | Rch Width (ft) | Rch Depth (ft) | Tributary Temp (°C) | Stream pH |
| Q7-10 | 0.100 | 550.00 | 0.00 | 0.000 | 0.000 | 0.0 | 730.00 | 15.00 | 5.00 | 7.00 |
| Q1-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | |
| Q30-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | |

| Discharge Data | | | | | | | |
|------------------|------------------|--------------------------|---------------------------|------------------------|----------------|----------------|---------|
| Name | Permit Number | Existing Disc Flow (mgd) | Permitted Disc Flow (mgd) | Design Disc Flow (mgd) | Reserve Factor | Disc Temp (°C) | Disc pH |
| Irvin Works | PA0004073 | 23.6000 | 0.0000 | 0.0000 | 0.000 | 20.00 | 7.00 |
| Parameter Data | | | | | | | |
| Parameter Name | Disc Conc (mg/L) | Trib Conc (mg/L) | Stream Conc (mg/L) | Fate Coef (1/days) | | | |
| CBOD5 | 25.00 | 2.00 | 0.00 | 1.50 | | | |
| Dissolved Oxygen | 5.00 | 12.80 | 0.00 | 0.00 | | | |
| NH3-N | 25.00 | 0.00 | 0.00 | 0.70 | | | |

Input Data WQM 7.0

| SWP Basin | Stream Code | Stream Name | RMI | Elevation | Drainage Area | Slope | PWS Withdrawal | Apply FC |
|-----------|-------------|-------------------|--------|-----------|---------------|---------|----------------|-------------------------------------|
| | | | (ft) | (sq mi) | (ft/ft) | (mgd) | | |
| 19A | 37185 | MONONGAHELA RIVER | 16.500 | 711.00 | 5411.00 | 0.00010 | 0.00 | <input checked="" type="checkbox"/> |

Stream Data

| Design Cond. | LFY | Trib Flow | Stream Flow | Rch Trav Time | Rch Velocity | WD Ratio | Rch Width | Rch Depth | Tributary Temp | pH | Stream Temp | pH |
|--------------|--------|-----------|-------------|---------------|--------------|----------|-----------|-----------|----------------|------|-------------|------|
| | (cfsm) | (cfs) | (cfs) | (days) | (fps) | | (ft) | (ft) | (°C) | | (°C) | |
| Q7-10 | 0.100 | 550.00 | 0.00 | 0.000 | 0.000 | 0.0 | 730.00 | 15.00 | 5.00 | 7.00 | 0.00 | 0.00 |
| Q1-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |
| Q30-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |

| Discharge Data | | | | | | | | |
|------------------|--|---------------|--------------------------|---------------------------|------------------------|--------------------|----------------|---------|
| Name | | Permit Number | Existing Disc Flow (mgd) | Permitted Disc Flow (mgd) | Design Disc Flow (mgd) | Reserve Factor | Disc Temp (°C) | Disc pH |
| | | | 0.0000 | 0.0000 | 0.0000 | 0.000 | 0.00 | 7.00 |
| Parameter Data | | | | | | | | |
| Parameter Name | | | Disc Conc (mg/L) | Trib Conc (mg/L) | Stream Conc (mg/L) | Fate Coef (1/days) | | |
| CBOD5 | | | 25.00 | 2.00 | 0.00 | 1.50 | | |
| Dissolved Oxygen | | | 3.00 | 8.24 | 0.00 | 0.00 | | |
| NH3-N | | | 25.00 | 0.00 | 0.00 | 0.70 | | |

Input Data WQM 7.0

| SWP Basin | Stream Code | Stream Name | | | RMI | Elevation (ft) | Drainage Area (sq mi) | Slope (ft/ft) | PWS Withdrawal (mgd) | Apply FC | | |
|-----------------------|-------------------------|--------------------|----------------------|-------------------------|-----------------------|-----------------------------|------------------------------|---------------------------|-------------------------------------|-------------------|--|--|
| | | | | | | | | | | | | |
| 19A | 37185 MONONGAHELA RIVER | | | 15.500 | 710.00 | 5412.00 | 0.00010 | 0.00 | <input checked="" type="checkbox"/> | | | |
| Stream Data | | | | | | | | | | | | |
| Design Cond. | LFY (cfsm) | Trib Flow (cfs) | Stream Flow (cfs) | Rch Trav Time (days) | Rch Velocity (fps) | WD Ratio | Rch Width (ft) | Rch Depth (ft) | Tributary Temp (°C) | Stream pH (°C) | | |
| Q7-10 | 0.100 | 550.00 | 0.00 | 0.000 | 0.000 | 0.0 | 730.00 | 15.00 | 5.00 | 7.00 | | |
| Q1-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |
| Q30-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |
| Discharge Data | | | | | | | | | | | | |
| | | | | Name | Permit Number | Existing Disc Flow (mgd) | Permitted Disc Flow (mgd) | Design Disc Flow (mgd) | Reserve Factor | Disc Temp (°C) | | |
| | | | | | | 0.0000 | 0.0000 | 0.0000 | 0.000 | 25.00 | | |
| Parameter Data | | | | | | | | | | | | |
| | | | | Parameter Name | Disc Conc (mg/L) | Trib Conc (mg/L) | Stream Conc (mg/L) | Fate Coef (1/days) | | | | |
| | | | | CBOD5 | 25.00 | 2.00 | 0.00 | 1.50 | | | | |
| | | | | Dissolved Oxygen | 3.00 | 8.24 | 0.00 | 0.00 | | | | |
| | | | | NH3-N | 25.00 | 0.00 | 0.00 | 0.70 | | | | |

WQM 7.0 Hydrodynamic Outputs

| SWP Basin | Stream Code | Stream Name | | | | | | | | | | |
|--------------------|----------------------|-------------------|--------------------------|-----------------------------|------------------------|-------------------|---------------|-----------|-------------------|---------------------------|-----------------------|-------------|
| | | 19A | | 37185 | | MONONGAHELA RIVER | | | | | | |
| RMI | Stream Flow (cfs) | PWS With (cfs) | Net Stream Flow (cfs) | Disc Analysis Flow (cfs) | Reach Slope (ft/ft) | Depth (ft) | Width (ft) | W/D Ratio | Velocity (fps) | Reach Trav Time (days) | Analysis Temp (°C) | Analysis pH |
| Q7-10 Flow | | | | | | | | | | | | |
| 17.530 | 550.00 | 0.00 | 550.00 | 36.5092 | 0.00010 | 15 | 730 | 48.67 | 0.05 | 1.175 | 5.93 | 7.00 |
| 16.500 | 1100.00 | 0.00 | 1100.00 | 36.5092 | 0.00010 | 15 | 730 | 48.67 | 0.10 | 0.589 | 5.48 | 7.00 |
| Q1-10 Flow | | | | | | | | | | | | |
| 17.530 | 352.00 | 0.00 | 352.00 | 36.5092 | 0.00010 | NA | NA | NA | 0.04 | 1.774 | 6.41 | 7.00 |
| 16.500 | 704.00 | 0.00 | 704.00 | 36.5092 | 0.00010 | NA | NA | NA | 0.07 | 0.904 | 5.74 | 7.00 |
| Q30-10 Flow | | | | | | | | | | | | |
| 17.530 | 748.00 | 0.00 | 748.00 | 36.5092 | 0.00010 | NA | NA | NA | 0.07 | 0.879 | 5.70 | 7.00 |
| 16.500 | 1496.00 | 0.00 | 1496.00 | 36.5092 | 0.00010 | NA | NA | NA | 0.14 | 0.437 | 5.36 | 7.00 |

WQM 7.0 Modeling Specifications

| | | | |
|--------------------|--------|-------------------------------------|-------------------------------------|
| Parameters | Both | Use Inputted Q1-10 and Q30-10 Flows | <input checked="" type="checkbox"/> |
| WLA Method | EMPR | Use Inputted W/D Ratio | <input type="checkbox"/> |
| Q1-10/Q7-10 Ratio | 0.64 | Use Inputted Reach Travel Times | <input type="checkbox"/> |
| Q30-10/Q7-10 Ratio | 1.36 | Temperature Adjust Kr | <input checked="" type="checkbox"/> |
| D.O. Saturation | 90.00% | Use Balanced Technology | <input checked="" type="checkbox"/> |
| D.O. Goal | 6 | | |

WQM 7.0 Wasteload Allocations

| SWP Basin | Stream Code | Stream Name |
|-----------|-------------|-------------------|
| 19A | 37185 | MONONGAHELA RIVER |

NH3-N Acute Allocations

| RMI | Discharge Name | Baseline Criterion (mg/L) | Baseline WLA (mg/L) | Multiple Criterion (mg/L) | Multiple WLA (mg/L) | Critical Reach | Percent Reduction |
|--------|----------------|---------------------------|---------------------|---------------------------|---------------------|----------------|-------------------|
| 17.530 | Irvin Works | 24.1 | 50 | 24.1 | 50 | 0 | 0 |
| 16.500 | | NA | NA | 24.1 | NA | NA | NA |

NH3-N Chronic Allocations

| RMI | Discharge Name | Baseline Criterion (mg/L) | Baseline WLA (mg/L) | Multiple Criterion (mg/L) | Multiple WLA (mg/L) | Critical Reach | Percent Reduction |
|--------|----------------|---------------------------|---------------------|---------------------------|---------------------|----------------|-------------------|
| 17.530 | Irvin Works | 4.36 | 25 | 4.36 | 25 | 0 | 0 |
| 16.500 | | NA | NA | 4.36 | NA | NA | NA |

Dissolved Oxygen Allocations

| RMI | Discharge Name | CBOD5 | | NH3-N | | Dissolved Oxygen | | Critical Reach | Percent Reduction |
|-------|----------------|-----------------|-----------------|-----------------|-----------------|------------------|-----------------|----------------|-------------------|
| | | Baseline (mg/L) | Multiple (mg/L) | Baseline (mg/L) | Multiple (mg/L) | Baseline (mg/L) | Multiple (mg/L) | | |
| 17.53 | Irvin Works | 25 | 25 | 25 | 25 | 5 | 5 | 0 | 0 |
| 16.50 | | NA | NA | NA | NA | NA | NA | NA | NA |

WQM 7.0 D.O. Simulation

| SWP Basin | Stream Code | Stream Name | | |
|--------------------------|----------------------------|---------------------------|----------------------|-------------|
| 19A | 37185 | MONONGAHELA RIVER | | |
| RMI | Total Discharge Flow (mgd) | Analysis Temperature (°C) | Analysis pH | |
| 17.530 | 23.800 | 5.934 | 7.000 | |
| Reach Width (ft) | Reach Depth (ft) | Reach WDRatio | Reach Velocity (fps) | |
| 730.000 | 15.000 | 48.667 | 0.054 | |
| Reach CBOD5 (mg/L) | Reach Kc (1/days) | Reach NH3-N (mg/L) | Reach Kn (1/days) | |
| 3.43 | 0.519 | 1.56 | 0.237 | |
| Reach DO (mg/L) | Reach Kr (1/days) | Kr Equation | Reach DO Goal (mg/L) | |
| 12.314 | 0.037 | O'Connor | 6 | |
| Reach Travel Time (days) | Subreach Results | | | |
| 1.175 | TravTime (days) | CBOD5 (mg/L) | NH3-N (mg/L) | D.O. (mg/L) |
| | 0.118 | 3.32 | 1.51 | 11.18 |
| | 0.235 | 3.22 | 1.47 | 11.18 |
| | 0.353 | 3.12 | 1.43 | 11.18 |
| | 0.470 | 3.02 | 1.39 | 10.98 |
| | 0.588 | 2.93 | 1.35 | 10.65 |
| | 0.705 | 2.83 | 1.32 | 10.35 |
| | 0.823 | 2.74 | 1.28 | 10.06 |
| | 0.940 | 2.66 | 1.25 | 9.78 |
| | 1.058 | 2.57 | 1.21 | 9.51 |
| | 1.175 | 2.49 | 1.18 | 9.25 |
| RMI | Total Discharge Flow (mgd) | Analysis Temperature (°C) | Analysis pH | |
| 16.500 | 23.600 | 5.482 | 7.000 | |
| Reach Width (ft) | Reach Depth (ft) | Reach WDRatio | Reach Velocity (fps) | |
| 730.000 | 15.000 | 48.667 | 0.104 | |
| Reach CBOD5 (mg/L) | Reach Kc (1/days) | Reach NH3-N (mg/L) | Reach Kn (1/days) | |
| 2.25 | 0.175 | 0.81 | 0.229 | |
| Reach DO (mg/L) | Reach Kr (1/days) | Kr Equation | Reach DO Goal (mg/L) | |
| 8.764 | 0.051 | O'Connor | 6 | |
| Reach Travel Time (days) | Subreach Results | | | |
| 0.589 | TravTime (days) | CBOD5 (mg/L) | NH3-N (mg/L) | D.O. (mg/L) |
| | 0.059 | 2.24 | 0.60 | 8.72 |
| | 0.118 | 2.23 | 0.59 | 8.68 |
| | 0.177 | 2.22 | 0.58 | 8.64 |
| | 0.236 | 2.21 | 0.58 | 8.59 |
| | 0.294 | 2.20 | 0.57 | 8.55 |
| | 0.353 | 2.18 | 0.56 | 8.51 |
| | 0.412 | 2.17 | 0.55 | 8.47 |
| | 0.471 | 2.16 | 0.55 | 8.43 |
| | 0.530 | 2.15 | 0.54 | 8.40 |
| | 0.589 | 2.14 | 0.53 | 8.36 |

WQM 7.0 Effluent Limits

| <u>SWP Basin</u> | | <u>Stream Code</u> | | <u>Stream Name</u> | | | |
|------------------|-------------|--------------------|-----------------|--------------------|--------------------------------|----------------------------|----------------------------|
| | 19A | | 37185 | MONONGAHELA RIVER | | | |
| RMI | Name | Permit Number | Disc Flow (mgd) | Parameter | Effl. Limit 30-day Ave. (mg/L) | Effl. Limit Maximum (mg/L) | Effl. Limit Minimum (mg/L) |
| 17.530 | Irvin Works | PA0004073 | 23.600 | CBOD5 | 25 | | |
| | | | | NH3-N | 25 | 50 | |
| | | | | Dissolved Oxygen | | | 5 |

Attachment E:

Site Temperature Model Spreadsheet Evaluation

| Facility: | USS Irvin Plant | | | | | |
|---------------------|-----------------------------|-------------------------------|--------------------------------|--------------------|------------------------------------|---|
| Permit Number: | PA0004073 | | | | | |
| Stream Name: | Monongahela River | | | | | |
| Analyst/Engineer: | Olesnakik | | | | | |
| Stream Q7-10 (cfs): | 550 | | | | | |
| | Facility Flows ¹ | | | | Stream Flows | |
| | Stream (Intake) (MGD) | External (Intake) (MGD) | Consumptive (Loss) (MGD) | Discharge (MGD) | Adj. Q7-10 Stream Flow (cfs) | Downstream ² Stream Flow (cfs) |
| Jan 1-31 | 26.1 | 0 | 0.78 | 25.32 | 1760.0 | 1758.8 |
| Feb 1-29 | 26.1 | 0 | 0.78 | 25.32 | 1925.0 | 1923.8 |
| Mar 1-31 | 26.1 | 0 | 0.78 | 25.32 | 3850.0 | 3848.8 |
| Apr 1-15 | 26.1 | 0 | 0.78 | 25.32 | 5115.0 | 5113.8 |
| Apr 16-30 | 26.1 | 0 | 0.78 | 25.32 | 5115.0 | 5113.8 |
| May 1-15 | 26.1 | 0 | 0.78 | 25.32 | 2805.0 | 2803.8 |
| May 16-31 | 26.1 | 0 | 0.78 | 25.32 | 2805.0 | 2803.8 |
| Jun 1-15 | 26.1 | 0 | 0.78 | 25.32 | 1650.0 | 1648.8 |
| Jun 16-30 | 26.1 | 0 | 0.78 | 25.32 | 1650.0 | 1648.8 |
| Jul 1-31 | 26.1 | 0 | 0.78 | 25.32 | 935.0 | 933.8 |
| Aug 1-15 | 26.1 | 0 | 0.78 | 25.32 | 770.0 | 768.8 |
| Aug 16-31 | 26.1 | 0 | 0.78 | 25.32 | 770.0 | 768.8 |
| Sep 1-15 | 26.1 | 0 | 0.78 | 25.32 | 605.0 | 603.8 |
| Sep 16-30 | 26.1 | 0 | 0.78 | 25.32 | 605.0 | 603.8 |
| Oct 1-15 | 26.1 | 0 | 0.78 | 25.32 | 660.0 | 658.8 |
| Oct 16-31 | 26.1 | 0 | 0.78 | 25.32 | 660.0 | 658.8 |
| Nov 1-15 | 26.1 | 0 | 0.78 | 25.32 | 880.0 | 878.8 |
| Nov 16-30 | 26.1 | 0 | 0.78 | 25.32 | 880.0 | 878.8 |
| Dec 1-31 | 26.1 | 0 | 0.78 | 25.32 | 1320.0 | 1318.8 |

¹ Facility flows are not required (and will not affect the permit limits) if all intake flow is from the receiving stream (Case 1),
consumptive losses are small, and permit limits will be expressed as Million BTUs/day.

² Downstream Stream Flow includes the discharge flow.

Please forward all comments to Tom Starosta at 717-787-4317, tstarosta@state.pa.us.

Version 1.0 -- 08/01/2004 Reference: Implementation Guidance for Temperature Criteria, DEP-ID: 391-2000-017

NOTE: The user can only edit fields that are blue.

NOTE: MGD x 1.547 = cfs.

| Facility: | USS Irvin Plant | | | | | | | | | | | |
|------------------------|-----------------------------|-----------------------------|-----------------------------|-----------------------------|--|---|--|--|--|--|--|--|
| Permit Number: | PA0004073 | | | | | | | | | | | |
| Stream: | Monongahela River | | | | | | | | | | | |
| <hr/> | | | | | | | | | | | | |
| <hr/> | | | | | | | | | | | | |
| | WWF Criteria (°F) | CWF Criteria (°F) | TSF Criteria (°F) | 316 Criteria (°F) | Q7-10 Multipliers (Used in Analysis) | Q7-10 Multipliers (Default - Info Only) | | | | | | |
| Jan 1-31 | 40 | 38 | 40 | 0 | 3.2 | 3.2 | | | | | | |
| Feb 1-29 | 40 | 38 | 40 | 0 | 3.5 | 3.5 | | | | | | |
| Mar 1-31 | 46 | 42 | 46 | 0 | 7 | 7 | | | | | | |
| Apr 1-15 | 52 | 48 | 52 | 0 | 9.3 | 9.3 | | | | | | |
| Apr 16-30 | 58 | 52 | 58 | 0 | 9.3 | 9.3 | | | | | | |
| May 1-15 | 64 | 54 | 64 | 0 | 5.1 | 5.1 | | | | | | |
| May 16-30 | 72 | 58 | 68 | 0 | 5.1 | 5.1 | | | | | | |
| Jun 1-15 | 80 | 60 | 70 | 0 | 3 | 3 | | | | | | |
| Jun 16-30 | 84 | 64 | 72 | 0 | 3 | 3 | | | | | | |
| Jul 1-31 | 87 | 66 | 74 | 0 | 1.7 | 1.7 | | | | | | |
| Aug 1-15 | 87 | 66 | 80 | 0 | 1.4 | 1.4 | | | | | | |
| Aug 16-31 | 87 | 66 | 87 | 0 | 1.4 | 1.4 | | | | | | |
| Sep 1-15 | 84 | 64 | 84 | 0 | 1.1 | 1.1 | | | | | | |
| Sep 16-30 | 78 | 60 | 78 | 0 | 1.1 | 1.1 | | | | | | |
| Oct 1-15 | 72 | 54 | 72 | 0 | 1.2 | 1.2 | | | | | | |
| Oct 16-31 | 66 | 50 | 66 | 0 | 1.2 | 1.2 | | | | | | |
| Nov 1-15 | 58 | 46 | 58 | 0 | 1.6 | 1.6 | | | | | | |
| Nov 16-30 | 50 | 42 | 50 | 0 | 1.6 | 1.6 | | | | | | |
| Dec 1-31 | 42 | 40 | 42 | 0 | 2.4 | 2.4 | | | | | | |
| <hr/> | | | | | | | | | | | | |
| <hr/> | | | | | | | | | | | | |
| NOTES: | | | | | | | | | | | | |
| WWF= Warm water fishes | | | | | | | | | | | | |
| CWF= Cold water fishes | | | | | | | | | | | | |
| TSF= Trout stocking | | | | | | | | | | | | |

| Facility: | USS Irvin Plant | | | | | |
|----------------|-------------------|----------------------|---------------------------|--------------------|-------|------------------|
| Permit Number: | PA0004073 | | | | | |
| Stream: | Monongahela River | | | | | |
| | | | | | | |
| | WWF | | | WWF | | WWF |
| | Ambient Stream | Ambient Stream | Target Maximum | Daily | | Daily |
| | Temperature (°F) | Temperature (°F) | Stream Temp. ¹ | WLA ² | | WLA ³ |
| | (Default) | (Site-specific data) | (°F) | (Million BTUs/day) | | at Discharge |
| Jan 1-31 | 35 | 0 | 40 | 47,399 | 110.0 | 25.32 |
| Feb 1-29 | 35 | 0 | 40 | 51,846 | 110.0 | 25.32 |
| Mar 1-31 | 40 | 0 | 46 | 124,470 | 110.0 | 25.32 |
| Apr 1-15 | 47 | 0 | 52 | 137,817 | 110.0 | 25.32 |
| Apr 16-30 | 53 | 0 | 58 | 137,817 | 110.0 | 25.32 |
| May 1-15 | 58 | 0 | 64 | 90,675 | 110.0 | 25.32 |
| May 16-30 | 62 | 0 | 72 | 151,124 | 110.0 | 25.32 |
| Jun 1-15 | 67 | 0 | 80 | 115,531 | 110.0 | 25.32 |
| Jun 16-30 | 71 | 0 | 84 | 115,531 | 110.0 | 25.32 |
| Jul 1-31 | 75 | 0 | 87 | 60,398 | 110.0 | 25.32 |
| Aug 1-15 | 74 | 0 | 87 | 53,869 | 110.0 | 25.32 |
| Aug 16-31 | 74 | 0 | 87 | 53,869 | 110.0 | 25.32 |
| Sep 1-15 | 71 | 0 | 84 | 42,308 | 110.0 | 25.32 |
| Sep 16-30 | 65 | 0 | 78 | 42,308 | 110.0 | 25.32 |
| Oct 1-15 | 60 | 0 | 72 | 42,611 | 110.0 | 25.32 |
| Oct 16-31 | 54 | 0 | 66 | 42,611 | 110.0 | 25.32 |
| Nov 1-15 | 48 | 0 | 58 | 47,367 | 110.0 | 25.32 |
| Nov 16-30 | 42 | 0 | 50 | 37,894 | 110.0 | 25.32 |
| Dec 1-31 | 37 | 0 | 42 | 35,541 | 110.0 | 25.32 |
| | | | | | | |

¹ This is the maximum of the WWF WQ criterion or the ambient temperature. The ambient temperature may be either the design (median) temperature for WWF, or the ambient stream temperature based on site-specific data entered by the user.

A minimum of 1°^oF above ambient stream temperature is allocated.

² The WLA expressed in Million BTUs/day is valid for Case 1 scenarios, and disabled for Case 2 scenarios.

³ The WLA expressed in °F is valid only if the limit is tied to a daily discharge flow limit (may be used for Case 1 or Case 2).

WLAs greater than 110°^oF are displayed as 110°^oF.

Attachment F:
Effluent Limitation Guidelines Calculations

United States Steel Corporation - Mon Valley Irvin Plant
Federal ELG Calculations
PA0004073
Authorization 827245

| NPDES Permit Application Reported Production Rates | |
|--|------------------------------|
| Operation | Max Monthly Average Tons/Day |
| 64" Pickle Line | 3316 |
| 84" Pickle Line | 5170 |
| Cont. Anneal Line | 779 |
| No. 3 5 Stand Mill | 8068 |
| No. 1 Galvanize Line | 605 |
| No. 2 Galvanize Line | 572 |
| No. 7 Temper Mill | 3741 |
| 80" Hot Strip Mill | 9994 |

IMP 201

64-Inch Continuous Pickle Production Line

ELG 40 CFR 420.94 (b)(2) NSPS Iron and Steel Manufacturing Hydrochloric Acid Pickling -Strip, sheet, and plate - Continuous

| Pollutant | ELG - BPT Effluent Limitations (lbs/1,000 lb product) | | Mass-Based Effluent Limits (lbs./day) | |
|-----------------|--|--|--|-----------|
| | Max for any 1 day | Average Daily Value for 30 consecutive days | Average Monthly | Max Daily |
| TSS | 0.0117 | 0.00501 | 33.226 | 77.594 |
| O&G* | 0.00501 | 0.00167 | 11.075 | 33.226 |
| Lead | 0.0000751 | 0.000025 | 0.166 | 0.498 |
| Zinc | 0.00010 | 0.0000334 | 0.222 | 0.663 |
| pH | Within Range of 6.0 to 9.0 | | Within Range of 6.0 to 9.0 | |

Sample Calculations

Mass-Based Effluent Limit (lbs/day) = [ELG Max for any 1 day (lbs/1,000 lbs production)] * [Daily Max Production (1,000 lbs production)]
TSS Max Daily (lbs/day) = (0.0117 lbs/1,000 lbs production) * [(3316 tons production/day) * (2,000 lbs/ton) / (1,000 lbs production)]
TSS Max Daily (lbs/day) = 838.989 lbs/day

* the limitations for oil and grease shall be applicable when acid picking wastewaters are treated with cold rolling wastewaters

ELG 40 CFR 420.94(b)(4) Iron and Steel Manufacturing Combination Acid Pickling -Fume Scrubbers (NSPS)

(1 scrubbers)

| Pollutant | ELG - BPT Effluent Limitations | | Mass-Based Effluent Limits | |
|-----------|--------------------------------|---|----------------------------|-----------|
| | Max for any 1 day | Average Daily Value for 30 consecutive days | Average Monthly | Max Daily |
| TSS | 5.720 | 2.45 | 5.401 | 12.610 |
| O&G* | 2.45 | 0.819 | 1.806 | 5.401 |
| Lead | 0.0368 | 0.0123 | 0.027 | 0.081 |
| Zinc | 0.04910 | 0.0164 | 0.036 | 0.108 |
| pH | Within Range of 6.0 to 9.0 | | Within Range of 6.0 to 9.0 | |

* the limitations for oil and grease shall be applicable when acid picking wastewaters are treated with cold rolling wastewaters

Sample Calculations

Mass-Based Effluent Limit (lbs/day) = [ELG Max for any 1 day (Kg/Day) * (mass unit conversion)*number of scrubbers

TSS Max Daily (lbs/day) = (5.720 kg/day) * (2.2046 lbs/Kg) * (1 Scrubbers)

TSS Max Daily (lbs/day) = 12.61 lbs/day

84-Inch Continuous Pickle Production Line

ELG 40 CFR 420.92 (b)(2) BAT Iron and Steel Manufacturing Hydrochloric Acid Pickling -Strip, sheet, and plate -

| Pollutant | ELG - BPT Effluent Limitations | | Mass-Based Effluent Limits | |
|-----------|--------------------------------|---|----------------------------|-----------|
| | Max for any 1 day | Average Daily Value for 30 consecutive days | Average Monthly | Max Daily |
| TSS | 0.0818 | 0.035 | 361.900 | 845.812 |
| O&G* | 0.035 | 0.0117 | 120.978 | 361.900 |
| Lead | 0.000526 | 0.000175 | 1.810 | 5.439 |
| Zinc | 0.000701 | 0.000234 | 2.420 | 7.248 |
| pH | Within Range of 6.0 to 9.0 | | Within Range of 6.0 to 9.0 | |

* the limitations for oil and grease shall be applicable when acid picking wastewaters are treated with cold rolling wastewaters

ELG 40 CFR 420.92(b)(4) Iron and Steel Manufacturing Combination Acid Pickling -Fume Scrubbers (BAT)

(1 scrubbers)

| Pollutant | ELG - BPT Effluent Limitations | | Mass-Based Effluent Limits | |
|-----------|--------------------------------|---|----------------------------|-----------|
| | Max for any 1 day | Average Daily Value for 30 consecutive days | Average Monthly | Max Daily |
| TSS | 5.720 | 2.45 | 5.401 | 12.610 |
| O&G* | 2.45 | 0.819 | 1.806 | 5.401 |
| Lead | 0.0368 | 0.0123 | 0.027 | 0.081 |
| Zinc | 0.04910 | 0.0164 | 0.036 | 0.108 |
| pH | Within Range of 6.0 to 9.0 | | Within Range of 6.0 to 9.0 | |

* the limitations for oil and grease shall be applicable when acid picking wastewaters are treated

Continuous Annealing Line (Alkaline Cleaning of Strip)

ELG 40 CFR 420.112 b) BPT Iron and Steel Manufacturing Alkaline Cleaning - Continuous

| Pollutant | ELG - BPT Effluent Limitations | | Mass-Based Effluent Limits | |
|-----------|--------------------------------|---|----------------------------|-----------|
| | Max for any 1 day | Average Daily Value for 30 consecutive days | Average Monthly | Max Daily |
| TSS | 0.102 | 0.0438 | 68.240 | 158.916 |
| O&G | 0.0438 | 0.0146 | 22.747 | 68.240 |
| pH | Within Range of 6.0 to 9.0 | | Within Range of 6.0 to 9.0 | |

Cold Reduction Mill (Cold Rolling of Steel in a five-stand Recirculating Mill)

ELG 40 CFR 420.102 a)(2) BPT Iron and Steel Manufacturing Cold Forming Cold Rolling Mill Recirculation - Multiple

| Pollutant | ELG - BPT Effluent Limitations | | Mass-Based Effluent Limits | |
|---------------------|--------------------------------|---|----------------------------|-----------|
| | Max for any 1 day | Average Daily Value for 30 consecutive days | Average Monthly | Max Daily |
| TSS | 0.00626 | 0.00313 | 50.506 | 101.011 |
| O&G | 0.00261 | 0.00104 | 16.781 | 42.115 |
| Chromium* | 0.000104 | 0.0000418 | 0.674 | 1.678 |
| Lead | 0.0000469 | 0.0000156 | 0.252 | 0.757 |
| Nickel* | 0.0000939 | 0.0000313 | 0.505 | 1.515 |
| Zinc | 0.0000313 | 0.0000104 | 0.168 | 0.505 |
| Naphthalene | 0.0000104 | | | 0.168 |
| Tetrachloroethylene | 0.0000156 | | | 0.252 |
| pH | Within Range of 6.0 to 9.0 | | Within Range of 6.0 to 9.0 | |

*The limitations for Chromium and Nickel Shall be appliavle in lieu of those lead and zinc when cold rolling wastewaters are treated with descaling or combination acid pickling wastewaters.

No.1 Galvanize Line (Hot Coating of Steel Strip)

ELG 40 CFR 420.122 a)(1) BPT Iron and Steel Manufacturing Hot Coating Galvanizing, terne coating, and other coatings - Strip, Sheet, and miscellaneous products

| Pollutant | ELG - BPT Effluent Limitations | | Mass-Based Effluent Limits | |
|------------------------|--------------------------------|---|----------------------------|-----------|
| | Max for any 1 day | Average Daily Value for 30 consecutive days | Average Monthly | Max Daily |
| TSS | 0.175 | 0.0751 | 90.871 | 211.750 |
| O&G | 0.0751 | 0.025 | 30.250 | 90.871 |
| Lead | 0.00113 | 0.000376 | 0.455 | 1.367 |
| Zinc | 0.00150 | 0.0005 | 0.605 | 1.815 |
| Chromium (hexavalent)* | 0.00015 | 0.0000501 | 0.061 | 0.182 |
| pH | Within Range of 6.0 to 9.0 | | Within Range of 6.0 to 9.0 | |

*The limitations for hexavalent chromium shall apply only to galvanizing operations which discharge wastewaters from the chromate rinse step

No.2 Galvanize Line (Alkaline Cleaning of Steel Strip, Hot Coating of Steel Strip and One Fume Scrubber)

ELG 40 CFR 420.112 (b) BPT Iron and Steel Manufacturing Alkaline Cleaning - Continuous

| Pollutant | ELG - BPT Effluent Limitations | | Mass-Based Effluent Limits | |
|-----------|--------------------------------|---|----------------------------|-----------|
| | Max for any 1 day | Average Daily Value for 30 consecutive days | Average Monthly | Max Daily |
| TSS | 0.102 | 0.0438 | 50.107 | 116.688 |
| O&G | 0.0438 | 0.0146 | 16.702 | 50.107 |
| pH | Within Range of 6.0 to 9.0 | | Within Range of 6.0 to 9.0 | |

ELG 40 CFR 420.122 (a)(1) BPT Iron and Steel Manufacturing Hot Coating Galvanizing, terne coating, and other coatings - Strip, Sheet, and miscellaneous products

| Pollutant | ELG - BPT Effluent Limitations | | Mass-Based Effluent Limits | |
|------------------------|--------------------------------|---|----------------------------|-----------|
| | Max for any 1 day | Average Daily Value for 30 consecutive days | Average Monthly | Max Daily |
| TSS | 0.175 | 0.0751 | 85.914 | 200.200 |
| O&G | 0.0751 | 0.025 | 28.600 | 85.914 |
| Lead | 0.00113 | 0.000376 | 0.430 | 1.293 |
| Zinc | 0.00150 | 0.0005 | 0.572 | 1.716 |
| Chromium (hexavalent)* | 0.00015 | 0.0000501 | 0.057 | 0.172 |
| pH | Within Range of 6.0 to 9.0 | | Within Range of 6.0 to 9.0 | |

*The limitations for hexavalent chromium shall apply only to galvanizing operations which discharge wastewaters from the chromate rinse step

**ELG 40 CFR 420.122/123 (c) BPT/BAT Iron and Steel Manufacturing Hot Coating
Galvanizing, terne coating, and other coatings - Fume Scrubber
(1 scrubbers)**

| Pollutant | ELG - BPT Effluent Limitations | | Mass-Based Effluent Limits | |
|------------------------|--------------------------------|---|----------------------------|-----------|
| | Max for any 1 day | Average Daily Value for 30 consecutive days | Average Monthly | Max Daily |
| TSS | 38.100 | 16.3 | 35.935 | 83.995 |
| O&G | 16.3 | 5.45 | 12.015 | 35.935 |
| Lead | 0.0368 | 0.0123 | 0.027 | 0.081 |
| Zinc | 0.04910 | 0.0164 | 0.036 | 0.108 |
| Chromium (Hexavalent)* | 0.0049 | 0.00163 | 0.004 | 0.011 |
| pH | Within Range of 6.0 to 9.0 | | Within Range of 6.0 to 9.0 | |

*The limitations for hexavalent chromium shall apply only to galvanizing operations which discharge wastewaters from the chromate rinse step

Temper Mill (Cold Rolling of Steel in Single-stand Direct Application Mill)

ELG 40 CFR 420.102 (a)(4) BPT Iron and Steel Manufacturing Cold Forming Cold Rolling Mill Direct Application - Single Stand

| Pollutant | ELG - BPT Effluent Limitations | | Mass-Based Effluent Limits | |
|---------------------|--------------------------------|---|----------------------------|-----------|
| | Max for any 1 day | Average Daily Value for 30 consecutive days | Average Monthly | Max Daily |
| TSS | 0.0225 | 0.0113 | 84.547 | 168.345 |
| O&G | 0.00939 | 0.00376 | 28.132 | 70.256 |
| Chromium* | 0.0003760 | 0.00015 | 1.122 | 2.813 |
| Lead | 0.0001690 | 0.0000563 | 0.421 | 1.264 |
| Nickel* | 0.0003380 | 0.000113 | 0.845 | 2.529 |
| Zinc | 0.0001130 | 0.0000376 | 0.281 | 0.845 |
| Naphthalene | 0.0000376 | | | 0.281 |
| Tetrachloroethylene | 0.0000563 | | | 0.421 |
| pH | Within Range of 6.0 to 9.0 | | Within Range of 6.0 to 9.0 | |

*The limitations for Chromium and Nickel Shall be applicable in lieu of those lead and zinc when cold rolling wastewaters are treated with descaling or combination acid pickling wastewaters.

| Pollutant | Mass-Based Effluent Limits | |
|-------------------------|----------------------------|-----------|
| | Average Monthly | Max Daily |
| TSS | 872.049 | 1989.533 |
| O&G | 290.893 | 849.368 |
| Chromium* | 1.797 | 4.491 |
| Chromium (Hexavalent)** | 0.122 | 0.364 |
| Lead | 3.615 | 10.862 |
| Nickel* | 1.351 | 4.044 |
| Zinc | 4.376 | 13.118 |
| Naphthalene | | 0.449 |
| Tetrachloroethylene | | 0.673 |
| pH | Within Range of 6.0 to 9.0 | |

*Chromium and Nickel limitations will not be imposed because cold rolling wastewaters are not treated with descaling or combination acid pickling wastewaters.

**Hexavalent Chromium limitations will not be imposed because the galvanizing operations do not discharge wastewater from the chromate rinse step.

IMP 301

Hot Strip Mill (Carbon Plate Mill Hot Forming Operations)

ELG 40 CFR 420.72 (c)(1) BPT Iron and Steel Manufacturing Hot Forming Flat Mills - Hot Strip and Sheet Mills, Carbon and Specialty

| Pollutant | ELG - BPT Effluent Limitations (lbs/1,000 lb product) | | Mass-Based Effluent Limits (lbs./day) | |
|-----------|--|--|--|-----------|
| | Max for any 1 day | Average Daily Value for 30 consecutive days | Average Monthly | Max Daily |
| TSS | 0.427 | 0.16 | 3198.080 | 8534.876 |
| O&G | 0.107 | | | 2138.716 |
| pH | Within Range of 6.0 to 9.0 | | Within Range of 6.0 to 9.0 | |

Attachment G:

Outfall 003 Toxics Management Spreadsheet Evaluation



Discharge Information

| Instructions | | | Discharge | | Stream | | | | | | |
|---|---------------------------------|--------------------|--|-------------------|-----------------|---------------------------------|-------------------|----------------|-----|---------------|-------------|
| Facility: USS Mon Valley Irvin Plant | | | NPDES Permit No.: PA0004073 | | | Outfall No.: 003 | | | | | |
| Evaluation Type: Major Sewage / Industrial Waste | | | Wastewater Description: NCCW, Boiler Blowdown | | | | | | | | |
| Discharge Characteristics | | | | | | | | | | | |
| Design Flow (MGD)* | Hardness (mg/l)* | pH (SU)* | Partial Mix Factors (PMFs) | | | Complete Mix Times (min) | | | | | |
| | | | AFC | CFC | THH | CRL | Q ₇₋₁₀ | Q _h | | | |
| 1.72 | 761 | 7.06 | | | | | | | | | |
| Discharge Pollutant | | | 0 if left blank | 0.5 if left blank | 0 if left blank | 1 if left blank | | | | | |
| | Units | Max Discharge Conc | Trib Conc | Stream Conc | Daily CV | Hourly CV | Stream CV | Fate Coeff | FOS | Criteri a Mod | Chem Transl |
| Group 1 | Total Dissolved Solids (PWS) | mg/L | 1280 | | | | | | | | |
| | Chloride (PWS) | mg/L | 116 | | | | | | | | |
| | Bromide | mg/L | 1 | | | | | | | | |
| | Sulfate (PWS) | mg/L | 591 | | | | | | | | |
| | Fluoride (PWS) | mg/L | 0.24 | | | | | | | | |
| Group 2 | Total Aluminum | µg/L | 220 | | | | | | | | |
| | Total Antimony | µg/L | 0.53 | | | | | | | | |
| | Total Arsenic | µg/L | < 1 | | | | | | | | |
| | Total Barium | µg/L | 21.5 | | | | | | | | |
| | Total Beryllium | µg/L | < 1 | | | | | | | | |
| | Total Boron | µg/L | 103 | | | | | | | | |
| | Total Cadmium | µg/L | < 0.16 | | | | | | | | |
| | Total Chromium (III) | µg/L | 0.44 | | | | | | | | |
| | Hexavalent Chromium | µg/L | 0.051 | | | | | | | | |
| | Total Cobalt | µg/L | 0.458 | | | | | | | | |
| | Total Copper | µg/L | 1.66 | | | | | | | | |
| | Free Cyanide | µg/L | | | | | | | | | |
| | Total Cyanide | µg/L | < 10 | | | | | | | | |
| | Dissolved Iron | µg/L | < 20 | | | | | | | | |
| | Total Iron | µg/L | 2380 | | | | | | | | |
| | Total Lead | µg/L | 0.33 | | | | | | | | |
| | Total Manganese | µg/L | 230 | | | | | | | | |
| | Total Mercury | µg/L | < 0.2 | | | | | | | | |
| | Total Nickel | µg/L | 7.5 | | | | | | | | |
| | Total Phenols (Phenolics) (PWS) | µg/L | < 2 | | | | | | | | |
| | Total Selenium | µg/L | < 2 | | | | | | | | |
| | Total Silver | µg/L | < 0.144 | | | | | | | | |
| | Total Thallium | µg/L | < 0.176 | | | | | | | | |
| | Total Zinc | µg/L | 11 | | | | | | | | |
| | Total Molybdenum | µg/L | 1.5 | | | | | | | | |
| | Acrolein | µg/L | < 1.3 | | | | | | | | |
| | Acrylamide | µg/L | < 0.011 | | | | | | | | |
| | Acrylonitrile | µg/L | < 2 | | | | | | | | |
| | Benzene | µg/L | < 0.12 | | | | | | | | |
| | Bromoform | µg/L | < 0.37 | | | | | | | | |

| | | | | | | | | | | | | | | | | | | | | |
|---------|-----------------------------|------|---|------|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|
| Group 3 | Carbon Tetrachloride | µg/L | < | 0.23 | | | | | | | | | | | | | | | | |
| | Chlorobenzene | µg/L | < | 0.25 | | | | | | | | | | | | | | | | |
| | Chlorodibromomethane | µg/L | < | 0.25 | | | | | | | | | | | | | | | | |
| | Chloroethane | µg/L | < | 0.27 | | | | | | | | | | | | | | | | |
| | 2-Chloroethyl Vinyl Ether | µg/L | < | 3.1 | | | | | | | | | | | | | | | | |
| | Chloroform | µg/L | < | 0.15 | | | | | | | | | | | | | | | | |
| | Dichlorobromomethane | µg/L | < | 0.18 | | | | | | | | | | | | | | | | |
| | 1,1-Dichloroethane | µg/L | < | 0.05 | | | | | | | | | | | | | | | | |
| | 1,2-Dichloroethane | µg/L | < | 0.12 | | | | | | | | | | | | | | | | |
| | 1,1-Dichloroethylene | µg/L | < | 0.13 | | | | | | | | | | | | | | | | |
| | 1,2-Dichloropropane | µg/L | < | 0.26 | | | | | | | | | | | | | | | | |
| | 1,3-Dichloropropylene | µg/L | < | 0.47 | | | | | | | | | | | | | | | | |
| | 1,4-Dioxane | µg/L | | 0.2 | | | | | | | | | | | | | | | | |
| | Ethylbenzene | µg/L | < | 0.2 | | | | | | | | | | | | | | | | |
| | Methyl Bromide | µg/L | < | 0.42 | | | | | | | | | | | | | | | | |
| | Methyl Chloride | µg/L | < | 0.33 | | | | | | | | | | | | | | | | |
| | Methylene Chloride | µg/L | < | 0.14 | | | | | | | | | | | | | | | | |
| | 1,1,2,2-Tetrachloroethane | µg/L | < | 0.38 | | | | | | | | | | | | | | | | |
| | Tetrachloroethylene | µg/L | < | 0.27 | | | | | | | | | | | | | | | | |
| | Toluene | µg/L | < | 0.24 | | | | | | | | | | | | | | | | |
| | 1,2-trans-Dichloroethylene | µg/L | < | 0.08 | | | | | | | | | | | | | | | | |
| | 1,1,1-Trichloroethane | µg/L | < | 0.12 | | | | | | | | | | | | | | | | |
| | 1,1,2-Trichloroethane | µg/L | < | 0.13 | | | | | | | | | | | | | | | | |
| | Trichloroethylene | µg/L | < | 0.29 | | | | | | | | | | | | | | | | |
| | Vinyl Chloride | µg/L | < | 0.33 | | | | | | | | | | | | | | | | |
| Group 4 | 2-Chlorophenol | µg/L | < | 0.38 | | | | | | | | | | | | | | | | |
| | 2,4-Dichlorophenol | µg/L | < | 0.43 | | | | | | | | | | | | | | | | |
| | 2,4-Dimethylphenol | µg/L | < | 0.46 | | | | | | | | | | | | | | | | |
| | 4,6-Dinitro-o-Cresol | µg/L | < | 1.2 | | | | | | | | | | | | | | | | |
| | 2,4-Dinitrophenol | µg/L | < | 2.8 | | | | | | | | | | | | | | | | |
| | 2-Nitrophenol | µg/L | < | 0.38 | | | | | | | | | | | | | | | | |
| | 4-Nitrophenol | µg/L | < | 1.3 | | | | | | | | | | | | | | | | |
| | p-Chloro-m-Cresol | µg/L | < | 0.38 | | | | | | | | | | | | | | | | |
| | Pentachlorophenol | µg/L | < | 1.7 | | | | | | | | | | | | | | | | |
| | Phenol | µg/L | < | 0.25 | | | | | | | | | | | | | | | | |
| Group 5 | 2,4,6-Trichlorophenol | µg/L | < | 0.46 | | | | | | | | | | | | | | | | |
| | Acenaphthene | µg/L | < | 0.39 | | | | | | | | | | | | | | | | |
| | Acenaphthylene | µg/L | < | 0.38 | | | | | | | | | | | | | | | | |
| | Anthracene | µg/L | < | 0.39 | | | | | | | | | | | | | | | | |
| | Benzidine | µg/L | < | 2.5 | | | | | | | | | | | | | | | | |
| | Benzo(a)Anthracene | µg/L | < | 0.4 | | | | | | | | | | | | | | | | |
| | Benzo(a)Pyrene | µg/L | < | 0.35 | | | | | | | | | | | | | | | | |
| | 3,4-Benzofluoranthene | µg/L | < | 0.39 | | | | | | | | | | | | | | | | |
| | Benzo(ghi)Perylene | µg/L | < | 0.41 | | | | | | | | | | | | | | | | |
| | Benzo(k)Fluoranthene | µg/L | < | 0.38 | | | | | | | | | | | | | | | | |
| | Bis(2-Chloroethoxy)Methane | µg/L | < | 0.43 | | | | | | | | | | | | | | | | |
| | Bis(2-Chloroethyl)Ether | µg/L | < | 0.37 | | | | | | | | | | | | | | | | |
| | Bis(2-Chloroisopropyl)Ether | µg/L | < | 0.43 | | | | | | | | | | | | | | | | |
| | Bis(2-Ethylhexyl)Phthalate | µg/L | | 3.1 | | | | | | | | | | | | | | | | |
| | 4-Bromophenyl Phenyl Ether | µg/L | < | 0.44 | | | | | | | | | | | | | | | | |
| | Butyl Benzyl Phthalate | µg/L | | 4.3 | | | | | | | | | | | | | | | | |
| | 2-Chloronaphthalene | µg/L | < | 0.39 | | | | | | | | | | | | | | | | |
| | 4-Chlorophenyl Phenyl Ether | µg/L | < | 0.39 | | | | | | | | | | | | | | | | |
| | Chrysene | µg/L | < | 0.41 | | | | | | | | | | | | | | | | |
| | Dibenzo(a,h)Anthracene | µg/L | < | 0.42 | | | | | | | | | | | | | | | | |
| | 1,2-Dichlorobenzene | µg/L | < | 0.37 | | | | | | | | | | | | | | | | |
| | 1,3-Dichlorobenzene | µg/L | < | 0.43 | | | | | | | | | | | | | | | | |
| | 1,4-Dichlorobenzene | µg/L | < | 0.43 | | | | | | | | | | | | | | | | |
| | 3,3-Dichlorobenzidine | µg/L | < | 0.97 | | | | | | | | | | | | | | | | |
| | Diethyl Phthalate | µg/L | | 1.4 | | | | | | | | | | | | | | | | |
| | Dimethyl Phthalate | µg/L | < | 0.46 | | | | | | | | | | | | | | | | |
| | Di-n-Butyl Phthalate | µg/L | | 3.2 | | | | | | | | | | | | | | | | |
| | 2,4-Dinitrotoluene | µg/L | < | 0.44 | | | | | | | | | | | | | | | | |

| | | | | | | | | | | | |
|---------------------------|------|---|------|--|--|--|--|--|--|--|--|
| 2,6-Dinitrotoluene | µg/L | < | 0.4 | | | | | | | | |
| Di-n-Octyl Phthalate | µg/L | < | 0.86 | | | | | | | | |
| 1,2-Diphenylhydrazine | µg/L | < | 0.37 | | | | | | | | |
| Fluoranthene | µg/L | < | 0.42 | | | | | | | | |
| Fluorene | µg/L | < | 0.37 | | | | | | | | |
| Hexachlorobenzene | µg/L | < | 0.42 | | | | | | | | |
| Hexachlorobutadiene | µg/L | < | 0.48 | | | | | | | | |
| Hexachlorocyclopentadiene | µg/L | < | 0.72 | | | | | | | | |
| Hexachloroethane | µg/L | < | 0.36 | | | | | | | | |
| Indeno(1,2,3-cd)Pyrene | µg/L | < | 0.39 | | | | | | | | |
| Isophorone | µg/L | < | 0.42 | | | | | | | | |
| Naphthalene | µg/L | < | 0.39 | | | | | | | | |
| Nitrobenzene | µg/L | < | 0.51 | | | | | | | | |
| n-Nitrosodimethylamine | µg/L | < | 0.97 | | | | | | | | |
| n-Nitrosodi-n-Propylamine | µg/L | < | 0.41 | | | | | | | | |
| n-Nitrosodiphenylamine | µg/L | < | 0.48 | | | | | | | | |
| Phenanthrene | µg/L | < | 0.38 | | | | | | | | |
| Pyrene | µg/L | < | 0.41 | | | | | | | | |
| 1,2,4-Trichlorobenzene | µg/L | < | 0.41 | | | | | | | | |



Stream / Surface Water Information

USS Mon Valley Irvin Plant, NPDES Permit No. PA0004073, Outfall 003

Instructions **Discharge** Stream

Receiving Surface Water Name: **Monongahela**

No. Reaches to Model: **1**

- Statewide Criteria
- Great Lakes Criteria
- ORSANCO Criteria

| Location | Stream Code* | RMI* | Elevation (ft)* | DA (mi ²)* | Slope (ft/ft) | PWS Withdrawal (MGD) | Apply Fish Criteria* |
|--------------------|--------------|-------|-----------------|------------------------|---------------|----------------------|----------------------|
| Point of Discharge | 037185 | 17.53 | 712 | 5410 | | | Yes |
| End of Reach 1 | 037185 | 16 | 710 | 5411 | | | Yes |

Q₇₋₁₀

| Location | RMI | LFY (cfs/mi ²)* | Flow (cfs) | | W/D Ratio | Width (ft) | Depth (ft) | Velocity (fps) | Travel Time (days) | Tributary | | Stream | | Analysis | |
|--------------------|-------|-----------------------------|------------|-----------|-----------|------------|------------|----------------|--------------------|-----------|----|-----------|-----|----------|----|
| | | | Stream | Tributary | | | | | | Hardness | pH | Hardness* | pH* | Hardness | pH |
| Point of Discharge | 17.53 | 0.1 | 550 | | | 850 | 12 | | | | | 100 | 7 | | |
| End of Reach 1 | 16 | 0.1 | 550 | | | 850 | 12 | | | | | | | | |

Q_h

| Location | RMI | LFY (cfs/mi ²)* | Flow (cfs) | | W/D Ratio | Width (ft) | Depth (ft) | Velocity (fps) | Travel Time (days) | Tributary | | Stream | | Analysis | |
|--------------------|-------|-----------------------------|------------|-----------|-----------|------------|------------|----------------|--------------------|-----------|----|-----------|-----|----------|----|
| | | | Stream | Tributary | | | | | | Hardness | pH | Hardness* | pH* | Hardness | pH |
| Point of Discharge | 17.53 | | | | | | | | | | | | | | |
| End of Reach 1 | 16 | | | | | | | | | | | | | | |



Model Results

USS Mon Valley Irvin Plant, NPDES Permit No. PA0004073, Outfall 003

All Inputs Results Limits

Hydrodynamics

Wasteload Allocations

AFC CCT (min): PMF: Analysis Hardness (mg/L): Analysis pH:

| Pollutants | Stream Conc (µg/L) | Stream CV | Trib Conc (µg/L) | Fate Coef | WQC (µg/L) | WQ Obj (µg/L) | WLA (µg/L) | Comments |
|---------------------------------|--------------------|-----------|------------------|-----------|------------|---------------|------------|----------------------------------|
| Total Dissolved Solids (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Chloride (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Sulfate (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Fluoride (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Aluminum | 0 | 0 | | 0 | 750 | 750 | 18,255 | |
| Total Antimony | 0 | 0 | | 0 | 1,100 | 1,100 | 23,841 | |
| Total Arsenic | 0 | 0 | | 0 | 340 | 340 | 7,369 | Chem Translator of 1 applied |
| Total Barium | 0 | 0 | | 0 | 21,000 | 21,000 | 455,144 | |
| Total Boron | 0 | 0 | | 0 | 8,100 | 8,100 | 175,556 | |
| Total Cadmium | 0 | 0 | | 0 | 2,608 | 2.8 | 60.6 | Chem Translator of 0.933 applied |
| Total Chromium (III) | 0 | 0 | | 0 | 708.556 | 2,242 | 48,598 | Chem Translator of 0.316 applied |
| Hexavalent Chromium | 0 | 0 | | 0 | 16 | 16.3 | 353 | Chem Translator of 0.982 applied |
| Total Cobalt | 0 | 0 | | 0 | 95 | 95.0 | 2,059 | |
| Total Copper | 0 | 0 | | 0 | 17.270 | 18.0 | 390 | Chem Translator of 0.96 applied |
| Dissolved Iron | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Iron | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Lead | 0 | 0 | | 0 | 86.186 | 115 | 2,483 | Chem Translator of 0.752 applied |
| Total Manganese | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Mercury | 0 | 0 | | 0 | 1.400 | 1.65 | 35.7 | Chem Translator of 0.85 applied |
| Total Nickel | 0 | 0 | | 0 | 586.497 | 588 | 12,737 | Chem Translator of 0.998 applied |
| Total Phenols (Phenolics) (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Selenium | 0 | 0 | | 0 | N/A | N/A | N/A | Chem Translator of 0.922 applied |
| Total Silver | 0 | 0 | | 0 | 5.085 | 5.98 | 130 | Chem Translator of 0.85 applied |
| Total Thallium | 0 | 0 | | 0 | 65 | 65.0 | 1,409 | |
| Total Zinc | 0 | 0 | | 0 | 146.827 | 150 | 3,254 | Chem Translator of 0.978 applied |
| Acrolein | 0 | 0 | | 0 | 3 | 3.0 | 65.0 | |

| | | | | | | | | |
|-----------------------------|---|---|--|---|--------|--------|---------|--|
| Acrylamide | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Acrylonitrile | 0 | 0 | | 0 | 650 | 650 | 14,088 | |
| Benzene | 0 | 0 | | 0 | 640 | 640 | 13,871 | |
| Bromoform | 0 | 0 | | 0 | 1,800 | 1,800 | 39,012 | |
| Carbon Tetrachloride | 0 | 0 | | 0 | 2,800 | 2,800 | 60,686 | |
| Chlorobenzene | 0 | 0 | | 0 | 1,200 | 1,200 | 26,008 | |
| Chlorodibromomethane | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 2-Chloroethyl Vinyl Ether | 0 | 0 | | 0 | 18,000 | 18,000 | 390,124 | |
| Chloroform | 0 | 0 | | 0 | 1,900 | 1,900 | 41,180 | |
| Dichlorobromomethane | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 1,2-Dichloroethane | 0 | 0 | | 0 | 15,000 | 15,000 | 325,103 | |
| 1,1-Dichloroethylene | 0 | 0 | | 0 | 7,500 | 7,500 | 162,552 | |
| 1,2-Dichloropropane | 0 | 0 | | 0 | 11,000 | 11,000 | 238,409 | |
| 1,3-Dichloropropylene | 0 | 0 | | 0 | 310 | 310 | 6,719 | |
| Ethylbenzene | 0 | 0 | | 0 | 2,900 | 2,900 | 62,853 | |
| Methyl Bromide | 0 | 0 | | 0 | 550 | 550 | 11,920 | |
| Methyl Chloride | 0 | 0 | | 0 | 28,000 | 28,000 | 606,859 | |
| Methylene Chloride | 0 | 0 | | 0 | 12,000 | 12,000 | 260,083 | |
| 1,1,2,2-Tetrachloroethane | 0 | 0 | | 0 | 1,000 | 1,000 | 21,674 | |
| Tetrachloroethylene | 0 | 0 | | 0 | 700 | 700 | 15,171 | |
| Toluene | 0 | 0 | | 0 | 1,700 | 1,700 | 36,845 | |
| 1,2-trans-Dichloroethylene | 0 | 0 | | 0 | 6,800 | 6,800 | 147,380 | |
| 1,1,1-Trichloroethane | 0 | 0 | | 0 | 3,000 | 3,000 | 65,021 | |
| 1,1,2-Trichloroethane | 0 | 0 | | 0 | 3,400 | 3,400 | 73,690 | |
| Trichloroethylene | 0 | 0 | | 0 | 2,300 | 2,300 | 49,849 | |
| Vinyl Chloride | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 2-Chlorophenol | 0 | 0 | | 0 | 560 | 560 | 12,137 | |
| 2,4-Dichlorophenol | 0 | 0 | | 0 | 1,700 | 1,700 | 36,845 | |
| 2,4-Dimethylphenol | 0 | 0 | | 0 | 660 | 660 | 14,305 | |
| 4,6-Dinitro-o-Cresol | 0 | 0 | | 0 | 80 | 80.0 | 1,734 | |
| 2,4-Dinitrophenol | 0 | 0 | | 0 | 660 | 660 | 14,305 | |
| 2-Nitrophenol | 0 | 0 | | 0 | 8,000 | 8,000 | 173,388 | |
| 4-Nitrophenol | 0 | 0 | | 0 | 2,300 | 2,300 | 49,849 | |
| p-Chloro-m-Cresol | 0 | 0 | | 0 | 160 | 160 | 3,468 | |
| Pentachlorophenol | 0 | 0 | | 0 | 8,864 | 8.86 | 192 | |
| Phenol | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 2,4,6-Trichlorophenol | 0 | 0 | | 0 | 460 | 460 | 9,970 | |
| Acenaphthene | 0 | 0 | | 0 | 83 | 83.0 | 1,799 | |
| Anthracene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Benzidine | 0 | 0 | | 0 | 300 | 300 | 6,502 | |
| Benzo(a)Anthracene | 0 | 0 | | 0 | 0.5 | 0.5 | 10.8 | |
| Benzo(a)Pyrene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 3,4-Benzofluoranthene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Benzo(k)Fluoranthene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Bis(2-Chloroethyl)Ether | 0 | 0 | | 0 | 30,000 | 30,000 | 650,206 | |
| Bis(2-Chloroisopropyl)Ether | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Bis(2-Ethylhexyl)Phthalate | 0 | 0 | | 0 | 4,500 | 4,500 | 97,531 | |
| 4-Bromophenyl Phenyl Ether | 0 | 0 | | 0 | 270 | 270 | 5,852 | |

| | | | | | | | | |
|---------------------------|---|---|--|---|--------|--------|---------|--|
| Butyl Benzyl Phthalate | 0 | 0 | | 0 | 140 | 140 | 3,034 | |
| 2-Chloronaphthalene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Chrysene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Dibenzo(a,h)Anthracene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 1,2-Dichlorobenzene | 0 | 0 | | 0 | 820 | 820 | 17,772 | |
| 1,3-Dichlorobenzene | 0 | 0 | | 0 | 350 | 350 | 7,586 | |
| 1,4-Dichlorobenzene | 0 | 0 | | 0 | 730 | 730 | 15,822 | |
| 3,3-Dichlorobenzidine | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Diethyl Phthalate | 0 | 0 | | 0 | 4,000 | 4,000 | 86,694 | |
| Dimethyl Phthalate | 0 | 0 | | 0 | 2,500 | 2,500 | 54,184 | |
| Di-n-Butyl Phthalate | 0 | 0 | | 0 | 110 | 110 | 2,384 | |
| 2,4-Dinitrotoluene | 0 | 0 | | 0 | 1,800 | 1,800 | 34,878 | |
| 2,6-Dinitrotoluene | 0 | 0 | | 0 | 990 | 990 | 21,457 | |
| 1,2-Diphenylhydrazine | 0 | 0 | | 0 | 15 | 15.0 | 325 | |
| Fluoranthene | 0 | 0 | | 0 | 200 | 200 | 4,335 | |
| Fluorene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Hexachlorobenzene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Hexachlorobutadiene | 0 | 0 | | 0 | 10 | 10.0 | 217 | |
| Hexachlorocyclopentadiene | 0 | 0 | | 0 | 5 | 5.0 | 108 | |
| Hexachloroethane | 0 | 0 | | 0 | 60 | 60.0 | 1,300 | |
| Indeno(1,2,3-cd)Pyrene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Isophorone | 0 | 0 | | 0 | 10,000 | 10,000 | 216,735 | |
| Naphthalene | 0 | 0 | | 0 | 140 | 140 | 3,034 | |
| Nitrobenzene | 0 | 0 | | 0 | 4,000 | 4,000 | 86,694 | |
| n-Nitrosodimethylamine | 0 | 0 | | 0 | 17,000 | 17,000 | 368,450 | |
| n-Nitrosodi-n-Propylamine | 0 | 0 | | 0 | N/A | N/A | N/A | |
| n-Nitrosodiphenylamine | 0 | 0 | | 0 | 300 | 300 | 6,502 | |
| Phenanthrene | 0 | 0 | | 0 | 5 | 5.0 | 108 | |
| Pyrene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 1,2,4-Trichlorobenzene | 0 | 0 | | 0 | 130 | 130 | 2,818 | |

CFC CCT (min): 720 PMF: 0.693 Analysis Hardness (mg/l): 104.58 Analysis pH: 7.00

| Pollutants | Stream Conc (µg/L) | Stream CV | Trib Conc (µg/L) | Fate Coef | WQC (µg/L) | WQ Obj (µg/L) | WLA (µg/L) | Comments |
|------------------------------|--------------------|-----------|------------------|-----------|------------|---------------|------------|----------------------------------|
| Total Dissolved Solids (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Chloride (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Sulfate (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Fluoride (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Aluminum | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Antimony | 0 | 0 | | 0 | 220 | 220 | 31,731 | |
| Total Arsenic | 0 | 0 | | 0 | 150 | 150 | 21,635 | Chem Translator of 1 applied |
| Total Barium | 0 | 0 | | 0 | 4,100 | 4,100 | 591,345 | |
| Total Boron | 0 | 0 | | 0 | 1,600 | 1,600 | 230,789 | |
| Total Cadmium | 0 | 0 | | 0 | 0.254 | 0.28 | 40.3 | Chem Translator of 0.907 applied |
| Total Chromium (III) | 0 | 0 | | 0 | 76.885 | 89.4 | 12,894 | Chem Translator of 0.86 applied |
| Hexavalent Chromium | 0 | 0 | | 0 | 10 | 10.4 | 1,499 | Chem Translator of 0.962 applied |

| | | | | | | | | |
|---------------------------------|---|---|--|---|---------|-------|---------|----------------------------------|
| Total Cobalt | 0 | 0 | | 0 | 19 | 19.0 | 2,740 | |
| Total Copper | 0 | 0 | | 0 | 9,305 | 9.69 | 1,398 | Chem Translator of 0.96 applied |
| Dissolved Iron | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Iron | 0 | 0 | | 0 | 1,500 | 1,500 | 311,552 | WQC = 30 day average; PMF = 1 |
| Total Lead | 0 | 0 | | 0 | 2,642 | 3.37 | 486 | Chem Translator of 0.784 applied |
| Total Manganese | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Mercury | 0 | 0 | | 0 | 0.770 | 0.91 | 131 | Chem Translator of 0.85 applied |
| Total Nickel | 0 | 0 | | 0 | 54,016 | 54.2 | 7,814 | Chem Translator of 0.997 applied |
| Total Phenols (Phenolics) (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Selenium | 0 | 0 | | 0 | 4,600 | 4.99 | 720 | Chem Translator of 0.922 applied |
| Total Silver | 0 | 0 | | 0 | N/A | N/A | N/A | Chem Translator of 1 applied |
| Total Thallium | 0 | 0 | | 0 | 13 | 13.0 | 1,875 | |
| Total Zinc | 0 | 0 | | 0 | 122,711 | 124 | 17,950 | Chem Translator of 0.988 applied |
| Acrolein | 0 | 0 | | 0 | 3 | 3.0 | 433 | |
| Acrylamide | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Acrylonitrile | 0 | 0 | | 0 | 130 | 130 | 18,750 | |
| Benzene | 0 | 0 | | 0 | 130 | 130 | 18,750 | |
| Bromoform | 0 | 0 | | 0 | 370 | 370 | 53,385 | |
| Carbon Tetrachloride | 0 | 0 | | 0 | 560 | 560 | 80,789 | |
| Chlorobenzene | 0 | 0 | | 0 | 240 | 240 | 34,615 | |
| Chlorodibromomethane | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 2-Chloroethyl Vinyl Ether | 0 | 0 | | 0 | 3,500 | 3,500 | 504,807 | |
| Chloroform | 0 | 0 | | 0 | 390 | 390 | 56,250 | |
| Dichlorobromomethane | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 1,2-Dichloroethane | 0 | 0 | | 0 | 3,100 | 3,100 | 447,115 | |
| 1,1-Dichloroethylene | 0 | 0 | | 0 | 1,500 | 1,500 | 216,346 | |
| 1,2-Dichloropropane | 0 | 0 | | 0 | 2,200 | 2,200 | 317,307 | |
| 1,3-Dichloropropylene | 0 | 0 | | 0 | 61 | 61.0 | 8,798 | |
| Ethylbenzene | 0 | 0 | | 0 | 580 | 580 | 83,654 | |
| Methyl Bromide | 0 | 0 | | 0 | 110 | 110 | 15,865 | |
| Methyl Chloride | 0 | 0 | | 0 | 5,500 | 5,500 | 793,268 | |
| Methylene Chloride | 0 | 0 | | 0 | 2,400 | 2,400 | 346,153 | |
| 1,1,2,2-Tetrachloroethane | 0 | 0 | | 0 | 210 | 210 | 30,288 | |
| Tetrachloroethylene | 0 | 0 | | 0 | 140 | 140 | 20,192 | |
| Toluene | 0 | 0 | | 0 | 330 | 330 | 47,596 | |
| 1,2-trans-Dichloroethylene | 0 | 0 | | 0 | 1,400 | 1,400 | 201,923 | |
| 1,1,1-Trichloroethane | 0 | 0 | | 0 | 610 | 610 | 87,981 | |
| 1,1,2-Trichloroethane | 0 | 0 | | 0 | 680 | 680 | 98,077 | |
| Trichloroethylene | 0 | 0 | | 0 | 450 | 450 | 64,904 | |
| Vinyl Chloride | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 2-Chlorophenol | 0 | 0 | | 0 | 110 | 110 | 15,865 | |
| 2,4-Dichlorophenol | 0 | 0 | | 0 | 340 | 340 | 49,038 | |
| 2,4-Dimethylphenol | 0 | 0 | | 0 | 130 | 130 | 18,750 | |
| 4,6-Dinitro-o-Cresol | 0 | 0 | | 0 | 16 | 16.0 | 2,308 | |
| 2,4-Dinitrophenol | 0 | 0 | | 0 | 130 | 130 | 18,750 | |

| | | | | | | | | |
|-----------------------------|---|---|--|---|-------|-------|---------|--|
| 2-Nitrophenol | 0 | 0 | | 0 | 1,600 | 1,600 | 230,769 | |
| 4-Nitrophenol | 0 | 0 | | 0 | 470 | 470 | 67,788 | |
| p-Chloro-m-Cresol | 0 | 0 | | 0 | 500 | 500 | 72,115 | |
| Pentachlorophenol | 0 | 0 | | 0 | 6,801 | 6.8 | 981 | |
| Phenol | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 2,4,6-Trichlorophenol | 0 | 0 | | 0 | 91 | 91.0 | 13,125 | |
| Acenaphthene | 0 | 0 | | 0 | 17 | 17.0 | 2,452 | |
| Anthracene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Benzidine | 0 | 0 | | 0 | 59 | 59.0 | 8,510 | |
| Benzo(a)Anthracene | 0 | 0 | | 0 | 0.1 | 0.1 | 14.4 | |
| Benzo(a)Pyrene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 3,4-Benzofluoranthene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Benzo(k)Fluoranthene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Bis(2-Chloroethyl)Ether | 0 | 0 | | 0 | 6,000 | 6,000 | 865,383 | |
| Bis(2-Chloroisopropyl)Ether | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Bis(2-Ethylhexyl)Phthalate | 0 | 0 | | 0 | 910 | 910 | 131,250 | |
| 4-Bromophenyl Phenyl Ether | 0 | 0 | | 0 | 54 | 54.0 | 7,788 | |
| Butyl Benzyl Phthalate | 0 | 0 | | 0 | 35 | 35.0 | 5,048 | |
| 2-Chloronaphthalene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Chrysene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Dibenzo(a,h)Anthracene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 1,2-Dichlorobenzene | 0 | 0 | | 0 | 160 | 160 | 23,077 | |
| 1,3-Dichlorobenzene | 0 | 0 | | 0 | 69 | 69.0 | 9,952 | |
| 1,4-Dichlorobenzene | 0 | 0 | | 0 | 150 | 150 | 21,635 | |
| 3,3-Dichlorobenzidine | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Diethyl Phthalate | 0 | 0 | | 0 | 800 | 800 | 115,384 | |
| Dimethyl Phthalate | 0 | 0 | | 0 | 500 | 500 | 72,115 | |
| Di-n-Butyl Phthalate | 0 | 0 | | 0 | 21 | 21.0 | 3,029 | |
| 2,4-Dinitrotoluene | 0 | 0 | | 0 | 320 | 320 | 46,154 | |
| 2,6-Dinitrotoluene | 0 | 0 | | 0 | 200 | 200 | 28,846 | |
| 1,2-Diphenylhydrazine | 0 | 0 | | 0 | 3 | 3.0 | 433 | |
| Fluoranthene | 0 | 0 | | 0 | 40 | 40.0 | 5,769 | |
| Fluorene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Hexachlorobenzene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Hexachlorobutadiene | 0 | 0 | | 0 | 2 | 2.0 | 288 | |
| Hexachlorocyclopentadiene | 0 | 0 | | 0 | 1 | 1.0 | 144 | |
| Hexachloroethane | 0 | 0 | | 0 | 12 | 12.0 | 1,731 | |
| Indeno(1,2,3-cd)Pyrene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Isophorone | 0 | 0 | | 0 | 2,100 | 2,100 | 302,884 | |
| Naphthalene | 0 | 0 | | 0 | 43 | 43.0 | 6,202 | |
| Nitrobenzene | 0 | 0 | | 0 | 810 | 810 | 116,827 | |
| n-Nitrosodimethylamine | 0 | 0 | | 0 | 3,400 | 3,400 | 490,384 | |
| n-Nitrosodi-n-Propylamine | 0 | 0 | | 0 | N/A | N/A | N/A | |
| n-Nitrosodiphenylamine | 0 | 0 | | 0 | 59 | 59.0 | 8,510 | |
| Phenanthrene | 0 | 0 | | 0 | 1 | 1.0 | 144 | |

| | | | | | | | | |
|------------------------|---|---|--|---|-----|------|-------|--|
| Pyrene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 1,2,4-Trichlorobenzene | 0 | 0 | | 0 | 26 | 26.0 | 3,750 | |

THH CCT (min): 720 PMF: 0.693 Analysis Hardness (mg/l): N/A Analysis pH: N/A

| Pollutants | Stream Conc (µg/L) | Stream CV | Trib Conc (µg/L) | Fate Coef | WQC (µg/L) | WQ Obj (µg/L) | WLA (µg/L) | Comments |
|---------------------------------|--------------------|-----------|------------------|-----------|------------|---------------|------------|----------|
| Total Dissolved Solids (PWS) | 0 | 0 | | 0 | 500,000 | 500,000 | N/A | |
| Chloride (PWS) | 0 | 0 | | 0 | 250,000 | 250,000 | N/A | |
| Sulfate (PWS) | 0 | 0 | | 0 | 250,000 | 250,000 | N/A | |
| Fluoride (PWS) | 0 | 0 | | 0 | 2,000 | 2,000 | N/A | |
| Total Aluminum | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Antimony | 0 | 0 | | 0 | 5.6 | 5.6 | 808 | |
| Total Arsenic | 0 | 0 | | 0 | 10 | 10.0 | 1,442 | |
| Total Barium | 0 | 0 | | 0 | 2,400 | 2,400 | 346,153 | |
| Total Boron | 0 | 0 | | 0 | 3,100 | 3,100 | 447,115 | |
| Total Cadmium | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Chromium (III) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Hexavalent Chromium | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Cobalt | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Copper | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Dissolved Iron | 0 | 0 | | 0 | 300 | 300 | 43,269 | |
| Total Iron | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Lead | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Manganese | 0 | 0 | | 0 | 1,000 | 1,000 | 144,231 | |
| Total Mercury | 0 | 0 | | 0 | 0.050 | 0.05 | 7.21 | |
| Total Nickel | 0 | 0 | | 0 | 610 | 610 | 87,981 | |
| Total Phenols (Phenolics) (PWS) | 0 | 0 | | 0 | 5 | 5.0 | N/A | |
| Total Selenium | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Silver | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Thallium | 0 | 0 | | 0 | 0.24 | 0.24 | 34.6 | |
| Total Zinc | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Acrolein | 0 | 0 | | 0 | 3 | 3.0 | 433 | |
| Acrylamide | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Acrylonitrile | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Benzene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Bromoform | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Carbon Tetrachloride | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Chlorobenzene | 0 | 0 | | 0 | 100 | 100.0 | 14,423 | |
| Chlorodibromomethane | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 2-Chloroethyl Vinyl Ether | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Chloroform | 0 | 0 | | 0 | 5.7 | 5.7 | 822 | |
| Dichlorobromomethane | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 1,2-Dichloroethane | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 1,1-Dichloroethylene | 0 | 0 | | 0 | 33 | 33.0 | 4,760 | |

| | | | | | | | |
|-----------------------------|---|---|--|---|--------|--------|-----------|
| 1,2-Dichloropropane | 0 | 0 | | 0 | N/A | N/A | N/A |
| 1,3-Dichloropropylene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Ethylbenzene | 0 | 0 | | 0 | 68 | 68.0 | 9,808 |
| Methyl Bromide | 0 | 0 | | 0 | 100 | 100.0 | 14,423 |
| Methyl Chloride | 0 | 0 | | 0 | N/A | N/A | N/A |
| Methylene Chloride | 0 | 0 | | 0 | N/A | N/A | N/A |
| 1,1,2,2-Tetrachloroethane | 0 | 0 | | 0 | N/A | N/A | N/A |
| Tetrachloroethylene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Toluene | 0 | 0 | | 0 | 57 | 57.0 | 8,221 |
| 1,2-trans-Dichloroethylene | 0 | 0 | | 0 | 100 | 100.0 | 14,423 |
| 1,1,1-Trichloroethane | 0 | 0 | | 0 | 10,000 | 10,000 | 1,442,305 |
| 1,1,2-Trichloroethane | 0 | 0 | | 0 | N/A | N/A | N/A |
| Trichloroethylene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Vinyl Chloride | 0 | 0 | | 0 | N/A | N/A | N/A |
| 2-Chlorophenol | 0 | 0 | | 0 | 30 | 30.0 | 4,327 |
| 2,4-Dichlorophenol | 0 | 0 | | 0 | 10 | 10.0 | 1,442 |
| 2,4-Dimethylphenol | 0 | 0 | | 0 | 100 | 100.0 | 14,423 |
| 4,6-Dinitro-o-Cresol | 0 | 0 | | 0 | 2 | 2.0 | 288 |
| 2,4-Dinitrophenol | 0 | 0 | | 0 | 10 | 10.0 | 1,442 |
| 2-Nitrophenol | 0 | 0 | | 0 | N/A | N/A | N/A |
| 4-Nitrophenol | 0 | 0 | | 0 | N/A | N/A | N/A |
| p-Chloro-m-Cresol | 0 | 0 | | 0 | N/A | N/A | N/A |
| Pentachlorophenol | 0 | 0 | | 0 | N/A | N/A | N/A |
| Phenol | 0 | 0 | | 0 | 4,000 | 4,000 | 576,922 |
| 2,4,6-Trichlorophenol | 0 | 0 | | 0 | N/A | N/A | N/A |
| Acenaphthene | 0 | 0 | | 0 | 70 | 70.0 | 10,096 |
| Anthracene | 0 | 0 | | 0 | 300 | 300 | 43,289 |
| Benzidine | 0 | 0 | | 0 | N/A | N/A | N/A |
| Benzo(a)Anthracene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Benzo(a)Pyrene | 0 | 0 | | 0 | N/A | N/A | N/A |
| 3,4-Benzofluoranthene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Benzo(k)Fluoranthene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Bis(2-Chloroethyl)Ether | 0 | 0 | | 0 | N/A | N/A | N/A |
| Bis(2-Chloroisopropyl)Ether | 0 | 0 | | 0 | 200 | 200 | 28,846 |
| Bis(2-Ethylhexyl)Phthalate | 0 | 0 | | 0 | N/A | N/A | N/A |
| 4-Bromophenyl Phenyl Ether | 0 | 0 | | 0 | N/A | N/A | N/A |
| Butyl Benzyl Phthalate | 0 | 0 | | 0 | 0.1 | 0.1 | 14.4 |
| 2-Chloronaphthalene | 0 | 0 | | 0 | 800 | 800 | 115,384 |
| Chrysene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Dibenzo(a,h)Anthracene | 0 | 0 | | 0 | N/A | N/A | N/A |
| 1,2-Dichlorobenzene | 0 | 0 | | 0 | 1,000 | 1,000 | 144,231 |
| 1,3-Dichlorobenzene | 0 | 0 | | 0 | 7 | 7.0 | 1,010 |
| 1,4-Dichlorobenzene | 0 | 0 | | 0 | 300 | 300 | 43,289 |
| 3,3-Dichlorobenzidine | 0 | 0 | | 0 | N/A | N/A | N/A |
| Diethyl Phthalate | 0 | 0 | | 0 | 600 | 600 | 86,538 |

| | | | | | | | | |
|---------------------------|---|---|--|---|-------|-------|---------|--|
| Dimethyl Phthalate | 0 | 0 | | 0 | 2,000 | 2,000 | 288,461 | |
| Di-n-Butyl Phthalate | 0 | 0 | | 0 | 20 | 20.0 | 2,885 | |
| 2,4-Dinitrotoluene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 2,6-Dinitrotoluene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 1,2-Diphenylhydrazine | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Fluoranthene | 0 | 0 | | 0 | 20 | 20.0 | 2,885 | |
| Fluorene | 0 | 0 | | 0 | 50 | 50.0 | 7,212 | |
| Hexachlorobenzene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Hexachlorobutadiene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Hexachlorocyclopentadiene | 0 | 0 | | 0 | 4 | 4.0 | 577 | |
| Hexachloroethane | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Indeno(1,2,3-cd)Pyrene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Isophorone | 0 | 0 | | 0 | 34 | 34.0 | 4,904 | |
| Naphthalene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Nitrobenzene | 0 | 0 | | 0 | 10 | 10.0 | 1,442 | |
| n-Nitrosodimethylamine | 0 | 0 | | 0 | N/A | N/A | N/A | |
| n-Nitrosodi-n-Propylamine | 0 | 0 | | 0 | N/A | N/A | N/A | |
| n-Nitrosodiphenylamine | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Phenanthrene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Pyrene | 0 | 0 | | 0 | 20 | 20.0 | 2,885 | |
| 1,2,4-Trichlorobenzene | 0 | 0 | | 0 | 0.07 | 0.07 | 10.1 | |

CRL

CCT (min): #####

PMF: 1

Analysis Hardness (mg/l):

N/A

Analysis pH:

N/A

| Pollutants | Stream Conc (µg/L) | Stream CV | Trib Conc (µg/L) | Fate Coef | WQC (µg/L) | WQ Obj (µg/L) | WLA (µg/L) | Comments |
|------------------------------|--------------------|-----------|------------------|-----------|------------|---------------|------------|----------|
| Total Dissolved Solids (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Chloride (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Sulfate (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Fluoride (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Aluminum | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Antimony | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Arsenic | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Barium | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Boron | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Cadmium | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Chromium (III) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Hexavalent Chromium | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Cobalt | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Copper | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Dissolved Iron | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Iron | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Lead | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Manganese | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Mercury | 0 | 0 | | 0 | N/A | N/A | N/A | |

| | | | | | | | | |
|---------------------------------|---|---|--|---|-------|------|--------|--|
| Total Nickel | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Phenols (Phenolics) (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Selenium | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Silver | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Thallium | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Zinc | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Acrolein | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Acrylamide | 0 | 0 | | 0 | 0.07 | 0.07 | 48.6 | |
| Acrylonitrile | 0 | 0 | | 0 | 0.08 | 0.08 | 41.7 | |
| Benzene | 0 | 0 | | 0 | 0.58 | 0.58 | 403 | |
| Bromoform | 0 | 0 | | 0 | 7 | 7.0 | 4,862 | |
| Carbon Tetrachloride | 0 | 0 | | 0 | 0.4 | 0.4 | 278 | |
| Chlorobenzene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Chlorodibromomethane | 0 | 0 | | 0 | 0.8 | 0.8 | 556 | |
| 2-Chloroethyl Vinyl Ether | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Chloroform | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Dichlorobromomethane | 0 | 0 | | 0 | 0.95 | 0.95 | 660 | |
| 1,2-Dichloroethane | 0 | 0 | | 0 | 9.9 | 9.9 | 6,876 | |
| 1,1-Dichloroethylene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 1,2-Dichloropropane | 0 | 0 | | 0 | 0.9 | 0.9 | 625 | |
| 1,3-Dichloropropylene | 0 | 0 | | 0 | 0.27 | 0.27 | 188 | |
| Ethylbenzene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Methyl Bromide | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Methyl Chloride | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Methylene Chloride | 0 | 0 | | 0 | 20 | 20.0 | 13,890 | |
| 1,1,2,2-Tetrachloroethane | 0 | 0 | | 0 | 0.2 | 0.2 | 139 | |
| Tetrachloroethylene | 0 | 0 | | 0 | 10 | 10.0 | 6,945 | |
| Toluene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 1,2-trans-Dichloroethylene | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 1,1,1-Trichloroethane | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 1,1,2-Trichloroethane | 0 | 0 | | 0 | 0.55 | 0.55 | 382 | |
| Trichloroethylene | 0 | 0 | | 0 | 0.6 | 0.6 | 417 | |
| Vinyl Chloride | 0 | 0 | | 0 | 0.02 | 0.02 | 13.9 | |
| 2-Chlorophenol | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 2,4-Dichlorophenol | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 2,4-Dimethylphenol | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 4,6-Dinitro-o-Cresol | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 2,4-Dinitrophenol | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 2-Nitrophenol | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 4-Nitrophenol | 0 | 0 | | 0 | N/A | N/A | N/A | |
| p-Chloro-m-Cresol | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Pentachlorophenol | 0 | 0 | | 0 | 0.030 | 0.03 | 20.8 | |
| Phenol | 0 | 0 | | 0 | N/A | N/A | N/A | |
| 2,4,6-Trichlorophenol | 0 | 0 | | 0 | 1.5 | 1.5 | 1,042 | |
| Acenaphthene | 0 | 0 | | 0 | N/A | N/A | N/A | |

| | | | | | | | |
|-----------------------------|---|---|--|---|---------|---------|-------|
| Anthracene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Benzidine | 0 | 0 | | 0 | 0.0001 | 0.0001 | 0.069 |
| Benzo(a)Anthracene | 0 | 0 | | 0 | 0.001 | 0.001 | 0.69 |
| Benzo(a)Pyrene | 0 | 0 | | 0 | 0.0001 | 0.0001 | 0.069 |
| 3,4-Benzofluoranthene | 0 | 0 | | 0 | 0.001 | 0.001 | 0.69 |
| Benzo(k)Fluoranthene | 0 | 0 | | 0 | 0.01 | 0.01 | 6.95 |
| Bis(2-Chloroethyl)Ether | 0 | 0 | | 0 | 0.03 | 0.03 | 20.8 |
| Bis(2-Chloroisopropyl)Ether | 0 | 0 | | 0 | N/A | N/A | N/A |
| Bis(2-Ethylhexyl)Phthalate | 0 | 0 | | 0 | 0.32 | 0.32 | 222 |
| 4-Bromophenyl Phenyl Ether | 0 | 0 | | 0 | N/A | N/A | N/A |
| Butyl Benzyl Phthalate | 0 | 0 | | 0 | N/A | N/A | N/A |
| 2-Chloronaphthalene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Chrysene | 0 | 0 | | 0 | 0.12 | 0.12 | 83.3 |
| Dibenzo(a,h)Anthracene | 0 | 0 | | 0 | 0.0001 | 0.0001 | 0.069 |
| 1,2-Dichlorobenzene | 0 | 0 | | 0 | N/A | N/A | N/A |
| 1,3-Dichlorobenzene | 0 | 0 | | 0 | N/A | N/A | N/A |
| 1,4-Dichlorobenzene | 0 | 0 | | 0 | N/A | N/A | N/A |
| 3,3-Dichlorobenzidine | 0 | 0 | | 0 | 0.05 | 0.05 | 34.7 |
| Diethyl Phthalate | 0 | 0 | | 0 | N/A | N/A | N/A |
| Dimethyl Phthalate | 0 | 0 | | 0 | N/A | N/A | N/A |
| Di-n-Butyl Phthalate | 0 | 0 | | 0 | N/A | N/A | N/A |
| 2,4-Dinitrotoluene | 0 | 0 | | 0 | 0.05 | 0.05 | 34.7 |
| 2,6-Dinitrotoluene | 0 | 0 | | 0 | 0.05 | 0.05 | 34.7 |
| 1,2-Diphenylhydrazine | 0 | 0 | | 0 | 0.03 | 0.03 | 20.8 |
| Fluoranthene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Fluorene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Hexachlorobenzene | 0 | 0 | | 0 | 0.00008 | 0.00008 | 0.056 |
| Hexachlorobutadiene | 0 | 0 | | 0 | 0.01 | 0.01 | 6.95 |
| Hexachlorocyclopentadiene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Hexachloroethane | 0 | 0 | | 0 | 0.1 | 0.1 | 69.5 |
| Indeno(1,2,3-cd)Pyrene | 0 | 0 | | 0 | 0.001 | 0.001 | 0.69 |
| Isophorone | 0 | 0 | | 0 | N/A | N/A | N/A |
| Naphthalene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Nitrobenzene | 0 | 0 | | 0 | N/A | N/A | N/A |
| n-Nitrosodimethylamine | 0 | 0 | | 0 | 0.0007 | 0.0007 | 0.49 |
| n-Nitrosodi-n-Propylamine | 0 | 0 | | 0 | 0.005 | 0.005 | 3.47 |
| n-Nitrosodiphenylamine | 0 | 0 | | 0 | 3.3 | 3.3 | 2,292 |
| Phenanthrene | 0 | 0 | | 0 | N/A | N/A | N/A |
| Pyrene | 0 | 0 | | 0 | N/A | N/A | N/A |
| 1,2,4-Trichlorobenzene | 0 | 0 | | 0 | N/A | N/A | N/A |

Recommended WQBELs & Monitoring Requirements

No. Samples/Month:

4

| Pollutants | Mass Limits | | Concentration Limits | | | | Governing WQBEL | WQBEL Basis | Comments |
|------------------------|---------------|---------------|----------------------|--------|--------|-------|-----------------|-------------|------------------------------------|
| | AML (lbs/day) | MDL (lbs/day) | AML | MDL | IMAX | Units | | | |
| Butyl Benzyl Phthalate | Report | Report | Report | Report | Report | µg/L | 14.4 | THH | Discharge Conc > 25% WQBEL (no RP) |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |

Other Pollutants without Limits or Monitoring

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., <= Target QL).

| Pollutants | Governing WQBEL | Units | Comments |
|---------------------------------|-----------------|-------|----------------------------|
| Total Dissolved Solids (PWS) | N/A | N/A | PWS Not Applicable |
| Chloride (PWS) | N/A | N/A | PWS Not Applicable |
| Bromide | N/A | N/A | No WQS |
| Sulfate (PWS) | N/A | N/A | PWS Not Applicable |
| Fluoride (PWS) | N/A | N/A | PWS Not Applicable |
| Total Aluminum | 10,419 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Antimony | 808 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Arsenic | N/A | N/A | Discharge Conc < TQL |
| Total Barium | 291,729 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Beryllium | N/A | N/A | No WQS |
| Total Boron | 112,524 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Cadmium | 38.8 | µg/L | Discharge Conc < TQL |
| Total Chromium (III) | 12,894 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Hexavalent Chromium | 226 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Cobalt | 1,320 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Copper | 250 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Cyanide | N/A | N/A | No WQS |
| Dissolved Iron | 43,269 | µg/L | Discharge Conc < TQL |
| Total Iron | 311,552 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Lead | 486 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Manganese | 144,231 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Mercury | 7.21 | µg/L | Discharge Conc < TQL |
| Total Nickel | 7,814 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Phenols (Phenolics) (PWS) | | µg/L | Discharge Conc < TQL |
| Total Selenium | 720 | µg/L | Discharge Conc < TQL |
| Total Silver | 83.1 | µg/L | Discharge Conc < TQL |
| Total Thallium | 34.6 | µg/L | Discharge Conc < TQL |
| Total Zinc | 2,086 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Molybdenum | N/A | N/A | No WQS |
| Acrolein | 41.7 | µg/L | Discharge Conc < TQL |

| | | | |
|----------------------------|---------|------|----------------------|
| Acrylamide | 48.6 | µg/L | Discharge Conc < TQL |
| Acrylonitrile | 41.7 | µg/L | Discharge Conc < TQL |
| Benzene | 403 | µg/L | Discharge Conc < TQL |
| Bromoform | 4,862 | µg/L | Discharge Conc < TQL |
| Carbon Tetrachloride | 278 | µg/L | Discharge Conc < TQL |
| Chlorobenzene | 14,423 | µg/L | Discharge Conc < TQL |
| Chlorodibromomethane | 556 | µg/L | Discharge Conc < TQL |
| Chloroethane | N/A | N/A | No WQS |
| 2-Chloroethyl Vinyl Ether | 250,054 | µg/L | Discharge Conc < TQL |
| Chloroform | 822 | µg/L | Discharge Conc < TQL |
| Dichlorobromomethane | 660 | µg/L | Discharge Conc < TQL |
| 1,1-Dichloroethane | N/A | N/A | No WQS |
| 1,2-Dichloroethane | 6,876 | µg/L | Discharge Conc < TQL |
| 1,1-Dichloroethylene | 4,760 | µg/L | Discharge Conc < TQL |
| 1,2-Dichloropropane | 625 | µg/L | Discharge Conc < TQL |
| 1,3-Dichloropropylene | 188 | µg/L | Discharge Conc < TQL |
| 1,4-Dioxane | N/A | N/A | No WQS |
| Ethylbenzene | 9,808 | µg/L | Discharge Conc < TQL |
| Methyl Bromide | 7,641 | µg/L | Discharge Conc < TQL |
| Methyl Chloride | 388,972 | µg/L | Discharge Conc < TQL |
| Methylene Chloride | 13,890 | µg/L | Discharge Conc < TQL |
| 1,1,2,2-Tetrachloroethane | 139 | µg/L | Discharge Conc < TQL |
| Tetrachloroethylene | 6,945 | µg/L | Discharge Conc < TQL |
| Toluene | 8,221 | µg/L | Discharge Conc < TQL |
| 1,2-trans-Dichloroethylene | 14,423 | µg/L | Discharge Conc < TQL |
| 1,1,1-Trichloroethane | 41,676 | µg/L | Discharge Conc < TQL |
| 1,1,2-Trichloroethane | 382 | µg/L | Discharge Conc < TQL |
| Trichloroethylene | 417 | µg/L | Discharge Conc < TQL |
| Vinyl Chloride | 13.9 | µg/L | Discharge Conc < TQL |
| 2-Chlorophenol | 4,327 | µg/L | Discharge Conc < TQL |
| 2,4-Dichlorophenol | 1,442 | µg/L | Discharge Conc < TQL |
| 2,4-Dimethylphenol | 9,169 | µg/L | Discharge Conc < TQL |
| 4,6-Dinitro-o-Cresol | 288 | µg/L | Discharge Conc < TQL |
| 2,4-Dinitrophenol | 1,442 | µg/L | Discharge Conc < TQL |
| 2-Nitrophenol | 111,135 | µg/L | Discharge Conc < TQL |
| 4-Nitrophenol | 31,951 | µg/L | Discharge Conc < TQL |
| p-Chloro-m-Cresol | 2,223 | µg/L | Discharge Conc < TQL |
| Pentachlorophenol | 20.8 | µg/L | Discharge Conc < TQL |
| Phenol | 576,922 | µg/L | Discharge Conc < TQL |
| 2,4,6-Trichlorophenol | 1,042 | µg/L | Discharge Conc < TQL |
| Acenaphthene | 1,153 | µg/L | Discharge Conc < TQL |
| Acenaphthylene | N/A | N/A | No WQS |
| Anthracene | 43,269 | µg/L | Discharge Conc < TQL |
| Benzidine | 0.069 | µg/L | Discharge Conc < TQL |
| Benzo(a)Anthracene | 0.69 | µg/L | Discharge Conc < TQL |


| | | | |
|---------------------------------|---------|------|----------------------------|
| Benzo(a)Pyrene | 0.069 | µg/L | Discharge Conc < TQL |
| 3,4-Benzofluoranthene | 0.69 | µg/L | Discharge Conc < TQL |
| Benzo(ghi)Perylene | N/A | N/A | No WQS |
| Benzo(k)Fluoranthene | 6.95 | µg/L | Discharge Conc < TQL |
| Bis(2-Chloroethoxy)Methane | N/A | N/A | No WQS |
| Bis(2-Chloroethyl)Ether | 20.8 | µg/L | Discharge Conc < TQL |
| Bis(2-Chloroisopropyl)Ether | 28,846 | µg/L | Discharge Conc < TQL |
| Bis(2-Ethylhexyl)Phthalate | 222 | µg/L | Discharge Conc ≤ 25% WQBEL |
| 4-Bromophenyl Phenyl Ether | 3,751 | µg/L | Discharge Conc < TQL |
| 2-Chloronaphthalene | 115,384 | µg/L | Discharge Conc < TQL |
| 4-Chlorophenyl Phenyl Ether | N/A | N/A | No WQS |
| Chrysene | 83.3 | µg/L | Discharge Conc < TQL |
| Dibenzo(a,h)Anthracene | 0.069 | µg/L | Discharge Conc < TQL |
| 1,2-Dichlorobenzene | 11,391 | µg/L | Discharge Conc < TQL |
| 1,3-Dichlorobenzene | 1,010 | µg/L | Discharge Conc < TQL |
| 1,4-Dichlorobenzene | 10,141 | µg/L | Discharge Conc < TQL |
| 3,3-Dichlorobenzidine | 34.7 | µg/L | Discharge Conc < TQL |
| Diethyl Phthalate | 55,567 | µg/L | Discharge Conc ≤ 25% WQBEL |
| Dimethyl Phthalate | 34,730 | µg/L | Discharge Conc < TQL |
| Di-n-Butyl Phthalate | 1,528 | µg/L | Discharge Conc ≤ 25% WQBEL |
| 2,4-Dinitrotoluene | 34.7 | µg/L | Discharge Conc < TQL |
| 2,6-Dinitrotoluene | 34.7 | µg/L | Discharge Conc < TQL |
| Di-n-Octyl Phthalate | N/A | N/A | No WQS |
| 1,2-Diphenylhydrazine | 20.8 | µg/L | Discharge Conc < TQL |
| Fluoranthene | 2,778 | µg/L | Discharge Conc < TQL |
| Fluorene | 7,212 | µg/L | Discharge Conc < TQL |
| Hexachlorobenzene | 0.056 | µg/L | Discharge Conc < TQL |
| Hexachlorobutadiene | 6.95 | µg/L | Discharge Conc < TQL |
| Hexachlorocyclopentadiene | 69.5 | µg/L | Discharge Conc < TQL |
| Hexachloroethane | 69.5 | µg/L | Discharge Conc < TQL |
| Indeno(1,2,3- <i>cd</i>)Pyrene | 0.69 | µg/L | Discharge Conc < TQL |
| Isophorone | 4,904 | µg/L | Discharge Conc < TQL |
| Naphthalene | 1,945 | µg/L | Discharge Conc < TQL |
| Nitrobenzene | 1,442 | µg/L | Discharge Conc < TQL |
| n-Nitrosodimethylamine | 0.49 | µg/L | Discharge Conc < TQL |
| n-Nitrosodi-n-Propylamine | 3.47 | µg/L | Discharge Conc < TQL |
| n-Nitrosodiphenylamine | 2,292 | µg/L | Discharge Conc < TQL |
| Phenanthrene | 69.5 | µg/L | Discharge Conc < TQL |
| Pyrene | 2,885 | µg/L | Discharge Conc < TQL |
| 1,2,4-Trichlorobenzene | 10.1 | µg/L | Discharge Conc < TQL |

Attachment H:
Outfall 003 TRC Spreadsheet Evaluation

TRC EVALUATION


| 550 | = Q stream (cfs) | 0.5 | = CV Daily |
|----------------|--------------------------------|--|--------------------------------------|
| 1.72 | = Q discharge (MGD) | 0.5 | = CV Hourly |
| 4 | = no. samples | 0.5 | = AFC_Partial Mix Factor |
| 0.3 | = Chlorine Demand of Stream | 0.5 | = CFC_Partial Mix Factor |
| 0 | = Chlorine Demand of Discharge | 15 | = AFC_Criteria Compliance Time (min) |
| 0.5 | = BAT/BPJ Value | 720 | = CFC_Criteria Compliance Time (min) |
| | = % Factor of Safety (FOS) | | = Decay Coefficient (K) |
| Source | Reference | AFC Calculations | Reference |
| TRC | 1.3.2.iii | WLA_afc = 32.988 | 1.3.2.iii |
| PENTOXSD TRG | 5.1a | LTAMULT_afc = 0.373 | 5.1c |
| PENTOXSD TRG | 5.1b | LTA_afc= 12.292 | 5.1d |
| Source | Effluent Limit Calculations | | |
| PENTOXSD TRG | 5.1f | AML MULT = 1.720 | |
| PENTOXSD TRG | 5.1g | AVG MON LIMIT (mg/l) = 0.500 | BAT/BPJ |
| | | INST MAX LIMIT (mg/l) = 1.170 | |
| WLA_afc | | (.019/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k*AFC_tc))... ...+ Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100) | |
| LTAMULT_afc | | EXP((0.5*LN(cvh^2+1))-2.326*LN(cvh^2+1)^0.5) | |
| LTA_afc | | wla_afc*LTAMULT_afc | |
| WLA_cfc | | (.011/e(-k*CFC_tc)) + [(CFC_Yc*Qs*.011/Qd*e(-k*CFC_tc))... ...+ Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100) | |
| LTAMULT_cfc | | EXP((0.5*LN(cvd^2/no_samples+1))-2.326*LN(cvd^2/no_samples+1)^0.5) | |
| LTA_cfc | | wla_cfc*LTAMULT_cfc | |
| AML MULT | | EXP(2.326*LN((cvd^2/no_samples+1)^0.5)-0.5*LN(cvd^2/no_samples+1)) | |
| AVG MON LIMIT | | MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT) | |
| INST MAX LIMIT | | 1.5*((av_mon_limit/AML_MULT)/LTAMULT_afc) | |

Attachment I:
Site Flow Diagrams



**UNITED STATES STEEL CORPORATION
MON VALLEY WORKS – IRVIN PLANT**

| | |
|--|--|
| AMENDOLA ENGINEERING INC. LAKWOOD, OHIO | FIGURE 2 PLANT WATER FLOW SCHEMATIC |
| DATE 03/08/2022 | REVISION 0 |
| DRAWN BY MAO | |





UNITED STATES STEEL CORPORATION
MON VALLEY WORKS – IRVIN PLANT

AMENDOLA
ENGINEERING
INC.
LAKWOOD, OHIO

FIGURE 3
SOUTH WATER TREATMENT PLANT

| DATE | REVISION | DRAWN BY |
|------------|----------|----------|
| 03/10/2022 | 0 | MAO |





UNITED STATES STEEL CORPORATION
MON VALLEY WORKS – IRVIN PLANT

AMENDOLA
ENGINEERING
INC.
LAKWOOD, OHIO

FIGURE 5
SANITARY PLANT

| DATE | REVISION | DRAWN BY |
|------------|----------|----------|
| 03/10/2022 | 0 | MAO |