

Application Type Renewal  
Facility Type Industrial  
Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL INDUSTRIAL WASTE (IW)  
AND IW STORMWATER**

Application No. PA0007854  
APS ID 996639  
Authorization ID 1279089

**Applicant and Facility Information**

Applicant Name	<u>PA American Water Co.</u>	Facility Name	<u>Milton Water System</u>
Applicant Address	<u>105 Sodom Road</u> <u>Milton, PA 17847-9232</u>	Facility Address	<u>702 S Front Street</u> <u>Milton, PA 17847-1020</u>
Applicant Contact	<u>Scott Sharp</u>	Facility Contact	<u>Laura Walter</u>
Applicant Phone	<u>(570) 538-4438</u>	Facility Phone	<u>(570) 742-4612</u>
Client ID	<u>87712</u>	Site ID	<u>257187</u>
SIC Code	<u>4941</u>	Municipality	<u>Milton Borough</u>
SIC Description	<u>Trans. &amp; Utilities - Water Supply</u>	County	<u>Northumberland</u>
Date Application Received	<u>July 2, 2019</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>July 17, 2019</u>	If No, Reason	<u></u>
Purpose of Application	<u>.Renewal of NPDES Permit No. PA0007854 for the discharge of water treatment plant wastewater.</u>		

**Summary of Review**

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		<i>Nicholas W. Hartranft</i> Nicholas W. Hartranft, P.E. / Environmental Engineer Manager	May 6, 2020
X		<i>Thomas M. Randis</i> Thomas M. Randis / Environmental Program Manager	May 7, 2020

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.1</u>
Latitude	<u>41° 0' 33.44"</u>	Longitude	<u>-76° 51' 56.56"</u>
Quad Name	<u>Milton</u>	Quad Code	<u>1031</u>
Wastewater Description: <u>Water Treatment Plant Wastewater</u>			
Receiving Waters	<u>West Branch Susquehanna River (WWF, MF)</u>	Stream Code	<u>18668</u>
NHD Com ID	<u>66919807</u>	RMI	<u>10.98</u>
Drainage Area	<u>6680</u>	Yield (cfs/mi <sup>2</sup> )	<u>0.122</u>
Q <sub>7-10</sub> Flow (cfs)	<u>817.5</u>	Q <sub>7-10</sub> Basis	<u>Gage No. 01553500</u>
Elevation (ft)	<u>450</u>	Slope (ft/ft)	<u>N/A</u>
Watershed No.	<u>10-D</u>	Chapter 93 Class.	<u>WWF, MF</u>
Existing Use	<u>N/A</u>	Existing Use Qualifier	<u>N/A</u>
Exceptions to Use	<u>N/A</u>	Exceptions to Criteria	<u>N/A</u>
Assessment Status	<u>Impaired</u>		
Cause(s) of Impairment	<u>POLYCHLORINATED BIPHENYLS (PCBS)</u>		
Source(s) of Impairment	<u>SOURCE UNKNOWN</u>		
TMDL Status	<u>Final</u>	Name	<u>West Branch Susquehanna</u>
Nearest Downstream Public Water Supply Intake	<u>Sunbury Municipal Water Authority</u>		
PWS Waters	<u>Susquehanna River</u>	Flow at Intake (cfs)	<u>2.430</u>
PWS RMI	<u>124.11</u>	Distance from Outfall (mi)	<u>12.39</u>

Changes Since Last Permit Issuance: The drainage area was changed slightly from 6681 mi<sup>2</sup> to 6680 mi<sup>2</sup> based on results from USGS Streamstats (Attached). The Q<sub>7-10</sub> was re-evaluated. Data from a USGS document titled, *Selected Streamflow Statistics for Streamgage Locations in and near Pennsylvania*, was used to derive the Q<sub>7-10</sub>. A representative reference gage located on the West Branch Susquehanna River near Lewisburg (Gage No. 01553500) was listed to have a drainage area of 6,847 mi<sup>2</sup> and a Q<sub>7-10</sub> of 838 cfs. The drainage area ratio analysis resulted in a Q<sub>7-10</sub> at Outfall 001 of 817.5 cfs.

Treatment Facility Summary				
<b>Treatment Facility Name:</b> Milton District Water Filtration Plant				
Wastewater treated from the Milton District Water Filtration Plant consists of filter backwash water, sludge settling supernatant, pump cooling water, and analyzer wastewater. The combined wastewater stream is conveyed to one of two lagoons (North Lagoon or South Lagoon) for solids settling prior to discharge to the West Branch Susquehanna River.				
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Industrial	Physical (Industrial Waste)	Sedimentation	No Disinfection	0.1
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.187	N/A	Not Overloaded	Sludge Lagoon	Hauled Off

Changes Since Last Permit Issuance: None

Other Comments: N/A

Compliance History

DMR Data for Outfall 001 (from March 1, 2019 to February 29, 2020)

Parameter	FEB-20	JAN-20	DEC-19	NOV-19	OCT-19	SEP-19	AUG-19	JUL-19	JUN-19	MAY-19	APR-19	MAR-19
Flow (MGD) Average Monthly	0.101	0.082	0.066	0.060	0.062	0.0734	0.059	0.0628	0.069	0.0629	0.0667	0.073
Flow (MGD) Daily Maximum	0.143	0.135	0.121	0.129	0.128	0.165	0.093	0.092	0.140	0.103	0.102	0.105
pH (S.U.) Instantaneous Minimum	7.0	7.0	7.0	7.0	7.2	7.1	7.2	7.1	6.9	7.1	7.0	7.1
pH (S.U.) Instantaneous Maximum	7.4	7.6	7.4	7.4	7.6	7.5	7.5	7.5	7.3	7.3	7.5	7.6
TRC (mg/L) Average Monthly	0.30	0.29	0.40	0.036	0.17	0.14	0.25	0.23	0.15	0.12	0.19	0.31
TRC (mg/L) Instantaneous Maximum	0.62	0.52	0.78	0.64	0.27	0.35	1.14	1.22	0.52	0.35	0.42	0.84
TSS (mg/L) Average Monthly	1.0	< 1.60	3.4	2.00	2.40	1.8	3.2	2.8	2.0	3.6	2.2	1.4
TSS (mg/L) Daily Maximum	1.0	< 1.60	3.4	2.00	2.40	1.80	3.2	2.8	2.0	3.6	2.2	1.4
Total Aluminum (mg/L) Average Monthly	0.185	< 0.100	0.475	0.400	0.410	0.251	0.356	0.364	0.199	0.219	0.328	0.208
Total Aluminum (mg/L) Daily Maximum	0.185	< 0.100	0.475	0.400	0.410	0.251	0.356	0.364	0.199	0.219	0.328	0.208
Total Iron (mg/L) Average Monthly	< 0.200	< 0.200	< 0.200	< 0.200	< 0.200	< 0.20	< 0.200	< 0.200	< 0.20	< 0.20	< 0.300	< 0.300
Total Iron (mg/L) Daily Maximum	< 0.200	< 0.200	< 0.200	< 0.200	< 0.200	< 0.200	< 0.200	< 0.200	< 0.20	< 0.20	< 0.300	< 0.300
Total Manganese (mg/L) Average Monthly	0.0367	0.106	0.0439	0.0251	0.0765	0.0588	0.178	0.235	0.053	0.0828	0.0339	0.037
Total Manganese (mg/L) Daily Maximum	0.0367	0.106	0.0439	0.0251	0.0765	0.0588	0.178	0.235	0.053	0.0828	0.0339	0.037

**Compliance History**

<b>Summary of DMRs:</b>	Throughout the past 12 months, no effluent violations have been noted.
<b>Summary of Inspections:</b>	The Department last conducted a compliance evaluation inspection of this facility on January 30, 2020. No violations were noted during the inspection. Discharge was observed from the outfall during the inspection.

Other Comments:

Below is a summary of open violations from a report pulled on April 24, 2020 for the client (ID No. 87712). Two violations noted are for a different facility under the NCRO Clean Water Program's jurisdiction.

FACILITY	INSP PROGRAM	PROGRAM SPECIFIC ID	VIOLATION DATE	VIOLATION	INSP REGION
STEELTON WATER FILTRATION PLT	Storage Tanks	22-63836	12/11/2019	Failure to meet containment requirements	SCRO
STEELTON WATER FILTRATION PLT	Storage Tanks	22-63836	12/11/2019	Failure to meet containment requirements	SCRO
PA AMERICAN WATER COMPANY SCRANTON WWTP	WPC NPDES	PA0026492	12/20/2019	NPDES - Violation of Part C permit condition(s)	NERO
TURBOTVILLE WWTP	WPC NPDES	PA0028100	03/23/2020	NPDES - Violation of effluent limits in Part A of permit	NCRO
TURBOTVILLE WWTP	WPC NPDES	PA0028100	03/23/2020	NPDES - Violation of effluent limits in Part A of permit	NCRO
PA AMER WATER POCONO COUNTRY PLACE WWTP	WPC NPDES	PA0060097	12/23/2019	NPDES - Violation of Part C permit condition(s)	NERO

**Existing Effluent Limitations**

**Outfall 001**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Minimum	Average Monthly	Daily Maximum	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	2/month	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/month	Grab
Total Residual Chlorine	XXX	XXX	XXX	0.5	XXX	2.3	1/week	Grab
Total Suspended Solids	XXX	XXX	XXX	30	60	75	1/month	Composite <sup>(3)</sup>
Total Aluminum	XXX	XXX	XXX	4.0	8.0	10	1/month	Composite <sup>(3)</sup>
Total Iron	XXX	XXX	XXX	2.0	4.0	5.0	1/month	Composite <sup>(3)</sup>
Total Manganese	XXX	XXX	XXX	1.0	2.0	2.5	1/month	Composite <sup>(3)</sup>

Footnotes

- (1) When sampling to determine compliance with mass effluent limitations, the discharge flow at the time of sampling must be measured and recorded.
- (2) This is the minimum number of sampling events required. Permittees are encouraged, and it may be advantageous in demonstrating compliance, to perform more than the minimum number of sampling events.
- (3) A composite for batch discharge mode of operation is defined as three equal volume grab samples to be taken as follows. The first is to be taken exactly 10 minutes after the commencement of the discharge. The second sample should be taken when approximately 1/3 of the total volume has been discharged. The third grab is to be taken when approximately 2/3 of the total volume has been discharged. The three grab samples should then be combined as a composite and analyzed.

**Development of Effluent Limitations**

<b>Outfall No.</b> <u>001</u> <b>Latitude</b> <u>41° 0' 34.00"</u> <b>Wastewater Description:</b> <u>Water Treatment Plant Effluent</u>	<b>Design Flow (MGD)</b> <u>0.1</u> <b>Longitude</b> <u>-76° 51' 47.00"</u>
---	--

**Technology-Based Limitations**

Guidance

The following technology-based limitations are recommended by *Technology-Based Control Requirements for Water Treatment Plant Wastes (362-2183-003, 10/1/97)* for wastewater from treatment of water treatment plant sludges and filter backwash.

Parameter	Limit (mg/l)	SBC
Total Suspended Solids	30	Monthly Avg
	60	Daily Max
Total Iron	2.0	Monthly Avg
	4.0	Daily Max
Total Aluminum	4.0	Monthly Avg
	8.0	Daily Max

<b>Total Manganese</b>	1.0	Monthly Avg
	2.0	Daily Max
<b>pH*</b>	6.0	Minimum
	9.0	IMAX
<b>Total Residual Chlorine</b>	0.5	Monthly Avg
	N/A	Daily Max

\*Also required by 25 Pa. Code 95.32(1)

Comments: These recommended effluent limitations are all currently established in the permit.

### **Water Quality-Based Limitations**

#### *Total Residual Chlorine (TRC)*

Total Residual Chlorine (TRC) limitations were reevaluated using the TRC\_CALC spreadsheet (attached). The spreadsheet indicates that the existing TRC TBEL of 0.5 mg/L required by 25 Pa. Code § 92a.48(b)(2) is protective. However, the spreadsheet indicates that an instantaneous maximum (IMAX) limit of 1.1 should be employed. This change is proposed for this permit term. Given sample results from the past 12 months for IMAX TRC, on two occasion the proposed IMAX TRC limit slightly exceeded at 1.14 and 1.22 mg/L respectively.

#### *Toxic Pollutants*

Sample results representing maximum concentrations from the current permit term from Pollutant Groups 1 and 2 provided in the application were run through the Toxic Screening Analysis (TSA) Spreadsheet model. The TSA is used to determine if any pollutants were candidates for PENTOXSD modeling by comparing effluent concentrations to the most stringent criterion. Where the TSA spreadsheet recommended modeling, the parameters were entered into PENTOXSD v2.0d. Based on the TSA, selenium, cadmium, copper, and fluoride were recommended for PENTOXSD modeling due to sample analysis being conducted at higher quantitation limits (QL) than the minimum QLs required. For selenium, cadmium, copper, and fluoride, the QL was used as the discharge concentration for modeling purposes.

Following modeling, the PENTOXSD recommended WQBELs are also entered in the Toxics Screening Analysis spreadsheet. Based on the data and PENTOXSD model output, the spreadsheet will either recommend no action, monitoring or effluent limitations.

Modeling input/output data has been attached. The model required no action with no WQBELs being established.

### **Chesapeake Bay**

This discharge will not produce a net increase in TN and TP loadings. Consequently, monitoring requirements and/or cap loads are not necessary.

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the “NPDES Permit Writer’s Manual” (362-0400-001) and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day)		Concentrations (mg/L)				Minimum Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Daily Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	2/month	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	9.0	XXX	1/month	Grab
Total Residual Chlorine	XXX	XXX	XXX	0.5	XXX	1.1	1/week	Grab
Total Suspended Solids	XXX	XXX	XXX	30.0	60.0	75	1/month	Grab-Composite*
Total Aluminum	XXX	XXX	XXX	4.0	8.0	10	1/month	Grab-Composite*
Total Iron	XXX	XXX	XXX	2.0	4.0	5	1/month	Grab-Composite*
Total Manganese	XXX	XXX	XXX	1.0	2.0	2.5	1/month	Grab-Composite*

(\*) A composite for batch discharge mode of operation is defined as three equal volume grab samples to be taken as follows. The first is to be taken exactly 10 minutes after the commencement of the discharge. The second sample should be taken when approximately 1/3 of the total volume has been discharged. The third grab is to be taken when approximately 2/3 of the total volume has been discharged. The three grab samples should then be combined as a composite and analyzed.

This language will be included in Part A of the draft permit as a footnote.



