



Application Type  
Facility Type  
Major / Minor

Renewal  
Industrial  
Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL INDUSTRIAL WASTE (IW)  
AND IW STORMWATER**

Application No. **PA0011274**  
APS ID **1127850**  
Authorization ID **1510374**

**Applicant and Facility Information**

Applicant Name	<b>Aqua PA Inc.</b>	Facility Name	<b>Neshaminy Falls Water Treatment Plant</b>
Applicant Address	762 W Lancaster Avenue	Facility Address	2520 W Lincoln Highway
	Bryn Mawr, PA 19010-3402		Oakford, PA 19047
Applicant Contact	Curt Steffy	Facility Contact	Thomas Walton
Applicant Phone	(610) 645-1122	Facility Phone	(215) 757-7565
Client ID	309251	Site ID	446375
SIC Code	4941	Municipality	Middletown Township
SIC Description	Trans. & Utilities - Water Supply	County	Bucks
Date Application Received	<u>December 17, 2024</u>	EPA Waived?	Yes
Date Application Accepted		If No, Reason	
Purpose of Application	NPDES permit renewal.		

**Summary of Review**

The Pa Department of Environmental Protection (PADEP/Department) received an NPDES permit renewal application from GHD, Inc. (consultant) on December 17, 2024, on behalf of Aqua PA Inc. (permittee) for Permittee's Neshaminy Falls Water Treatment Plant (facility). This is a Minor IW facility without ELG (MIIW1) located in Middletown Township, Bucks County. The discharges are in Neshaminy Creek, a WWF/MF, in state watershed 2-F. The existing permit will expire on June 30, 2025. The terms and conditions of the permit were automatically extended since the renewal application was received at least 180 days prior to the permit expiration date. Renewal NPDES permit applications under Clean Water program are not covered by DEP's PDG, per 021-2100-001.

Changes to existing permit: Added: PFOA, PFOS, HFPO-DA, and PFBS. New Outfall 005 added. Removed: TDS

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		Reza H. Chowdhury, E.I.T. / Project Manager 	December 23, 2024
X		<b>Pravin Patel</b> Pravin C. Patel, P.E. / Environmental Engineer Manager	12/30/2024

NPDES Permit Fact Sheet  
Neshaminy Falls Water Treatment Plant

NPDES Permit No. PA0011274

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	002	Design Flow (MGD)	.425
Latitude	40° 8' 45"	Longitude	-74° 57' 9.0"
Quad Name	Langhorne	Quad Code	1746
Wastewater Description:	Treated filter backwash water from lagoons and belt filter presses (Maintenance and Emergency only)		
Receiving Waters	Neshaminy Creek (WWF, MF)	Stream Code	02484
NHD Com ID	25480850	RMI	8.2800
Drainage Area	214 mi <sup>2</sup>	Yield (cfs/mi <sup>2</sup> )	0.06
Q <sub>7-10</sub> Flow (cfs)	12.84	Q <sub>7-10</sub> Basis	Please see below
Elevation (ft)	25.44	Slope (ft/ft)	
Watershed No.	2-F	Chapter 93 Class.	WWF, MF
Existing Use	WWF, MF	Existing Use Qualifier	Ch. 93
Exceptions to Use	WWF, MF	Exceptions to Criteria	Add Tur
Assessment Status	Impaired		
Cause(s) of Impairment	NUTRIENTS, ORGANIC ENRICHMENT, PATHOGENS, SILTATION		
Source(s) of Impairment	MUNICIPAL POINT SOURCE DISCHARGES, MUNICIPAL POINT SOURCE DISCHARGES, SOURCE UNKNOWN, SOURCE UNKNOWN		
TMDL Status	Final, 04/09/2003	Name	Neshaminy Creek
Background/Ambient Data			
pH (SU)	8.1	Data Source	WQN0121, median Jul-Sep, 1999-2019
Temperature (°F)	24		WQN0121, median Jul-Sep, 1999-2018
Hardness (mg/L)	140.5		WQN0121, median Jul-Sep, 1999-2019
Other:			
Nearest Downstream Public Water Supply Intake			
PWS Waters	Delaware River	Philadelphia Water Department	
PWS RMI	35.36	Flow at Intake (cfs)	
		Distance from Outfall (mi)	14.68
Discharge, Receiving Waters and Water Supply Information			
Outfall No.	003	Design Flow (MGD)	0.216
Latitude	40° 8' 53"	Longitude	-74° 57' 22"
Quad Name	Langhorne	Quad Code	1746
Wastewater Description:	Wastewater discharge from leaf screen at Neshaminy Creek Intake (Chlorinated drinking water)		

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	004	Design Flow (MGD)	0
Latitude	40° 9' 2"	Longitude	-74° 57' 21"
Quad Name	Langhorne	Quad Code	1746
Wastewater Description:	Stormwater/leachate from Residual Waste storage (Monofill Land)		

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	005	Design Flow (MGD)	0
Latitude	40° 9' 6"	Longitude	-74° 57' 20"
Quad Name	Langhorne	Quad Code	1746
Wastewater Description:	Stormwater/leachate from Residual Waste storage (Monofill Land)		

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	.364
Latitude	40° 8' 47"	Longitude	-74° 56' 57"
Quad Name	Langhorne	Quad Code	1746
Wastewater Description:	Treated filter backwash from lagoons and belt presses		
Receiving Waters	Neshaminy Creek (WWF, MF)	Stream Code	02484
NHD Com ID	25480850	RMI	8.2900
Drainage Area	214 mi <sup>2</sup>	Yield (cfs/mi <sup>2</sup> )	0.06
Q <sub>7-10</sub> Flow (cfs)	12.84	Q <sub>7-10</sub> Basis	Please see below
Elevation (ft)	23.79	Slope (ft/ft)	
Watershed No.	2-F	Chapter 93 Class.	WWF, MF
Existing Use	WWF, MF	Existing Use Qualifier	Ch. 93
Exceptions to Use	WWF, MF	Exceptions to Criteria	Add Tur <sub>1</sub>
Assessment Status	Impaired		
Cause(s) of Impairment	NUTRIENTS, ORGANIC ENRICHMENT, PATHOGENS, SILTATION MUNICIPAL POINT SOURCE DISCHARGES, MUNICIPAL POINT SOURCE		
Source(s) of Impairment	DISCHARGES, SOURCE UNKNOWN, SOURCE UNKNOWN		
TMDL Status	Final	Name	Neshaminy Creek
Background/Ambient Data		Data Source	
pH (SU)	8.1		WQN0121, median Jul-Sep, 1999-2019
Temperature (°C)	24		WQN0121, median Jul-Sep, 1999-2018
Hardness (mg/L)	140.5		WQN0121, median Jul-Sep, 1999-2019
Nearest Downstream Public Water Supply Intake		Philadelphia Water Department	
PWS Waters	Delaware River	Flow at Intake (cfs)	
PWS RMI	35.36	Distance from Outfall (mi)	14.27

Changes Since Last Permit Issuance: Outfall 005 is proposed as a new outfall that'll receive

**Drainage Area:**

The discharge from Outfalls 001 and 002 are into Neshaminy Creek at RMI 8.29 and 8.7, respectively. The drainage area upstream of the points of discharge is 214 mi<sup>2</sup> according to USGS PA StreamStats, accessible at <https://streamstats.usgs.gov/ss/>

**Stream Flow:**

The nearest USGS Streamgage is 01465500 on Neshaminy Creek near Langhorne, PA which is approximately 2.77 miles upstream of Outfall 001 at RMI 11.06. Recent stream flow retrievals resulted in a Q<sub>7-10</sub>, Q<sub>1-10</sub>, and Q<sub>30-10</sub> of 12.7 cfs, 9.0 cfs, and 17.3 cfs, respectively, at this gage for record period of 1936-2008. These values were obtained from the latest USGS streamflow report <sup>(1)</sup>.

(1) Stuckey, M.H., Roland, M.A., 2011, Selected streamflow statistics for streamgage locations in and near Pennsylvania: U.S. Geological Survey Scientific Investigations Report 2011-1070, 9p, 22p.

The drainage area is reported to be 210 mi<sup>2</sup> at the gage station. The drainage area at Outfall 001 is found to be 214 mi<sup>2</sup> from USGS StreamStats Version 3.0, accessed on January 23, 2020. The flow calculations are shown below:

$$Q_{7-10} \text{ runoff rate (yield)} = 12.7/210 = 0.06 \text{ cfs/mi}^2.$$

$$Q_{30-10}: Q_{7-10} = 17.3/12.7 = 1.362:1$$

$$Q_{1-10}: Q_{7-10} = 9.0/12.7 = 0.709:1$$

$$Q_{7-10} = 0.06 * 214 = 12.84 \text{ cfs}$$

**PWS Intake:**

The nearest downstream public water supply is Philadelphia Water Department on Delaware River at RMI 35.36. It is approximately 14.27 miles downstream of Outfall 001. Due to the distance, dilution, and effluent limits the discharge is not expected to impact the water supply. The distance is calculated as below:

+ Discharge Point RMI at Neshaminy Creek (02484) -----	8.29 mile
+ RMI at Delaware River (00002) at confluence with Neshaminy Creek -----	41.34 mile
- RMI at PWS intake -----	35.36 mile
Total = 14.27 mile	

**Wastewater Characteristics:**

A median pH of 7.37 S.U. during December 1 2023 through November 30, 2024 from daily eEDMR, a default discharge temperature of 20°C, and total hardness of 166 mg/l from application will be used for modeling, if needed.

**Background/Ambient Stream Data:**

The Water Quality Network station WQN0121 is located approximately 2.77 miles upstream of Outfall 001. Historical data were analyzed for Stream Temperature, pH, and Total Hardness for July through September for the years 1999-2018/2019. The analysis indicated a median temperature, pH, and total hardness of 24 °C, 8.1 S.U. and 140.5 mg/l, respectively.

**303d Listed Streams:**

The discharge from this facility is in Neshaminy Creek at 8.29 RMI in state watershed 2-F which is aquatic life impaired for Organic Enrichment/Low D.O., Siltation, Nutrients from Municipal Point Source. It is also Recreational Use impaired due to Pathogens from unknown source while attaining its fish consumption use. The permit limits, terms, and conditions were developed in such a way that the discharge from this facility is expected not to contribute to the existing impairment of the receiving stream or the watershed.

**Neshaminy Creek Watershed Total Maximum Daily Load (TMDL):**

A TMDL for Neshaminy Creek Watershed was finalized on April 9, 2003 which was revised on December 2003. The Neshaminy Creek is located in state watershed 2-F, in Bucks and Montgomery Counties. It has approximately 418.3 miles of streams. Since 1996, 203.3 miles of these streams have been included on Pennsylvania's 303(d) list of streams having aquatic life use impairments. The watershed as a whole is very much a point source-dominated system. On an annual basis, the municipal wastewater treatment plants in the watershed contribute about 25% of the total phosphorus load. During critical low-flow periods, effluent discharges comprise over 90% of the total stream flow in many reaches. Upland erosion from developing areas and agriculture, and streambank erosion are other major sources of phosphorus, as well as sediment. However, in September 6, 2007, the nutrients portion of the TMDL was withdrawn by PADEP and approved by USEPA on January 31, 2008. No sediment WLA was assigned for this facility other than urban BMPs.

**Antidegradation (93.4):**

The effluent limits for this discharge have been developed to ensure that existing in-stream water uses and the level of water quality necessary to protect the existing uses are maintained and protected. No High-Quality Waters are impacted by this discharge. No Exceptional Value Waters are impacted by this discharge.

**Class A Wild Trout Fisheries:**

No Class A Wild Trout Fisheries are impacted by this discharge.

Treatment Facility Summary				
<b>Treatment Facility Name:</b> Neshaminy Falls Water Treatment Plant				
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Industrial			No Disinfection	
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
		Not Overloaded		

Changes Since Last Permit Issuance: Outfall 005 is added.

**Other Comments:**

Aqua owns and operates a Water Treatment Plant named Neshaminy Falls Water Treatment Plant (Plant) located in Middletown Township, Bucks County which discharges under the NPDES permit number PA0011274. Aqua requests renewal of the NPDES permit for a discharge of 0.519 MGD of treated filter backwash water from lagoons and belt presses, through Outfall 001. The plant also discharges through Outfall 002 (maintenance and emergency only), 003 (chlorinated wastewater discharge from leaf screen at Neshaminy Creek intake), and 004 (Stormwater/leachate from residual waste storage/Monofill land.) According to the permit renewal application, filter backwash water from the water treatment plant is clarified in two onsite lagoons and then discharged through Outfall 001. Sludge from the plate settler unit in the flocculators is thickened and then dewatered using two belt filter presses. Filtrate from the belt filter presses can also be discharged through Outfall 001. Average flow during production/operation is 0.187 MGD and maximum flow during production/operation 0.298 MGD.

The permittee is currently constructing an additional residual waste fill area, designated as Cell 3, on the monofill property. Two stormwater management basins will be constructed downgradient of the Cell 3 site. These stormwater basins will have a drainage outfall to the Neshaminy Creek, which will be designated as Outfall 005. Outfall 005 is designed similar to existing Outfall 004 in that discharge from the stormwater basins is unlikely to occur. The bottom of Cell 3 has an elevation of 75 feet, and the top of the embankment downgradient of Cell 3 has an elevation of 96 feet. Cell 3 is designed to be filled to an elevation of 172 feet over a 220-year lifespan. This equates to a fill rate of approximately 0.44 feet per year. At this rate, it would take over 47 years for the fill level to reach the embankment elevation of 96 feet. Therefore, no discharge is expected from Outfall 005 in the foreseeable future. No discharge has been recorded at Outfall 004, which has a similar design, in over 10 years. Construction of Cell 3 and the stormwater basins will be completed by end of this year. The earliest Aqua would start dumping residuals into Cell 3 would be Q1 of 2025. A Solid Waste Management permit/major amendment was issued on July 15, 2024 to authorize the new Cell 3 construction/operation.

Water is drawn from Neshaminy Creek into the plant's intake chamber through two 24-inch influent lines. The influent flows through the debris screens and into Raw Well. The debris screen/traveling screens are periodically backwashed and the backwash water flows to the existing retention basin. Effluent from traveling screen chamber is sent to raw well which has 3 pumps. Alum, chlorine, sulfuric acid, lime, and PAC are added at the discharge pipe from pumps that goes to the flocculation tank. The flocculation tanks are two stage flocculators. The effluent from the second stage flows to the up-flow clarifiers. The up-flow clarifiers have a plate settler at an angle to settle out the floc particles. There are a chain and flight auger screw sludge collectors that remove the sludge from the bottom. Sludge is wasted to the residuals pump pit for approximately 2 hours per day from each up-flow clarifier. Sludge is pumped to the 2 sludge thickeners from the sludge pump pit. Polymer is injected to the sludge before it enters the thickeners. Thickened sludge from clarifiers is sent to sludge equalization basins, which will also receive sludge from Bristol WTP in future, and pumped through sludge pumps to belt filter presses after polymer is added. Pressed sludges are lifted through screw conveyors and dumped into dump truck. Supernatant from the thickeners and belt filter presses are sent to recycle pump station from where it is pumped to head of the water plant or recycle to wastewater transfer pit and discharge through Outfall 001. Supernatant from plate settlers is sent to gravity filters after polymer, PAC, lime, chlorine, sulfur dioxide, and ammonia addition. Filtrates from gravity filter goes to clear well. Filter backwash water is sent to wash water transfer pit. Wastewater from transfer pit is pumped to the lagoons through two pumps, from where it is discharged through Outfall 001 and 002 (emergency/maintenance only.)

Per the PADEP's inspection report dated September 28, 2016, the facility consists of the following treatment units:

1. Up-flow clarifiers
2. Eight filters
3. Two sludge thickeners
4. Two belt filter presses
5. Two wastewater lagoons
6. Two influent screens
7. One screen lagoon

**Chemicals Used:** Per application data, Sulfur Dioxide (dechlorination) at 1360 lbs./month, Praestol DW 340 (flocculation) at 30 lbs./month, and Praestol A 3040 LTR (flocculation) at 2000 lbs./month rate.

There are no proposed upgrades to this facility within the next five years.

Compliance History	
<b>Summary of Inspections:</b>	<p><b>09/08/2022:</b> CEI conducted. No violation observed during the inspection. The effluent appeared clear.</p> <p><b>10/09/2020:</b> CEI conducted. Violation noted: Lagoon #2 was actively discharging to outfall 001 during the inspection. The sludge level was approximately 2-8 inches from the surface of the effluent and was above the surface in several locations. These conditions represent a failure to properly operate and maintain the wastewater treatment lagoon and are in violation of NPDES permit PA0011274.</p>

Compliance History

DMR Data for Outfall 001 (from November 1, 2023 to October 31, 2024)

Parameter	OCT-24	SEP-24	AUG-24	JUL-24	JUN-24	MAY-24	APR-24	MAR-24	FEB-24	JAN-24	DEC-23	NOV-23
Flow (MGD) Average Monthly	0.184	0.187	0.182	0.178	0.181	0.185	0.18	0.176	0.179	0.175	0.185	0.182
Flow (MGD) Daily Maximum	0.229	0.293	0.229	0.227	0.229	0.244	0.298	0.235	0.286	0.214	0.274	0.225
pH (S.U.) IMIN	7.2	7.28	7.22	7.25	7.14	7.12	7.01	7.02	7.07	7.02	6.88	7.08
pH (S.U.) IMAX	7.49	7.53	7.44	7.47	7.48	7.35	7.33	7.4	7.49	7.27	7.18	7.44
TRC (mg/L) Average Monthly	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01
TRC (mg/L) IMAX	0.02	0.01	0.04	0.04	0.10	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01
TSS (lbs/day) Average Monthly	6	5	4	3	< 3	5	5	< 4	5	7	6	10
TSS (lbs/day) Daily Maximum	9	8	6	9	7	8	11	12	6	17	13	26
TSS (mg/L) Average Monthly	3.8	3.4	3	2.2	< 2.3	3.2	2.6	< 3.4	3.3	4.7	4	7
TSS (mg/L) Daily Maximum	6.5	6	4	5.2	4.8	5.6	4.5	10	4.7	10	7.2	20
Total Dissolved Solids (mg/L) Daily Maximum			297			288			312			298
Total Phosphorus (lbs/day) Average Monthly	< 0.07	< 0.08	< 0.09	0.07	< 0.09	< 0.1	< 0.09	< 0.07	< 0.09	< 0.07	< 0.09	< 0.08
Total Phosphorus (lbs/day) Daily Maximum	< 0.09	0.09	0.1	0.09	0.1	0.2	< 0.1	0.09	0.1	< 0.09	0.1	0.1
Total Phosphorus (mg/L) Average Monthly	< 0.05	< 0.06	< 0.06	0.05	< 0.06	< 0.06	< 0.05	< 0.05	< 0.05	< 0.05	< 0.06	< 0.05
Total Phosphorus (mg/L) Daily Maximum	0.05	0.07	0.08	0.05	0.08	0.09	< 0.05	0.05	0.08	< 0.05	0.07	0.06
Total Aluminum (lbs/day) Average Monthly	0.5	0.6	0.8	0.4	0.5	0.5	0.4	0.4	0.5	0.5	0.7	0.5
Total Aluminum (lbs/day) Daily Maximum	0.8	0.9	1.0	0.7	0.8	0.6	0.5	0.4	0.8	1.0	1.0	0.9

NPDES Permit Fact Sheet  
Neshaminy Falls Water Treatment Plant

NPDES Permit No. PA0011274

Total Aluminum (mg/L) Average Monthly	0.35	0.44	0.53	0.31	0.33	0.33	0.22	0.25	0.34	0.36	0.43	0.32
Total Aluminum (mg/L) Daily Maximum	0.54	0.63	0.72	0.39	0.42	0.39	0.26	0.27	0.44	0.58	0.76	0.47
Total Iron (lbs/day) Average Monthly	< 0.1	< 0.1	< 0.2	< 0.1	< 0.1	< 0.2	< 0.2	< 0.1	< 0.2	< 0.1	< 0.2	< 0.2
Total Iron (lbs/day) Daily Maximum	< 0.2	< 0.2	< 0.2	< 0.2	< 0.2	< 0.2	< 0.2	< 0.2	< 0.2	< 0.2	< 0.2	< 0.2
Total Iron (mg/L) Average Monthly	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1
Total Iron (mg/L) Daily Maximum	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1
Total Manganese (lbs/day) Average Monthly	0.1	0.1	0.1	0.2	0.1	0.2	0.08	0.06	0.1	0.1	0.09	0.07
Total Manganese (lbs/day) Daily Maximum	0.2	0.2	0.1	0.6	0.2	0.5	0.1	0.07	0.2	0.1	0.09	0.1
Total Manganese (mg/L) Average Monthly	0.09	0.07	0.07	0.13	0.09	0.14	0.05	0.04	0.09	0.07	0.06	0.04
Total Manganese (mg/L) Daily Maximum	0.14	0.1	0.1	0.34	0.15	0.24	0.06	0.04	0.19	0.1	0.07	0.06

DMR Data for Outfall 003 (from November 1, 2023 to October 31, 2024)

Parameter	OCT-24	SEP-24	AUG-24	JUL-24	JUN-24	MAY-24	APR-24	MAR-24	FEB-24	JAN-24	DEC-23	NOV-23
TRC (mg/L) Average Monthly	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01	< 0.1	< 0.01	< 0.01	< 0.03	< 0.01	< 0.04
TRC (mg/L) IMAX	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01	0.25	< 0.01	< 0.01	0.1	< 0.01	0.15

**Existing Effluent Limitations and Monitoring Requirements**

**For Outfall 001:**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Minimum	Average Monthly	Daily Maximum	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	1/week	Metered
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
Total Residual Chlorine (TRC)	XXX	XXX	XXX	0.11	XXX	0.34	1/day	Grab
Total Suspended Solids	58	117	XXX	30	60	75	1/week	8-Hr Composite
Total Dissolved Solids	XXX	XXX	XXX	Report Daily Max	XXX	XXX	1/quarter	8-Hr Composite
Total Phosphorus	1.9	3.9	XXX	1.0	2.0	2.5	1/week	8-Hr Composite
Aluminum, Total	1.6	3.2	XXX	0.82	1.64	2.05	1/week	8-Hr Composite
Iron, Total	Report	Report	XXX	2.0	4.0	5	1/week	8-Hr Composite
Manganese, Total	1.9	3.9	XXX	1.0	2.0	2.5	1/week	8-Hr Composite

**For Outfall 002:**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Minimum	Average Monthly	Daily Maximum	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Daily when Discharging	Metered
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	Daily when Discharging	Grab
Total Residual Chlorine (TRC)	XXX	XXX	XXX	0.11	XXX	0.34	Daily when Discharging	Grab
Total Suspended Solids	58	117	XXX	30	60	75	Daily when Discharging	8-Hr Composite
Total Phosphorus	1.9	3.9	XXX	1.0	2.0	2.5	Daily when Discharging	8-Hr Composite

NPDES Permit Fact Sheet  
Neshaminy Falls Water Treatment Plant

NPDES Permit No. PA0011274

Parameter	Effluent Limitations						Monitoring Requirements Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type		
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)							
	Average Monthly	Daily Maximum	Minimum	Average Monthly	Daily Maximum	Instant. Maximum				
Aluminum, Total	1.6	3.2	XXX	0.82	1.64	2.05	Daily when Discharging	8-Hr Composite		
Iron, Total	Report	Report	XXX	2.0	4.0	5	Daily when Discharging	8-Hr Composite		
Manganese, Total	1.9	3.9	XXX	1.0	2.0	2.5	Daily when Discharging	8-Hr Composite		

For Outfall 003:

Parameter	Effluent Limitations						Monitoring Requirements Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type		
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)							
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum				
Total Residual Chlorine (TRC)	XXX	XXX	XXX	0.5	XXX	1.0	1/week	Grab		

For Outfall 004:

Parameter	Effluent Limitations						Monitoring Requirements Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type		
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)							
	Average Monthly	Average Weekly	Minimum	Average Monthly	Daily Maximum	Instant. Maximum				
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Monthly When Discharging	Metered		
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	Monthly When Discharging	Grab		
Total Residual Chlorine (TRC)	XXX	XXX	XXX	0.5	XXX	1.2	Monthly When Discharging	Grab		
Total Suspended Solids	XXX	XXX	XXX	30	60	75	Monthly When Discharging	8-Hr Composite		
Total Phosphorus	XXX	XXX	XXX	Report	Report	XXX	Monthly When Discharging	8-Hr Composite		
Aluminum, Total	XXX	XXX	XXX	4.0	8.0	10	Monthly When Discharging	8-Hr Composite		
Iron, Total	XXX	XXX	XXX	2.0	4.0	5	Monthly When Discharging	8-Hr Composite		
Manganese, Total	XXX	XXX	XXX	1.0	2.0	2.5	Monthly When Discharging	8-Hr Composite		

**Development of Effluent Limitations**

Outfall No. 001  
Latitude 40° 8' 47"

Design Flow (MGD) 0.519  
Longitude -74° 56' 57"

Wastewater Description: Filter backwash water from lagoons and belt presses

**Technology-Based Limitations**

The industrial wastewaters discharged through Outfall 001 is generated from Filter backwash and belt filter press filtrate. DEP's technical guidance no. 362-2183-003 addresses technology-based control requirements along with the following recommended Best Practicable Control Technology Currently Available (BPT) effluent requirements for WTP sludge and filter backwash:

Parameter	Limit (mg/l)	SBC
Suspended Solids	30	Average Monthly
	60	Daily Maximum
Iron, Total	2.0	Average Monthly
	4.0	Daily Maximum
Aluminum, Total	4.0	Average Monthly
	8.0	Daily Maximum
Manganese, Total	1.0	Average Monthly
	2.0	Daily Maximum
Flow	Monitor	Average Monthly
pH	6.0	Minimum
	9.0	Maximum
Total Residual Chlorine	0.5	Average Monthly
	1.0	Daily Maximum

**Water Quality-Based Limitations**

DEP's SOP no. BCW-PMT-037 recommends the average monthly flow during production or operation as a design flow in water quality modeling unless a different flow is determined to be more representative of site-specific conditions. The volume of effluent discharged from facilities such as water treatment plants is heavily depended upon the quality of source water as more backwashing is needed to maintain acceptable filter performance if the intake water quality is poor. Past five-year effluent flow data were analyzed. The average of the data was 0.1815 MGD with the 90<sup>th</sup> percentile of 0.191 MGD and daily maximum of 0.376 MGD. The long-term average flow value of 0.1815 MGD will be used in the water quality modeling.

**WQM 7.0**

Since the facility injects ammonia prior to filtration, the WQM 7.0 was utilized. The following data were used in the attached computer model of the stream:

• Discharge pH	7.37	(90 <sup>th</sup> percentile, Dec 1 2023-Nov 30, 2024)
• Discharge Temperature	20°C	(Default data)
• Discharge Hardness	166 mg/l	(Application data)
• Stream pH	8.1	(WQN0121, median Jul-Sep, 1999-2019)
• Stream Temperature	24°C	(WQN0121, median Jul-Sep, 1999-2018)
• Stream Hardness	140.5 mg/l	(WQN0121, median Jul-Sep, 1999-2019)

The following three nodes were used in modeling:

Node 1: Outfall 001 at Neshaminy Creek (02484)  
 Elevation: 25.44 ft (USGS TNM viewer, 02/25/2020)  
 Drainage Area: 214 mi<sup>2</sup> (StreamStat Version 3.0, 01/23/2020)  
 River Mile Index: 8.28 mile (PA DEP eMapPA)  
 Low Flow Yield: 0.06 cfs/mi<sup>2</sup>  
 Discharge Flow: 0.1815 MGD

Node 2:	At the confluence with UNT 02508
Elevation:	20.6 ft (USGS TNM 2.0 viewer, 02/25/2020)
Drainage Area:	217 mi <sup>2</sup> (StreamStat Version 3.0, 01/23/2020)
River Mile Index:	7.175 (PA DEP eMapPA)
Low Flow Yield:	0.06 cfs/mi <sup>2</sup>
Discharge Flow:	0.00 MGD

#### NH<sub>3</sub>-N

The WQM 7.0 suggested NH<sub>3</sub>-N limit of 25 mg/l as average monthly and 50 mg/l as instantaneous maximum limit during summer to protect water quality standards. The existing permit doesn't have NH<sub>3</sub>-N limits. The application data indicated an average discharge concentration of 0.07 mg/l which is much lower compared to model suggested value. Therefore, it is determined that NH<sub>3</sub>-N is not a pollutant of concern and no limits/monitoring requirements will be placed in this permit term. This determination will be re-evaluated during the next permit term.

#### CBOD<sub>5</sub>:

The WQM 7.0 model suggests a monthly average CBOD<sub>5</sub> limit of 25 mg/l. The existing permit doesn't have CBOD<sub>5</sub> limits. The application data indicated an average BOD<sub>5</sub> discharge concentration of <2.17 mg/l which is much lower than the suggested value by the model. Therefore, it is determined that CBOD<sub>5</sub> is not a pollutant of concern and no limits/monitoring requirements will be applied in this renewal. This determination will be re-evaluated during the next permit term.

#### Total Residual Chlorine

Chlorine is used for source water disinfection, injected at the headworks, after flocculation, and after filtration. Since chlorine is introduced prior to flocculation/sedimentation and filtration, residual chlorine is expected to be present in the effluent discharged via Outfall 001. Accordingly, Total Residual Chlorine (TRC) effluent concentrations must be monitored and regulated per 25 Pa Code §92a.48(b). DEP's TRC\_CALC worksheet was utilized to determine if existing TBELs are still appropriate at discharge flow of 0.1815 MGD. The spreadsheet indicated an average monthly and IMAX limit of 0.5 mg/l and 1.6 mg/l. The BPT IMAX limit is 1.0 mg/l which is more stringent compared to WQBEL. The existing permit has an average monthly and IMAX limit of 0.11 mg/l and 0.34 mg/l, respectively. Since none of the exceptions are applicable, backsliding is not allowed, and the existing limits will be carried over in this renewal.

#### Toxics

#### **General Discussion on Toxics Management Spreadsheet (TMS)**

Based on the available data, PADEP utilizes Toxics Management Spreadsheet (TMS) to (1) evaluate reasonable potential for toxic pollutants to cause or contribute to an excursion above the water quality standards and (2) develop WQBELs for those such toxic pollutants (i.e., 40 CFR § 122.44(d)(1)(i)). It is noteworthy that some of these pollutants that may be reported as "non-detect", but still exceeded the criteria, were determined to be candidates for modeling because the method detection levels used to analyze those pollutants were higher than target QLs and/or the most stringent Chapter 93 criteria. The model then recommended the appropriate action for the Pollutants of Concerns based on the following logic as stated in PADEP's SOP titled *"Establishing Water Quality-Based Effluent Limitations (WQBELs) and Permit Conditions for Toxic Pollutants in NPDES Permits for Existing Dischargers (DEP SOP No.: BCW-PMT-037, Revised May 20, 2021)"*:

1. In general, establish limits in the draft permit where the effluent concentration determined in B.1 or B.2 equals or exceeds 50% of the WQBEL (i.e., RP is demonstrated). Use the average monthly, maximum daily and instantaneous maximum (IMAX) limits for the permit as recommended by the TMS (or, if appropriate, use a multiplier of 2 times the average monthly limit for the maximum daily limit and 2.5 times the average monthly limit for IMAX).
2. For non-conservative pollutants, in general, establish monitoring requirements where the effluent concentration determined in B.1 or B.2 is between 25% - 50% of the WQBEL.
3. For conservative pollutants, in general, establish monitoring requirements where the effluent concentration determined in B.1 or B.2 is between 10% - 50% of the WQBEL.

**NOTE 4** – If the effluent concentration determined in B.1 or B.2 is "non-detect" at or below the target quantitation limit (TQL) for the pollutant as specified in the TMS and permit application, the pollutant may be eliminated as a candidate for WQBELs or monitoring requirements unless 1) a more sensitive analytical method is available for the pollutant under 40 CFR Part 136 where the quantitation limit for the method is less than the applicable water quality criterion and 2) a detection at the more sensitive method may lead to a determination that an effluent limitation is necessary, considering available dilution at design conditions.

**NOTE 5** – If the effluent concentration determined in B.1 or B.2 is a detection below the TQL but above or equal to the applicable water quality criterion, WQBELs or monitoring may be established for the pollutant.

4. Application managers may, on a site- and pollutant-specific basis, deviate from these guidelines where there is specific rationale that is documented in the fact sheet.

Maximum sample results of a given pollutant is the input of the model if the sample size is less than 10. For pollutants with sample size  $\geq 10$ , PADEP utilizes TOXCONC to calculate Average Monthly Effluent Concentration (AMEC) and Coefficient of Variation (CoV) to refine the model input. The statistical methodologies used in this spreadsheet are taken from EPA's *TSD for Water Quality-based Toxics Control, Appendix E* and are consistent with PADEP's technical guidance 391-2000-024. The pollutants are modeled through TMS and output from the TMS is provided below:

**Recommended WQBELs & Monitoring Requirements**

No. Samples/Month: 4

Pollutants	Mass Limits		Concentration Limits				Governing WQBEL	WQBEL Basis	Comments
	AML (lbs/day)	MDL (lbs/day)	AML	MDL	IMAX	Units			

The current permit has limits for Total Aluminum, Total Iron, and Total Manganese. The Total Aluminum was WQBEL and Total Iron and Manganese were BPT limits. Since there's no RP demonstrated for Total Aluminum, BPT limits will be applied. Mass limits are adjusted accordingly.

### Additional Considerations

#### Flow Monitoring

Flow monitoring will remain in the permit and is required by 40 CFR § 122.44(i)(1)(ii).

#### Total Dissolved Solids (TDS) and its constituents:

PADEP has determined that they have sufficient data over the past 7 years of implementing the special monitoring logic for Sulfate, Chloride, and Bromide and a monitoring is no longer needed. Existing TDS quarterly monitoring will be removed.

#### Total Phosphorus:

The maximum reported Total Phosphorus concentration was 0.09 mg/l and mass was 0.2 lbs./day. The long term monthly average concentration is <0.05 mg/l. Therefore, the existing limits of 1.0 mg/l as average monthly, 2.0 mg/l as daily maximum, and 2.5 mg/l as IMAX will be carried over in this renewal.

#### Total Nitrogen:

The maximum reported Total Nitrogen (calculated as sum of TKN and Nitrate-Nitrite-Nitrogen) was <3.28 lbs./day which is less than the threshold value as specified in BCW-PMT-032. Therefore, no TN limit or monitoring requirement will be added in this permit term.

#### PFOA, PFOS, HFPO-DA and PFBS:

The sample results for these pollutants show that three out of four were detected. When sample results show detected values, per SOP BCW-PMT-001 (revised February 5, 2024), a PFAS Reduction condition will be added in the Part C of the permit. A quarterly monitoring will be added in the Part A of the permit with the following footnote:

*“The permittee may discontinue monitoring for PFOA, PFOS, HFPO-DA, and PFBS if the results in 4 consecutive monitoring periods indicate non-detect results at or below Quantitation Limits of 4.0 ng/L for PFOA, 3.7 ng/L for PFOS, 3.5 ng/L for PFBS and 6.4 ng/L for HFPO-DA. When monitoring is discontinued, permittees must enter a No Discharge Indicator (NODI) Code of “GG” on DMRs.”*

#### Anti-Degradation requirements

The effluent limits for this discharge have been developed to ensure the existing in-stream uses and the level of water quality necessary to protect the existing uses are maintained and protected. No High-Quality stream is impacted by this discharge. No Exceptional-Value stream is impacted by this discharge.

Anti-Backsliding Requirements

Unless stated otherwise in this fact sheet, all proposed effluent limits have developed for this permit renewal are at least as stringent as effluent limits developed for the previous permit renewal. Therefore, anti-backsliding provision is not applicable.

**Development of Effluent Limitations**

<b>Outfall No.</b>	002	<b>Design Flow (MGD)</b>	0.0
<b>Latitude</b>	40° 8' 45"	<b>Longitude</b>	-74° 57' 9"
<b>Wastewater Description:</b>	Treated filter backwash water from lagoons and belt presses (maintenance and emergency only)		

**Other comments:** The average flow through Outfall 002 is 0.425 MGD which combines the flow from belt filter press (0.155 MGD) and filter backwash water (0.27 MGD). It is recommended that the proposed limitations for Outfall 001 will be applied to Outfall 002 in this renewal, since the characteristics of the waste stream is the same as for Outfall 001.

**Development of Effluent Limitations**

<b>Outfall No.</b>	003	<b>Design Flow (MGD)</b>	0.0
<b>Latitude</b>	40° 8' 53"	<b>Longitude</b>	-74° 57' 22"
<b>Wastewater Description:</b>	Wastewater discharge from leaf screen at Neshaminy Creek intake (chlorinated drinking water)		

**Other comments:** The backwash water from the leaf screen at Neshaminy Creek intake is first discharged to the existing retention basin from where it overflows to the creek. Treated, chlorinated, potable water is used for backwash. Therefore, the existing BPT limitations for TRC are applicable. The existing limitations are BPT limits which will be carried over in this renewal. Part C Special Condition E related to TRC limits at this outfall will remain in the permit.

**Development of Effluent Limitations**

<b>Outfall No.</b>	004	<b>Design Flow (MGD)</b>	0.0
<b>Latitude</b>	40° 9' 2"	<b>Longitude</b>	-74° 57' 21"
<b>Wastewater Description:</b>	Stormwater/leachate from Residual Waste Storage (Monofill land)		

**Other comments:** This outfall receives stormwater and leachate from residual waste storage/Monofill land. The monofill is still active, however, there is no flow reported from this outfall since December 2014. Since the discharge through this outfall has a potential of causing pollution to the receiving stream, the existing limitations will be carried over when such discharge occurs.

**Development of Effluent Limitations**

<b>Outfall No.</b>	005	<b>Design Flow (MGD)</b>	0.0
<b>Latitude</b>	40° 9' 6"	<b>Longitude</b>	-74° 57' 20"
<b>Wastewater Description:</b>	Stormwater/leachate from Residual Waste Storage (Monofill land)		

**Other comments:** This outfall will receive stormwater and leachate from the proposed Cell 3 residual waste storage/Monofill land. Since the characteristics of this discharge will be the same as for Outfall 004, the limits/monitoring requirements of Outfall 004 will be applied to Outfall 005.

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Minimum	Average Monthly	Daily Maximum	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	1/week	Metered
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
TRC	XXX	XXX	XXX	0.11	XXX	0.34	1/day	Grab
TSS	58	117	XXX	30	60	75	1/week	8-Hr Composite
Total Phosphorus	1.9	3.9	XXX	1.0	2.0	2.5	1/week	8-Hr Composite
Total Aluminum	6.05	12.11	XXX	4.0	8.0	XXX	1/week	8-Hr Composite
Total Iron	Report	Report	XXX	2.0	4.0	5	1/week	8-Hr Composite
Total Manganese	1.9	3.9	XXX	1.0	2.0	2.5	1/week	8-Hr Composite
PFOA (ug/L)	XXX	XXX	XXX	XXX	XXX	Report	1/quarter	Grab
PFOS (ug/L)	XXX	XXX	XXX	XXX	XXX	Report	1/quarter	Grab
PFBS (ug/L)	XXX	XXX	XXX	XXX	XXX	Report	1/quarter	Grab
HFPO-DA (ug/L)	XXX	XXX	XXX	XXX	XXX	Report	1/quarter	Grab

Compliance Sampling Location: At Outfall 001

Other Comments: None

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

**Outfall 002, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Minimum	Average Monthly	Daily Maximum	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Daily when Discharging	Metered
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	Daily when Discharging	Grab
TRC	XXX	XXX	XXX	0.11	XXX	0.34	Daily when Discharging	Grab
TSS	58	117	XXX	30	60	75	Daily when Discharging	8-Hr Composite
Total Phosphorus	1.9	3.9	XXX	1.0	2.0	2.5	Daily when Discharging	8-Hr Composite
Total Aluminum	6.05	12.11	XXX	4.0	8.0	XXX	1/week	8-Hr Composite
Total Iron	Report	Report	XXX	2.0	4.0	5	1/week	8-Hr Composite
Total Manganese	1.9	3.9	XXX	1.0	2.0	2.5	1/week	8-Hr Composite
PFOA (ug/L)	XXX	XXX	XXX	XXX	XXX	Report	1/quarter	Grab
PFOS (ug/L)	XXX	XXX	XXX	XXX	XXX	Report	1/quarter	Grab
PFBS (ug/L)	XXX	XXX	XXX	XXX	XXX	Report	1/quarter	Grab
HFPO-DA (ug/L)	XXX	XXX	XXX	XXX	XXX	Report	1/quarter	Grab

Compliance Sampling Location: At Outfall 002

Other Comments: None

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

**Outfall 003, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
TRC	XXX	XXX	XXX	0.5	XXX	1.0	1/week	Grab

Compliance Sampling Location: At Outfall 003

Other Comments: None

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

**Outfall 004, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Daily Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Monthly When Discharging	Metered
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	Monthly When Discharging	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.2	Monthly When Discharging	Grab
TSS	XXX	XXX	XXX	30	60	75	Monthly When Discharging	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	Report	Report	XXX	Monthly When Discharging	8-Hr Composite
Total Aluminum	XXX	XXX	XXX	4.0	8.0	10	Monthly When Discharging	8-Hr Composite
Total Iron	XXX	XXX	XXX	2.0	4.0	5	Monthly When Discharging	8-Hr Composite
Total Manganese	XXX	XXX	XXX	1.0	2.0	2.5	Monthly When Discharging	8-Hr Composite

Compliance Sampling Location: At Outfall 004

Other Comments: None

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

**Outfall 005, Effective Period: Permit Effective Date through Permit Expiration Date.**


Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Daily Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Monthly When Discharging	Metered
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	Monthly When Discharging	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.2	Monthly When Discharging	Grab
TSS	XXX	XXX	XXX	30	60	75	Monthly When Discharging	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	Report	Report	XXX	Monthly When Discharging	8-Hr Composite
Total Aluminum	XXX	XXX	XXX	4.0	8.0	10	Monthly When Discharging	8-Hr Composite
Total Iron	XXX	XXX	XXX	2.0	4.0	5	Monthly When Discharging	8-Hr Composite
Total Manganese	XXX	XXX	XXX	1.0	2.0	2.5	Monthly When Discharging	8-Hr Composite

Compliance Sampling Location: At Outfall 005

Other Comments: None

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment [REDACTED])
<input checked="" type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [REDACTED])
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 386-2000-002, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input checked="" type="checkbox"/>	SOP: BCW-PMT-001
<input type="checkbox"/>	Other: [REDACTED]

Locational Map and Flow Diagrams



Paper Size ANSI A  
0 0,000  
0 US Feet  
Map Projection: Lambert Conformal Conic  
Horizontal Datum: North American 1983  
Grid: NAD 1983 StatePlane Pennsylvania South FIPS 3702 Feet




AQUA PENNSYLVANIA, INC.  
MIDDLETOWN TOWNSHIP, BUCKS COUNTY, PA  
USGS QUAD: LANGHORNE

NESHAMINY WATER TREATMENT PLANT  
NPDES PERMIT NO. PA0011274

Project No. 11188762  
Revision No. -  
Date 11/19/2024

NPDES Permit Fact Sheet  
Neshaminy Falls Water Treatment Plant

NPDES Permit No. PA0011274



USGS PA StreamStats



Prepared in cooperation with the Pennsylvania Department of Environmental Protection

## Selected Streamflow Statistics for Streamgage Locations in and near Pennsylvania



Open-File Report 2011-1070

U.S. Department of the Interior  
U.S. Geological Survey

Table 1 3

Table 1. List of U.S. Geological Survey streamgage locations in and near Pennsylvania with updated streamflow statistics.—Continued  
[Latitude and Longitude in decimal degrees; mi<sup>2</sup>, square miles]

Streamgage number	Streamgage name	Latitude	Longitude	Drainage area (mi <sup>2</sup> )	Regulated?
01439500	Bush Kill at Shoemakers, Pa.	41.088	-75.038	117	N
01440000	Flat Brook near Flatbrookville, N.J.	41.106	-74.953	64.0	N
01440200	Delaware River near Delaware Water Gap, Pa.	41.013	-75.086	3,850	Y
01440400	Brodhead Creek near Analomink, Pa.	41.085	-75.215	65.9	N
01441000	McMichael Creek near Stroudsburg, Pa.	40.979	-75.201	65.3	N
01442500	Brodhead Creek at Minisink Hills, Pa.	40.999	-75.143	259	N
01443280	East Branch Paulins Kill near Lafayette, N.J.	41.076	-74.695	13.0	N
01443500	Paulins Kill at Blairstown, N.J.	40.981	-74.953	126	N
01443900	Yards Creek near Blairstown, N.J.	40.981	-75.039	5.34	N
01445000	Pequest River at Hantsville, N.J.	40.981	-74.776	31.0	N
01445500	Pequest River at Pequest, N.J.	40.831	-74.978	106	N
01446000	Beaver Brook near Belvidere, N.J.	40.843	-75.046	36.7	N
01446500	Delaware River at Belvidere, N.J.	40.826	-75.083	4,535	Y
01446600	Martins Creek near East Bangor, Pa.	40.900	-75.202	10.4	N
01447500	Lehigh River at Steedartsville, Pa.	41.130	-75.625	91.7	N
01447680	Tunkhannock Creek near Long Pond, Pa.	41.065	-75.522	20.0	LF
01447720	Tobysanna Creek near Blakeslee, Pa.	41.085	-75.605	118	LF
01447800	Lehigh River below Francis E. Walter Res near White Haven, Pa.	41.105	-75.732	290	Y
01448000	Lehigh River at Tannery, Pa.	41.040	-75.761	322	N
01448500	Dilldown Creek near Long Pond, Pa.	41.036	-75.543	2.39	N
01449000	Lehigh River at Lehighton, Pa.	40.829	-75.705	591	Y
01449360	Pohopoco Creek at Kresgeville, Pa.	40.898	-75.502	49.9	N
01449800	Pohopoco Creek below Beltzville Dam near Parryville, Pa.	40.846	-75.646	96.4	Y
01450500	Aquashicola Creek at Palmerston, Pa.	40.806	-75.598	76.7	N
01451000	Lehigh River at Walnuport, Pa.	40.757	-75.603	889	Y
01451500	Little Lehigh Creek near Allentown, Pa.	40.582	-75.483	80.8	N
01451650	Little Lehigh Creek at Tenth St. Br. at Allentown, Pa.	40.596	-75.474	98.2	N
01451800	Jordan Creek near Schnecksville, Pa.	40.662	-75.627	53.0	N
01452000	Jordan Creek at Allentown, Pa.	40.623	-75.482	75.8	N
01452500	Monocacy Creek at Bethlehem, Pa.	40.641	-75.379	44.5	N
01453000	Lehigh River at Bethlehem, Pa.	40.615	-75.379	1,279	Y
01454700	Lehigh River at Glenden, Pa.	40.669	-75.236	1,359	Y
01455160	Bress Castle Creek near Washington, N.J.	40.765	-75.018	2.34	N
01455500	Musconetcong River at outlet of Lake Hopatcong, N.J.	40.917	-74.666	25.3	N
01457000	Musconetcong River near Bloomsbury, N.J.	40.672	-75.061	141	N
01459500	Tohickon Creek near Pipersville, Pa.	40.634	-75.117	97.4	Y
01463500	Delaware River at Trenton, N.J.	40.222	-74.778	6,780	Y
01463620	Assumpink Creek near Cheksville, N.J.	40.270	-74.672	34.3	N
01464000	Assumpink Creek at Trenton, N.J.	40.224	-74.749	90.6	N
01464500	Crosswicks Creek at Extenville, N.J.	40.137	-74.6	81.5	N
01464645	NB Neshaminy Creek at Lake Galena near New Britain, Pa.	40.312	-75.207	16.2	Y
01464720	NB Neshaminy Creek at Chalfont, Pa.	40.288	-75.204	31.5	Y
01465000	Neshaminy Creek at Rushland, Pa.	40.255	-75.033	134	N
01465500	Neshaminy Creek near Langhorne, Pa.	40.174	-74.957	210	N
01465770	Poquessing Creek at Trevose Road, Phila., Pa.	40.132	-74.994	5.08	N

22 Selected Streamflow Statistics for Streamgage Locations in and near Pennsylvania

Table 2. Selected flow statistics for streamgage locations in and near Pennsylvania.—Continued

[0.01, cubic feet per second; —, statistic not computed; <, less than]

Streamgage number	Period of record used in analysis <sup>1</sup>	Number of years used in analysis	1-day, 10-year (ft/s)	7-day, 10-year (ft/s)	7-day, 2-year (ft/s)	10-day, 10-year (ft/s)	10-day, 2-year (ft/s)	90-day, 10-year (ft/s)
01453000	1906-1937	18	237	312	447	378	546	472
01454700	1968-2005	38	471	510	745	600	902	760
01455500	1930-2008	52	0	.4	7.8	—	—	6.0
01457000	1905-2008	89	40.6	45.6	70.5	52.2	81.7	62.5
01459500	1975-2008	34	1.9	2.1	4.1	2.9	7.1	5.7
01459500	1937-1973	37	.4	.9	2.1	1.3	3.6	2.9
01463500	1914-2008	95	1,540	1,720	2,700	1,560	3,120	2,430
01463620	1974-2008	19	2.4	2.7	7.6	4.8	10.6	8.6
01464000	1925-2008	84	9.4	14.2	25.7	18.7	34.2	29.3
01464500	1942-2008	65	16.4	18.9	34.0	24.4	42.3	37.3
01464645	1987-2008	22	3.3	3.6	12.3	4.4	13.6	5.4
01464720	1992-2008	17	3.0	3.6	5.8	4.5	7.3	6.2
01465000	1886-1934	28	—	3.4	10.1	4.9	15.0	12.9
01465500	1936-2008	73	9.0	12.7	26.4	17.3	37.4	28.6
01465770	1966-1982	16	.3	.4	1.2	.8	1.7	1.7
01465798	1967-2008	42	1.0	1.2	3.6	3.0	6.8	7.9
01465850	1963-2008	19	5.2	8.5	13.2	12.1	19.5	17.1
01466500	1955-2008	54	.8	.8	1.1	.9	1.2	.9
01467000	1923-2008	86	26.2	34.2	51.8	41.6	63.2	53.2
01467042	1966-1981	16	8.6	9.3	16.8	11.3	21.5	17.0
01467048	1967-2008	42	10.7	12.1	18.9	16.6	27.2	26.6
01467050	1967-1981	15	.3	.4	.8	.7	1.3	1.6
01467081	1969-2008	38	2.4	2.9	4.1	3.9	6.0	6.3
01467086	1967-1988	23	3.3	4.4	6.9	6.6	9.9	10.4
01467087	1984-2008	25	1.6	2.1	6.1	4.8	10.1	12.0
01467089	1968-1982	15	4.8	6.6	9.6	10.3	16.0	20.1
01467150	1965-2008	44	3.9	5.4	10.1	7.3	13.2	11.5
01467500	1945-1969	25	14.6	17.2	24.5	19.8	28.5	23.4
01468500	1949-2008	40	40.8	44.5	70.6	52.1	82.4	65.0
01469500	1921-2008	88	4.8	5.5	10.9	7.3	14.4	10.1
01470500	1949-2008	60	69.2	82.3	137	102	164	133
01470756	1974-1995	22	14.8	16.7	30.5	23.4	43.9	35.5
01470779	1976-2008	33	21.9	24.6	39.3	29.4	45.2	34.8
01470853	1984-2005	22	.2	.4	1.2	.8	1.6	1.1
01470960	1980-2008	29	29.4	31.8	52.4	47.0	74.7	66.3
01470960	1967-1978	12	32.7	38.2	74.0	47.6	88.3	59.5
01471000	1980-2008	29	36.9	43.4	69.4	58.9	95.9	81.0
01471000	1952-1978	27	41.8	47.6	77.1	55.3	91.2	68.6
01471510	1980-2008	29	222	244	347	274	422	340
01471510	1916-1930	10	142	173	279	206	337	245
01471875	1995-2008	14	10.9	11.8	21.2	14.1	25.3	19.0
01471980	1976-2004	29	16.5	17.8	29.2	21.7	34.9	29.7
01472000	1980-2008	29	276	301	432	349	527	453
01472000	1929-1978	50	228	258	411	298	486	374
01472157	1970-2008	39	9.5	10.2	17.2	12.5	21.8	17.0


## PA0011274 at Outfall 001

Region ID: PA

Workspace ID: PA20200123132729074000

Clicked Point (Latitude, Longitude): 40.14580, -74.95090

Time: 2020-01-23 08:27:47 -0500



### Basin Characteristics

Parameter	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	214	square miles
BSLOPD	Mean basin slope measured in degrees	2.5	degrees
ROCKDEP	Depth to rock	4.3	feet
URBAN	Percentage of basin with urban development	28	percent

**Low-Flow Statistics Parameters (Low Flow Region 1)**

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	214	square miles	4.78	1150
BSLOPD	Mean Basin Slope degrees	2.5	degrees	1.7	6.4
ROCKDEP	Depth to Rock	4.3	feet	4.13	5.21
URBAN	Percent Urban	28	percent	0	89

**Low-Flow Statistics Flow Report (Low Flow Region 1)**

PIL: Prediction Interval-Lower, PPU: Prediction Interval-Upper, SEP: Standard Error of Prediction, SE: Standard Error (other -- see report)

Statistic	Value	Unit	SE	SEP
7 Day 2 Year Low Flow	21.2	ft <sup>3</sup> /s	46	46
30 Day 2 Year Low Flow	32.5	ft <sup>3</sup> /s	38	38
7 Day 10 Year Low Flow	9.35	ft <sup>3</sup> /s	51	51
30 Day 10 Year Low Flow	14.4	ft <sup>3</sup> /s	46	46
90 Day 10 Year Low Flow	29.8	ft <sup>3</sup> /s	41	41

**Low-Flow Statistics Citations**

Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.


## PA0011274 at node 2

Region ID: PA

Workspace ID: PA20200123133322256000

Clicked Point (Latitude, Longitude): 40.15352, -74.93126

Time: 2020-01-23 08:33:39 -0500



### Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	217	square miles
BSLOPD	Mean basin slope measured in degrees	2.6	degrees
ROCKDEP	Depth to rock	4.3	feet
URBAN	Percentage of basin with urban development	29	percent

Low-Flow Statistics Parameters (Low Flow Region 1)

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	217	square miles	4.78	1150
BSLOPD	Mean Basin Slope degrees	2.6	degrees	1.7	6.4
ROCKDEP	Depth to Rock	4.3	feet	4.13	5.21
URBAN	Percent Urban	29	percent	0	89

Low-Flow Statistics Flow Report (Low Flow Region 1)

PIL: Prediction Interval-Lower, Plu: Prediction Interval-Upper, SEP: Standard Error of Prediction, SE: Standard Error (other -- see report)

Statistic	Value	Unit	SE	SEP
7 Day 2 Year Low Flow	22.9	ft <sup>3</sup> /s	46	46
30 Day 2 Year Low Flow	34.8	ft <sup>3</sup> /s	38	38
7 Day 10 Year Low Flow	10.3	ft <sup>3</sup> /s	51	51
30 Day 10 Year Low Flow	15.8	ft <sup>3</sup> /s	46	46
90 Day 10 Year Low Flow	31.8	ft <sup>3</sup> /s	41	41

Low-Flow Statistics Citations

Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

WQM 7.0

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name		RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC		
									0.00	<input checked="" type="checkbox"/>	
<b>Stream Data</b>											
Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio (ft)	Rch Width (ft)	Rch Depth (°C)	Tributary Temp (°C)	Stream Temp (°C)	Stream pH
Q7-10	0.060	0.00	0.00	0.000	0.000	0.0	0.00	0.00	24.00	8.10	0.00
Q1-10		0.00	0.00	0.000	0.000						
Q30-10		0.00	0.00	0.000	0.000						
<b>Discharge Data</b>											
	Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH			
	Neshaminy Falls	PA0011274	0.1815	0.1815	0.1815	0.000	20.00	7.37			
<b>Parameter Data</b>											
	Parameter Name		Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)					
	CBOD5		25.00	2.00	0.00	1.50					
	Dissolved Oxygen		5.00	8.24	0.00	0.00					
	NH3-N		25.00	0.00	0.00	0.70					

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name		RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC	
02F	2484 NESHAMINY CREEK			7.175	20.60	217.00	0.00000	0.00	<input checked="" type="checkbox"/>	
<b>Stream Data</b>										
Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio (ft)	Rch Width (ft)	Tributary Temp (°C)	Stream Temp (°C)	pH
Q7-10	0.060	0.00	0.00	0.000	0.000	0.0	0.00	24.00	8.10	0.00
Q1-10		0.00	0.00	0.000	0.000					
Q30-10		0.00	0.00	0.000	0.000					
<b>Discharge Data</b>										
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH			
		0.0000	0.0000	0.0000	0.000	25.00	7.00			
<b>Parameter Data</b>										
Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)						
CBOD5	25.00	2.00	0.00	1.50						
Dissolved Oxygen	3.00	8.24	0.00	0.00						
NH3-N	25.00	0.00	0.00	0.70						

Friday, December 27, 2024

Version 1.1

Page 2 of 2

**WQM 7.0 Modeling Specifications**

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.709	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.362	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

**WQM 7.0 Hydrodynamic Outputs**

SWP Basin		Stream Code		Stream Name								
02F		2484		NESHAMINY CREEK								
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)		(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
<b>Q7-10 Flow</b>												
8.280	12.84	0.00	12.84	.2808 0.00083		.862	64.8	75.2	0.23	0.287	23.91	8.06
<b>Q1-10 Flow</b>												
8.280	9.10	0.00	9.10	.2808 0.00083		NA	NA	NA	0.19	0.347	23.88	8.05
<b>Q30-10 Flow</b>												
8.280	17.49	0.00	17.49	.2808 0.00083		NA	NA	NA	0.28	0.242	23.94	8.07

**WQM 7.0 Wasteload Allocations**

SWP Basin		Stream Code		Stream Name															
02F		2484		NESHAMINY CREEK															
<b>NH3-N Acute Allocations</b>																			
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction												
8.280	Neshaminy Falls	2.59	50	2.59	50	0	0												
<b>NH3-N Chronic Allocations</b>																			
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction												
8.280	Neshaminy Falls	.54	25	.54	25	0	0												
<b>Dissolved Oxygen Allocations</b>																			
RMI	Discharge Name	CBOD5		NH3-N		Dissolved Oxygen			Critical Reach	Percent Reduction									
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)												
8.28	Neshaminy Falls	25	25	25	25	5	5	0	0										

**WQM 7.0 D.O.Simulation**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
02F	2484	NESHAMINY CREEK		
<u>RMI</u>	Total Discharge Flow (mgd)		<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>
8.280	0.182		23.914	8.061
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>		<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>
64.799	0.862		75.198	0.235
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>		<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>
2.49	0.263		0.53	0.946
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>		<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>
8.174	1.460		Tsivoglou	5
<u>Reach Travel Time (days)</u>	<b>Subreach Results</b>			
0.287	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
	0.029	2.47	0.52	7.68
	0.057	2.45	0.51	7.68
	0.086	2.43	0.49	7.68
	0.115	2.40	0.48	7.68
	0.144	2.38	0.47	7.68
	0.172	2.36	0.45	7.68
	0.201	2.34	0.44	7.68
	0.230	2.32	0.43	7.65
	0.259	2.30	0.42	7.61
	0.287	2.28	0.41	7.56

**WQM 7.0 Effluent Limits**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>				
02F	2484	NESHAMINY CREEK				
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)
8.280	Neshaminy Falls	PA0011274	0.182	CBOD5	25	
				NH3-N	25	50
				Dissolved Oxygen		5

TMS



## Discharge Information

Instructions			Discharge		Stream	
Facility: Neshaminy Falls WTP			NPDES Permit No.: PA0011274		Outfall No.: 001	
Evaluation Type: Major Sewage / Industrial Waste			Wastewater Description: Treated filter backwash			
Discharge Characteristics						
Design Flow (MGD)*	Hardness (mg/l)*	pH (SU)*	Partial Mix Factors (PMFs)			Complete Mix Times (min)
			AFC	CFC	THH	
0.1815	166	7.37				
			0 if left blank	0.5 if left blank	1 if left blank	
			Trib Conc	Stream Conc	Daily CV	Hourly CV
			Strea m CV	Fate Coeff	FOS	Criteri a Mod
						Chem Transl
Group 1						
Total Dissolved Solids (PWS)	mg/L					
Chloride (PWS)	mg/L					
Bromide	mg/L					
Sulfate (PWS)	mg/L					
Fluoride (PWS)	mg/L					
Group 2						
Total Aluminum	µg/L	0.35				
Total Antimony	µg/L	0.8				
Total Arsenic	µg/L	2				
Total Barium	µg/L	108				
Total Beryllium	µg/L	< 1				
Total Boron	µg/L	< 200				
Total Cadmium	µg/L	< 0.2				
Total Chromium (III)	µg/L	1.4				
Hexavalent Chromium	µg/L					
Total Cobalt	µg/L	0.7				
Total Copper	µg/L	5				
Free Cyanide	µg/L					
Total Cyanide	µg/L	< 10				
Dissolved Iron	µg/L	< 20				
Total Iron	µg/L	< 0.099				
Total Lead	µg/L	< 1				
Total Manganese	µg/L	0.079				
Total Mercury	µg/L	< 0.2				
Total Nickel	µg/L	3.5				
Total Phenols (Phenolics) (PWS)	µg/L	< 2				
Total Selenium	µg/L	< 1				
Total Silver	µg/L	< 0.4				
Total Thallium	µg/L	< 0.3				
Total Zinc	µg/L	24				
Total Molybdenum	µg/L	4				
Acrolein	µg/L	<				
Acrylamide	µg/L	<				
Acrylonitrile	µg/L	<				
Benzene	µg/L	<				
Bromoform	µg/L	<				
Carbon Tetrachloride	µg/L	<				



### Discharge Information

12/27/2024

Page 3

### Stream / Surface Water Information

Neshaminy Falls WTP, NPDES Permit No. PA0011274, Outfall 001

**Instructions      Discharge      Stream**

10.1007/s00332-010-9000-0

- Statewide Criteria
- Great Lakes Criteria
- OBCANCO Criteria

Location	Stream Code*	RMI*	Elevation (ft)*	DA (mi <sup>2</sup> )*	Slope (ft/ft)	PWS Withdrawal (MGD)	Apply Fish Criteria*
Point of Discharge	002484	8.28	25.44	214			Yes
End of Reach 1	002484	7.175	20.6	217			Yes

Q <sub>7-10</sub>															
Location	RML	LFY (cfs/mi <sup>2</sup> ) <sup>*</sup>	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness <sup>*</sup>	pH <sup>*</sup>	Hardness	pH
Point of Discharge	8.28	0.06										140.5	8.1		
End of Reach 1	7.175	0.06										140.5	8.1		

NPDES Permit Fact Sheet  
Neshaminy Falls Water Treatment Plant

NPDES Permit No. PA0011274

Instructions Results RETURN TO INPUTS SAVE AS PDF PRINT All 0 Inputs 0 Results 0 Limits

Hydrodynamics

Wasteload Allocations

AFC CCT (min):  PMF:  Analysis Hardness (mg/l):  Analysis pH:

Pollutants	Stream Conc	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Aluminum	0	0		0	750	750	9,338	
Total Antimony	0	0		0	1,100	1,100	13,696	
Total Arsenic	0	0		0	340	340	4,233	
Total Barium	0	0		0	21,000	21,000	261,470	
Total Boron	0	0		0	8,100	8,100	100,853	
Total Cadmium	0	0		0	2,842	3.06	38.1	Chem Translator of 1 applied
Total Chromium (III)	0	0		0	761,709	2,410	30,013	Chem Translator of 0.929 applied
Total Cobalt	0	0		0	95	95.0	1,183	Chem Translator of 0.316 applied
Total Copper	0	0		0	18,769	19.6	243	Chem Translator of 0.96 applied
Dissolved Iron	0	0		0	N/A	N/A	N/A	
Total Iron	0	0		0	N/A	N/A	N/A	
Total Lead	0	0		0	94,792	128	1,596	Chem Translator of 0.739 applied
Total Manganese	0	0		0	N/A	N/A	N/A	
Total Mercury	0	0		0	1,400	1.65	20.5	Chem Translator of 0.85 applied
Total Nickel	0	0		0	631,998	633	7,885	Chem Translator of 0.998 applied
Total Phenols (Phenolics) (PWS)	0	0		0	N/A	N/A	N/A	
Total Selenium	0	0		0	N/A	N/A	N/A	Chem Translator of 0.922 applied
Total Silver	0	0		0	5,919	6.96	86.7	Chem Translator of 0.85 applied
Total Thallium	0	0		0	65	65.0	809	
Total Zinc	0	0		0	158,236	162	2,015	Chem Translator of 0.978 applied

CFC CCT (min):  PMF:  Analysis Hardness (mg/l):  Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Aluminum	0	0		0	N/A	N/A	N/A	
Total Antimony	0	0		0	220	220	10,281	

Model Results

12/27/2024

Page 5

Total Arsenic	0	0		0	150	150	7,009	Chem Translator of 1 applied
Total Barium	0	0		0	4,100	4,100	191,592	
Total Boron	0	0		0	1,600	1,600	74,767	
Total Cadmium	0	0		0	0.312	0.35	16.3	Chem Translator of 0.895 applied
Total Chromium (III)	0	0		0	98,227	114	5,337	Chem Translator of 0.86 applied
Total Cobalt	0	0		0	19	19.0	888	
Total Copper	0	0		0	12,015	12.5	585	Chem Translator of 0.96 applied
Dissolved Iron	0	0		0	N/A	N/A	N/A	
Total Iron	0	0		0	1,500	1,500	70,095	WQC = 30 day average; PMF = 1
Total Lead	0	0		0	3,652	4.93	230	Chem Translator of 0.741 applied
Total Manganese	0	0		0	N/A	N/A	N/A	
Total Mercury	0	0		0	0.770	0.91	42.3	Chem Translator of 0.85 applied
Total Nickel	0	0		0	69,569	69.8	3,261	Chem Translator of 0.997 applied
Total Phenols (Phenolics) (PWS)	0	0		0	N/A	N/A	N/A	
Total Selenium	0	0		0	4,600	4.99	233	Chem Translator of 0.922 applied
Total Silver	0	0		0	N/A	N/A	N/A	Chem Translator of 1 applied
Total Thallium	0	0		0	13	13.0	607	
Total Zinc	0	0		0	158,105	160	7,493	Chem Translator of 0.966 applied

THH CCT (min):  PMF:  Analysis Hardness (mg/l):  Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Aluminum	0	0		0	N/A	N/A	N/A	
Total Antimony	0	0		0	5.6	5.6	262	
Total Arsenic	0	0		0	10	10.0	467	
Total Barium	0	0		0	2,400	2,400	112,151	
Total Boron	0	0		0	3,100	3,100	144,662	
Total Cadmium	0	0		0	N/A	N/A	N/A	
Total Chromium (III)	0	0		0	N/A	N/A	N/A	
Total Cobalt	0	0		0	N/A	N/A	N/A	
Total Copper	0	0		0	N/A	N/A	N/A	
Dissolved Iron	0	0		0	300	300	14,019	
Total Iron	0	0		0	N/A	N/A	N/A	
Total Lead	0	0		0	N/A	N/A	N/A	
Total Manganese	0	0		0	1,000	1,000	46,730	
Total Mercury	0	0		0	0.050	0.05	2.34	
Total Nickel	0	0		0	610	610	28,505	
Total Phenols (Phenolics) (PWS)	0	0		0	5	5.0	N/A	
Total Selenium	0	0		0	N/A	N/A	N/A	
Total Silver	0	0		0	N/A	N/A	N/A	
Total Thallium	0	0		0	0.24	0.24	11.2	
Total Zinc	0	0		0	N/A	N/A	N/A	

CRL CCT (min):  PMF:  Analysis Hardness (mg/l):  Analysis pH:

NPDES Permit Fact Sheet  
Neshaminy Falls Water Treatment Plant

NPDES Permit No. PA0011274

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Aluminum	0	0	0	0	N/A	N/A	N/A	
Total Antimony	0	0	0	0	N/A	N/A	N/A	
Total Arsenic	0	0	0	0	N/A	N/A	N/A	
Total Barium	0	0	0	0	N/A	N/A	N/A	
Total Boron	0	0	0	0	N/A	N/A	N/A	
Total Cadmium	0	0	0	0	N/A	N/A	N/A	
Total Chromium (III)	0	0	0	0	N/A	N/A	N/A	
Total Cobalt	0	0	0	0	N/A	N/A	N/A	
Total Copper	0	0	0	0	N/A	N/A	N/A	
Dissolved Iron	0	0	0	0	N/A	N/A	N/A	
Total Iron	0	0	0	0	N/A	N/A	N/A	
Total Lead	0	0	0	0	N/A	N/A	N/A	
Total Manganese	0	0	0	0	N/A	N/A	N/A	
Total Mercury	0	0	0	0	N/A	N/A	N/A	
Total Nickel	0	0	0	0	N/A	N/A	N/A	
Total Phenols (Phenolics) (PWS)	0	0	0	0	N/A	N/A	N/A	
Total Selenium	0	0	0	0	N/A	N/A	N/A	
Total Silver	0	0	0	0	N/A	N/A	N/A	
Total Thallium	0	0	0	0	N/A	N/A	N/A	
Total Zinc	0	0	0	0	N/A	N/A	N/A	

Recommended WQBELs & Monitoring Requirements

No. Samples/Month: 4

Pollutants	Mass Limits		Concentration Limits				Governing WQBEL	WQBEL Basis	Comments
	AML (lbs/day)	MDL (lbs/day)	AML	MDL	IMAX	Units			

Other Pollutants without Limits or Monitoring

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., <= Target QL).

Pollutants	Governing WQBEL	Units	Comments
Total Aluminum	5,985	µg/L	Discharge Conc ≤ 10% WQBEL
Total Antimony	262	µg/L	Discharge Conc ≤ 10% WQBEL
Total Arsenic	467	µg/L	Discharge Conc ≤ 10% WQBEL
Total Barium	112,151	µg/L	Discharge Conc ≤ 10% WQBEL
Total Beryllium	N/A	N/A	No WQS
Total Boron	N/A	N/A	Discharge Conc < TQL
Total Cadmium	N/A	N/A	Discharge Conc < TQL
Total Chromium (III)	5,337	µg/L	Discharge Conc ≤ 10% WQBEL

Total Cobalt	758	µg/L	Discharge Conc ≤ 10% WQBEL
Total Copper	156	µg/L	Discharge Conc ≤ 10% WQBEL
Total Cyanide	N/A	N/A	No WQS
Dissolved Iron	14,019	µg/L	Discharge Conc < TQL
Total Iron	70,095	µg/L	Discharge Conc < TQL
Total Lead	230	µg/L	Discharge Conc < TQL
Total Manganese	46,730	µg/L	Discharge Conc ≤ 10% WQBEL
Total Mercury	2.34	µg/L	Discharge Conc < TQL
Total Nickel	3,261	µg/L	Discharge Conc ≤ 10% WQBEL
Total Phenols (Phenolics) (PWS)		µg/L	Discharge Conc < TQL
Total Selenium	233	µg/L	Discharge Conc < TQL
Total Silver	55.6	µg/L	Discharge Conc < TQL
Total Thallium	11.2	µg/L	Discharge Conc < TQL
Total Zinc	1,291	µg/L	Discharge Conc ≤ 10% WQBEL
Total Molybdenum	N/A	N/A	No WQS

TRC\_Spreadsheet

TRC\_CALC

TRC EVALUATION					
Input appropriate values in A3:A9 and D3:D9					
12.84	= Q stream (cfs)	0.5	= CV Daily		
0.1815	= Q discharge (MGD)	0.5	= CV Hourly		
30	= no. samples	1	= AFC_Partial Mix Factor		
0.3	= Chlorine Demand of Stream	1	= CFC_Partial Mix Factor		
0	= Chlorine Demand of Discharge	15	= AFC_Criteria Compliance Time (min)		
0.5	= BAT/BPJ Value	720	= CFC_Criteria Compliance Time (min)		
0	= % Factor of Safety (FOS)		=Decay Coefficient (K)		
Source	Reference	AFC Calculations	Reference	CFC Calculations	
TRC	1.3.2.iii	WLA_afc = 14.607	1.3.2.iii	WLA_cfc = 14.233	
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373	5.1c	LTAMULT_cfc = 0.581	
PENTOXSD TRG	5.1b	LTA_afc= 5.443	5.1d	LTA_cfc = 8.274	
Source					
Effluent Limit Calculations					
PENTOXSD TRG	5.1f	AML MULT = 1.231			
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.500		BAT/BPJ	
		INST MAX LIMIT (mg/l) = 1.635			
WLA_afc	$(.019/e(-k* AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k* AFC_tc))...\\ ...+ Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$				
LTAMULT_afc	$\text{EXP}((0.5*\text{LN}(cvh^2+1))-2.326*\text{LN}(cvh^2+1)^{0.5})$				
LTA_afc	wla_afc*LTAMULT_afc				
WLA_cfc	$(.011/e(-k* CFC_tc)) + [(CFC_Yc*Qs*.011/Qd*e(-k* CFC_tc))...\\ ...+ Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$				
LTAMULT_cfc	$\text{EXP}((0.5*\text{LN}(cvd^2/no\_samples+1))-2.326*\text{LN}(cvd^2/no\_samples+1)^{0.5})$				
LTA_cfc	wla_cfc*LTAMULT_cfc				
AML MULT	$\text{EXP}(2.326*\text{LN}((cvd^2/no\_samples+1)^{0.5})-0.5*\text{LN}(cvd^2/no\_samples+1))$				
AVG MON LIMIT	MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT)				
INST MAX LIMIT	1.5*((av_mon_limit/AML_MULT)/LTAMULT_afc)				