

Application Type Renewal
Facility Type Industrial
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL INDUSTRIAL WASTE (IW)
AND IW STORMWATER**

Application No. PA0011282
APS ID 1011708
Authorization ID 1306110

Applicant and Facility Information

Applicant Name	<u>Aqua Pennsylvania, Inc.</u>	Facility Name	<u>Crum Creek Water Treatment Plant</u>
Applicant Address	<u>762 W Lancaster Avenue</u> <u>Bryn Mawr, PA 19010-3489</u>	Facility Address	<u>965 Beatty Road</u> <u>Springfield, PA 19064</u>
Applicant Contact	<u>Todd M. Duerr</u>	Facility Contact	<u>Robert Burston</u>
Applicant Phone	<u>(610) 645-1122</u>	Facility Phone	<u>(610) 543-7514</u>
Client ID	<u>309251</u>	Site ID	<u>493382</u>
SIC Code	<u>4941</u>	Municipality	<u>Springfield Township</u>
SIC Description	<u>Trans. & Utilities - Water Supply</u>	County	<u>Delaware</u>
Date Application Received	<u>January 31, 2020</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>March 30, 2021</u>	If No, Reason	<u></u>
Purpose of Application	<u>Permit Renewal.</u>		

Summary of Review


The PA Department of Environmental Protection (PADEP/Department) received an NPDES permit renewal application from GHD on behalf of Aqua Pennsylvania, Inc. (Aqua/permittee) for Aqua's Crum Creek WTP (facility) on January 31, 2020. This is a minor IWTP without ELG with an average annual design flow of 0.555 MGD (Outfall 002) and 0.094 MGD (Outfall 013). The current permit expired on July 31, 2020. The terms and conditions are automatically extended since the renewal application was received at least 180 days prior to permit expiration date. Renewal NPDES permit under Clean Water Program are not eligible for PDG, per 021-2100-001.

This fact sheet is developed in accordance with 40 CFR §124.56.

Changes in this permit: None

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
√		Reza H. Chowdhury, E.I.T. / Project Manager 	November 19, 2021
X		Pravin Patel Pravin C. Patel, P.E. / Environmental Engineer Manager	11/22/2021

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	002	Design Flow (MGD)	0.555
Latitude	39° 55' 23.35"	Longitude	-75° 21' 53.16"
Quad Name	Lansdowne	Quad Code	1943
Wastewater Description: Process wastewater discharge from residuals basin			
Receiving Waters	Crum Creek (WWF)	Stream Code	00692
NHD Com ID	25601315	RMI	8.0
Drainage Area	28.9 mi ²	Yield (cfs/mi ²)	0.276
Q ₇₋₁₀ Flow (cfs)	7.99	Q ₇₋₁₀ Basis	Please see below
Elevation (ft)	90.08	Slope (ft/ft)	
Watershed No.	3-G	Chapter 93 Class.	WWF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Impaired		
Cause(s) of Impairment	CAUSE UNKNOWN, DEWATERING, FLOW REGIME MODIFICATION, SILTATION		
Source(s) of Impairment	URBAN RUNOFF/STORM SEWERS, URBAN RUNOFF/STORM SEWERS, URBAN RUNOFF/STORM SEWERS, URBAN RUNOFF/STORM SEWERS		
TMDL Status		Name	
Background/Ambient Data		Data Source	
pH (SU)	7.0	Default	
Temperature (°C)	25	Default	
Hardness (mg/L)	100	Default	
Other:			
Nearest Downstream Public Water Supply Intake	None		
PWS Waters		Flow at Intake (cfs)	
PWS RMI		Distance from Outfall (mi)	

Changes Since Last Permit Issuance: None

Drainage Area:

The drainage area upstream of the point of discharge is 28.9 mi² according to USGS PA StreamStats, accessible at <https://streamstats.usgs.gov/ss/>

Stream Flow:

The streamflow at Outfall 002 is correlated to USGS's watershed delineation tool StreamStats (<https://streamstats.usgs.gov/ss/>). The stream flow retrievals resulted in a Q₇₋₁₀ and Q₃₋₁₀ of 7.99 cfs and 9.93 cfs, respectively, at Outfall 002. The flow calculations are shown below:

$$Q_{7-10} \text{ runoff rate (yield)} = 7.99/28.9 = 0.276 \text{ cfs/mi}^2.$$

$$Q_{30-10}: Q_{7-10} = 9.93/7.99 = 1.24:1$$

Default Q₁₋₁₀:Q₇₋₁₀ of 0.64 will be used in modeling, if needed.

PWS Intake:

There is no PWS intake from Outfall 002 till the PA-DE border.

Wastewater Characteristics:

There was no discharge reported in the DMR from Outfall 002 in last 12 months. Therefore, a default pH of 7.0 and discharge temperature of 20°C will be used in the modeling.

Background/Ambient Stream Data:

There is no nearby active WQN station from the discharge points. In absence of site-specific data, a default pH of 7.0, temperature of 25°C, and stream hardness of 99 mg/l from application will be used.

303d Listed Streams:

The receiving stream is impaired for siltation and flow regime modification from urban runoff and unknown sources. The permit limits, terms, and conditions were developed in such a way that the discharge from this facility is expected not to contribute to the existing impairment of the receiving stream or the watershed.

Antidegradation (93.4):

The effluent limits for this discharge have been developed to ensure that existing in-stream water uses and the level of water quality necessary to protect the existing uses are maintained and protected. No High-Quality Waters are impacted by this discharge. No Exceptional Value Waters are impacted by this discharge.

Class A Wild Trout Fisheries:

No Class A Wild Trout Fisheries are impacted by this discharge.

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0</u>
Latitude	<u>39° 55' 28.6"</u>	Longitude	<u>-75° 21' 51.76"</u>
Quad Name	<u>Lansdowne</u>	Quad Code	<u>1943</u>
Wastewater Description:	<u>Emergency process wastewater discharge from filter backwash tanks, recycled back to the front of WTP and mixes with raw water.</u>		
Receiving Waters	<u>Crum Creek (WWF)</u>	Stream Code	<u>00692</u>
NHD Com ID	<u>25601315</u>	RMI	<u>8.0</u>

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>003</u>	Design Flow (MGD)	<u>0</u>
Latitude	<u>39° 55' 30"</u>	Longitude	<u>-75° 21' 55"</u>
Quad Name	<u>Lansdowne</u>	Quad Code	<u>1943</u>
Wastewater Description:	<u>Emergency wastewater discharge from filter backwash drain</u>		
Receiving Waters	<u>Crum Creek (WWF)</u>	Stream Code	<u>00692</u>
NHD Com ID	<u>25601315</u>	RMI	<u>8.0</u>

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>004</u>	Design Flow (MGD)	<u>0</u>
Latitude	<u>39° 55' 30"</u>	Longitude	<u>-75° 21' 55"</u>
Quad Name	<u>Lansdowne</u>	Quad Code	<u>1943</u>
Wastewater Description:	<u>Emergency wastewater discharge from two flapper valves for transfer pit overflows</u>		
Receiving Waters	<u>Crum Creek (WWF)</u>	Stream Code	<u>00692</u>
NHD Com ID	<u>25601315</u>	RMI	<u>8.0</u>

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>006</u>	Design Flow (MGD)	<u>0</u>
Latitude	<u>39° 55' 33"</u>	Longitude	<u>-75° 21' 59"</u>
Quad Name	<u>Lansdowne</u>	Quad Code	<u>1943</u>
Wastewater Description: <u>36" Venturi vault drains-raw water leakage and groundwater from meter pit</u>			
Receiving Waters	<u>Crum Creek (WWF)</u>	Stream Code	<u>00692</u>
NHD Com ID	<u>25601315</u>	RMI	<u>8.0</u>

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>007</u>	Design Flow (MGD)	<u>0</u>
Latitude	<u>39° 55' 32"</u>	Longitude	<u>-75° 21' 59"</u>
Quad Name	<u>Lansdowne</u>	Quad Code	<u>1943</u>
Wastewater Description: <u>Venturi pit drain</u>			
Receiving Waters	<u>Crum Creek (WWF)</u>	Stream Code	<u>00692</u>
NHD Com ID	<u>25601315</u>	RMI	<u>8.0</u>

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>008</u>	Design Flow (MGD)	<u>0</u>
Latitude	<u>39° 55' 31"</u>	Longitude	<u>-75° 21' 57"</u>
Quad Name	<u>Lansdowne</u>	Quad Code	<u>1943</u>
Wastewater Description: <u>Sump drainage for elevator pit-used to remove groundwater from pit</u>			
Receiving Waters	<u>Crum Creek (WWF)</u>	Stream Code	<u>00692</u>
NHD Com ID	<u>25601315</u>	RMI	<u>8.0</u>

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>009</u>	Design Flow (MGD)	<u>0</u>
Latitude	<u>39° 55' 36"</u>	Longitude	<u>-75° 21' 52"</u>
Quad Name	<u>Lansdowne</u>	Quad Code	<u>1943</u>
Wastewater Description: <u>16" groundwater drain-drain groundwater from the area behind the settling basin</u>			
Receiving Waters	<u>Crum Creek (WWF)</u>	Stream Code	<u>00692</u>
NHD Com ID	<u>25601315</u>	RMI	<u>8.0</u>

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>010</u>	Design Flow (MGD)	<u>0</u>
Latitude	<u>39° 55' 34"</u>	Longitude	<u>-75° 22' 0"</u>
Quad Name	<u>Lansdowne</u>	Quad Code	<u>1943</u>
Wastewater Description: <u>Raw untreated creek water</u>			
Receiving Waters	<u>Crum Creek (WWF)</u>	Stream Code	<u>00692</u>
NHD Com ID	<u>25601315</u>	RMI	<u>8.0</u>

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>011</u>	Design Flow (MGD)	<u>0</u>
Latitude	<u>39° 55' 32"</u>	Longitude	<u>-75° 21' 59"</u>
Quad Name	<u>Lansdowne</u>	Quad Code	<u>1943</u>
Wastewater Description: <u>Raw untreated creek water</u>			
Receiving Waters	<u>Crum Creek (WWF)</u>	Stream Code	<u>00692</u>
NHD Com ID	<u>25601315</u>	RMI	<u>8.0</u>

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	013	Design Flow (MGD)	.094
Latitude	39° 55' 34"	Longitude	-75° 22' 0"
Quad Name	Lansdowne	Quad Code	1943
Wastewater Description: Chlorinated drinking water from traveling screen cleaning operations			
Receiving Waters	Crum Creek (WWF)	Stream Code	00692
NHD Com ID	25601315	RMI	8.0
Drainage Area	28.9	Yield (cfs/mi ²)	
Q ₇₋₁₀ Flow (cfs)	7.99	Q ₇₋₁₀ Basis	Please see page 2
Elevation (ft)		Slope (ft/ft)	
Watershed No.	3-G	Chapter 93 Class.	WWF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Impaired		
Cause(s) of Impairment	CAUSE UNKNOWN, DEWATERING, FLOW REGIME MODIFICATION, SILTATION		
Source(s) of Impairment	URBAN RUNOFF/STORM SEWERS, URBAN RUNOFF/STORM SEWERS, URBAN RUNOFF/STORM SEWERS, URBAN RUNOFF/STORM SEWERS		
TMDL Status		Name	


Discharge, Receiving Waters and Water Supply Information			
Outfall No.	014	Design Flow (MGD)	0
Latitude	39° 55' 29"	Longitude	-75° 21' 52"
Quad Name	Lansdowne	Quad Code	1943
Wastewater Description: Groundwater/stormwater drains, groundwater overflow from infiltration trenches near clear wells			
Receiving Waters	Crum Creek (WWF)	Stream Code	00692
NHD Com ID	25601315	RMI	8.0

Treatment Facility Summary				
Treatment Facility Name: Crum Creek Water Filtration Plant				
WQM Permit No.	Issuance Date			
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Industrial			No Disinfection	
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
		Not Overloaded		

Changes Since Last Permit Issuance: None

Other Comments:

Aqua Pennsylvania, Inc. (Aqua) owns and operates a Water Treatment Plant (WTP) named Crum Creek Water Treatment Plant (Crum Creek WTP) located in Springfield Township, Delaware County, which discharges into the Crum Creek under NPDES permit PA0011282. Aqua requests renewal of its NPDES permit to continue discharge of 0.555 MGD through Outfall 002 and 0.094 MGD through Outfall 013, and through several other outfalls in case of emergency, and stormwater. The WTP withdraws 20 MGD of raw water as a yearly average. Outfall 013 is the only outfall that discharges on continuous basis. All other outfalls are either emergency only or intermittent. There was no discharge from Outfalls 001, 003, 004, 006, 007, 008, 010, and 014 during current permit term (since January 2014). Outfall 002 had only two discharges during the current permit term on June 2017 (0.5 MGD) and November 2017 (0.35 MGD). The process schematic is provided below:



GHD
 AQUA PENNSYLVANIA INC
 CRUM CREEK WTP
 NPDES RENEWAL
 RESIDUALS TREATMENT
 PROCESS SCHEMATIC

1240 North Mountain Road, Harrisburg PA 17112 USA T-717 541 0632 F-1717 4

Decant from the thickeners, belt press, and filter wash water tank is typically recycled; however, if necessary it can be discharged through Outfall 002. Prior to discharge through Outfall 013, the cleaning water from traveling screen is dechlorinated using asborbic acid. The following wastewater treatment chemicals are used at the WTP:

NPDES Permit Fact Sheet
Aqua Pennsylvania Crum Creek Water Treatment Plant

NPDES Permit No. PA0011282

Outfall	Chemical name	Purpose	Max usage rate	units
002	Magnafloc LT340 (polymer)	Flocculation	7	Lbs./day
	Praestol A3040	Flocculation	1,814	Lbs./day
013	Ascorbic acid	Dechlorination	2.5	lbs./day

Compliance History

DMR Data for Outfall 013 (from February 1, 2020 to January 31, 2021)

Parameter	JAN-21	DEC-20	NOV-20	OCT-20	SEP-20	AUG-20	JUL-20	JUN-20	MAY-20	APR-20	MAR-20	FEB-20
Flow (MGD) Average Monthly	0.005	0.005	0.005	0.005	0.005	0.05	0.005	0.005	0.005	0.005	0.005	0.005
Flow (MGD) Daily Maximum	0.005	0.005	0.005	0.005	0.005	0.05	0.006	0.005	0.005	0.006	0.005	0.005
pH (S.U.) Instantaneous Minimum	7.4	7.3	7.3	7.4	7.4	7.3	7.3	7.2	7.2	7.2	7.2	7.2
pH (S.U.) Instantaneous Maximum	7.6	7.8	7.8	7.6	7.6	7.6	7.7	7.7	7.7	7.5	7.5	7.6
TRC (mg/L) Average Monthly	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01
TRC (mg/L) Instantaneous Maximum	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01

There is no reported non-compliance for the last 12 months.

Existing limits

The table below summarizes effluent limitations and monitoring requirements specified in the existing final NPDES permit that was in effect between August 1, 2015 to July 31, 2020.

For Outfall 001:

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Instant. Minimum	Average Monthly	Daily Maximum	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Daily when Discharging	Estimate
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	Daily when Discharging	Grab
Total Residual Chlorine	XXX	XXX	XXX	0.5	1.0	1.2	Daily when Discharging	Grab
Total Suspended Solids	XXX	XXX	XXX	30	60	75	Daily when Discharging	*24-Hr Composite
Total Aluminum	XXX	XXX	XXX	1.24	2.48	3.10	Daily when Discharging	*24-Hr Composite
Total Iron	XXX	XXX	XXX	2.0	4.0	5.0	Daily when Discharging	*24-Hr Composite
Total Manganese	XXX	XXX	XXX	1.0	2.0	2.5	Daily when Discharging	*24-Hr Composite
Chlorodibromomethane	XXX	XXX	XXX	XXX	Report	XXX	Daily when Discharging	Grab
Dichlorobromomethane	XXX	XXX	XXX	XXX	Report	XXX	Daily when Discharging	Grab
Chloroform	XXX	XXX	XXX	XXX	Report	XXX	Daily when Discharging	Grab

For Outfall 002:

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				**Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Instant. Minimum	Average Monthly	Daily Maximum	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Daily when Discharging	Estimate
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	Daily when Discharging	Grab
Total Residual Chlorine	XXX	XXX	XXX	0.5	1.0	1.2	Daily when Discharging	Grab

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				**Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Instant. Minimum	Average Monthly	Daily Maximum	Instant. Maximum		
Total Suspended Solids	XXX	XXX	XXX	30	60	75	Daily when Discharging	24-Hr Composite
Total Aluminum	XXX	XXX	XXX	4.0	8.0	10.0	Daily when Discharging	24-Hr Composite
Total Iron	XXX	XXX	XXX	2.0	4.0	5.0	Daily when Discharging	24-Hr Composite
Total Manganese	XXX	XXX	XXX	2.0	4.0	5.0	Daily when Discharging	24-Hr Composite
Acrylamide	XXX	XXX	XXX	XXX	Report	XXX	Daily when Discharging	24-Hr Composite
Chlorodibromomethane	XXX	XXX	XXX	XXX	Report	XXX	Daily when Discharging	Grab
Dichlorobromomethane	XXX	XXX	XXX	XXX	Report	XXX	Daily when Discharging	Grab
Chloroform	XXX	XXX	XXX	XXX	Report	XXX	Daily when Discharging	Grab
Total Dissolved Solids	XXX	XXX	XXX	XXX	Report	XXX	1/6 months	24-Hr Composite

For Outfall 003:

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Instant. Minimum	Average Monthly	Daily Maximum	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Hourly when Discharging	Estimate
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	Hourly when Discharging	Grab
Total Residual Chlorine	XXX	XXX	XXX	0.5	1.0	1.2	Hourly when Discharging	Grab
Total Suspended Solids	XXX	XXX	XXX	XXX	Report	XXX	Hourly when Discharging	Grab
Total Aluminum	XXX	XXX	XXX	XXX	Report	XXX	Hourly when Discharging	Grab
Total Iron	XXX	XXX	XXX	XXX	Report	XXX	Hourly when Discharging	Grab
Total Manganese	XXX	XXX	XXX	XXX	Report	XXX	Hourly when Discharging	Grab

For Outfall 004:

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Instant. Minimum	Average Monthly	Daily Maximum	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Hourly when Discharging	Estimate
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	Hourly when Discharging	Grab
Total Residual Chlorine	XXX	XXX	XXX	0.5	1.0	1.2	Hourly when Discharging	Grab
Total Suspended Solids	XXX	XXX	XXX	XXX	Report	XXX	Hourly when Discharging	Grab
Total Aluminum	XXX	XXX	XXX	XXX	Report	XXX	Hourly when Discharging	Grab
Total Iron	XXX	XXX	XXX	XXX	Report	XXX	Hourly when Discharging	Grab
Total Manganese	XXX	XXX	XXX	XXX	Report	XXX	Hourly when Discharging	Grab

For Outfall 006, 007, 008, 009, 010, 011, and 014: Not monitored.

For Outfall 013:

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Instant. Minimum	Average Monthly		Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	1/day	Estimate
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
Total Residual Chlorine	XXX	XXX	XXX	0.5	XXX	1.0	1/day	Grab

Development of Effluent Limitations

Outfall No. 001 **Design Flow (MGD)** 0
Latitude 39° 55' 28.6" **Longitude** -75° 21' 51.76"

Wastewater Description: Emergency process wastewater discharge from filter backwash tanks, recycled back to the front of WTP and mixes with raw water.

Technology-Based Limitations

The industrial wastewaters discharged through Outfall 001 is generated from Filter backwash. DEP's technical guidance no. 362-2183-003 addresses technology-based control requirements along with the following recommended Best Practicable Control Technology Currently Available (BPT) effluent requirements for WTP sludge and filter backwash:

Parameter	Limit (mg/l)	SBC
Suspended Solids	30	Average Monthly
	60	Daily Maximum
Iron, Total	2.0	Average Monthly
	4.0	Daily Maximum
Aluminum, Total	4.0	Average Monthly
	8.0	Daily Maximum
Manganese, Total	1.0	Average Monthly
	2.0	Daily Maximum
Flow	Monitor	Average Monthly
pH	6.0	Minimum
	9.0	Maximum
Total Residual Chlorine	0.5	Average Monthly
	1.0	Daily Maximum

Water Quality-Based Limitations

WQBELs couldn't be determined due to the absence of flow and sample results. The existing parameters with applicable limits/monitoring requirement will be carried over. The final limit applicable to this outfall is:

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day)		Concentrations (mg/L)				Minimum Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Instant. Minimum	Average Monthly	Daily Maximum	IMAX		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Daily when Discharging	Estimate
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	Daily when Discharging	Grab
Total Residual Chlorine	XXX	XXX	XXX	0.5	1.0	1.2	Daily when Discharging	Grab
Total Suspended Solids	XXX	XXX	XXX	30	60	75	Daily when Discharging	24-Hr Composite
Total Aluminum	XXX	XXX	XXX	1.24	2.48	3.10	Daily when Discharging	24-Hr Composite
Total Iron	XXX	XXX	XXX	2.0	4.0	5.0	Daily when Discharging	24-Hr Composite
Total Manganese	XXX	XXX	XXX	1.0	2.0	2.5	Daily when Discharging	24-Hr Composite
Chlorodibromomethane	XXX	XXX	XXX	XXX	Report	XXX	Daily when Discharging	Grab
Dichlorobromomethane	XXX	XXX	XXX	XXX	Report	XXX	Daily when Discharging	Grab
Chloroform	XXX	XXX	XXX	XXX	Report	XXX	Daily when Discharging	Grab

Development of Effluent Limitations

Outfall No.	002	Design Flow (MGD)	0.555
Latitude	39° 55' 23.35"	Longitude	-75° 21' 53.16"
Wastewater Description: Process wastewater discharge from residuals basin			

Technology-Based Limitations

The industrial wastewaters discharged through Outfall 002 is the process wastewater discharge from residual basin. DEP's technical guidance no. 362-2183-003 addresses technology-based control requirements along with the following recommended Best Practicable Control Technology Currently Available (BPT) effluent requirements for WTP sludge and filter backwash:

Parameter	Limit (mg/l)	SBC
Suspended Solids	30	Average Monthly
	60	Daily Maximum
Iron, Total	2.0	Average Monthly
	4.0	Daily Maximum
Aluminum, Total	4.0	Average Monthly
	8.0	Daily Maximum
Manganese, Total	1.0	Average Monthly
	2.0	Daily Maximum
Flow	Monitor	Average Monthly
pH	6.0	Minimum
	9.0	Maximum
Total Residual Chlorine	0.5	Average Monthly
	1.0	Daily Maximum

Water Quality-Based Limitations

WQBELs couldn't be determined due to the absence of sample results. The existing parameters with applicable limits/monitoring requirement will be carried over. The facility still uses Magnafloc LT340 containing Acrylamide, therefore, existing acrylamide monitoring will be carried over. The final limit applicable to this outfall is:

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day)		Concentrations (mg/L)				Minimum Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Instant. Minimum	Average Monthly	Daily Maximum	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Daily when Discharging	Estimate
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	Daily when Discharging	Grab
Total Residual Chlorine	XXX	XXX	XXX	0.5	1.0	1.2	Daily when Discharging	Grab
Total Suspended Solids	XXX	XXX	XXX	30	60	75	Daily when Discharging	24-Hr Composite
Total Aluminum	XXX	XXX	XXX	4.0	8.0	10.0	Daily when Discharging	24-Hr Composite
Total Iron	XXX	XXX	XXX	2.0	4.0	5.0	Daily when Discharging	24-Hr Composite
Total Manganese	XXX	XXX	XXX	2.0	4.0	5.0	Daily when Discharging	24-Hr Composite
Acrylamide	XXX	XXX	XXX	XXX	Report	XXX	Daily when Discharging	24-Hr Composite
Chlorodibromom ethane	XXX	XXX	XXX	XXX	Report	XXX	Daily when Discharging	Grab
Dichlorobromom ethane	XXX	XXX	XXX	XXX	Report	XXX	Daily when Discharging	Grab
Chloroform	XXX	XXX	XXX	XXX	Report	XXX	Daily when Discharging	Grab
Total Dissolved Solids	XXX	XXX	XXX	XXX	Report	XXX	1/6 months	24-Hr Composite

Development of Effluent Limitations

Outfall No.	003/004	Design Flow (MGD)	0.0
Latitude	39° 55' 30"	Longitude	-75° 21' 55"
Wastewater Description: Emergency wastewater discharge from filter backwash drain (003), Emergency wastewater discharge from two flapper valves for transfer pit overflows (004)			

There was no discharge from Outfall 003 or 004 since 2014. No sample results available to conduct an RP. The existing monitoring requirements will be carried over for both outfalls. The proposed limits are:

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day)		Concentrations (mg/L)				Minimum Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Instant. Minimum	Average Monthly	Daily Maximum	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Hourly when Discharging	Estimate
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	Hourly when Discharging	Grab
Total Residual Chlorine	XXX	XXX	XXX	0.5	1.0	1.2	Hourly when Discharging	Grab
Total Suspended Solids	XXX	XXX	XXX	XXX	Report	XXX	Hourly when Discharging	Grab
Total Aluminum	XXX	XXX	XXX	XXX	Report	XXX	Hourly when Discharging	Grab
Total Iron	XXX	XXX	XXX	XXX	Report	XXX	Hourly when Discharging	Grab
Total Manganese	XXX	XXX	XXX	XXX	Report	XXX	Hourly when Discharging	Grab

Outfalls 006, 007, 008, 009, and 014: There is currently no monitoring requirement for these outfalls. Outfalls 009 and 014 are stormwater only outfalls. Outfall 009 is representative of Outfall 014. A stormwater sample was collected during a storm event on December 10, 2019 that shows Oil and Grease <5 mg/l, BOD5 <2.0 mg/l, COV <25 mg/l, TSS <1 mg/l, Total Nitrogen <1.1 mg/l, Total Phosphorus 0.11 mg/l, and pH of 7.42 S.U. There is no applicable sector specific stormwater monitoring requirement for potable water treatment facilities (related to NAICS 221310), therefore, no monitoring requirement will be placed for any of these outfalls.

Outfall 010 and 011: These outfall discharges raw untreated creek water. There is currently no monitoring requirement applied to these outfalls. There was no discharge from these outfalls since 2014.

Outfall No.	013	Design Flow (MGD)	0.094
Latitude	39° 55' 34.00"	Longitude	75° 22' 0.00"
Wastewater Description: Chlorinated drinking water from traveling screen cleaning operations			

Water Quality-Based Limitations

The following data were used in the attached computer model of the stream:

- Discharge pH 7.57 (median July-Sep, 2021, daily eDMR data)
- Discharge Temperature 69°F (Application data)
- Discharge Hardness 113 mg/l (Application data)
- Stream pH 7.0 (Default)
- Stream Temperature 25°C (Default)
- Stream Hardness 99 mg/l (Application data)

The following two nodes were used in modeling:

Node 1:	Outfall 013 at Crum Creek (00692)
Elevation:	90.08 ft (USGS TNM viewer, 11/19/2021)
Drainage Area:	28.8 mi ² (StreamStat Version 3.0, 11/19/2021)
River Mile Index:	8.0 mile (PA DEP eMapPA)
Low Flow Yield:	0.276 cfs/mi ²

Discharge Flow: 0.094 MGD

Node 2: At the confluence with UNT 00696
 Elevation: 73.04 ft (USGS TNM 2.0 viewer, 11/19/2021)
 Drainage Area: 31.1 mi² (StreamStat Version 3.0, 11/19/2021)
 River Mile Index: 6.51 (PA DEP eMapPA)
 Low Flow Yield: 0.276 cfs/mi²
 Discharge Flow: 0.00 MGD

Toxics

Based on the available data, PADEP utilizes Toxics Management Spreadsheet (TMS) to (1) evaluate reasonable potential for toxic pollutants to cause or contribute to an excursion above the water quality standards and (2) develop WQBELs for those such toxic pollutants (i.e., 40 CFR § 122.44(d)(1)(i)). It is noteworthy that some of these pollutants that may be reported as “non-detect”, but still exceeded the criteria, were determined to be candidates for modeling because the method detection levels used to analyze those pollutants were higher than target QLs and/or the most stringent Chapter 93 criteria. The model then recommended the appropriate action for the Pollutants of Concerns based on the following logic:

1. In general, establish limits in the draft permit where the effluent concentration determined in B.1 or B.2 equals or exceeds 50% of the WQBEL (i.e., RP is demonstrated). Use the average monthly, maximum daily and instantaneous maximum (IMAX) limits for the permit as recommended by the TMS (or, if appropriate, use a multiplier of 2 times the average monthly limit for the maximum daily limit and 2.5 times the average monthly limit for IMAX).
2. For non-conservative pollutants, in general, establish monitoring requirements where the effluent concentration determined in B.1 or B.2 is between 25% - 50% of the WQBEL.
3. For conservative pollutants, in general, establish monitoring requirements where the effluent concentration determined in B.1 or B.2 is between 10% - 50% of the WQBEL.

NOTE 4 – If the effluent concentration determined in B.1 or B.2 is “non-detect” at or below the target quantitation limit (TQL) for the pollutant as specified in the TMS and permit application, the pollutant may be eliminated as a candidate for WQBELs or monitoring requirements unless 1) a more sensitive analytical method is available for the pollutant under 40 CFR Part 136 where the quantitation limit for the method is less than the applicable water quality criterion and 2) a detection at the more sensitive method may lead to a determination that an effluent limitation is necessary, considering available dilution at design conditions.

NOTE 5 – If the effluent concentration determined in B.1 or B.2 is a detection below the TQL but above or equal to the applicable water quality criterion, WQBELs or monitoring may be established for the pollutant.

4. Application managers may, on a site- and pollutant-specific basis, deviate from these guidelines where there is specific rationale that is documented in the fact sheet.

The applicable sample results for Outfall 013 for the pollutants group 1 and 2 were entered into TMS. TMS model resulted in no new limit or monitoring requirements for any input parameter. The final output table is provided below and complete TMS report is provided in the attachment.

Recommended WQBELs & Monitoring Requirements

No. Samples/Month: 4

Pollutants	Mass Limits		Concentration Limits			Units	Governing WQBEL	WQBEL Basis	Comments
	AML (lbs/day)	MDL (lbs/day)	AML	MDL	IMAX				

TRC:

The attached computer printout utilizes the equation and calculations as presented in the Department's 2003 Implementation Guidance for Total Residual Chlorine (TRC) (ID#391-2000-015) for developing chlorine limitations. The attached printout indicates that a water quality limit of 0.5 mg/l would be needed to prevent toxicity concerns at the discharge point for Outfall 013. The Instantaneous Maximum (IMAX) limit is 1.6 mg/l. The existing permit has AML limit of 0.5 mg/l and IMAX limit of 1.0 mg/l. The IMAX is a little more stringent and will be carried over due to anti-backsliding policy.

Additional Considerations

Flow Monitoring

Flow monitoring will remain in the permit and is required by 40 CFR § 122.44(i)(1)(ii).

Anti-Degradation requirements

The effluent limits for this discharge have been developed to ensure the existing in-stream uses and the level of water quality necessary to protect the existing uses are maintained and protected. No High-Quality stream is impacted by this discharge. No Exceptional-Value stream is impacted by this discharge.

Anti-Backsliding Requirements

Unless stated otherwise in this fact sheet, all proposed effluent limits have developed for this permit renewal are at least as stringent as effluent limits developed for the previous permit renewal. Therefore, anti-backsliding provision is not applicable.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Daily Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Daily when Discharging	Estimate
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	Daily when Discharging	Grab
TRC	XXX	XXX	XXX	0.5	1.0	1.2	Daily when Discharging	Grab
TSS	XXX	XXX	XXX	30	60	75	Daily when Discharging	*24-Hr Composite
Total Aluminum	XXX	XXX	XXX	1.24	2.48	3.1	Daily when Discharging	*24-Hr Composite
Total Iron	XXX	XXX	XXX	2.0	4.0	5	Daily when Discharging	*24-Hr Composite
Total Manganese	XXX	XXX	XXX	1.0	2.0	2.5	Daily when Discharging	*24-Hr Composite
Chlorodibromo-methane	XXX	XXX	XXX	XXX	Report	XXX	Daily when Discharging	Grab
Dichlorobromo-methane	XXX	XXX	XXX	XXX	Report	XXX	Daily when Discharging	Grab
Chloroform	XXX	XXX	XXX	XXX	Report	XXX	Daily when Discharging	Grab

*If the discharge is less than 24 hours, one composite sample shall be collected during the period of discharge.

Compliance Sampling Location: At Outfall 001

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 002, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				**Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Daily Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Daily when Discharging	Estimate
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	Daily when Discharging	Grab
TRC	XXX	XXX	XXX	0.5	1.0	1.2	Daily when Discharging	Grab
TSS	XXX	XXX	XXX	30	60	75	Daily when Discharging	24-Hr Composite
Total Dissolved Solids	XXX	XXX	XXX	XXX	Report	XXX	1/6 months	24-Hr Composite
Total Aluminum	XXX	XXX	XXX	4.0	8.0	10	Daily when Discharging	24-Hr Composite
Total Iron	XXX	XXX	XXX	2.0	4.0	5	Daily when Discharging	24-Hr Composite
Total Manganese	XXX	XXX	XXX	2.0	4.0	5	Daily when Discharging	24-Hr Composite
Acrylamide*	XXX	XXX	XXX	XXX	Report	XXX	Daily when Discharging	24-Hr Composite
Chlorodibromo-methane	XXX	XXX	XXX	XXX	Report	XXX	Daily when Discharging	Grab
Dichlorobromo-methane	XXX	XXX	XXX	XXX	Report	XXX	Daily when Discharging	Grab
Chloroform	XXX	XXX	XXX	XXX	Report	XXX	Daily when Discharging	Grab

* Acrylamide shall be sampled using EPA method 8270 with a detection limit of 10 µg/L or any other approved test method with equal or greater sensitivity. See Part C.I.Other Requirement No. H.

** If discharge continues more than 24 hours during any single discharge event, sample shall be taken weekly except for TDS.

Compliance Sampling Location: At Outfall 002

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the “NPDES Permit Writer’s Manual” (362-0400-001), SOPs and/or BPJ.

Outfall 003, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Daily Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Hourly when Discharging	Estimate
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	Hourly when Discharging	Grab
TRC	XXX	XXX	XXX	0.5	1.0	1.2	Hourly when Discharging	Grab
TSS	XXX	XXX	XXX	XXX	Report	XXX	Hourly when Discharging	Grab
Total Aluminum	XXX	XXX	XXX	XXX	Report	XXX	Hourly when Discharging	Grab
Total Iron	XXX	XXX	XXX	XXX	Report	XXX	Hourly when Discharging	Grab
Total Manganese	XXX	XXX	XXX	XXX	Report	XXX	Hourly when Discharging	Grab

Compliance Sampling Location: At Outfall 003

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 004, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Daily Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Hourly when Discharging	Estimate
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	Hourly when Discharging	Grab
TRC	XXX	XXX	XXX	0.5	1.0	1.2	Hourly when Discharging	Grab
TSS	XXX	XXX	XXX	XXX	Report	XXX	Hourly when Discharging	Grab
Total Aluminum	XXX	XXX	XXX	XXX	Report	XXX	Hourly when Discharging	Grab
Total Iron	XXX	XXX	XXX	XXX	Report	XXX	Hourly when Discharging	Grab
Total Manganese	XXX	XXX	XXX	XXX	Report	XXX	Hourly when Discharging	Grab

Compliance Sampling Location: At Outfall 004

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 013, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	1/day	Estimate
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.0	1/day	Grab


Compliance Sampling Location: At Outfall 013

Other Comments:

Tools and References Used to Develop Permit	
<input type="checkbox"/>	WQM for Windows Model (see Attachment [redacted])
<input checked="" type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [redacted])
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 385-2000-011, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 391-2000-006, 9/97.
<input type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 391-2000-023, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97.
<input type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input type="checkbox"/>	SOP: [redacted]
<input type="checkbox"/>	Other: [redacted]

PA0011282 at Outfall 013

Region ID: PA
 Workspace ID: PA20211120000808741000
 Clicked Point (Latitude, Longitude): 39.92608, -75.36670
 Time: 2021-11-19 19:08:32 -0500



Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	28.8	square miles
BSLOPD	Mean basin slope measured in degrees	4.4568	degrees
ROCKDEP	Depth to rock	5	feet
URBAN	Percentage of basin with urban development	39.8305	percent

Low-Flow Statistics Parameters [Low Flow Region 1]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	28.8	square miles	4.78	1150
BSLOPD	Mean Basin Slope degrees	4.4568	degrees	1.7	6.4
ROCKDEP	Depth to Rock	5	feet	4.13	5.21
URBAN	Percent Urban	39.8305	percent	0	89

Low-Flow Statistics Flow Report [Low Flow Region 1]

Pll: Prediction Interval-Lower, Plu: Prediction Interval-Upper, ASEp: Average Standard Error of Prediction, SE: Standard Error (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	13.3	ft ³ /s	46	46
30 Day 2 Year Low Flow	16.6	ft ³ /s	38	38
7 Day 10 Year Low Flow	7.93	ft ³ /s	51	51
30 Day 10 Year Low Flow	9.86	ft ³ /s	46	46
90 Day 10 Year Low Flow	14.1	ft ³ /s	41	41

Low-Flow Statistics Citations

Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

PA0011282 at node 2 for Outfall 013

Region ID: PA
 Workspace ID: PA20211120001133960000
 Clicked Point (Latitude, Longitude): 39.91377, -75.35816
 Time: 2021-11-19 19:11:54 -0500



Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	31.1	square miles
BSLOPD	Mean basin slope measured in degrees	4.5261	degrees
ROCKDEP	Depth to rock	5	feet
URBAN	Percentage of basin with urban development	42.5027	percent

Low-Flow Statistics Parameters [Low Flow Region 1]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	31.1	square miles	4.78	1150
BSLOPD	Mean Basin Slope degrees	4.5261	degrees	1.7	6.4
ROCKDEP	Depth to Rock	5	feet	4.13	5.21
URBAN	Percent Urban	42.5027	percent	0	89

Low-Flow Statistics Flow Report [Low Flow Region 1]

Pll: Prediction Interval-Lower, Plu: Prediction Interval-Upper, ASEp: Average Standard Error of Prediction, SE: Standard Error (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	15.2	ft ³ /s	46	46
30 Day 2 Year Low Flow	18.9	ft ³ /s	38	38
7 Day 10 Year Low Flow	9.25	ft ³ /s	51	51
30 Day 10 Year Low Flow	11.4	ft ³ /s	46	46
90 Day 10 Year Low Flow	16.2	ft ³ /s	41	41

Low-Flow Statistics Citations

Stuckey, M.H.,2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

TRC_CALC

TRC EVALUATION					
Input appropriate values in A3:A9 and D3:D9					
7.99	= Q stream (cfs)		0.5	= CV Daily	
0.094	= Q discharge (MGD)		0.5	= CV Hourly	
30	= no. samples		1	= AFC_Partial Mix Factor	
0.3	= Chlorine Demand of Stream		1	= CFC_Partial Mix Factor	
0	= Chlorine Demand of Discharge		15	= AFC_Criteria Compliance Time (min)	
0.5	= BAT/BPJ Value		720	= CFC_Criteria Compliance Time (min)	
0	= % Factor of Safety (FOS)			= Decay Coefficient (K)	
Source	Reference	AFC Calculations		Reference	CFC Calculations
TRC	1.3.2.iii	WLA_afc = 17.546		1.3.2.iii	WLA_cfc = 17.099
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373		5.1c	LTAMULT_cfc = 0.581
PENTOXSD TRG	5.1b	LTA_afc = 6.538		5.1d	LTA_cfc = 9.941
Source	Effluent Limit Calculations				
PENTOXSD TRG	5.1f	AML_MULT = 1.231			
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.500		BAT/BPJ	
		INST MAX LIMIT (mg/l) = 1.635			
WLA_afc	$(.019/e^{-k \cdot AFC_tc}) + [(AFC_Yc \cdot Qs \cdot .019 / Qd \cdot e^{-k \cdot AFC_tc}) \dots + Xd + (AFC_Yc \cdot Qs \cdot Xs / Qd)]^{(1-FOS/100)}$				
LTAMULT_afc	$EXP((0.5 \cdot LN(cvh^2 + 1)) - 2.326 \cdot LN(cvh^2 + 1)^{0.5})$				
LTA_afc	wla_afc * LTAMULT_afc				
WLA_cfc	$(.011/e^{-k \cdot CFC_tc}) + [(CFC_Yc \cdot Qs \cdot .011 / Qd \cdot e^{-k \cdot CFC_tc}) \dots + Xd + (CFC_Yc \cdot Qs \cdot Xs / Qd)]^{(1-FOS/100)}$				
LTAMULT_cfc	$EXP((0.5 \cdot LN(cvd^2 / no_samples + 1)) - 2.326 \cdot LN(cvd^2 / no_samples + 1)^{0.5})$				
LTA_cfc	wla_cfc * LTAMULT_cfc				
AML_MULT	$EXP(2.326 \cdot LN((cvd^2 / no_samples + 1)^{0.5}) - 0.5 \cdot LN(cvd^2 / no_samples + 1))$				
AVG MON LIMIT	MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc) * AML_MULT)				
INST MAX LIMIT	1.5 * (av_mon_limit / AML_MULT) / LTAMULT_afc				



Toxics Management Spreadsheet
 Version 1.3, March 2021

Discharge Information

Instructions Discharge Stream

Facility: Aqua Pennsylvania Crum creek WTP NPDES Permit No.: PA0011282 Outfall No.: 013
 Evaluation Type: Major Sewage / Industrial Waste Wastewater Description: Chlorinated drinking water

Discharge Characteristics								
Design Flow (MGD)*	Hardness (mg/l)*	pH (SU)*	Partial Mix Factors (PMFs)				Complete Mix Times (min)	
			AFC	CFC	THH	CRL	Q ₇₋₁₀	Q _h
0.004	113	7.57						

Discharge Pollutant	Units	Max Discharge Conc	0 if left blank		0.5 if left blank		0 if left blank			1 if left blank		
			Trib Conc	Stream Conc	Daily CV	Hourly CV	Stream CV	Fate Coeff	FOS	Criteria Mod	Chem Transl	
Group 1	Total Dissolved Solids (PWS)	mg/L	284									
	Chloride (PWS)	mg/L	71									
	Bromide	mg/L	< 0.2									
	Sulfate (PWS)	mg/L	12									
	Fluoride (PWS)	mg/L	0.2									
Group 2	Total Aluminum	µg/L	30									
	Total Antimony	µg/L	< 0.3									
	Total Arsenic	µg/L	< 1									
	Total Barium	µg/L	78									
	Total Beryllium	µg/L	< 1									
	Total Boron	µg/L	< 200									
	Total Cadmium	µg/L	< 0.2									
	Total Chromium (III)	µg/L										
	Hexavalent Chromium	µg/L	0.47									
	Total Cobalt	µg/L	< 1									
	Total Copper	µg/L	2									
	Free Cyanide	µg/L										
	Total Cyanide	µg/L	11									
	Dissolved Iron	µg/L	< 20									
	Total Iron	µg/L	30									
	Total Lead	µg/L	< 1									
	Total Manganese	µg/L	55									
	Total Mercury	µg/L	< 0.2									
	Total Nickel	µg/L	< 1									
	Total Phenols (Phenolics) (PWS)	µg/L	13									
	Total Selenium	µg/L	< 1									
	Total Silver	µg/L	< 0.2									
	Total Thallium	µg/L	< 1									
Total Zinc	µg/L	78										
Total Molybdenum	µg/L	< 1										
Acrolein	µg/L	<										
Acrylamide	µg/L	<										
Acrylonitrile	µg/L	<										
Benzene	µg/L	<										
Bromoform	µg/L	<										



Stream / Surface Water Information

Aqua Pennsylvania Crum creek WTP, NPDES Permit No. PA0011282, Outfall 013

Instructions Discharge **Stream**

Receiving Surface Water Name: Crum Creek

No. Reaches to Model: 1

- Statewide Criteria
- Great Lakes Criteria
- ORSANCO Criteria

Location	Stream Code*	RMI*	Elevation (ft)*	DA (mi ²)*	Slope (ft/ft)	PWS Withdrawal (MGD)	Apply Fish Criteria*
Point of Discharge	000892	8	90.08	28.8			Yes
End of Reach 1	000892	6.51	73.04	31.1			Yes

Q₇₋₁₀

Location	RMI	LFY (cfs/mi ²)*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness*	pH*	Hardness	pH
Point of Discharge	8	0.276										99	7		
End of Reach 1	6.51	0.276													

Q_h

Location	RMI	LFY (cfs/mi ²)*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness*	pH*	Hardness	pH
Point of Discharge	8														
End of Reach 1	6.51														



Model Results

Aqua Pennsylvania Crum creek WTP, NPDES Permit No. PA0011282, Outfall 013

Instructions

Results

RETURN TO INPUTS

SAVE AS PDF

PRINT

All

Inputs

Results

Limits

Hydrodynamics

Wasteload Allocations

AFC

CCT (min):

PMF:

Analysis Hardness (mg/l):

Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Fluoride (PWS)	0	0		0	N/A	N/A	N/A	
Total Aluminum	0	0		0	750	750	19,995	
Total Antimony	0	0		0	1,100	1,100	29,325	
Total Arsenic	0	0		0	340	340	9,064	Chem Translator of 1 applied
Total Barium	0	0		0	21,000	21,000	559,848	
Total Boron	0	0		0	8,100	8,100	215,941	
Total Cadmium	0	0		0	2.004	2.12	56.6	Chem Translator of 0.944 applied
Hexavalent Chromium	0	0		0	16	16.3	434	Chem Translator of 0.982 applied
Total Cobalt	0	0		0	95	95.0	2,533	
Total Copper	0	0		0	13.379	13.9	372	Chem Translator of 0.96 applied
Dissolved Iron	0	0		0	N/A	N/A	N/A	
Total Iron	0	0		0	N/A	N/A	N/A	
Total Lead	0	0		0	64.248	81.2	2,163	Chem Translator of 0.792 applied
Total Manganese	0	0		0	N/A	N/A	N/A	
Total Mercury	0	0		0	1.400	1.85	43.9	Chem Translator of 0.85 applied
Total Nickel	0	0		0	466.354	467	12,458	Chem Translator of 0.998 applied
Total Phenols (Phenolics) (PWS)	0	0		0	N/A	N/A	N/A	
Total Selenium	0	0		0	N/A	N/A	N/A	Chem Translator of 0.922 applied
Total Silver	0	0		0	3.191	3.75	100	Chem Translator of 0.85 applied
Total Thallium	0	0		0	65	65.0	1,733	
Total Zinc	0	0		0	116.709	119	3,181	Chem Translator of 0.978 applied

CFC

CCT (min):

PMF:

Analysis Hardness (mg/l):

Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Fluoride (PWS)	0	0		0	N/A	N/A	N/A	
Total Aluminum	0	0		0	N/A	N/A	N/A	
Total Antimony	0	0		0	220	220	12,246	
Total Arsenic	0	0		0	150	150	8,349	Chem Translator of 1 applied
Total Barium	0	0		0	4,100	4,100	228,213	
Total Boron	0	0		0	1,800	1,800	89,059	
Total Cadmium	0	0		0	0.245	0.27	15.0	Chem Translator of 0.909 applied
Hexavalent Chromium	0	0		0	10	10.4	579	Chem Translator of 0.962 applied
Total Cobalt	0	0		0	19	19.0	1,058	
Total Copper	0	0		0	8.898	9.27	516	Chem Translator of 0.96 applied
Dissolved Iron	0	0		0	N/A	N/A	N/A	
Total Iron	0	0		0	1,500	1,500	83,493	WQC = 30 day average; PMF = 1
Total Lead	0	0		0	2.496	3.15	175	Chem Translator of 0.792 applied
Total Manganese	0	0		0	N/A	N/A	N/A	
Total Mercury	0	0		0	0.770	0.91	50.4	Chem Translator of 0.85 applied
Total Nickel	0	0		0	51.877	51.8	2,885	Chem Translator of 0.997 applied
Total Phenols (Phenolics) (PWS)	0	0		0	N/A	N/A	N/A	
Total Selenium	0	0		0	4.800	4.99	278	Chem Translator of 0.922 applied
Total Silver	0	0		0	N/A	N/A	N/A	Chem Translator of 1 applied
Total Thallium	0	0		0	13	13.0	724	
Total Zinc	0	0		0	117.389	119	6,827	Chem Translator of 0.986 applied

THH CCT (min): PMF: Analysis Hardness (mg/l): Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	500,000	500,000	N/A	
Chloride (PWS)	0	0		0	250,000	250,000	N/A	
Sulfate (PWS)	0	0		0	250,000	250,000	N/A	
Fluoride (PWS)	0	0		0	2,000	2,000	N/A	
Total Aluminum	0	0		0	N/A	N/A	N/A	
Total Antimony	0	0		0	5.6	5.6	312	
Total Arsenic	0	0		0	10	10.0	557	
Total Barium	0	0		0	2,400	2,400	133,588	
Total Boron	0	0		0	3,100	3,100	172,551	
Total Cadmium	0	0		0	N/A	N/A	N/A	
Hexavalent Chromium	0	0		0	N/A	N/A	N/A	
Total Cobalt	0	0		0	N/A	N/A	N/A	
Total Copper	0	0		0	N/A	N/A	N/A	

Dissolved Iron	0	0		0	300	300	16,699	
Total Iron	0	0		0	N/A	N/A	N/A	
Total Lead	0	0		0	N/A	N/A	N/A	
Total Manganese	0	0		0	1,000	1,000	55,662	
Total Mercury	0	0		0	0.050	0.05	2.78	
Total Nickel	0	0		0	610	610	33,954	
Total Phenols (Phenolics) (PWS)	0	0		0	5	5.0	N/A	
Total Selenium	0	0		0	N/A	N/A	N/A	
Total Silver	0	0		0	N/A	N/A	N/A	
Total Thallium	0	0		0	0.24	0.24	13.4	
Total Zinc	0	0		0	N/A	N/A	N/A	

CRL CCT (min): PMF: Analysis Hardness (mg/l): Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Fluoride (PWS)	0	0		0	N/A	N/A	N/A	
Total Aluminum	0	0		0	N/A	N/A	N/A	
Total Antimony	0	0		0	N/A	N/A	N/A	
Total Arsenic	0	0		0	N/A	N/A	N/A	
Total Barium	0	0		0	N/A	N/A	N/A	
Total Boron	0	0		0	N/A	N/A	N/A	
Total Cadmium	0	0		0	N/A	N/A	N/A	
Hexavalent Chromium	0	0		0	N/A	N/A	N/A	
Total Cobalt	0	0		0	N/A	N/A	N/A	
Total Copper	0	0		0	N/A	N/A	N/A	
Dissolved Iron	0	0		0	N/A	N/A	N/A	
Total Iron	0	0		0	N/A	N/A	N/A	
Total Lead	0	0		0	N/A	N/A	N/A	
Total Manganese	0	0		0	N/A	N/A	N/A	
Total Mercury	0	0		0	N/A	N/A	N/A	
Total Nickel	0	0		0	N/A	N/A	N/A	
Total Phenols (Phenolics) (PWS)	0	0		0	N/A	N/A	N/A	
Total Selenium	0	0		0	N/A	N/A	N/A	
Total Silver	0	0		0	N/A	N/A	N/A	
Total Thallium	0	0		0	N/A	N/A	N/A	
Total Zinc	0	0		0	N/A	N/A	N/A	

Recommended WQBELs & Monitoring Requirements

No. Samples/Month:

Pollutants	Mass Limits		Concentration Limits			Units	Governing WQBEL	WQBEL Basis	Comments
	AML (lbs/day)	MDL (lbs/day)	AML	MDL	IMAX				

Other Pollutants without Limits or Monitoring

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., <= Target QL).

Pollutants	Governing WQBEL	Units	Comments
Total Dissolved Solids (PWS)	N/A	N/A	PWS Not Applicable
Chloride (PWS)	N/A	N/A	PWS Not Applicable
Bromide	N/A	N/A	No WQS
Sulfate (PWS)	N/A	N/A	PWS Not Applicable
Fluoride (PWS)	N/A	N/A	PWS Not Applicable
Total Aluminum	12,816	µg/L	Discharge Conc ≤ 10% WQBEL
Total Antimony	N/A	N/A	Discharge Conc < TQL
Total Arsenic	N/A	N/A	Discharge Conc < TQL
Total Barium	133,588	µg/L	Discharge Conc ≤ 10% WQBEL
Total Beryllium	N/A	N/A	No WQS
Total Boron	89,059	µg/L	Discharge Conc < TQL
Total Cadmium	15.0	µg/L	Discharge Conc < TQL
Hexavalent Chromium	278	µg/L	Discharge Conc ≤ 10% WQBEL
Total Cobalt	1,058	µg/L	Discharge Conc < TQL
Total Copper	238	µg/L	Discharge Conc ≤ 10% WQBEL
Total Cyanide	N/A	N/A	No WQS
Dissolved Iron	16,699	µg/L	Discharge Conc < TQL
Total Iron	83,493	µg/L	Discharge Conc ≤ 10% WQBEL
Total Lead	175	µg/L	Discharge Conc < TQL
Total Manganese	55,662	µg/L	Discharge Conc ≤ 10% WQBEL
Total Mercury	2.78	µg/L	Discharge Conc < TQL
Total Nickel	2,885	µg/L	Discharge Conc < TQL
Total Phenols (Phenolics) (PWS)		µg/L	PWS Not Applicable
Total Selenium	278	µg/L	Discharge Conc < TQL
Total Silver	64.1	µg/L	Discharge Conc < TQL
Total Thallium	13.4	µg/L	Discharge Conc < TQL
Total Zinc	2,039	µg/L	Discharge Conc ≤ 10% WQBEL
Total Molybdenum	N/A	N/A	No WQS