



Application Type
Facility Type
Major / Minor

Renewal
Industrial
Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL INDUSTRIAL WASTE (IW)
AND IW STORMWATER**

Application No. **PA0014427**
APS ID **1098226**
Authorization ID **1457244**

Applicant and Facility Information

Applicant Name	<u>US Fish and Wildlife Service</u>	Facility Name	<u>Allegheny National Fish Hatchery</u>
Applicant Address	<u>6616 Hemlock Road</u>	Facility Address	<u>6616 Hemlock Road</u>
	<u>Warren, PA 16365-8055</u>		<u>Warren, PA 16365-8055</u>
Applicant Contact	<u>Lawrence Miller</u>	Facility Contact	<u>Lawrence Miller</u>
Applicant Phone	<u>(814) 726-0890</u>	Facility Phone	<u>814-726-0890</u>
Client ID	<u>288650</u>	Site ID	<u>257901</u>
SIC Code	<u>0921</u>	Municipality	<u>Glade Township</u>
SIC Description	<u>Agriculture - Fish Hatcheries And Preserves</u>	County	<u>Warren</u>
Date Application Received	<u>September 29, 2023</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted		If No, Reason	
Purpose of Application	<u>Renewal of an NPDES permit for existing discharges of industrial waste.</u>		

Summary of Review

The plant discharges to the Allegheny River which is known to contain threatened and endangered mussel species. A summary of threatened and endangered mussel species concerns and considerations is included on page 9 of this Fact Sheet. Additionally, the draft permit will be forwarded to the PA Fish & Boat Commission.

There are currently no open violations for this client as of 5/9/2025

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		Jordan A. Frey, E.I.T. Jordan A. Frey, E.I.T. / Project Manager	May 9, 2025
X		Adam Olesnanik Adam Olesnanik, P.E. / Environmental Engineer Manager	May 13, 2025

Discharge, Receiving Waters and Water Supply Information

Outfall No.	001	Design Flow (MGD)	.76
Latitude	41° 50' 20.00"	Longitude	-79° 0' 16.78"
Quad Name	Clarendon	Quad Code	41079G1
Wastewater Description: Discharges from settling pond, hatchery, raceways, and stormwater			
Receiving Waters	Allegheny River (WWF)	Stream Code	42122
NHD Com ID	112373893	RMI	198.284
Drainage Area	2180	Yield (cfs/mi ²)	0.08
Q ₇₋₁₀ Flow (cfs)	174.4	Q ₇₋₁₀ Basis	Streamstats
Elevation (ft)	1200	Slope (ft/ft)	
Watershed No.	16-B	Chapter 93 Class.	WWF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Impaired		
Cause(s) of Impairment	MERCURY		
Source(s) of Impairment	SOURCE UNKNOWN		
TMDL Status		Name	
Background/Ambient Data			
pH (SU)	7.0	Data Source	
Temperature (°F)	25	Default	
Hardness (mg/L)	100	Default WWF	
Other:		Default	
Nearest Downstream Public Water Supply Intake			
PWS Waters	Allegheny River	Flow at Intake (cfs)	1376
PWS RMI	90.0	Distance from Outfall (mi)	25

Changes Since Last Permit Issuance: None.

Other Comments:

NPDES Permit Fact Sheet
Allegheny National Fish Hatchery

NPDES Permit No. PA0014427

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	002	Design Flow (MGD)	4.75
Latitude	41° 50' 19.14"	Longitude	-79° 0' 15.13"
Quad Name	Clarendon	Quad Code	41079G1
Wastewater Description:	Cold water fish culture wastewater		
Receiving Waters	Allegheny River (WWF)	Stream Code	42122
NHD Com ID	112373899	RMI	198.28
Drainage Area	2180	Yield (cfs/mi ²)	0.08
Q ₇₋₁₀ Flow (cfs)	174.4	Q ₇₋₁₀ Basis	Streamstats
Elevation (ft)	1200	Slope (ft/ft)	--
Watershed No.	16-B	Chapter 93 Class.	WWF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Impaired		
Cause(s) of Impairment	MERCURY		
Source(s) of Impairment	SOURCE UNKNOWN		
TMDL Status		Name	
Background/Ambient Data			
pH (SU)	7.0	Data Source	Default
Temperature (°F)	25		Default WWF
Hardness (mg/L)	100		Default
Other:			
Nearest Downstream Public Water Supply Intake			
PWS Waters	Allegheny River	Flow at Intake (cfs)	1376
PWS RMI	90.0	Distance from Outfall (mi)	>25

Changes Since Last Permit Issuance: None.

Other Comments:

NPDES Permit Fact Sheet
Allegheny National Fish Hatchery

NPDES Permit No. PA0014427

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	003	Design Flow (MGD)	.29
Latitude	41° 50' 22.23"	Longitude	-79° 0' 19.09"
Quad Name	Clarendon	Quad Code	41079G1
Wastewater Description:	Condensate Discharge, Groundwater / Spring Discharge		
Receiving Waters	Allegheny River (WWF)	Stream Code	42122
NHD Com ID	112373893	RMI	198.32
Drainage Area	2180	Yield (cfs/mi ²)	0.08
Q ₇₋₁₀ Flow (cfs)	174.4	Q ₇₋₁₀ Basis	Streamstats
Elevation (ft)	1200	Slope (ft/ft)	---
Watershed No.	16-B	Chapter 93 Class.	WWF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Impaired		
Cause(s) of Impairment	MERCURY		
Source(s) of Impairment	SOURCE UNKNOWN		
TMDL Status		Name	
Background/Ambient Data			
pH (SU)	7.0	Data Source	Default
Temperature (°F)	25		Default WWF
Hardness (mg/L)	100		Default
Other:			
Nearest Downstream Public Water Supply Intake			
PWS Waters	Allegheny River	Flow at Intake (cfs)	1376
PWS RMI	90.0	Distance from Outfall (mi)	>25

Changes Since Last Permit Issuance: None

Other Comments:

Treatment Facility Summary				
Treatment Facility Name: Allegheny National Fish Hatchery				
WQM Permit No.	Issuance Date			
6274202	8/3/2011			
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Industrial	Primary	Settling Ponds	No Disinfection	
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
		Not Overloaded		

Changes Since Last Permit Issuance: None

Other Comments: Treatment consists of one settling pond with a capacity of 164,000 gallons

Development of Effluent Limitations

Outfall No. 001
Latitude 41° 50' 21.00"
Wastewater Description: Other Miscellaneous Discharges

Design Flow (MGD) .76
Longitude -79° 0' 16.00"

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Parameter	Limit (mg/l)	SBC	Federal Regulation	State Regulation
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)

Comments: None.

Water Quality-Based Limitations

The following limitations were determined through water quality modeling (output files attached):

Parameter	Limit (mg/l)	SBC	Model
Ammonia	25	Average Monthly	WQM 7.0b

Comments: See section on Anti-Backsliding

Best Professional Judgment (BPJ) Limitations

Comments: In accordance with the Department's SOP entitled "Establishing Effluent Limitations for Individual Industrial Permits," effluent limits or monitoring requirements found in the PAG-11 NPDES General Permit pertaining to aquaculture facilities were incorporated into this permit.

These parameters include ammonia nitrogen, total nitrogen, total phosphorus and dissolved oxygen. Net limits for CBOD₅, TSS and total nitrogen from in the general permit were converted to effluent limits due to the source water not originating from the same watercourse as the discharge was to (40 CFR § 122.45 (g)). In conjunction with that decision, influent monitoring requirements found in the general permit were not placed in the permit. A seasonal multiplier for winter ammonia is not needed because this facility can easily meet the summertime criteria year-round.

Monitoring for the following parameters is being added in accordance with the SOP, based on Chapter 92a.61:

PFOA (ng/L)
PFOS (ng/L)
PFBS (ng/L)
HFPO-DA (ng/L)

Anti-Backsliding

WQM 7.0 modeling determined an Ammonia limit of 25.0 mg/l to be protective, but the previous permit's limits shall be kept in place in accordance with the Department's Anti-Backsliding policy.

The average monthly and IMAX effluent limits for CBOD₅ (BOD₅) and TSS are existing effluent limits, based on BPJ, that were retained in the previous renewed permit due to anti-backsliding provisions. The CBOD₅ limits were converted to BOD₅ limits to be consistent with other state fish hatchery permits issued in the Northwest Region at that time and by also acknowledging that the concentration of CBOD₅ and BOD₅ should be practically the same at concentrations below 10 mg/l.

Development of Effluent Limitations

Outfall No. 002
Latitude 41° 50' 27.75"

Design Flow (MGD) 4.75
Longitude -79° 0' 22.67"

Wastewater Description: Other Miscellaneous Discharges

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Parameter	Limit (mg/l)	SBC	Federal Regulation	State Regulation
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)

Comments: None.

Water Quality-Based Limitations

The following limitations were determined through water quality modeling (output files attached):

Parameter	Limit (mg/l)	SBC	Model
Ammonia	25	Average Monthly	WQM 7.0b

Comments: See section on Anti-Backsliding

Best Professional Judgment (BPJ) Limitations

Comments: In accordance with the Department's SOP entitled "Establishing Effluent Limitations for Individual Industrial Permits," effluent limits or monitoring requirements found in the PAG-11 NPDES General Permit pertaining to aquaculture facilities were incorporated into this permit.

These parameters include ammonia nitrogen, total nitrogen, total phosphorus and dissolved oxygen. Net limits for CBOD₅, TSS and total nitrogen from in the general permit were converted to effluent limits due to the source water not originating from the same watercourse as the discharge was to (40 CFR § 122.45 (g)). In conjunction with that decision, influent monitoring requirements found in the general permit were not placed in the permit. A seasonal multiplier for winter ammonia is not needed because this facility can easily meet the summertime criteria year-round.

Monitoring for the following parameters is being added in accordance with the SOP, based on Chapter 92a.61:

PFOA (ng/L)
PFOS (ng/L)
PFBS (ng/L)
HFPO-DA (ng/L)

Anti-Backsliding

WQM 7.0 modeling determined an Ammonia limit of 25.0 mg/l to be protective, but the previous permit's limits shall be kept in place in accordance with the Department's Anit-Backsliding policy.

The average monthly and IMAX effluent limits for CBOD₅ (BOD₅) and TSS are existing effluent limits, based on BPJ, that were retained in the previous renewed permit due to anti-backsliding provisions. The CBOD₅ limits were converted to BOD₅ limits to be consistent with other state fish hatchery permits issued in the Northwest Region at that time and by also acknowledging that the concentration of CBOD₅ and BOD₅ should be practically the same at concentrations below 10 mg/l.

Development of Effluent Limitations

Outfall No. 003
Latitude 41° 50' 24.90"

Design Flow (MGD) .29
Longitude -79° 0' 17.90"

Wastewater Description: Condensate Discharge, Groundwater / Spring Discharge

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Parameter	Limit (mg/l)	SBC	Federal Regulation	State Regulation
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)

Comments: None

Best Professional Judgment (BPJ) Limitations

Comments: None.

Anti-Backsliding

WQM 7.0 modeling determined an Ammonia limit of 25.0 mg/l, a BOD5 limit of 25 mg/l, and a Dissolved Oxygen limit of 3.0 mg/l to be protective, but the previous permit's limits shall be kept in place in accordance with the Department's Anti-Backsliding policy. These limits are 15.0 mg/l for Ammonia, 10.0 mg/l for BOD5, and 6.0 mg/l for Dissolved Oxygen.

Threatened and Endangered Mussel Species Concerns and Considerations

The Allegheny River is known to contain state and federally listed threatened and endangered mussel species. Due to this being a direct discharge to the Allegheny River, potential impacts to endangered and threatened species were evaluated.

The USFWS has indicated in comment letters on other NPDES permits that in order to protect threatened and endangered mussel species, wastewater discharges containing ammonia-nitrogen ($\text{NH}_3\text{-N}$), chloride (Cl^-), copper, zinc and nickel, where mussels or their habitat exist, can be no more than 1.9 mg/l, 78 mg/l, 10.0 $\mu\text{g/l}$, 13.18 $\mu\text{g/l}$ and 7.3 $\mu\text{g/l}$, respectively.

There have been no known populations of state and federally listed threatened and endangered mussel species found in the Allegheny River between to outlet of the Kinzua Dam and the confluence with the Conewango Creek, which lies approximately six miles downstream of the fish hatchery outfalls, from the various mussel surveys that have been conducted in that reach, including the September 2012 Federal Energy Regulatory Commission (FERC) Mussel Survey conducted by Aquatic Systems Corporation.

Based on the known presence of chloride in the permit application's Analysis Results Table (at maximum reported values of 14.8 mg/l for both Outfall 001 & 002) and the presence of chloride in certain listed chemical additives, quarterly monitoring for chloride shall be imposed. But as there are no known or foreseeable sources of copper, zinc, or nickel present in the fish hatchery's operations, no monitoring for these parameters shall be imposed at this time.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Quarterly	Daily Maximum	Instant. Maximum		
Flow (MGD)	Report	XXX	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0 Daily Min	XXX	9.0	XXX	1/week	Grab
DO	XXX	XXX	6.0 Daily Min	XXX	XXX	XXX	1/week	Grab
BOD ₅	XXX	XXX	XXX	10.0	10.0	25	1/quarter	8-Hr Composite
TSS	XXX	XXX	XXX	10.0	20.0	25	1/quarter	8-Hr Composite
Total Nitrogen	XXX	XXX	XXX	XXX	20.0	XXX	1/quarter	8-Hr Composite
Ammonia	81 Avg Qrtly	XXX	XXX	15.0	XXX	30	1/quarter	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	XXX	Report	XXX	1/quarter	8-Hr Composite
Chloride	XXX	XXX	XXX	Report	XXX	XXX	1/quarter	Grab
PFOA (ng/L)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
PFOS (ng/L)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
PFBS (ng/L)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
HFPO-DA (ng/L)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab

Compliance Sampling Location: Outfall 001, prior to mixing with any other waters.

Other Comments: Monitoring frequencies for flow, dissolved oxygen, pH, BOD₅, TSS, ammonia nitrogen, total nitrogen, and total phosphorus were set referencing the PAG-11 NPDES General Permit.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 002, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Quarterly	Daily Maximum	Instant. Maximum		
Flow (MGD)	Report	XXX	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0 Daily Min	XXX	9.0	XXX	1/week	Grab
DO	XXX	XXX	6.0 Daily Min	XXX	XXX	XXX	1/week	Grab
BOD ₅	XXX	XXX	XXX	10.0	10.0	25	1/quarter	8-Hr Composite
TSS	XXX	XXX	XXX	10.0	20.0	25	1/quarter	8-Hr Composite
Total Nitrogen	XXX	XXX	XXX	XXX	20.0	XXX	1/quarter	8-Hr Composite
Ammonia	81 Avg Qrtly	XXX	XXX	15.0	XXX	30	1/quarter	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	XXX	Report	XXX	1/quarter	8-Hr Composite
Chloride	XXX	XXX	XXX	Report	XXX	XXX	1/quarter	Grab
PFOA (ng/L)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
PFOS (ng/L)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
PFBS (ng/L)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
HFPO-DA (ng/L)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab

Compliance Sampling Location: Outfall 002, prior to mixing with any other waters.

Other Comments: Monitoring frequencies for flow, dissolved oxygen, pH, BOD₅, TSS, ammonia nitrogen, total nitrogen, and total phosphorus were set referencing the PAG-11 NPDES General Permit.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 003, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	XXX	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0 Daily Min	XXX	9.0 Daily Max	XXX	1/week	Grab

Compliance Sampling Location: Outfall 003, prior to mixing with any other waters.

Other Comments: None.

WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>	
18A	42122	ALLEGHENY RIVER	
<u>RMI</u> 198.280	<u>Total Discharge Flow (mgd)</u> 5.510	<u>Analysis Temperature (°C)</u> 25.000	<u>Analysis pH</u> 7.000
<u>Reach Width (ft)</u> 248.284	<u>Reach Depth (ft)</u> 1.183	<u>Reach WDRatio</u> 209.931	<u>Reach Velocity (fps)</u> 0.623
<u>Reach CBOD5 (mg/L)</u> 2.37	<u>Reach Kc (1/days)</u> 0.194	<u>Reach NH3-N (mg/L)</u> 1.16	<u>Reach Kn (1/days)</u> 1.029
<u>Reach DO (mg/L)</u> 8.138	<u>Reach Kr (1/days)</u> 1.950	<u>Kr Equation</u> Tsivoglou	<u>Reach DO Goal (mg/L)</u> 5
<u>Reach Travel Time (days)</u> 0.561	<u>Subreach Results</u>		
	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)
		0.056	2.34
		0.112	2.31
		0.168	2.28
		0.224	2.25
		0.281	2.22
		0.337	2.19
		0.393	2.16
		0.449	2.13
		0.505	2.10
		0.561	2.07
			D.O. (mg/L)
			1.10
			7.54
			1.04
			7.36
			0.98
			7.19
			0.92
			7.04
			0.87
			6.93
			0.82
			6.83
			0.78
			6.76
			0.73
			6.71
			0.69
			6.68

WQM 7.0 Effluent Limits

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>					
18A	42122	ALLEGHENY RIVER					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
198.280	Allegheny Nat'l	PA0014427	5.510	CBOD5	10		
				NH3-N	25	50	
				Dissolved Oxygen			6

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name			RMI	Elevation	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC		
18A	42122	ALLEGHENY RIVER			198.280	1200.00	2180.00	0.00000	0.00	<input checked="" type="checkbox"/>		
Stream Data												
Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream pH		
Q7-10	0.080	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.00		
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							
Discharge Data												
	Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH				
	Allegheny Nat'l	PA0014427	5.5100	0.0000	0.0000	0.000	25.00	7.00				
Parameter Data												
	Parameter Name		Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)						
	CBOD5		10.00	2.00	0.00	1.50						
	Dissolved Oxygen		6.00	8.24	0.00	0.00						
	NH3-N		25.00	0.00	0.00	0.70						

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
18A	42122	ALLEGHENY RIVER	192.560	1182.00	2220.00	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream pH	Temp (°C)	Stream pH
	(cfsm)	(cfs)	(cfs)									
Q7-10	0.080	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data								
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH	
Allegheny River	PA0014427	0.3100	0.0000	0.0000	0.000	25.00	7.00	
Parameter Data								
Parameter Name		Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)			
CBOD5		25.00	2.00	0.00	1.50			
Dissolved Oxygen		4.00	8.24	0.00	0.00			
NH3-N		25.00	0.00	0.00	0.70			

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>								
18A		42122		ALLEGHENY RIVER								
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
Q7-10 Flow												
198.280	174.40	0.00	174.40	8.524	0.00060	1.183	248.28	209.93	0.62	0.561	25.00	7.00
Q1-10 Flow												
198.280	111.62	0.00	111.62	8.524	0.00060	NA	NA	NA	0.49	0.710	25.00	7.00
Q30-10 Flow												
198.280	237.18	0.00	237.18	8.524	0.00060	NA	NA	NA	0.73	0.476	25.00	7.00

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>							
18A	42122	ALLEGHENY RIVER							
NH3-N Acute Allocations									
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction		
198.280	Allegheny Nat'l	6.76	50	6.76	50	0	0		
NH3-N Chronic Allocations									
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction		
198.280	Allegheny Nat'l	1.34	25	1.34	25	0	0		
Dissolved Oxygen Allocations									
RMI	Discharge Name	CBOD5 Baseline (mg/L)	CBOD5 Multiple (mg/L)	NH3-N Baseline (mg/L)	NH3-N Multiple (mg/L)	Dissolved Oxygen Baseline (mg/L)	Dissolved Oxygen Multiple (mg/L)	Critical Reach	Percent Reduction
198.28	Allegheny Nat'l	10	10	25	25	6	6	0	0



Discharge Information

Instructions Discharge Stream

Facility: Allegheny National Fish Hatchery NPDES Permit No.: PA0014427 Outfall No.: 001

Evaluation Type: Major Sewage / Industrial Waste Wastewater Description: IW

Discharge Characteristics						
Design Flow (MGD)*	Hardness (mg/l)*	pH (SU)*	Partial Mix Factors (PMFs)			Complete Mix Times (min)
			AFC	CFC	THH	
0.76	91.9	8.59				

	Discharge Pollutant	Units	Max Discharge Conc	0 if left blank		0.5 if left blank		0 if left blank		1 if left blank	
				Trib Conc	Stream Conc	Daily CV	Hourly CV	Stream CV	Fate Coeff	FOS	Criteri a Mod
Group 1	Total Dissolved Solids (PWS)	mg/L	137								
	Chloride (PWS)	mg/L	14.8								
	Bromide	mg/L	< 0.2								
	Sulfate (PWS)	mg/L	5.26								
	Fluoride (PWS)	mg/L	< 1								
Group 2	Total Aluminum	µg/L									
	Total Antimony	µg/L									
	Total Arsenic	µg/L									
	Total Barium	µg/L									
	Total Beryllium	µg/L									
	Total Boron	µg/L									
	Total Cadmium	µg/L									
	Total Chromium (III)	µg/L									
	Hexavalent Chromium	µg/L									
	Total Cobalt	µg/L									
	Total Copper	µg/L									
	Free Cyanide	µg/L									
	Total Cyanide	µg/L									
	Dissolved Iron	µg/L									
	Total Iron	µg/L									
	Total Lead	µg/L									
	Total Manganese	µg/L									
	Total Mercury	µg/L									
	Total Nickel	µg/L									
	Total Phenols (Phenolics) (PWS)	µg/L									
	Total Selenium	µg/L									
	Total Silver	µg/L									
	Total Thallium	µg/L									
	Total Zinc	µg/L									
	Total Molybdenum	µg/L									
	Acrolein	µg/L	<								
	Acrylamide	µg/L	<								
	Acrylonitrile	µg/L	<								
	Benzene	µg/L	<								
	Bromoform	µg/L	<								

Group 3	Carbon Tetrachloride	µg/L	<									
	Chlorobenzene	µg/L										
	Chlorodibromomethane	µg/L	<									
	Chloroethane	µg/L	<									
	2-Chloroethyl Vinyl Ether	µg/L	<									
	Chloroform	µg/L	^									
	Dichlorobromomethane	µg/L	<									
	1,1-Dichloroethane	µg/L	<									
	1,2-Dichloroethane	µg/L	<									
	1,1-Dichloroethylene	µg/L	<									
	1,2-Dichloropropane	µg/L	<									
	1,3-Dichloropropylene	µg/L	<									
	1,4-Dioxane	µg/L	<									
	Ethylbenzene	µg/L	<									
	Methyl Bromide	µg/L	<									
	Methyl Chloride	µg/L	<									
	Methylene Chloride	µg/L	<									
	1,1,2,2-Tetrachloroethane	µg/L	<									
	Tetrachloroethylene	µg/L	<									
	Toluene	µg/L	<									
	1,2-trans-Dichloroethylene	µg/L	<									
	1,1,1-Trichloroethane	µg/L	<									
	1,1,2-Trichloroethane	µg/L	<									
	Trichloroethylene	µg/L	<									
	Vinyl Chloride	µg/L	<									
Group 4	2-Chlorophenol	µg/L	<									
	2,4-Dichlorophenol	µg/L	^									
	2,4-Dimethylphenol	µg/L	<									
	4,6-Dinitro-o-Cresol	µg/L	<									
	2,4-Dinitrophenol	µg/L	<									
	2-Nitrophenol	µg/L	<									
	4-Nitrophenol	µg/L	<									
	p-Chloro-m-Cresol	µg/L	<									
	Pentachlorophenol	µg/L	<									
	Phenol	µg/L	<									
	2,4,6-Trichlorophenol	µg/L	<									
Group 5	Acenaphthene	µg/L	<									
	Acenaphthylene	µg/L	<									
	Anthracene	µg/L	<									
	Benzidine	µg/L	<									
	Benzo(a)Anthracene	µg/L	<									
	Benzo(a)Pyrene	µg/L	<									
	3,4-Benzo fluoranthene	µg/L	<									
	Benzo(ghi)Perylene	µg/L	<									
	Benzo(k)Fluoranthene	µg/L	<									
	Bis(2-Chloroethoxy)Methane	µg/L	<									
	Bis(2-Chloroethyl)Ether	µg/L	<									
	Bis(2-Chloroisopropyl)Ether	µg/L	<									
	Bis(2-Ethylhexyl)Phthalate	µg/L	<									
	4-Bromophenyl Phenyl Ether	µg/L	<									
	Butyl Benzyl Phthalate	µg/L	<									
	2-Chloronaphthalene	µg/L	<									
	4-Chlorophenyl Phenyl Ether	µg/L	<									
	Chrysene	µg/L	<									
	Dibenzo(a,h)Anthracene	µg/L	<									
	1,2-Dichlorobenzene	µg/L	<									
	1,3-Dichlorobenzene	µg/L	<									
	1,4-Dichlorobenzene	µg/L	<									
	3,3-Dichlorobenzidine	µg/L	<									
	Diethyl Phthalate	µg/L	<									
	Dimethyl Phthalate	µg/L	<									
	Di-n-Butyl Phthalate	µg/L	<									
	2,4-Dinitrotoluene	µg/L	<									



Stream / Surface Water Information

Allegheny National Fish Hatchery, NPDES Permit No. PA0014427, Outfall 001

Instructions **Discharge** Stream

Receiving Surface Water Name: **Allegheny River**

No. Reaches to Model: **1**

- Statewide Criteria
- Great Lakes Criteria
- ORSANCO Criteria

Location	Stream Code*	RMI*	Elevation (ft)*	DA (mi ²)*	Slope (ft/ft)	PWS Withdrawal (MGD)	Apply Fish Criteria*
Point of Discharge	042122	198.28	1200	2180			Yes
End of Reach 1	042122	192.56	1182	2220			Yes

Q₇₋₁₀

Location	RMI	LFY (cfs/mi ²)*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness*	pH*	Hardness	pH
Point of Discharge	198.28	0.08										100	7		
End of Reach 1	192.56	0.08													

Q_b

Location	RMI	LFY (cfs/mi ²)*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness*	pH*	Hardness	pH
Point of Discharge	198.28														
End of Reach 1	192.56														



Model Results

Allegheny National Fish Hatchery, NPDES Permit No. PA0014427, Outfall 001

All Inputs Results Limits

Hydrodynamics

Wasteload Allocations

AFC

CCT (min):

PMF:

Analysis Hardness (mg/l):

Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Fluoride (PWS)	0	0		0	N/A	N/A	N/A	

CFC

CCT (min):

PMF:

Analysis Hardness (mg/l):

Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Fluoride (PWS)	0	0		0	N/A	N/A	N/A	

THH

CCT (min):

PMF:

Analysis Hardness (mg/l):

Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	500,000	500,000	N/A	
Chloride (PWS)	0	0		0	250,000	250,000	N/A	
Sulfate (PWS)	0	0		0	250,000	250,000	N/A	
Fluoride (PWS)	0	0		0	2,000	2,000	N/A	

CRL

CCT (min):

PMF:

Analysis Hardness (mg/l):

Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Fluoride (PWS)	0	0		0	N/A	N/A	N/A	

Recommended WQBELs & Monitoring Requirements

No. Samples/Month:

4

Pollutants	Mass Limits		Concentration Limits				Governing WQBEL	WQBEL Basis	Comments
	AML (lbs/day)	MDL (lbs/day)	AML	MDL	IMAX	Units			

Other Pollutants without Limits or Monitoring

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., <= Target QL).

Pollutants	Governing WQBEL	Units	Comments
Total Dissolved Solids (PWS)	N/A	N/A	PWS Not Applicable
Chloride (PWS)	N/A	N/A	PWS Not Applicable
Bromide	N/A	N/A	No WQS
Sulfate (PWS)	N/A	N/A	PWS Not Applicable
Fluoride (PWS)	N/A	N/A	PWS Not Applicable



Discharge Information

Instructions Discharge Stream

Facility: Allegheny National Fish Hatchery NPDES Permit No.: PA0014427 Outfall No.: 002

Evaluation Type: Major Sewage / Industrial Waste Wastewater Description: IW

Discharge Characteristics						
Design Flow (MGD)*	Hardness (mg/l)*	pH (SU)*	Partial Mix Factors (PMFs)			Complete Mix Times (min)
			AFC	CFC	THH	
4.75	92.85	7.76				

	Discharge Pollutant	Units	Max Discharge Conc	0 if left blank		0.5 if left blank		0 if left blank		1 if left blank	
				Trib Conc	Stream Conc	Daily CV	Hourly CV	Stream CV	Fate Coeff	FOS	Criteri a Mod
Group 1	Total Dissolved Solids (PWS)	mg/L	134								
	Chloride (PWS)	mg/L	14.8								
	Bromide	mg/L	< 0.2								
	Sulfate (PWS)	mg/L	5.27								
	Fluoride (PWS)	mg/L	< 1								
Group 2	Total Aluminum	µg/L									
	Total Antimony	µg/L									
	Total Arsenic	µg/L									
	Total Barium	µg/L									
	Total Beryllium	µg/L									
	Total Boron	µg/L									
	Total Cadmium	µg/L									
	Total Chromium (III)	µg/L									
	Hexavalent Chromium	µg/L									
	Total Cobalt	µg/L									
	Total Copper	µg/L									
	Free Cyanide	µg/L									
	Total Cyanide	µg/L									
	Dissolved Iron	µg/L									
	Total Iron	µg/L									
	Total Lead	µg/L									
	Total Manganese	µg/L									
	Total Mercury	µg/L									
	Total Nickel	µg/L									
	Total Phenols (Phenolics) (PWS)	µg/L									
	Total Selenium	µg/L									
	Total Silver	µg/L									
	Total Thallium	µg/L									
	Total Zinc	µg/L									
	Total Molybdenum	µg/L									
	Acrolein	µg/L	<								
	Acrylamide	µg/L	<								
	Acrylonitrile	µg/L	<								
	Benzene	µg/L	<								
	Bromoform	µg/L	<								

Group 3	Carbon Tetrachloride	µg/L	<									
	Chlorobenzene	µg/L										
	Chlorodibromomethane	µg/L	<									
	Chloroethane	µg/L	<									
	2-Chloroethyl Vinyl Ether	µg/L	<									
	Chloroform	µg/L	^									
	Dichlorobromomethane	µg/L	<									
	1,1-Dichloroethane	µg/L	<									
	1,2-Dichloroethane	µg/L	<									
	1,1-Dichloroethylene	µg/L	<									
	1,2-Dichloropropane	µg/L	<									
	1,3-Dichloropropylene	µg/L	<									
	1,4-Dioxane	µg/L	<									
	Ethylbenzene	µg/L	<									
	Methyl Bromide	µg/L	<									
	Methyl Chloride	µg/L	<									
	Methylene Chloride	µg/L	<									
	1,1,2,2-Tetrachloroethane	µg/L	<									
	Tetrachloroethylene	µg/L	<									
	Toluene	µg/L	<									
	1,2-trans-Dichloroethylene	µg/L	<									
	1,1,1-Trichloroethane	µg/L	<									
	1,1,2-Trichloroethane	µg/L	<									
	Trichloroethylene	µg/L	<									
	Vinyl Chloride	µg/L	<									
Group 4	2-Chlorophenol	µg/L	<									
	2,4-Dichlorophenol	µg/L	^									
	2,4-Dimethylphenol	µg/L	<									
	4,6-Dinitro-o-Cresol	µg/L	<									
	2,4-Dinitrophenol	µg/L	<									
	2-Nitrophenol	µg/L	<									
	4-Nitrophenol	µg/L	<									
	p-Chloro-m-Cresol	µg/L	<									
	Pentachlorophenol	µg/L	<									
	Phenol	µg/L	<									
	2,4,6-Trichlorophenol	µg/L	<									
Group 5	Acenaphthene	µg/L	<									
	Acenaphthylene	µg/L	<									
	Anthracene	µg/L	<									
	Benzidine	µg/L	<									
	Benzo(a)Anthracene	µg/L	<									
	Benzo(a)Pyrene	µg/L	<									
	3,4-Benzo fluoranthene	µg/L	<									
	Benzo(ghi)Perylene	µg/L	<									
	Benzo(k)Fluoranthene	µg/L	<									
	Bis(2-Chloroethoxy)Methane	µg/L	<									
	Bis(2-Chloroethyl)Ether	µg/L	<									
	Bis(2-Chloroisopropyl)Ether	µg/L	<									
	Bis(2-Ethylhexyl)Phthalate	µg/L	<									
	4-Bromophenyl Phenyl Ether	µg/L	<									
	Butyl Benzyl Phthalate	µg/L	<									
	2-Chloronaphthalene	µg/L	<									
	4-Chlorophenyl Phenyl Ether	µg/L	<									
	Chrysene	µg/L	<									
	Dibenzo(a,h)Anthracene	µg/L	<									
	1,2-Dichlorobenzene	µg/L	<									
	1,3-Dichlorobenzene	µg/L	<									
	1,4-Dichlorobenzene	µg/L	<									
	3,3-Dichlorobenzidine	µg/L	<									
	Diethyl Phthalate	µg/L	<									
	Dimethyl Phthalate	µg/L	<									
	Di-n-Butyl Phthalate	µg/L	<									
	2,4-Dinitrotoluene	µg/L	<									



Stream / Surface Water Information

Allegheny National Fish Hatchery, NPDES Permit No. PA0014427, Outfall 002

Instructions **Discharge** Stream

Receiving Surface Water Name: _____

No. Reaches to Model: 1

- Statewide Criteria
- Great Lakes Criteria
- ORSANCO Criteria

Location	Stream Code*	RMI*	Elevation (ft)*	DA (mi ²)*	Slope (ft/ft)	PWS Withdrawal (MGD)	Apply Fish Criteria*
Point of Discharge	042122	198.28	1200	2180			Yes
End of Reach 1	042122	192.56	1182	2220			Yes

Q₇₋₁₀

Location	RMI	LFY (cfs/mi ²)*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness*	pH*	Hardness	pH
Point of Discharge	198.28	0.08										100	7		
End of Reach 1	192.56	0.08													

Q_b

Location	RMI	LFY (cfs/mi ²)*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness*	pH*	Hardness	pH
Point of Discharge	198.28														
End of Reach 1	192.56														



Model Results

Allegheny National Fish Hatchery, NPDES Permit No. PA0014427, Outfall 002

All Inputs Results Limits

Hydrodynamics

Wasteload Allocations

AFC CCT (min): PMF: Analysis Hardness (mg/l): Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Fluoride (PWS)	0	0		0	N/A	N/A	N/A	

CFC CCT (min): PMF: Analysis Hardness (mg/l): Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Fluoride (PWS)	0	0		0	N/A	N/A	N/A	

THH CCT (min): PMF: Analysis Hardness (mg/l): Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	500,000	500,000	N/A	
Chloride (PWS)	0	0		0	250,000	250,000	N/A	
Sulfate (PWS)	0	0		0	250,000	250,000	N/A	
Fluoride (PWS)	0	0		0	2,000	2,000	N/A	

CRL CCT (min): PMF: Analysis Hardness (mg/l): Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Fluoride (PWS)	0	0		0	N/A	N/A	N/A	

Recommended WQBELs & Monitoring Requirements

No. Samples/Month:

4

Pollutants	Mass Limits		Concentration Limits				Governing WQBEL	WQBEL Basis	Comments
	AML (lbs/day)	MDL (lbs/day)	AML	MDL	IMAX	Units			

Other Pollutants without Limits or Monitoring

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., <= Target QL).

Pollutants	Governing WQBEL	Units	Comments
Total Dissolved Solids (PWS)	N/A	N/A	PWS Not Applicable
Chloride (PWS)	N/A	N/A	PWS Not Applicable
Bromide	N/A	N/A	No WQS
Sulfate (PWS)	N/A	N/A	PWS Not Applicable
Fluoride (PWS)	N/A	N/A	PWS Not Applicable



Discharge Information

Instructions Discharge Stream

Facility: Allegheny National Fish Hatchery NPDES Permit No.: PA0014427 Outfall No.: 003

Evaluation Type: Major Sewage / Industrial Waste Wastewater Description: IW

Discharge Characteristics											
Design Flow (MGD)*	Hardness (mg/l)*	pH (SU)*	Partial Mix Factors (PMFs)				Complete Mix Times (min)				
			AFC	CFC	THH	CRL	Q ₇₋₁₀	Q _h			
0.29	97.3	7.77									

			0 if left blank		0.5 if left blank		0 if left blank		1 if left blank				
Discharge Pollutant			Units	Max Discharge Conc	Trib Conc	Stream Conc	Daily CV	Hourly CV	Stream CV	Fate Coeff	FOS	Criteri a Mod	Chem Transl
Group 1	Total Dissolved Solids (PWS)	mg/L		123									
	Chloride (PWS)	mg/L		14.6									
	Bromide	mg/L	<	0.2									
	Sulfate (PWS)	mg/L		5.24									
	Fluoride (PWS)	mg/L	<	1									
Group 2	Total Aluminum	µg/L											
	Total Antimony	µg/L											
	Total Arsenic	µg/L											
	Total Barium	µg/L											
	Total Beryllium	µg/L											
	Total Boron	µg/L											
	Total Cadmium	µg/L											
	Total Chromium (III)	µg/L											
	Hexavalent Chromium	µg/L											
	Total Cobalt	µg/L											
	Total Copper	µg/L											
	Free Cyanide	µg/L											
	Total Cyanide	µg/L											
	Dissolved Iron	µg/L											
	Total Iron	µg/L											
	Total Lead	µg/L											
	Total Manganese	µg/L											
	Total Mercury	µg/L											
	Total Nickel	µg/L											
	Total Phenols (Phenolics) (PWS)	µg/L											
	Total Selenium	µg/L											
	Total Silver	µg/L											
	Total Thallium	µg/L											
	Total Zinc	µg/L											
	Total Molybdenum	µg/L											
Group 3	Acrolein	µg/L	<										
	Acrylamide	µg/L	<										
	Acrylonitrile	µg/L	<										
	Benzene	µg/L	<										
	Bromoform	µg/L	<										

Group 3	Carbon Tetrachloride	µg/L	<									
	Chlorobenzene	µg/L										
	Chlorodibromomethane	µg/L	<									
	Chloroethane	µg/L	<									
	2-Chloroethyl Vinyl Ether	µg/L	<									
	Chloroform	µg/L	^									
	Dichlorobromomethane	µg/L	<									
	1,1-Dichloroethane	µg/L	<									
	1,2-Dichloroethane	µg/L	<									
	1,1-Dichloroethylene	µg/L	<									
	1,2-Dichloropropane	µg/L	<									
	1,3-Dichloropropylene	µg/L	<									
	1,4-Dioxane	µg/L	<									
	Ethylbenzene	µg/L	<									
	Methyl Bromide	µg/L	<									
	Methyl Chloride	µg/L	<									
	Methylene Chloride	µg/L	<									
	1,1,2,2-Tetrachloroethane	µg/L	<									
	Tetrachloroethylene	µg/L	<									
	Toluene	µg/L	<									
	1,2-trans-Dichloroethylene	µg/L	<									
	1,1,1-Trichloroethane	µg/L	<									
	1,1,2-Trichloroethane	µg/L	<									
	Trichloroethylene	µg/L	<									
	Vinyl Chloride	µg/L	<									
Group 4	2-Chlorophenol	µg/L	<									
	2,4-Dichlorophenol	µg/L	^									
	2,4-Dimethylphenol	µg/L	<									
	4,6-Dinitro-o-Cresol	µg/L	<									
	2,4-Dinitrophenol	µg/L	<									
	2-Nitrophenol	µg/L	<									
	4-Nitrophenol	µg/L	<									
	p-Chloro-m-Cresol	µg/L	<									
	Pentachlorophenol	µg/L	<									
	Phenol	µg/L	<									
	2,4,6-Trichlorophenol	µg/L	<									
Group 5	Acenaphthene	µg/L	<									
	Acenaphthylene	µg/L	<									
	Anthracene	µg/L	<									
	Benzidine	µg/L	<									
	Benzo(a)Anthracene	µg/L	<									
	Benzo(a)Pyrene	µg/L	<									
	3,4-Benzo fluoranthene	µg/L	<									
	Benzo(ghi)Perylene	µg/L	<									
	Benzo(k)Fluoranthene	µg/L	<									
	Bis(2-Chloroethoxy)Methane	µg/L	<									
	Bis(2-Chloroethyl)Ether	µg/L	<									
	Bis(2-Chloroisopropyl)Ether	µg/L	<									
	Bis(2-Ethylhexyl)Phthalate	µg/L	<									
	4-Bromophenyl Phenyl Ether	µg/L	<									
	Butyl Benzyl Phthalate	µg/L	<									
	2-Chloronaphthalene	µg/L	<									
	4-Chlorophenyl Phenyl Ether	µg/L	<									
	Chrysene	µg/L	<									
	Dibenzo(a,h)Anthracene	µg/L	<									
	1,2-Dichlorobenzene	µg/L	<									
	1,3-Dichlorobenzene	µg/L	<									
	1,4-Dichlorobenzene	µg/L	<									
	3,3-Dichlorobenzidine	µg/L	<									
	Diethyl Phthalate	µg/L	<									
	Dimethyl Phthalate	µg/L	<									
	Di-n-Butyl Phthalate	µg/L	<									
	2,4-Dinitrotoluene	µg/L	<									



Stream / Surface Water Information

Allegheny National Fish Hatchery, NPDES Permit No. PA0014427, Outfall 003

Instructions **Discharge** Stream

Receiving Surface Water Name: _____

No. Reaches to Model: 1

- Statewide Criteria
- Great Lakes Criteria
- ORSANCO Criteria

Location	Stream Code*	RMI*	Elevation (ft)*	DA (mi ²)*	Slope (ft/ft)	PWS Withdrawal (MGD)	Apply Fish Criteria*
Point of Discharge	042122	198.28	1200	2180			Yes
End of Reach 1	042122	192.56	1182	2220			Yes

Q₇₋₁₀

Location	RMI	LFY (cfs/mi ²)*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness*	pH*	Hardness	pH
Point of Discharge	198.28	0.08										100	7		
End of Reach 1	192.56	0.08													

Q_b

Location	RMI	LFY (cfs/mi ²)*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness*	pH*	Hardness	pH
Point of Discharge	198.28														
End of Reach 1	192.56														



Model Results

Allegheny National Fish Hatchery, NPDES Permit No. PA0014427, Outfall 003

All Inputs Results Limits

Hydrodynamics

Wasteload Allocations

AFC CCT (min): PMF: Analysis Hardness (mg/l): Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Fluoride (PWS)	0	0		0	N/A	N/A	N/A	

CFC CCT (min): PMF: Analysis Hardness (mg/l): Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Fluoride (PWS)	0	0		0	N/A	N/A	N/A	

THH CCT (min): PMF: Analysis Hardness (mg/l): Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	500,000	500,000	N/A	
Chloride (PWS)	0	0		0	250,000	250,000	N/A	
Sulfate (PWS)	0	0		0	250,000	250,000	N/A	
Fluoride (PWS)	0	0		0	2,000	2,000	N/A	

CRL CCT (min): PMF: Analysis Hardness (mg/l): Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Fluoride (PWS)	0	0		0	N/A	N/A	N/A	

Recommended WQBELs & Monitoring Requirements

No. Samples/Month:

4

Pollutants	Mass Limits		Concentration Limits				Governing WQBEL	WQBEL Basis	Comments
	AML (lbs/day)	MDL (lbs/day)	AML	MDL	IMAX	Units			

Other Pollutants without Limits or Monitoring

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., <= Target QL).

Pollutants	Governing WQBEL	Units	Comments
Total Dissolved Solids (PWS)	N/A	N/A	PWS Not Applicable
Chloride (PWS)	N/A	N/A	PWS Not Applicable
Bromide	N/A	N/A	No WQS
Sulfate (PWS)	N/A	N/A	PWS Not Applicable
Fluoride (PWS)	N/A	N/A	PWS Not Applicable