

Application Type Amendment, Major
 Facility Type Non-Municipal
 Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0020435 A-1
 APS ID 840244
 Authorization ID 1476601

Applicant and Facility Information

Applicant Name	<u>Aqua Pennsylvania Wastewater, Inc.</u>	Facility Name	<u>White Haven Wastewater Treatment Plant (WWTP)</u>
Applicant Address	<u>1 Aqua Way</u> <u>White Haven, PA 18661-1115</u>	Facility Address	<u>One Aqua Way</u> <u>White Haven, PA 18661</u>
Applicant Contact	<u>Alan P. Cerep, Project Engineer</u>	Facility Contact	<u>Alan P. Cerep, Project Engineer</u>
Applicant Phone	<u>(610) 645-1122</u>	Facility Phone	<u>(610) 645-1122</u>
Client ID	<u>62614</u>	Site ID	<u>257459</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>White Haven Borough</u>
Connection Status	<u>No Limitations</u>	County	<u>Luzerne</u>
Date Application Received	<u>March 6, 2024</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>March 19, 2024</u>	If No, Reason	
Purpose of Application	<u>Relocation of Outfall</u>		

Summary of Review

The purpose of this NPDES permit amendment is for the relocation of the existing outfall location. A new 24-inch outfall pipe will be installed from the existing wastewater treatment plant (WWTP) ultraviolet (UV) disinfection channel directly to the Lehigh River.

The White Haven WWTP is owned and operated by Aqua Pennsylvania, Inc. (Aqua). The WWTP is permitted to discharge 0.6 MGD of treated effluent. The existing WWTP consists of an influent pump station, fine screening, grit removal, activated sludge reactor trains, clarification, post aeration, UV disinfection, and aerobic sludge holding tanks. Lime is used for pH adjustment, improved sludge settling, and sludge conditioning.

The Outfall 001 coordinates were updated in the NPDES permit to what was provided/confirmed by the permittee's consultant. The Outfall location is only slightly changing and is now proposed to be above the typical water level of the Lehigh River. Access stairs will also be provided.

No other changes were made to the NPDES Permit.

An "A-1" notation has been added after the NPDES permit number to indicate the number of amendments issued since the original permit was issued.

The WQM Permit Amendment (4017404 A-1) for this facility and project will be issued in conjunction with final NPDES Permit amendment.

There are currently 11 open violations for this client in the Clean Water Program and one open violation in the Safe Drinking Water Program that may need to be resolved before issuance of the final permit amendment.

Approve	Deny	Signatures	Date
X		/s/ Allison S. Zukosky / Project Manager	May 22, 2024
X		/s/ Amy M. Bellanca, P.E. / Program Manager	6-6-24

Summary of Review

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

DRAFT

DRAFT

Approve	Deny	Signatures	Date
X		/s/ Allison S. Zukosky / Project Manager	May 22, 2024
X		/s/ Amy M. Bellanca, P.E. / Program Manager	6-6-24