



Application Type  
Facility Type  
Major / Minor

Renewal  
Municipal  
Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0020508  
APS ID 16695  
Authorization ID 1528739

**Applicant and Facility Information**

Applicant Name	<b>McConnellsburg Sewerage Authority Fulton County</b>	Facility Name	<b>McConnellsburg STP</b>
Applicant Address	PO Box 681  McConnellsburg, PA 17233-0681	Facility Address	20789 Great Cove Road  McConnellsburg, PA 17233
Applicant Contact	Craig Strait	Facility Contact	Craig Strait
Applicant Phone	(717) 485-4728	Facility Phone	(717) 485-4728
Client ID	36766	Site ID	251564
Ch 94 Load Status	Not Overloaded	Municipality	Ayr Township
Connection Status	No Limitations	County	Fulton
Date Application Received	<u>May 29, 2025</u>	EPA Waived?	No
Date Application Accepted	<u>May 30, 2025</u>	If No, Reason	Significant CB Discharge
Purpose of Application	NPDES Permit Renewal.		

**Summary of Review**

McConnellsburg Sewerage Authority has applied to the Pennsylvania Department of Environmental Protection (DEP) for reissuance of its NPDES permit. The permit was last reissued on January 14, 2021 and became effective on February 1, 2021. The permit will be expired on January 31, 2026.

The facility has an average annual design flow of 0.6 MGD that discharges to Big Cove Creek. The application states the following flow contribution sources: McConnellsburg Borough (41.3%), Ayr Township (30.2%), and Todd Township (28.5%).

WQM Part II No. 2998401 original was issued on June 25, 1999, and amendment issued on October 20, 2010. The WQM Part II extensions & pumping stations No. 2900402 was issued on December 21, 2000.

Sludge use and disposal description and location(s): N/A because sludge hauling is by facility's contractor.

Changes from the previous permit:

- The E. Coli monitoring and report requirements will be added to the proposed permit.
- TRC limit of 0.056 mg/l AML, and 0.18 mg/l IMAX will be replaced in the proposed permit.
- The Raw Sewage Influent "Daily Average" concentration (mg/L) report of BOD<sub>5</sub> & TSS will be added to the proposed permit which were missing in the previous permit.

Based on the review outline in this fact sheet, it is recommended that the permit be drafted and published in the Pennsylvania Bulletin for public comments for 30 days.

Approve	Deny	Signatures	Date
X		Hilaryle Hilary H. Le / Environmental Engineering Specialist	November 21, 2025
X		Daniel W. Martin Daniel W. Martin, P.E. / Environmental Engineer Manager	December 22, 2025

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	0.6
Latitude	39° 55' 32.97"	Longitude	-78° 0' 20.27"
Quad Name	Meadow Ground	Quad Code	
Wastewater Description:	Effluent		
Receiving Waters	Big Cove Creek (CWF)	Stream Code	60482
NHD Com ID	49470424	RMI	15.13 miles
Drainage Area	7.4 mi. <sup>2</sup>	Yield (cfs/mi <sup>2</sup> )	See comments below
Q <sub>7-10</sub> Flow (cfs)	See comments below	Q <sub>7-10</sub> Basis	USGS StreamStats
Elevation (ft)	848.58	Slope (ft/ft)	
Watershed No.	13-B	Chapter 93 Class.	CWF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Impaired		
Cause(s) of Impairment	Nutrients, Siltation		
Source(s) of Impairment	Grazing in Riparian or Shoreline Zones		
TMDL Status	Name		
Nearest Downstream Public Water Supply Intake	R.C. Wilson Water Treatment Plant		
PWS Waters	Potomac River	Flow at Intake (cfs)	
PWS RMI	26 miles to PA-MA border	Distance from Outfall (mi)	Approximate 38.84 miles

Changes Since Last Permit Issuance:

#### Drainage Area

The discharge is to Big Cove Creek at RMI 15.13 miles. A drainage area upstream of the discharge is estimated to be 7.4 mi.<sup>2</sup>, according to USGS PA StreamStats available at <https://streamstats.usgs.gov/ss/>.

#### Streamflow

There are no nearby stream gages with low flow data that have extensive or recent periods of record. Since USGS PA StreamStats estimated the drainage area that is below the minimum value allowed by USGS's regression equations, the USGS StreamStats on Licking Creek at the PA/MD border will be used to calculate the Q<sub>7-10</sub> at the point of discharge using a low flow yield method. The Q<sub>7-10</sub> here is 6.03 cfs and the drainage area is 159 mi.<sup>2</sup> which results in a Q<sub>7-10</sub> low flow yield of 0.038 cfs/mi.<sup>2</sup>. This information is used to obtain a chronic or 30-day (Q<sub>30-10</sub>), and an acute or 1-day (Q<sub>1-10</sub>) exposure stream flow for the discharge point as follows (Guidance No. 391-2000-023):

$$\begin{aligned}
 \text{Low Flow Yield} &= Q_{7-10} / \text{Drainage Area} = 6.03 \text{ cfs} / 159 \text{ mi.}^2 = 0.038 \text{ cfs/mi.}^2 \\
 Q_{7-10\text{discharge}} &= 0.038 \text{ cfs/mi.}^2 * \text{Drainage Area}_{\text{discharge}} = 0.038 \text{ cfs/mi.}^2 * 7.4 \text{ mi.}^2 = 0.3 \text{ cfs} \\
 Q_{30-10} &= 1.36 * Q_{7-10\text{discharge}} = 1.36 * 0.3 \text{ cfs} = 0.41 \text{ cfs} \\
 Q_{1-10} &= 0.64 * Q_{7-10\text{discharge}} = 0.64 * 0.3 \text{ cfs} = 0.19 \text{ cfs}
 \end{aligned}$$

The resulting Q<sub>7-10</sub> dilution ratio is: Q<sub>stream</sub> / Q<sub>discharge</sub> = 0.3 cfs / [0.6 MGD \* (1.55 cfs/MGD)] = 0.32:1

#### Big Cove Creek

25 Pa Code § 93.9z classifies Big Cove Creek as Cold Water and Migratory Fishes (CWF, MF) surface water. Based on the 2024 Integrated Report, Big Cove Creek, assessment unit IDs 6138 & 19105, is not impaired. A TMDL currently does not exist for this stream segment, therefore, no TMDL has been taken into consideration during this review.

#### Public Water Supply

The closest downstream water supply intake from the discharge point is for the Hagerstown City water supply. The R.C. Wilson Water Treatment Plant near Williamsport, Maryland is the main production plant for the City of Hagerstown. The source for this facility is the Potomac River. The distance downstream from the discharge to the intake is approximately 38.84 miles. The discharge will not impact the intake because of the distance, dilution, and effluent limits.

Treatment Facility Summary				
<b>Treatment Facility Name:</b> Mcconnellsburg STP				
WQM Permit No.	Issuance Date	Reason		
2998401	6/26/1999	New		
2998401 10-1	10/20/2010	Amendment		
2900402	12/21/2000	New (extension & pumping station)		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage			Hypochlorite	0.6
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.6	1380	Not Overloaded		

Changes Since Last Permit Issuance:

Other Comments:

The treatment process, according to the revised application, is as follows:

Lift Station → Fine Screen/Grit Removal → EQ Tank (1) → Sludge Storage Tanks (2) → Clarifiers (2) → Chlorine Contact Tank (1) → Dechlorination (1) → Aeration Tank (1) → Outfall 001

Chemical used:

The subject facility utilizes the following chemicals as part of their treatment process.



- Sodium Hypochlorite (liquid) for disinfection
- Sodium Bisulfate (liquid) for dechlorination
- Superfloc SD2081 for dewatering aid
- DelPAC 2000 for Phosphorus removal

Biosolids:

The total sewage sludge/biosolids production within the facility for the previous year was 69.8 dry tons.

Compliance History	
<b>Summary of DMRs:</b>	DMRs reported last 12 months are summarized in the next page.
<b>Summary of Inspections:</b>	<p>10/9/2025: Mr. Clark, DEP WQS, conducted compliance evaluation inspection. There were no violations noted during inspection. The recommendations were 1. Repair sludge centrifuge. 2. Submit influent supplemental forms with monthly DMRs. 3. Submit a Laboratory Accreditation Supplemental form with updated lab information. 4. Record all maintenance, repair, and process control test results in logbook or log sheets. The effluent looked clear. The field test results were within permit limits.</p> <p>8/8/2024: Mr. Clark, DEP WQS, conducted compliance evaluation inspection. The recommendations were calibrated the flow meter and download the newest version of the influent and daily Effluent Supplemental forms the DEP website and use them for future DMR submittals. The effluent looked clear. The field test results were within permit limits. There were no violations noted during inspection.</p>
<b>Other Comments:</b>	There are no open violations associated with this facility or permittee.

Other Comments:



Compliance History

DMR Data for Outfall 001 (from October 1, 2024 to September 30, 2025)

Parameter	SEP-25	AUG-25	JUL-25	JUN-25	MAY-25	APR-25	MAR-25	FEB-25	JAN-25	DEC-24	NOV-24	OCT-24
Flow (MGD) Average Monthly	0.228	0.235	0.293	0.395	0.532	0.297	0.296	0.346	0.275	0.271	0.236	0.215
Flow (MGD) Daily Maximum	0.243	0.368	0.340	0.600	1.086	0.338	0.353	0.406	0.284	0.341	0.323	0.241
pH (S.U.) Instantaneous Minimum	7.4	7.3	7.4	7.3	7.3	6.7	7.1	7.1	7.0	7.1	7.2	7.2
pH (S.U.) Instantaneous Maximum	8.0	7.9	7.8	7.7	7.7	7.7	7.6	7.5	7.6	7.6	7.7	7.7
DO (mg/L) Instantaneous Minimum	8.0	7.1	7.3	7.6	8.2	8.6	9.0	9.0	8.7	8.2	7.6	6.6
TRC (mg/L) Average Monthly	< 0.02	< 0.03	0.02	0.01	0.02	< 0.03	0.03	< 0.03	0.04	0.04	0.04	0.03
TRC (mg/L) Instantaneous Maximum	0.04	0.08	0.05	0.06	0.08	0.07	0.09	0.08	0.09	0.09	0.16	0.08
CBOD5 (lbs/day) Average Monthly	4	6	9	10	17	10	8	11	9	9	7.0	8
CBOD5 (lbs/day) Weekly Average	4	6	12	13	27	19	9	18	18	14	10.0	13
CBOD5 (mg/L) Average Monthly	2	3	3.19	3	3.23	< 4.28	3.0	< 3.67	3.96	3.3	3.34	3.81
CBOD5 (mg/L) Weekly Average	2.0	3.0	3.93	3.0	3.91	8.5	3.0	5.39	7.79	4.2	4.36	7.05
BOD5 (lbs/day) Raw Sewage Influent Average Monthly	170	259	522	495	710	589	753	603	637	650	665	497
BOD5 (lbs/day) Raw Sewage Influent   Daily Maximum	281	312	843	763	1168	757	974	662	1037	949	905	630
BOD5 (mg/L) Raw Sewage Influent Average Monthly	94	129.7	193	146	139	234	296	215	277	246	309	251
TSS (lbs/day) Average Monthly	7	6	9	16	34	17	21	29	16	11	8.0	10

NPDES Permit Fact Sheet  
McConnellsburg STP

NPDES Permit No. PA0020508

TSS (lbs/day) Raw Sewage Influent Average Monthly	339	243	490	625	884	710	890	599	421	433	734	762
TSS (lbs/day) Raw Sewage Influent   Daily Maximum	456	295	1070	1044	1848	989	1361	791	622	483	1095	1158
TSS (lbs/day) Weekly Average	8	11	15	25	65	22	33	57	38	24	13.0	16
TSS (mg/L) Average Monthly	4	3.2	3.4	5.0	6.55	7.0	8.2	9.7	6.6	3.7	3.8	4.7
TSS (mg/L) Raw Sewage Influent Average Monthly	187	122	184	193	159	282	353	219	180	184	341	385
TSS (mg/L) Weekly Average	4	5.6	6.0	6.4	8.0	8.8	12.8	16.8	14.8	5.23	6.4	7.6
Fecal Coliform (No./100 ml) Geometric Mean	9.1	3.2	171	8.6	9.2	< 4.2	22.9	16.7	4.0	4.4	4.0	12
Fecal Coliform (No./100 ml) Instantaneous Maximum	156	15.8	1299.7	10.9	26.2	8.6	53.6	21.6	15	7.4	6.0	23
Nitrate-Nitrite (mg/L) Average Monthly	3.62	< 2.83	3.82	6.48	5.09	5.4	4.96	4.61	4.59	3.91	3.61	4.53
Nitrate-Nitrite (lbs) Total Monthly	201	171	320	648	705	405	394	372	336	290	239.0	276
Total Nitrogen (mg/L) Average Monthly	< 4.15	< 3.34	4.35	7.04	5.72	5.98	5.69	5.41	5.33	4.82	4.64	5.42
Total Nitrogen (lbs) Effluent Net   Total Monthly	230	201	365	706	790	450	452	438	390	359	307	330
Total Nitrogen (lbs) Total Monthly	230	201	365	706	790	450	452	438	390	359	307.0	330
Ammonia (lbs/day) Average Monthly	0.02	0.2	0.3	0.3	0.4	0.2	0.3	0.3	0.2	0.2	0.2	0.2
Ammonia (mg/L) Average Monthly	0.1	0.1	0.1	0.1	0.09	0.1	0.1	0.1	0.11	0.1	0.1	0.1
Ammonia (lbs) Total Monthly	6	6	8	10	13	7	8	8	7	7	7.0	6
TKN (mg/L) Average Monthly	< 0.53	< 0.50	0.53	0.56	0.63	0.62	0.73	0.80	0.74	0.91	1.03	0.88
TKN (lbs) Total Monthly	29	30	44	58	85	45	58	66	54	69	68	54
Total Phosphorus (lbs/day) Average Monthly	3	2	2	6	4	3	0.5	2	3.0	4	4.0	5

NPDES Permit Fact Sheet  
McConnellsburg STP

NPDES Permit No. PA0020508

Total Phosphorus (mg/L)											
Average Monthly	1.43	0.80	0.83	1.85	0.95	1.02	0.20	0.67	1.09	1.57	1.91
Total Phosphorus (lbs)											
Effluent Net   Total Monthly	79	48	71	184	131	75	16	55	79	116	127
Total Phosphorus (lbs)											
Total Monthly	79	48	71	184	131	75	16	55	79	116	127.0

**Existing Effluent Limitations and Monitoring Requirements**

Outfall 001,

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
D.O.	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.08	XXX	0.28	1/day	Grab
CBOD <sub>5</sub> May 1 - Oct 31	75.0	113 Wkly Avg	XXX	15.0	22.5	30.0	1/week	8-Hr Composite
CBOD <sub>5</sub> Nov 1 - Apr 30	125	200 Wkly Avg	XXX	25.0	40.0	50.0	1/week	8-Hr Composite
TSS	150	225 Wkly Avg	XXX	30.0	45.0	60.0	1/week	8-Hr Composite
BOD <sub>5</sub> Raw Sewage Influent	Report	Report	XXX	Report	XXX	XXX	1/week	8-Hr Composite
TSS Raw Sewage Influent	Report	Report	XXX	Report	XXX	XXX	1/week	8-Hr Composite
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1,000	1/week	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2,000 Geo Mean	XXX	10,000	1/week	Grab
Ammonia May 1 - Oct 31	10.0	XXX	XXX	2.0	XXX	4.0	2/week	8-Hr Composite

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Ammonia Nov 1 - Apr 30	30.0	XXX	XXX	6.0	XXX	12.0	2/week	8-Hr Composite
Total Phosphorus	10.0	XXX	XXX	2.0	XXX	4.0	2/week	8-Hr Composite

**Existing Effluent Limitations and Monitoring Requirements**

**Chesapeake Bay Outfall 001,**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Monthly	Annual	Minimum	Monthly Average	Maximum	Instant. Maximum		
Ammonia---N	Report	Report	XXX	Report	XXX	XXX	2/week	8-Hr Composite
Kjeldahl---N	Report	XXX	XXX	Report	XXX	XXX	2/week	8-Hr Composite
Nitrate-Nitrite as N	Report	XXX	XXX	Report	XXX	XXX	2/week	8-Hr Composite
Total Nitrogen	Report	Report	XXX	Report	XXX	XXX	1/month	Calculation
Total Phosphorus	Report	Report	XXX	Report	XXX	XXX	2/week	8-Hr Composite
Net Total Nitrogen	Report	10,959	XXX	XXX	XXX	XXX	1/month	Calculation
Net Total Phosphorus	Report	1,461	XXX	XXX	XXX	XXX	1/month	Calculation

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
D.O.	XXX	XXX	5.0 Inst Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.056	XXX	0.18	1/day	Grab
CBOD5 Nov 1 - Apr 30	125.0	200.0	XXX	25.0	40.0	50.0	1/week	8-Hr Composite
CBOD5 May 1 - Oct 31	75.0	113.0	XXX	15.0	22.5	30.0	1/week	8-Hr Composite
BOD5 Raw Sewage Influent	Report	Report Daily Max	XXX	Report	Report Daily Max	XXX	1/week	8-Hr Composite
TSS	150.0	225.0	XXX	30.0	45.0	60.0	1/week	8-Hr Composite
TSS Raw Sewage Influent	Report	Report Daily Max	XXX	Report	Report Daily Max	XXX	1/week	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2,000 Geo Mean	XXX	10,000	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1,000	1/week	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/quarter	Grab
Ammonia Nov 1 - Apr 30	30.0	XXX	XXX	6.0	XXX	12.0	2/week	8-Hr Composite
Ammonia May 1 - Oct 31	10.0	XXX	XXX	2.0	XXX	4.0	2/week	8-Hr Composite
Total Phosphorus	10.0	XXX	XXX	2.0	XXX	4.0	2/week	8-Hr Composite

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Monthly	Annual	Monthly	Monthly Average	Maximum	Instant. Maximum		
Ammonia---N	Report	Report	XXX	Report	XXX	XXX	2/week	8-Hr Composite
Kjeldahl---N	Report	XXX	XXX	Report	XXX	XXX	2/week	8-Hr Composite
Nitrate-Nitrite as N	Report	XXX	XXX	Report	XXX	XXX	2/week	8-Hr Composite
Total Nitrogen	Report	Report	XXX	Report	XXX	XXX	1/month	Calculation
Total Phosphorus	Report	Report	XXX	Report	XXX	XXX	2/week	8-Hr Composite
Net Total Nitrogen	Report	10,959	XXX	XXX	XXX	XXX	1/month	Calculation
Net Total Phosphorus	Report	1,461	XXX	XXX	XXX	XXX	1/month	Calculation

**Development of Effluent Limitations**

Outfall No. 001  
Latitude 39° 55' 32.97"  
Wastewater Description: Effluent

Design Flow (MGD) 0.6  
Longitude -78° 0' 20.27"

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments:

**Water Quality-Based Limitations**

**Ammonia (NH<sub>3</sub>-N):**

NH<sub>3</sub>N calculations are based on the Department's Implementation Guidance of Section 93.7 Ammonia Criteria, dated 11/4/97 (ID No. 391-2000-013). The following data is necessary to determine the in-stream NH<sub>3</sub>-N criteria used in the attached WQM 7.0 computer model of the stream:

- \* Discharge pH = 7.0 (Default)
- \* Discharge Temperature = 20°C (Default)
- \* Stream pH = 7.0 (Default)
- \* Stream Temperature = 20°C (Default)
- \* Background NH<sub>3</sub>-N = 0 mg/L (Default)

Analysis Results WQM 7.0

Hydrodynamics		NH <sub>3</sub> -N Allocations		D.O. Allocations		D.O. Simulation		Effluent Limitations																	
RMI	Discharge Name	Permit Number Disc Flow (mgd)																							
15.13	McConnellsburg	PA0020508	0.6000																						
<table border="1"> <thead> <tr> <th>Parameter</th> <th>Effluent Limit 30 Day Average (mg/L)</th> <th>Effluent Limit Maximum (mg/L)</th> <th>Effluent Limit Minimum (mg/L)</th> </tr> </thead> <tbody> <tr> <td>CBOD<sub>5</sub></td> <td>17.51</td> <td>5.32</td> <td>5</td> </tr> <tr> <td>NH<sub>3</sub>-N</td> <td>2.66</td> <td></td> <td></td> </tr> <tr> <td>Dissolved Oxygen</td> <td></td> <td></td> <td></td> </tr> </tbody> </table>										Parameter	Effluent Limit 30 Day Average (mg/L)	Effluent Limit Maximum (mg/L)	Effluent Limit Minimum (mg/L)	CBOD <sub>5</sub>	17.51	5.32	5	NH <sub>3</sub> -N	2.66			Dissolved Oxygen			
Parameter	Effluent Limit 30 Day Average (mg/L)	Effluent Limit Maximum (mg/L)	Effluent Limit Minimum (mg/L)																						
CBOD <sub>5</sub>	17.51	5.32	5																						
NH <sub>3</sub> -N	2.66																								
Dissolved Oxygen																									
Record: 1 of 1   < Back   Next >   No Filter   Search																									
<input type="button" value="Print"/>		<input type="button" value="Archive"/>		<input type="button" value="Cancel"/>																					

The model input data and results are attached. The printout of the WQM 7.0 output indicates that at a discharge of 0.6 MGD, limits (rounded according to the NPDES Technical Guidance 362-0400-001) of 2.66 mg/L as monthly average and 5.32 mg/L as instantaneous maximum limit during summer to protect water quality standards. However, the existing permit limits of 2.0 mg/L as monthly average and 4 mg/L as instantaneous maximum NH<sub>3</sub>-N are more stringent and will remain in effect due to federal anti-backsliding policy. The winter effluent limit will be set at three-times the summer limits. Recent DMRs and inspection reports indicate that the facility has been consistently achieving these limits. Mass limits are calculated as follows:

Summer average monthly mass limit: 2.0 mg/L x 0.6 MGD x 8.34 = 10.0 lbs/day

Winter average monthly mass limit: 10.0 lbs/day x 3 = 30.0 lbs/day

**Dissolved Oxygen (D.O.):**

A minimum D.O. of 5.0 mg/L is required per 25 Pa. Code § 93.7. This is consistent with the previous permit renewal and current Department criteria.

**Carbonaceous Biochemical Oxygen Demand (CBOD<sub>5</sub>):**

The attached WQM 7.0 modeling results show that secondary treatment is adequate to protect the water quality of the stream. Recent DMRs and inspection reports show that the facility has been consistently achieving concentrations below this existing limit. The WQM 7.0 model suggests a monthly average CBOD<sub>5</sub> limit may be 17.48 mg/l, however, the existing summer limit of 15.0 mg/l is more stringent and will remain in place. Mass limits are calculated as follows:

Average monthly mass limit: 15.0 mg/L x 0.6 MGD x 8.34 = 75.06 (75.0) lbs/day

Average weekly mass limit: 22.5 mg/L x 0.6 MGD x 8.34 = 112.59 (113.0) lbs/day

The winter season average monthly limit of 25.0 mg/L, average weekly limit of 40.0 mg/L, and instantaneous maximum limit of 50.0 mg/l will also remain in place. Mass limits are calculated as follows:

Average monthly mass limit: 25.0 mg/L x 0.6 MGD x 8.34 = 125.1 (125.0) lbs/day

Average weekly mass limit: 40.0 mg/L x 0.6 MGD x 8.34 = 200.16 (200.0) lbs/day

Recent DMRs and inspection reports show that the facility has been consistently achieving these limits.

**Fecal Coliform:**

The recent coliform guidance in 25 Pa. Code § 92a.47.(a)(4) requires a summer technology limit of 200/100 ml as a geometric mean and an instantaneous maximum not greater than 1,000/100ml and 25 Pa. Code § 92a.47.(a)(5) requires a winter limit of 2,000/100ml as a geometric mean and an instantaneous maximum not greater than 10,000/100ml.

Therefore, instantaneous maximum limits for summer and winter seasons will be introduced in this renewal to be consistent with regulations. Inspection reports are showing that the permittee is capable of meeting this requirement.

**E. Coli:**

As recommended by DEP's SOP No. BCW-PMT-033, version 2.0 revised February 5, 2024, a routine monitoring for E. Coli will be included in the proposed permit under 25 Pa. Code § 92a.61. This requirement applies to all sewage dischargers greater than 0.002 MGD in their new and reissued permits. A monitoring frequency of 1/quarter will be included in the permit to be consistent with the recommendation from this SOP.

**Total Suspended Solids (TSS):**

The existing technology-based limits of 30.0 mg/L average monthly, 45.0 mg/L average weekly, and 60.0 mg/L instantaneous maximum will remain in the permit based on the minimum level of effluent quality attainable by secondary treatment based on 25 Pa. Code § 92a.47 47 and 40CFR 133.102(b). Recent DMRs and inspection reports show that the facility has been consistently achieving these limits. Mass limits are calculated as follows:

Average monthly mass limit: 30.0 mg/L x 0.6 MGD x 8.34 = 150.12 (150.0) lbs/day

Average weekly mass limit: 45.0 mg/L x 0.6 MGD x 8.34 = 225.18 (225.0) lbs/day

**Total Phosphorus:**

The discharge from this facility is located on Big Cove Creek which is impaired due to nutrients and siltation approximately 0.4 miles downstream from the discharge point. In order to prevent, the effluent phosphorus level must be controlled in accordance with 25 Pa Code § 96.5(c). The Department has determined that limits specified in the existing permit are appropriate (i.e., 2.0 mg/L (average monthly), 4.0 mg/L (instantaneous maximum)) as these limits have been assigned to other facilities with similar technology. Accordingly, existing TP limits will remain in the proposed permit. See the EPA guidance, Nutrient Criteria Technical Guidance Manual – Rivers and Streams, 07/2000 EPA-822-B-00-002, for more information about nutrient impacts on streams. Mass limits are calculated as follows:

Average monthly mass limit: 2.0 mg/L x 0.6 MGD x 8.34 = 10.0 lbs/day

**Total Residual Chlorine (TRC):**

The attached TRC\_CALC printout utilizes the equations and calculations as presented in the Department's 2003 Implementation Guidance for Total Residual Chlorine (TRC) (Document ID#391-2000-015) for developing chlorine limitations. The attached printout indicates average monthly limit of 0.056 mg/L and instantaneous maximum limit of 0.18 mg/L that would be needed to prevent toxicity concerns. The existing permit limits were 0.08 mg/L average monthly and 0.28 mg/L IMAX. However, recent DMRs and inspection reports were 0.04 mg/L average monthly & 0.16 mg/L IMAX that the facility has been consistently achieving these limits. Therefore, a limit of 0.056 mg/l AML, and 0.18 mg/l IMAX are more stringent and recommended for this permit cycle.

<b>TRC EVALUATION</b>															
Input appropriate values in A3:A9 and D3:D9															
Source	Reference	AFC Calculations			Reference	CFC Calculations									
TRC	<b>1.3.2.iii</b>	WLA_afc = <b>0.122</b>			<b>1.3.2.iii</b>	WLA_cfc = <b>0.112</b>									
PENTOXSD TRG	<b>5.1a</b>	LTAMULT_afc = <b>0.373</b>			<b>5.1c</b>	LTAMULT_cfc = <b>0.581</b>									
PENTOXSD TRG	<b>5.1b</b>	LTA_afc = <b>0.045</b>			<b>5.1d</b>	LTA_cfc = <b>0.065</b>									
Source															
Effluent Limit Calculations															
PENTOXSD TRG	<b>5.1f</b>	AML MULT = <b>1.231</b>			AFC										
PENTOXSD TRG	<b>5.1g</b>	AVG MON LIMIT (mg/l) = <b>0.056</b>			CFC										
		INST MAX LIMIT (mg/l) = <b>0.183</b>													
WLA_afc	$(.019/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k*AFC_tc))... \\ ... + Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$														
LTAMULT_afc	$EXP((0.5*LN(cvh^2+1))-2.326*LN(cvh^2+1)^0.5)$														
LTA_afc	wla_afc*LTAMULT_afc														
WLA_cfc	$(.011/e(-k*CFC_tc)) + [(CFC_Yc*Qs*.011/Qd*e(-k*CFC_tc))... \\ ... + Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$														
LTAMULT_cfc	$EXP((0.5*LN(cvd^2/no_samples+1))-2.326*LN(cvd^2/no_samples+1)^0.5)$														
LTA_cfc	wla_cfc*LTAMULT_cfc														
AML MULT	$EXP(2.326*LN((cvd^2/no_samples+1)^0.5)-0.5*LN(cvd^2/no_samples+1))$														
AVG MON LIMIT	$MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT)$														
INST MAX LIMIT	$1.5*((av_mon_limit/AML_MULT)/LTAMULT_afc)$														

**pH:**

The effluent discharge pH should remain above 6.0 and below 9.0 standard units according to 25 Pa. Code § 95.2(2).

**Temperature:**

The facility temperature is not of concern at this time and no monitoring or limitation is necessary.

**Toxics:**

Recommended WQBELs & Monitoring Requirements

No. Samples/Month:

Pollutants	Mass Limits		Concentration Limits				Governing WQBEL	WQBEL Basis	Comments
	AML (lbs/day)	MDL (lbs/day)	AML	MDL	IMAX	Units			

The data was analyzed based on the guidelines found in DEP's Water Quality Toxics Management Strategy (Document No. 361-0100-003) and DEP's SOP No. BPNPSM-PMT-033. Spreadsheet results are attached to this fact sheet (page 32-41). The Toxics Management Spreadsheet uses the following logic:

- Establish average monthly and IMAX limits in the draft permit where the maximum reported concentration exceeds 50% of the WQBEL.

- b. For non-conservative pollutants, establish monitoring requirements where the maximum reported concentration is between 25% - 50% of the WQBEL.
- c. For conservative pollutants, establish monitoring requirements where the maximum reported concentration is between 10%-50% of the WQBEL.

Pollutant testing results on the current (2021) application were reviewed in comparison with DEP's Toxic Management Spreadsheet, version 1.4, May 2023, output no recommends a routine monitoring and/or effluent limit requirements for any pollutants. Therefore, no monitoring requirements need in this proposed permit.

**Total Dissolved Solids (TDS):**

Total Dissolved Solids and its major constituents including Bromide, Chloride, and Sulfate have become statewide pollutants of concern and threats to DEP's mission to prevent violations of water quality standards. The requirement to monitor these pollutants must be considered under the criteria specified in 25 Pa. Code § 95.10 and the following January 23, 2014 DEP Central Office Directive:

For point source discharges and upon issuance or reissuance of an individual NPDES permit:

- Where the concentration of TDS in the discharge exceeds 1,000 mg/L, or the net TDS load from a discharge exceeds 20,000 lbs/day, and the discharge flow exceeds 0.1 MGD, Part A of the permit should include monitor and report for TDS, sulfate, chloride, and bromide. Discharges of 0.1 MGD or less should monitor and report for TDS, sulfate, chloride, and bromide if the concentration of TDS in the discharge exceeds 5,000 mg/L.
- Where the concentration of bromide in a discharge exceeds 1 mg/L and the discharge flow exceeds 0.1 MGD, Part A of the permit should include monitor and report for bromide. Discharges of 0.1 MGD or less should monitor and report for bromide if the concentration of bromide in the discharge exceeds 10 mg/L.
- Where the concentration of 1,4-dioxane (CAS 123-91-1) in a discharge exceeds 10 µg/L and the discharge flow exceeds 0.1 MGD, Part A of the permit should include monitor and report for 1,4-dioxane. Discharges of 0.1 MGD or less should monitor and report for 1,4-dioxane if the concentration of 1,4-dioxane in the discharge exceeds 100 µg/L.

McConnellsburg Sewage Authority reported the maximum effluent TDS concentration of 448 mg/L, chloride concentration of 89.7 mg/L, sulfate concentration of 90.1 mg/L, and Bromide concentration of <0.011 mg/L. Based upon the data provided in the application, monitor requirements for TDS, Sulfate, Chloride, and Bromide are not needed in the permit.

**Stormwater:**

There is no stormwater outfall associated with this facility.

**Oil and Grease:**

The facility historically had no issues in regard to the presence of Oil and Grease in the effluent (also no visible film on the surface of the receiving water). Therefore, no monitoring of Oil and Grease is necessary.

**Hauled-in wastes:**

According to the permit renewal application, the hauled-in wastes are as follows:

Source Name	Gallons received	Location received	% Solids
Todd Township WWTP Sludge	15,000	Wasting at pit at Sludge Pumping Facility	1.6%
Hustontown Joint Sewer Auth WWTP Sludge	25,000	Wasting at pit at Sludge Pumping Facility	1.17%
Guest Farm Village Sewer Auth WWTP Sludge	20,000	Wasting at pit at Sludge Pumping Facility	1.34%

PAG073522 general permit was issued on March 6, 2018 to the permittee to handle Exceptional Quality Biosolids.

**Chesapeake Bay:**

In the Phase 3 WIP Wastewater Supplement revised on July 29, 2022, Table 5 of this document shows that McConnellsburg Borough has been allocated 10,959 lbs/year of TN and 1,461 lbs/year of TP. This approach is consistent with the Chesapeake Bay TMDL was based on the actual performance data previously evaluated by the Department. Since the permittee is easily capable of achieving compliance with these loads, the Department determines that no "compliance schedule" for the requirements associated with the Chesapeake Bay Strategy is necessary. Accordingly, the Chesapeake Bay nutrient existing limitations and monitoring requirements will remain in the proposed permit.

Phase 3 WIP Wastewater Supplement  
Revised, July 29, 2022

Table 5: Significant Chesapeake Bay Sewage NPDES Permits Issued

NPDES Permit No.	Phase	Facility	Latest Permit Issuance Date	Permit Expiration Date	Cap Load Compliance Start Date	TN Cap Load (lbs/yr)	TN Offsets Included in Cap Load (lbs/yr)	TP Cap Load (lbs/yr)	TN Delivery Ratio	TP Delivery Ratio
PA0020036	3	Blossburg Borough	6/2/2022	6/30/2027	10/1/2012	7,306	-	974	0.521	0.339
PA0020214	3	Mount Union Borough	4/17/2017	4/30/2022	10/1/2013	20,091	-	2,679	0.790	0.351
PA0020249	3	Roaring Spring Borough	1/31/2020	1/31/2025	1/1/2016	12,785	-	1,705	0.713	0.519
PA0020273	2	Milton Regional Sewage Authority	9/25/2017	9/30/2022	10/1/2009	72,217	-	10,049	0.816	.0461
PA0020320	1	Lititz Sewer Authority	7/19/2019	6/30/2023	10/1/2010	70,319	-	9,376	0.593	0.581
PA0020338	3	Kulpmont-Marion Heights Joint Municipal Authority	6/29/2022	6/30/2027	10/1/2011	9,132	-	1,218	0.693	0.386
PA0020486	1	Bellefonte Borough	6/1/2019	5/31/2024	10/1/2010	58,812	-	7,842	0.647	0.333
PA0020508	3	McConnellsburg Borough	1/14/2021	1/30/2026	10/1/2012	10,959	1	1,461	0.700	0.550
PA0020567	3	Northumberland Borough	1/17/2018	9/31/2023	10/1/2012	20,548	-	2,740	0.807	0.462
PA0020583	2	Middleburg Municipal Authority	7/16/2020	7/31/2025	10/1/2012	8,219	-	1,096	0.768	0.322
PA0020621	2	Waynesboro Borough	9/14/2018	9/30/2023	10/1/2013	29,223	-	3,896	0.864	0.725
PA0020664	1	Middletown STP	2/16/2021	2/28/2026	10/1/2011	40,182	-	5,358	0.837	0.503
PA0020800	3	White Deer Township	2/10/2021	2/28/2026	10/1/2011	10,959	-	1,461	0.789	0.448
PA0020818	2	Glen Rock Sewer Authority	9/29/2021	9/30/2026	10/1/2012	10,959	-	1,461	0.750	0.397
PA0020826	1	Dover Township Sewer Authority	6/2/2017	6/30/2022	10/1/2010	146,117	-	19,482	0.543	0.185
PA0020834	2	Franklin County Authority – Greencastle	5/21/2021	5/31/2026	10/1/2012	17,351	-	2,314	0.971	0.742
PA0020885	1	Mechanicsburg Borough Municipal Authority	4/27/2017	4/30/2022	10/1/2012	37,990	-	5,065	0.831	0.492
PA0020893	1	Manheim Borough Authority	3/16/2022	3/31/2027	10/1/2011	20,822	-	2,776	0.819	0.477
PA0020915	2	Pine Grove Borough Authority	3/21/2022	3/31/2027	10/1/2012	27,397	-	3,653	0.511	0.403
PA0020923	1	New Oxford Municipal Authority	11/15/2021	11/30/2026	10/1/2011	32,657	-	4,354	0.631	0.189
PA0021067	1	Mount Joy Borough	2/18/2021	2/28/2026	10/1/2010	27,945	-	3,726	0.698	0.477
PA0021229	3	Littlestown Borough	7/21/2020	7/31/2025	10/1/2014	18,265	-	2,435	0.570	0.720

- 6 -

### Anti-Degradation Requirement

Chapter 93.4a(b) of the Department's rules and regulations require that "Existing instream water uses and the level of water quality necessary to protect the existing uses shall be maintained and protected." The discharge is into Big Cove Creek which is classified as Cold-Water Fishes (CWF) and Migratory Fishes (MF.) No High Quality (HQ) Waters are impacted by this discharge. No Exceptional Value (EV) Waters are impacted by this discharge.

### Class A Wild Trout Streams:

No Class A Wild Trout Fishery will be impacted by this discharge.

### 303d Listed Streams:

The discharge from this facility is to Big Cove Creek. This creek is impaired due to nutrients and siltation approximately 0.4 miles downstream from the discharge point, after the confluence with tributary 60577 to Big Cove Creek. The previous permit engineer mentioned that the permittee is aware about the future TMDL and was planning a design for phosphorous removal that can be expanded to meet more stringent limits in future based on the outcome of the TMDL.

*	Discharge pH	=	7.0	(Default)
*	Discharge Temperature	=	20°C	(Default)
*	Stream pH	=	7.0	(Default)
*	Stream Temperature	=	20°C	(Default)
*	Background NH <sub>3</sub> -N	=	0 mg/L	(Default)

The following two nodes were used in modeling:

Node 1: Outfall 001 on Big Cove Creek (60482)  
 Elevation: 848.58 ft (USGS National Map Viewer)  
 Drainage Area: 7.4 mi.<sup>2</sup> (USGS PA StreamStats)  
 River Mile Index: 15.13 (PA DEP eMapPA)  
 Low Flow Yield: 0.038 cfs/mi.<sup>2</sup>  
 Discharge Flow: 0.6 MGD

Node 2: At the confluence with Tributary 60674 to Big Cove Creek  
 Elevation: 815.2 ft (USGS National Map Viewer)  
 Drainage Area: 11.1 mi.<sup>2</sup> (USGS PA StreamStats)  
 River Mile Index: 13.645 (PA DEP eMapPA)  
 Low Flow Yield: 0.038 cfs/mi.<sup>2</sup>  
 Discharge Flow: 0.0 MGD

Analysis Results WQM 7.0

Hydrodynamics NH3-N Allocations D.O. Allocations D.O. Simulation Effluent Limitations

RMI	Discharge Name	Permit Number	Disc. Flow (mgd)	
15.13	McConnellsburg	PA0020508	0.6000	
		Effluent Limit 30 Day Average (mg/L)	Effluent Limit Maximum (mg/L)	Effluent Limit Minimum (mg/L)
	CBOD5	17.51		
	NH3-N	2.66	5.32	
	Dissolved Oxygen			5

Record: 1 of 1 | < Back | Next > | No Filter | Search |

Print | Archive | Cancel |

NPDES Permit Fact Sheet  
McConnellsburg STP

NPDES Permit No. PA0020508

**WQM 7.0 Effluent Limits**

SWP Basin	Stream Code	Stream Name
13B	80402	BIG COVE CREEK

RM	Name	Permit Number	Disch. Flow (mg/L)	Parameter	Eff. Limit 30-day Avg. (mg/L)	Eff. Limit Maximum (mg/L)	Eff. Limit Minimum (mg/L)
15.130	McConnellsburg	PA0020508	0.800	CBOD5	17.51		
				NH3-N	2.88	5.32	
				Dissolved Oxygen	5		

Wednesday, November 19, 2025 Version 1.1 Page 1 of 1

**WQM 7.0 Wasteload Allocations**

SWP Basin	Stream Code	Stream Name
13B	80402	BIG COVE CREEK

NH3-N Acute Allocations						
RM	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach
15.130	McConnellsburg	16.76	20.01	16.76	20.01	0

NH3-N Chronic Allocations						
RM	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach
15.130	McConnellsburg	1.59	2.88	1.59	2.88	0

Dissolved Oxygen Allocations						
RM	Discharge Name	CBOD5 Baseline (mg/L)	CBOD5 Multiple (mg/L)	NH3-N Baseline (mg/L)	NH3-N Multiple (mg/L)	Dissolved Oxygen Baseline (mg/L)
15.13	McConnellsburg	17.51	17.51	2.88	2.88	5

Wednesday, November 19, 2025 Version 1.1 Page 1 of 1

**WQM 7.0 D.O. Simulation**

SWP Basin	Stream Code	Stream Name
13B	80402	BIG COVE CREEK

RM	Total Discharge Flow (mg/L)	Analytic Temperature (°C)	Analytic pH
15.130	0.800	20.00	7.000
Reach Width (ft)	Reach Depth (ft)	Reach W/S Ratio	Reach Velocity (ips)
15.525	0.525	20.00	0.148
Reach CBOD5 (mg/L)	Reach Kd (days)	Reach NH3-N (mg/L)	Reach DO (days)
15.130	0.000	7.8	7.0
Reach DO (mg/L)	Reach Kt (days)	Kd (mg/L)	Reach DO Goal (mg/L)
5.54	8.008	1.000	5
Reach Travel Time (days)			
0.611			

Inv. Time	Subreach Results
(days)	CBOD5 (mg/L) NH3-N (mg/L) D.O. (mg/L)
0.081	13.08 1.58 5.44
0.122	12.30 1.58 5.09
0.183	11.57 1.58 5.27
0.245	10.88 1.52 5.31
0.306	10.24 1.45 5.41
0.367	9.63 1.38 5.53
0.428	9.08 1.32 5.68
0.489	8.52 1.25 5.83
0.550	8.01 1.19 5.99
0.611	7.54 1.13 6.14

Wednesday, November 19, 2025 Version 1.1 Page 1 of 1

**WQM 7.0 Modeling Specifications**

Parameter	Value	Notes
WLA Method	EMPR	Use Impacted WLA Ratio
Q-10/Q-10 Ratio	0.84	Use Impacted Reach Travel Time
Q30-10/Q-10 Ratio	1.38	Temperature Adjust Rr
D.O. Saturation	90.00%	Use Balanced Technology
D.O. Goal	5	

Wednesday, November 19, 2025 Version 1.1 Page 1 of 1

NPDES Permit Fact Sheet  
McConnellsburg STP

NPDES Permit No. PA0020508

**rptHydro**

**WQM 7.0 Hydrodynamic Outputs**

SWP Basin	Stream Code	Stream Name: BIG COVE CREEK												
SWP Basin	Stream Code	Stream Name	FWL	Stream Flow (cfs)	Net Flow (cfs)	Net Flow (cfs)	Reach Slope (ft/ft)	Reach Depth (ft)	Width (ft)	WD Ratio (ft/ft)	Reach Velocity (ft/s)	Reach Temp (deg F)	Analysis Temp (deg C)	Analysis pH
13.00	60482		13.00	0.28	0.28	0.28	0.0426	.525	15.53	29.8	0.13	0.611	20.00	7.00
<b>Q1-10 Flow</b>														
13.00	0.28	0.28	0.28	0.0426	NA	NA	NA	NA	NA	NA	0.14	0.642	20.00	7.00
<b>Q30-10 Flow</b>														
13.00	0.28	0.28	0.28	0.0426	NA	NA	NA	NA	NA	NA	0.16	0.584	20.00	7.00

Wednesday, November 19, 2025      Version 1.1      Page 1 of 1

**rptGeneral**

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	FWL	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
13.0	60482	BIG COVE CREEK	13.840	815.20	11.10	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow (cfs)	Stream Flow (cfs)	Rich Time (days)	Rich Velocity (ft/s)	WD Ratio (ft/ft)	Rich Width (ft)	Rich Depth (ft)	Interflow pH	Temp (°C)	Stream pH
QF-10	0.038	0.00	0.00	0.0000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10	0.00	0.00	0.00	0.0000	0.0	0.00	0.00	0.00	0.00	0.00	0.00
Q30-10	0.00	0.00	0.00	0.0000	0.0	0.00	0.00	0.00	0.00	0.00	0.00

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Disc Reserve Factor	Disc Temp (°C)	Disc pH
McConnellsburg	PA0020508	0.8000	0.8000	0.8000	0.0000	20.00	7.00

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/day)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	5.00	8.24	0.00	0.00
NH3N	25.00	0.00	0.00	0.70

Wednesday, November 19, 2025      Version 1.1      Page 1 of 2

**rptGeneral**

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	FWL	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
13.0	60482	BIG COVE CREEK	13.845	815.20	11.10	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow (cfs)	Stream Flow (cfs)	Rich Time (days)	Rich Velocity (ft/s)	WD Ratio (ft/ft)	Rich Width (ft)	Rich Depth (ft)	Interflow pH	Temp (°C)	Stream pH
QF-10	0.038	0.00	0.00	0.0000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10	0.00	0.00	0.00	0.0000	0.0	0.00	0.00	0.00	0.00	0.00	0.00
Q30-10	0.00	0.00	0.00	0.0000	0.0	0.00	0.00	0.00	0.00	0.00	0.00

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Disc Reserve Factor	Disc Temp (°C)	Disc pH
McConnellsburg	PA0020508	0.0000	0.0000	0.0000	0.0000	20.00	7.00

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/day)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	5.00	8.24	0.00	0.00
NH3N	25.00	0.00	0.00	0.70

Wednesday, November 19, 2025      Version 1.1      Page 2 of 2

18

NPDES Permit Fact Sheet  
McConnellsburg STP

NPDES Permit No. PA0020508

Toxic:

- Discharge pH = 7.2 (average 2025 renewal application)
- Discharge Hardness = 100 mg/L (Default)
- Stream pH = 7.0 (Default)
- Stream Hardness = 100 mg/L (Default)
- Background NH<sub>3</sub>-N = 0 mg/L (Default)

Node 1: Outfall 001 on Big Cove Creek (60482)

Elevation: 848.58 ft (USGS National Map Viewer)  
Drainage Area: 7.4 mi.<sup>2</sup> (USGS PA StreamStats)  
River Mile Index: 15.13 (PA DEP eMapPA)  
Low Flow Yield: 0.038 cfs/mi.<sup>2</sup>  
Discharge Flow: 0.6 MGD

Node 2: At the confluence with Tributary 60674 to Big Cove Creek

Elevation: 815.2 ft (USGS National Map Viewer)  
Drainage Area: 11.1 mi.<sup>2</sup> (USGS PA StreamStats)  
River Mile Index: 13.645 (PA DEP eMapPA)  
Low Flow Yield: 0.038 cfs/mi.<sup>2</sup>  
Discharge Flow: 0.0 MGD

Recommended WQBELs & Monitoring Requirements

No. Samples/Month:

Pollutants	Mass Limits		Concentration Limits				Governing WQBEL	WQBEL Basis	Comments
	AML (lbs/day)	MDL (lbs/day)	AML	MDL	IMAX	Units			



Toxics Management Spreadsheet  
Version 1.4, May 2023

Discharge Information

Instructions			Discharge	Stream																																																																																																															
Facility:	McConnellsburg Sewerage Authority	NPDES Permit No.:	PA0020508	Outfall No.:	001																																																																																																														
Evaluation Type:	Custom / Additives	Wastewater Description:	Big Cove Creek																																																																																																																
<table border="1"> <thead> <tr> <th colspan="3">Discharge Characteristics</th> <th colspan="3">Partial Mix Factors (PMFs)</th> <th colspan="3">Complete Mix Times (min)</th> </tr> <tr> <th>Design Flow (MGD)*</th> <th>Hardness (mg/l)*</th> <th>pH (SU)*</th> <th>AFC</th> <th>CFC</th> <th>THH</th> <th>CRL</th> <th>Q<sub>7-10</sub></th> <th>Q<sub>b</sub></th> </tr> </thead> <tbody> <tr> <td>0.6</td> <td>100</td> <td>7.2</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>						Discharge Characteristics			Partial Mix Factors (PMFs)			Complete Mix Times (min)			Design Flow (MGD)*	Hardness (mg/l)*	pH (SU)*	AFC	CFC	THH	CRL	Q <sub>7-10</sub>	Q <sub>b</sub>	0.6	100	7.2																																																																																									
Discharge Characteristics			Partial Mix Factors (PMFs)			Complete Mix Times (min)																																																																																																													
Design Flow (MGD)*	Hardness (mg/l)*	pH (SU)*	AFC	CFC	THH	CRL	Q <sub>7-10</sub>	Q <sub>b</sub>																																																																																																											
0.6	100	7.2																																																																																																																	
<table border="1"> <thead> <tr> <th rowspan="2">Discharge Pollutant</th> <th rowspan="2">Units</th> <th rowspan="2">Max Discharge Conc</th> <th colspan="2">0 if left blank</th> <th colspan="2">0.5 if left blank</th> <th colspan="2">0 if left blank</th> <th colspan="2">1 if left blank</th> </tr> <tr> <th>Trib Conc</th> <th>Stream Conc</th> <th>Daily CV</th> <th>Hourly CV</th> <th>Stream CV</th> <th>Fate Coeff</th> <th>FOS</th> <th>Criteria Mod</th> <th>Chem Transl</th> </tr> </thead> <tbody> <tr> <td>Total Dissolved Solids (PWS)</td> <td>mg/L</td> <td>448</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Chloride (PWS)</td> <td>mg/L</td> <td>89.7</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Bromide</td> <td>mg/L</td> <td>&lt; 0.011</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Sulfate (PWS)</td> <td>mg/L</td> <td>90.1</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Total Copper</td> <td>mg/L</td> <td>0.0122</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Total Lead</td> <td>mg/L</td> <td>0.00059</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Total Zinc</td> <td>mg/L</td> <td>0.0576</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Total Chromium</td> <td>mg/L</td> <td>&lt; 0.00199</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Total Nickel</td> <td>mg/L</td> <td>0.00351</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>						Discharge Pollutant	Units	Max Discharge Conc	0 if left blank		0.5 if left blank		0 if left blank		1 if left blank		Trib Conc	Stream Conc	Daily CV	Hourly CV	Stream CV	Fate Coeff	FOS	Criteria Mod	Chem Transl	Total Dissolved Solids (PWS)	mg/L	448								Chloride (PWS)	mg/L	89.7								Bromide	mg/L	< 0.011								Sulfate (PWS)	mg/L	90.1								Total Copper	mg/L	0.0122								Total Lead	mg/L	0.00059								Total Zinc	mg/L	0.0576								Total Chromium	mg/L	< 0.00199								Total Nickel	mg/L	0.00351							
Discharge Pollutant	Units	Max Discharge Conc	0 if left blank		0.5 if left blank				0 if left blank		1 if left blank																																																																																																								
			Trib Conc	Stream Conc	Daily CV	Hourly CV	Stream CV	Fate Coeff	FOS	Criteria Mod	Chem Transl																																																																																																								
Total Dissolved Solids (PWS)	mg/L	448																																																																																																																	
Chloride (PWS)	mg/L	89.7																																																																																																																	
Bromide	mg/L	< 0.011																																																																																																																	
Sulfate (PWS)	mg/L	90.1																																																																																																																	
Total Copper	mg/L	0.0122																																																																																																																	
Total Lead	mg/L	0.00059																																																																																																																	
Total Zinc	mg/L	0.0576																																																																																																																	
Total Chromium	mg/L	< 0.00199																																																																																																																	
Total Nickel	mg/L	0.00351																																																																																																																	



## Stream / Surface Water Information

McConnellsburg Sewerage Authority, NPDES Permit No. PA0020508, Outfall 001

Instructions Discharge Stream

Receiving Surface Water Name: **Big Cove Creek**

No. Reaches to Model: **1**

Statewide Criteria  
 Great Lakes Criteria  
 ORSANCO Criteria

Location	Stream Code*	RMI*	Elevation (ft)*	DA (mi <sup>2</sup> )*	Slope (ft/ft)	PWS Withdrawal (MGD)	Apply Fish Criteria*
Point of Discharge	060482	15.13	848.58	7.4			Yes
End of Reach 1	060482	13.645	815.2	11.1			Yes

**Q<sub>7-10</sub>**

Location	RMI	LFY (cfs/mi <sup>2</sup> )*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness*	pH*	Hardness	pH
Point of Discharge	15.13	0.038										100	7		
End of Reach 1	13.645	0.038													

**Q<sub>h</sub>**

Location	RMI	LFY (cfs/mi <sup>2</sup> )*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness*	pH*	Hardness	pH
Point of Discharge	15.13														
End of Reach 1	13.645														

Stream / Surface Water Information

11/19/2025

Page 2



Toxics Management Spreadsheet  
Version 1.4, May 2023

## Model Results

McConnellsburg Sewerage Authority, NPDES Permit No. PA0020508, Outfall 001

Instructions Results RETURN TO INPUTS SAVE AS PDF PRINT All Inputs Results Limits

Hydrodynamics

Wasteload Allocations

AFC

CCT (min): **0.721**

PMF: **1**

Analysis Hardness (mg/l): **100**

Analysis pH: **7.14**

Pollutants	Stream Conc (mg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Total Copper	0	0		0	13.439	14.0	18.2	Chem Translator of 0.96 applied
Total Lead	0	0		0	64.581	81.6	106	Chem Translator of 0.791 applied
Total Zinc	0	0		0	117.180	120	156	Chem Translator of 0.978 applied
Total Nickel	0	0		0	468.236	469	611	Chem Translator of 0.968 applied

CFC

CCT (min): **0.721**

PMF: **1**

Analysis Hardness (mg/l): **100**

Analysis pH: **7.14**

Pollutants	Stream Conc (mg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Total Copper	0	0		0	8.956	9.33	12.2	Chem Translator of 0.96 applied
Total Lead	0	0		0	2.517	3.18	4.15	Chem Translator of 0.791 applied
Total Zinc	0	0		0	118.139	120	156	Chem Translator of 0.986 applied
Total Nickel	0	0		0	52.007	52.2	68.0	Chem Translator of 0.997 applied

THH

CCT (min): **0.721**

PMF: **1**

Analysis Hardness (mg/l): **N/A**

Analysis pH: **N/A**

Pollutants	Stream Conc (mg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	500,000	500,000	N/A	

NPDES Permit Fact Sheet  
McConnellsburg STP

NPDES Permit No. PA0020508

Chloride (PWS)	0	0		0	250,000	250,000	N/A	
Sulfate (PWS)	0	0		0	250,000	250,000	N/A	
Total Copper	0	0		0	N/A	N/A	N/A	
Total Lead	0	0		0	N/A	N/A	N/A	
Total Zinc	0	0		0	N/A	N/A	N/A	
Total Nickel	0	0		0	610	610	795	

CRL

CCT (min): 3,560

PMF: 1

Analysis Hardness (mg/l):

N/A

Analysis pH: N/A

Pollutants	Stream Conc (μg/L)	Stream CV	Trib Conc (μg/L)	Fate Coef	WQC (μg/L)	WQ Obj (μg/L)	WLA (μg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Total Copper	0	0		0	N/A	N/A	N/A	
Total Lead	0	0		0	N/A	N/A	N/A	
Total Zinc	0	0		0	N/A	N/A	N/A	
Total Nickel	0	0		0	N/A	N/A	N/A	

Recommended WQBELs & Monitoring Requirements

No. Samples/Month: 4

Pollutants	Mass Limits		Concentration Limits					Governing WQBEL	WQBEL Basis	Comments
	AML (lbs/day)	MDL (lbs/day)	AML	MDL	IMAX	Units				

Other Pollutants without Limits or Monitoring

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., <= Target QL).

Pollutants	Governing WQBEL	Units	Comments
Total Dissolved Solids (PWS)	N/A	N/A	PWS Not Applicable
Chloride (PWS)	N/A	N/A	PWS Not Applicable
Bromide	N/A	N/A	No WQS
Sulfate (PWS)	N/A	N/A	PWS Not Applicable
Total Copper	12.2	μg/L	Discharge Conc ≤ 10% WQBEL
Total Lead	4.15	μg/L	Discharge Conc ≤ 10% WQBEL
Total Zinc	120	μg/L	Discharge Conc ≤ 10% WQBEL
Total Chromium	N/A	N/A	No WQS
Total Nickel	68.0	μg/L	Discharge Conc ≤ 10% WQBEL


Model Results

11/19/2025

Page 4

NPDES Permit Fact Sheet  
McConnellsburg STP

NPDES Permit No. PA0020508



**USGS StreamStats**

StreamStats is a web-based tool for calculating streamflow characteristics. To use it, enter the stream name or number, then select the types of reports you wish to generate. Then click the "Build Report" button.

**Basin Characteristics**

Parameter	Value
DRNAREA	7.4
PRECIP	41
STRDEN	3.1
ROCKDEP	5.3
CARBON	50.86

**Select available reports to display:**

- ✓ Basin Characteristics Report
- ✓ Scenario Flow Reports
- Hydrologic Features Report

**Open Report**

POWERED BY WIM

USGS Home Contact USGS Search USGS

**Basin Characteristics**

Parameter Code	Parameter Description	Value	Unit
CARBON	Percentage of area of carbonate rock	50.86	percent
DRNAREA	Area that drains to a point on a stream	7.4	square miles
PRECIP	Mean Annual Precipitation	41	inches
ROCKDEP	Depth to rock	5.3	feet
STRDEN	Stream Density -- total length of streams divided by drainage area	3.1	miles per square mile

**Low-Flow Statistics**


**Low-Flow Statistics Parameters [Low Flow Region 2]**

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
CARBON	Percent Carbonate	50.86	percent	0	99
DRNAREA	Drainage Area	7.4	square miles	4.93	1280
PRECIP	Mean Annual Precipitation	41	inches	35	50.4
ROCKDEP	Depth to Rock	5.3	feet	3.32	5.65
STRDEN	Stream Density	3.1	miles per square mile	0.51	3.1

**Low-Flow Statistics Flow Report [Low Flow Region 2]**

PIL: Lower 90% Prediction Interval, PIU: Upper 90% Prediction Interval, ASEp: Average Standard Error of Prediction, SE: Standard Error, PC: Percent Correct, RMSE: Root Mean Squared Error, PseudoR<sup>2</sup>: Pseudo R Squared (other - see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	1.07	ft <sup>3</sup> /s	38	38
30 Day 2 Year Low Flow	1.29	ft <sup>3</sup> /s	33	33
7 Day 10 Year Low Flow	0.641	ft <sup>3</sup> /s	51	51
30 Day 10 Year Low Flow	0.747	ft <sup>3</sup> /s	46	46
90 Day 10 Year Low Flow	0.89	ft <sup>3</sup> /s	36	36



# NPDES Permit Fact Sheet

## McConnellsburg STP

NPDES Permit No. PA0020508

**USGS StreamStats**

**BUILD A REPORT** Report Built

Step 1: You can modify computed basin characteristics here, then select the types of reports you wish to generate. Then click the "Build Report" button

Hide Basin Characteristics

Basin Characteristics can be edited here

Parameter	Value
DRNAREA	159
PRECIP	39
STRDEN	2.71
ROCKDEP	4.1
CARBON	15.95

Select available reports to display:

- Basin Characteristics Report
- Scenario Flow Reports
- Hydrologic Features Report

**Open Report**

Zoom Level: Map Scale: Lat: 39.650 Lng: -78.750

**Basin Characteristics**

Parameter Code	Parameter Description	Value	Unit
CARBON	Percentage of area of carbonate rock	15.95	percent
DRNAREA	Area that drains to a point on a stream	159	square miles
PRECIP	Mean Annual Precipitation	39	inches
ROCKDEP	Depth to rock	4.1	feet
STRDEN	Stream Density -- total length of streams divided by drainage area	2.71	miles per square mile

**Low-Flow Statistics**


Low-Flow Statistics Parameters [Low Flow Region 2]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
CARBON	Percent Carbonate	15.95	percent	0	99
DRNAREA	Drainage Area	159	square miles	4.93	1280
PRECIP	Mean Annual Precipitation	39	inches	35	50.4
ROCKDEP	Depth to Rock	4.1	feet	3.32	5.65
STRDEN	Stream Density	2.71	miles per square mile	0.51	3.1

Low-Flow Statistics Flow Report [Low Flow Region 2]

PIL: Lower 90% Prediction Interval, PIU: Upper 90% Prediction Interval, ASE: Average Standard Error of Prediction, SE: Standard Error, PC: Percent Correct, RMSE: Root Mean Squared Error, PseudoR<sup>2</sup>: Pseudo R Squared (other - see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	12.6	ft <sup>3</sup> /s	38	38
30 Day 2 Year Low Flow	17	ft <sup>3</sup> /s	33	33
7 Day 10 Year Low Flow	6.03	ft <sup>3</sup> /s	51	51
30 Day 10 Year Low Flow	8.31	ft <sup>3</sup> /s	46	46
90 Day 10 Year Low Flow	12.5	ft <sup>3</sup> /s	36	36



**USGS StreamStats**

characteristics here, then select the types of reports you wish to generate. Then click the "Build Report" button

Hide Basin Characteristics

Basin Characteristics can be edited here

Parameter	Value
DRNAREA	11.1
PRECIP	41
STRDEN	2.81
ROCKDEP	5.3
CARBON	55.82

Select available reports to display:

- Basin Characteristics Report
- Scenario Flow Reports
- Hydrologic Features Report

**Open Report**

Zoom Level: Map Scale: Lat: 39.950 Lng: -78.750

**Basin Characteristics**

Parameter Code	Parameter Description	Value	Unit
CARBON	Percentage of area of carbonate rock	55.82	percent
DRNAREA	Area that drains to a point on a stream	11.1	square miles
PRECIP	Mean Annual Precipitation	41	inches
ROCKDEP	Depth to rock	5.3	feet
STRDEN	Stream Density -- total length of streams divided by drainage area	2.81	miles per square mile

**Low-Flow Statistics**


Low-Flow Statistics Parameters [Low Flow Region 2]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
CARBON	Percent Carbonate	55.82	percent	0	99
DRNAREA	Drainage Area	11.1	square miles	4.93	1280
PRECIP	Mean Annual Precipitation	41	inches	35	50.4
ROCKDEP	Depth to Rock	5.3	feet	3.32	5.65
STRDEN	Stream Density	2.81	miles per square mile	0.51	3.1

Low-Flow Statistics Flow Report [Low Flow Region 2]

PIL: Lower 90% Prediction Interval, PIU: Upper 90% Prediction Interval, ASE: Average Standard Error of Prediction, SE: Standard Error, PC: Percent Correct, RMSE: Root Mean Squared Error, PseudoR<sup>2</sup>: Pseudo R Squared (other - see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	1.92	ft <sup>3</sup> /s	38	38
30 Day 2 Year Low Flow	2.27	ft <sup>3</sup> /s	33	33
7 Day 10 Year Low Flow	1.2	ft <sup>3</sup> /s	51	51
30 Day 10 Year Low Flow	1.37	ft <sup>3</sup> /s	46	46
90 Day 10 Year Low Flow	1.59	ft <sup>3</sup> /s	36	36



23

McConnellsburg Sewerage Authority  
Renewal of NPDES Permit No. PA0020508  
Industrial / Commercial Wastewater Contributors

Business Name	Type of Business	Average Wastewater Flow (MGD)
Peck Insurance Agency	Office	0.00017
Countryside Coin Laundry	Laundromat	0.00119
Quick 'n Easy Auto Wash	Car Wash	0.00085
Door of Hope Church	Church	0.00017
Giant	Grocery Store	0.00119
Wine & Spirits Store #2901	Retail Store	0.00017
Arch Telecom	Retail Store	0.00017
Sheetz	Gas Station and Convenience Store	0.00051
A & M Fitness	Fitness Center	0.00017
A to Z Land Consulting Services LLC	Office	0.00017
Wells Fargo	Office	0.00017
Bedford/Fulton Head Start	Childcare	0.00017
Saint Stephen Catholic Church	Church	0.00034
Antietam Iron Center	Offices	0.00017
Clugston's Market	Retail Store	0.00017
AutoZone	Auto Parts Store	0.00017
Fulton Pub	Restaurant	0.00034
Dorothy Berry Beauty Salon	Beauty Salon	0.00017
Main Moon Chinese Restaurant	Restaurant	0.00017
Krazy Rays BBQ	Restaurant	0.00051
Save-A-Lot	Grocery Store	0.00051
McLaughlin Drug Store	Retail Store	0.00017
Family Dollar	Retail Store	0.00017
Buchanan Trail Sportsters	Retail Store	0.00017
Eddy's Engraving	Retail Store	0.00017
Area Agency on Aging	Office	0.00017
Boost Mobile	Retail Store	0.00017
PA Health Department	Office	0.00017
Vape Kings	Retail Store	0.00017
Fendley Financial	Office	0.00017
Michael Binder Garage	Auto Repair	0.00017
Ridgeline	Auto Body Shop	0.00017
Michael Binder Office Building	Offices	0.00051
Borough of McConnellsburg	Office	0.00017
Randy Bunch Rentals	Beauty Salon/Spa	0.00051
Fulton Post American Legion	Civic/Social Hall	0.00136
Center for Community Action	Offices	0.00085
Central Fulton School District	Public School	0.01445
William Clevenger Rentals	Food Stands	0.00034
Agway	Retail Store	0.00017
Community State Bank of Orbisonia	Bank	0.00017
Conair Corporation / Waring Products	Manufacturer of electric housewares	0.00204
Kelso-Cornelius Funeral Home	Funeral Home	0.00017
County of Fulton	County Agency Offices	0.00289
Fulton County Senior Center	Community Hall	0.00017
Great Cove Road Partnership	Office	0.00017

**NPDES Permit Fact Sheet**  
**McConnellsburg STP**

**NPDES Permit No. PA0020508**

Business Name	Type of Business	Average Wastewater Flow (MGD)
Great Cove Road Partnership	Auto Repair	0.00017
P & H Flooring	Retail Store	0.00017
Kwality Karpets	Retail Store	0.00017
Flawless Roots by Alena Everts	Beauty Salon	0.00017
Evangel Assembly of God	Church	0.00017
F & M Trust Company	Bank	0.00068
F & M Trust Company	Community Hall	0.00017
Olde Town Kitchen	Restaurant	0.00017
Fulton County Historical Society	Museum	0.00017
Fulton County Library Inc	Library	0.00017
Fulton Precision Industries	Precision Machining	0.00238
Gerald R Peck Transportation	Office	0.00017
CG Racing Engines	Auto Repair	0.00017
Fulton County News	Newspaper Office	0.00017
McConnellsburg True Value	Retail Store	0.00017
McConnellsburg Veterinary Clinic	Veterinarian	0.00017
Howard Sipes, Inc	Funeral Home	0.00017
Missy's Outlet	Retail Store	0.00017
JLG Industries Inc	Manufacturer of access equipment	0.02686
Dollar General	Retail Store	0.00017
Fulton County Chiropractic	Chiropractor Office	0.00017
Junction Motel	Motel	0.00136
John A Kelso Garage	Auto Repair	0.00017
Dr. Rachel Kendall, DMD	Dentist Office	0.00017
Travis Kendall	Office	0.00017
Law Office of Stanley Kerlin	Law Office	0.00017
Joey L. Lane, OD	Eye Doctor Office	0.00017
Lake Insurance	Office	0.00017
Souders Garage	Auto Repair	0.00017
Ed Lininger Plumbing, Heating & AC	Office - Plumbing & HVAC Contractor	0.00017
Marmon/Keystone LLC	Distributor of pipe, tubing, and speciality bar	0.00017
McConnellsburg Alumni Building	Community Hall	0.00017
McConnellsburg Citgo	Gas Station and Repair Shop	0.00034
McConnellsburg United Presbyterian Church	Church	0.00017
McConnellsburg Volunteer Fire Co	Fire Company	0.00034
McDonald's	Restaurant	0.00051
Keystone Electric	Office - Electrical Contractor	0.00017
Dick's Home Care	Retail Store	0.00017
Edward Jones	Office	0.00017
McConnellsburg Motor & Implement	Retail - Agricultural equipment and supplies	0.00017
Mountain View Mennonite Church	Church	0.00017
Mount Zion Masonic Temple	Church	0.00017
Palmer Realty	Office	0.00017
Palmers Construction Company	Commercial Construction Company	0.00017
Peckwood Inc	Restaurant	0.00017
Donald L. Peck Enterprises	Office	0.00017
Peckies Auto Body	Auto Repair	0.00017
USPS	Post Office	0.00017
PA State Police	State Agency	0.00017
Mamma's Pizza	Restaurant	0.00017
Tickle Your Fancy Gifts and Tea	Retail Store	0.00017
Town & Country Real Estate	Office	0.00017

**NPDES Permit Fact Sheet**  
**McConnellsburg STP**

**NPDES Permit No. PA0020508**

Business Name	Type of Business	Average Wastewater Flow (MGD)
Tangles Hair Salon	Beauty Salon	0.00017
Ronald Richards Rental	Office	0.00017
Rock Kwest Rental	Beauty Salon	0.00017
PennDOT Photo License Center	Office	0.00017
Tractor Supply	Retail Store	0.00017
GM Shearer	Office - Plumbing & HVAC Contractor	0.00017
Shoemaker's Insurance	Office	0.00017
Sister Suds LLC	Retail Store	0.00017
Robert Snyder Insurance Agency	Office	0.00034
St Paul Evangelical Lutheran Church	Church	0.00017
St Paul's United Church of Christ	Church	0.00017
Jack D. Steele DMD	Dentist Office	0.00017
Rep. Jesse Topper	Office	0.00017
Fulton County Medical Center	Medical Center	0.02295
The Garlic Knot	Restaurant	0.00034
Edward Jones	Office	0.00017
Tri State Community Health Center	Medical Center	0.00068
TrueNorth Wellness Services	Office	0.00017
Mendy Ulsh Rental	Auto Repair	0.00017
United Methodist Church	Church	0.00017
Brightspeed / CenturyLink	Office	0.00017
Veterans of Foreign Wars Post 655	Civic/Social Hall	0.00051
DA Washabaugh Enterprises	Office	0.00017
Dave's Putting a New Leash on Life	Retail Store	0.00017
Family Behavioral Resources	Office	0.00017
McConnellsburg Borough Municipal Authority	Municipal Water Authority	0.00034
First Energy/West Penn Power	Office and Truck Staging Area	0.00068
Dana Signs & Graphics	Signage Company	0.00017
Ashman's Cozy Nest	Retail Store	0.00017
Prime Time Capital Rental	Retail Store	0.00017
	Total =	0.10336

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment [REDACTED])
<input checked="" type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [REDACTED])
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 386-2000-002, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input checked="" type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input checked="" type="checkbox"/>	SOP: BCW-PMT-033
<input type="checkbox"/>	Other: [REDACTED]